

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Wilson High School - Test 6**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level	Units
126-CH-1935-N/A-006-A	Hallway (229)	12/6/2019	12/11/2019	A9L0186-36	Lead	3.53	0.20	15	ppb
126-CH-1926-N/A-006-A	Halway (124)	12/6/2019	12/11/2019	A9L0186-37	Lead	3.12	0.20	15	ppb