

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Winterhaven School - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
239-CH1378-N/A-003-A	Classroom 1	4/24/2019	5/8/2019	A9D0963-01	Lead	16.70	0.20	15	ppb
239-CH1371-N/A-003-A	Classroom 3	4/24/2019	5/8/2019	A9D0963-02	Lead	21.60	0.20	15	ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.