

**Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Woodlawn Re-Test 1**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
294-CH3043-N/A-002-A	Hall Bubbler	5/3/2018	5/16/2018	A8E0136-01	Copper	0.248	0.001	1.3	ppm
294-CH3043-N/A-002-A	Hall Bubbler	5/3/2018	5/16/2018	A8E0136-01	Lead	4.4	0.2	15	ppb
294-CH3043-N/A-002-B	Hall Bubbler	5/3/2018	5/16/2018	A8E0136-02	Copper	0.186	0.001	1.3	ppm
294-CH3043-N/A-002-B	Hall Bubbler	5/3/2018	5/16/2018	A8E0136-02	Lead	0.743	0.2	15	ppb

Analyzed by: Apex Laboratories

Reviewed by: PBS Engineering and Environmental

*EPA action level for lead is 20 ppb and 1.3 ppm for copper

Page 1 of 1