

Portland Public Schools
Lead and Copper Water Sampling Results
A (Initial) and B (Follow-Up) Sample Data
Woodmere Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level*	Units
296-5188-A-001A Food Prep Sprayer - Kitchen	08/01/18 12:00 PM	08/03/18 6:02 PM	18017131	Copper	0.1	1.3	ppm
296-5188-A-001A Food Prep Sprayer - Kitchen	08/01/18 12:00 PM	08/03/18 6:02 PM	18017131	Lead	<1	15	ppb
296-5188-A-001B Food Prep Sprayer - Kitchen	08/01/18 12:00 PM	08/03/18 6:05 PM	18017138	Copper	0.1	1.3	ppm
296-5188-A-001B Food Prep Sprayer - Kitchen	08/01/18 12:00 PM	08/03/18 6:05 PM	18017138	Lead	<1	15	ppb
296-5188-B-001A Food Prep Faucet - Kitchen	08/01/18 12:05 PM	08/03/18 6:07 PM	18017134	Copper	0.1	1.3	ppm
296-5188-B-001A Food Prep Faucet - Kitchen	08/01/18 12:05 PM	08/03/18 6:07 PM	18017134	Lead	<1	15	ppb
296-5188-B-001B Food Prep Faucet - Kitchen	08/01/18 12:05 PM	08/03/18 6:09 PM	18017140	Copper	0.1	1.3	ppm
296-5188-B-001B Food Prep Faucet - Kitchen	08/01/18 12:05 PM	08/03/18 6:09 PM	18017140	Lead	<1	15	ppb
296-5194-A-001A Cafeteria Closest to Stage	08/01/18 12:16 PM	08/03/18 6:12 PM	18017133	Copper	0.4	1.3	ppm
296-5194-A-001A Cafeteria Closest to Stage	08/01/18 12:16 PM	08/03/18 6:12 PM	18017133	Lead	4	15	ppb
296-5194-A-001B Cafeteria Closest to Stage	08/01/18 12:16 PM	08/03/18 6:14 PM	18017142	Copper	0.7	1.3	ppm
296-5194-A-001B Cafeteria Closest to Stage	08/01/18 12:16 PM	08/03/18 6:14 PM	18017142	Lead	1	15	ppb
296-5191-A-001A Cafeteria - Kitchen Sink	08/01/18 12:22 PM	08/03/18 6:17 PM	18017136	Copper	0.8	1.3	ppm
296-5191-A-001A Cafeteria - Kitchen Sink	08/01/18 12:22 PM	08/03/18 6:17 PM	18017136	Lead	1	15	ppb
296-5191-A-001B Cafeteria - Kitchen Sink	08/01/18 12:22 PM	08/03/18 6:19 PM	18017141	Copper	0.6	1.3	ppm
296-5191-A-001B Cafeteria - Kitchen Sink	08/01/18 12:22 PM	08/03/18 6:19 PM	18017141	Lead	1	15	ppb
296-5205-A-001A Hallway Near Rm 31	08/01/18 12:39 PM	08/03/18 6:22 PM	18017137	Copper	0.4	1.3	ppm
296-5205-A-001A Hallway Near Rm 31	08/01/18 12:39 PM	08/03/18 6:22 PM	18017137	Lead	6	15	ppb
296-5205-A-001B Hallway Near Rm 31	08/01/18 12:39 PM	08/03/18 6:24 PM	18017132	Copper	0.5	1.3	ppm
296-5205-A-001B Hallway Near Rm 31	08/01/18 12:39 PM	08/03/18 6:24 PM	18017132	Lead	1	15	ppb
296-5201-A-001A Next to Rm 28	08/01/18 12:45 PM	08/03/18 6:41 PM	18017144	Copper	0.5	1.3	ppm
296-5201-A-001A Next to Rm 28	08/01/18 12:45 PM	08/03/18 6:41 PM	18017144	Lead	1	15	ppb
296-5201-A-001B Next to Rm 28	08/01/18 12:45 PM	08/03/18 6:43 PM	18017139	Copper	0.5	1.3	ppm
296-5201-A-001B Next to Rm 28	08/01/18 12:45 PM	08/03/18 6:43 PM	18017139	Lead	1	15	ppb
296-5186-A-001A Gym	08/01/18 12:52 PM	08/03/18 6:46 PM	18017135	Copper	0.9	1.3	ppm
296-5186-A-001A Gym	08/01/18 12:52 PM	08/03/18 6:46 PM	18017135	Lead	6	15	ppb
296-5186-A-001B Gym	08/01/18 12:52 PM	08/06/18 10:49 AM	18017143	Copper	1.3	1.3	ppm
296-5186-A-001B Gym	08/01/18 12:52 PM	08/03/18 6:48 PM	18017143	Lead	1	15	ppb
296-5197-A-001A Library Hallway	08/01/18 1:00 PM	08/03/18 6:50 PM	18017145	Copper	0.7	1.3	ppm
296-5197-A-001A Library Hallway	08/01/18 1:00 PM	08/03/18 6:50 PM	18017145	Lead	3	15	ppb
296-5197-A-001B Library Hallway	08/01/18 1:00 PM	08/06/18 10:53 AM	18017146	Copper	1.7	1.3	ppm
296-5197-A-001B Library Hallway	08/01/18 1:00 PM	08/03/18 6:53 PM	18017146	Lead	<1	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.

Analyzed by: Pixis Labs

Reviewed by: TRC Environmental Corporation

*EPA action level for lead is 20 ppb and 1.3 for copper