

Portland Public Schools
Lead and Copper Water Sampling Results
Initial and Follow Up Flush Sample Data
Woodstock Elementary

Sample Identification #	Location	Date Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
297-1181-N/A-001-A	Classroom Sink Bubbler - Classroom 18	8/9/2018	8/16/2018	A8H0251-01	Copper	0.339	0.00200	1.3	ppm
297-1181-N/A-001-A	Classroom Sink Bubbler - Classroom 18	8/9/2018	8/16/2018	A8H0251-01	Lead	34.8	0.200	15	ppb
297-1181-N/A-001-B	Classroom Sink Bubbler - Classroom 18	8/9/2018	8/16/2018	A8H0251-02	Copper	0.591	0.00200	1.3	ppm
297-1181-N/A-001-B	Classroom Sink Bubbler - Classroom 18	8/9/2018	8/16/2018	A8H0251-02	Lead	31.1	0.200	15	ppb
297-1178-N/A-001-A	Classroom Sink - Classroom 27/Faculty Office	8/9/2018	8/16/2018	A8H0251-03	Copper	0.0773	0.00200	1.3	ppm
297-1178-N/A-001-A	Classroom Sink - Classroom 27/Faculty Office	8/9/2018	8/16/2018	A8H0251-03	Lead	18.2	0.200	15	ppb
297-1178-N/A-001-B	Classroom Sink - Classroom 27/Faculty Office	8/9/2018	8/16/2018	A8H0251-04	Copper	0.00845	0.00200	1.3	ppm
297-1178-N/A-001-B	Classroom Sink - Classroom 27/Faculty Office	8/9/2018	8/16/2018	A8H0251-04	Lead	4.82	0.200	15	ppb
297-1175-N/A-001-A	Classroom Sink - Classroom 27/Faculty Office	8/9/2018	8/16/2018	A8H0251-05	Copper	0.0918	0.00200	1.3	ppm
297-1175-N/A-001-A	Classroom Sink - Classroom 27/Faculty Office	8/9/2018	8/16/2018	A8H0251-05	Lead	10.5	0.200	15	ppb
297-1175-N/A-001-B	Classroom Sink - Classroom 27/Faculty Office	8/9/2018	8/17/2018	A8H0251-06	Copper	0.0175	0.00200	1.3	ppm
297-1175-N/A-001-B	Classroom Sink - Classroom 27/Faculty Office	8/9/2018	8/17/2018	A8H0251-06	Lead	7.01	0.200	15	ppb
297-1189-N/A-001-A	Classroom Sink Bubbler - Classroom 10	8/9/2018	8/17/2018	A8H0251-07	Copper	0.163	0.00200	1.3	ppm
297-1189-N/A-001-A	Classroom Sink Bubbler - Classroom 10	8/9/2018	8/17/2018	A8H0251-07	Lead	5.86	0.200	15	ppb
297-1189-N/A-001-B	Classroom Sink Bubbler - Classroom 10	8/9/2018	8/17/2018	A8H0251-08	Copper	0.405	0.00200	1.3	ppm
297-1189-N/A-001-B	Classroom Sink Bubbler - Classroom 10	8/9/2018	8/17/2018	A8H0251-08	Lead	13.3	0.200	15	ppb
297-1188-N/A-001-A	Classroom Sink Bubbler - Classroom 9	8/9/2018	8/17/2018	A8H0251-09	Copper	0.274	0.00200	1.3	ppm
297-1188-N/A-001-A	Classroom Sink Bubbler - Classroom 9	8/9/2018	8/17/2018	A8H0251-09	Lead	7.72	0.200	15	ppb
297-1188-N/A-001-B	Classroom Sink Bubbler - Classroom 9	8/9/2018	8/17/2018	A8H0251-10	Copper	0.452	0.00200	1.3	ppm
297-1188-N/A-001-B	Classroom Sink Bubbler - Classroom 9	8/9/2018	8/17/2018	A8H0251-10	Lead	6.82	0.200	15	ppb
297-1182-N/A-001-A	Classroom Sink Bubbler - Classroom 8	8/9/2018	8/17/2018	A8H0251-11	Copper	0.787	0.00200	1.3	ppm
297-1182-N/A-001-A	Classroom Sink Bubbler - Classroom 8	8/9/2018	8/17/2018	A8H0251-11	Lead	21.8	0.200	15	ppb
297-1182-N/A-001-B	Classroom Sink Bubbler - Classroom 8	8/9/2018	8/17/2018	A8H0251-12RE1	Copper	1.20	0.00400	1.3	ppm

297-1182-N/A-001-B	Classroom Sink Bubbler - Classroom 8	8/9/2018	8/17/2018	A8H0251-12	Lead	9.02	0.200	15	ppb
297-1168-N/A-001-A	Classroom Sink Bubbler - Classroom 7A	8/9/2018	8/17/2018	A8H0251-13	Copper	0.0438	0.00200	1.3	ppm
297-1168-N/A-001-A	Classroom Sink Bubbler - Classroom 7A	8/9/2018	8/17/2018	A8H0251-13	Lead	5.98	0.200	15	ppb
297-1168-N/A-001-B	Classroom Sink Bubbler - Classroom 7A	8/9/2018	8/17/2018	A8H0251-14	Copper	0.0206	0.00200	1.3	ppm
297-1168-N/A-001-B	Classroom Sink Bubbler - Classroom 7A	8/9/2018	8/17/2018	A8H0251-14	Lead	4.19	0.200	15	ppb
297-1171-N/A-001-A	Classroom Sink Bubbler - Classroom 6A	8/9/2018	8/17/2018	A8H0251-15	Copper	0.0288	0.00200	1.3	ppm
297-1171-N/A-001-A	Classroom Sink Bubbler - Classroom 6A	8/9/2018	8/17/2018	A8H0251-15	Lead	3.85	0.200	15	ppb
297-1171-N/A-001-B	Classroom Sink Bubbler - Classroom 6A	8/9/2018	8/17/2018	A8H0251-16	Copper	0.00964	0.00200	1.3	ppm
297-1171-N/A-001-B	Classroom Sink Bubbler - Classroom 6A	8/9/2018	8/17/2018	A8H0251-16	Lead	3.05	0.200	15	ppb
297-1176-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 2A	8/9/2018	8/17/2018	A8H0251-17	Copper	0.00404	0.00200	1.3	ppm
297-1176-N/A-001-A	Drinking Fountain (Porcelain) - Classroom 2A	8/9/2018	8/17/2018	A8H0251-17	Lead	4.05	0.200	15	ppb
297-1176-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 2A	8/9/2018	8/17/2018	A8H0251-18	Copper	ND	0.00200	1.3	ppm
297-1176-N/A-001-B	Drinking Fountain (Porcelain) - Classroom 2A	8/9/2018	8/17/2018	A8H0251-18	Lead	1.79	0.200	15	ppb
297-1179-N/A-001-A	Classroom Sink Bubbler - Classroom 5A	8/9/2018	8/17/2018	A8H0251-19	Copper	0.0263	0.00200	1.3	ppm
297-1179-N/A-001-A	Classroom Sink Bubbler - Classroom 5A	8/9/2018	8/17/2018	A8H0251-19	Lead	22.3	0.200	15	ppb
297-1179-N/A-001-B	Classroom Sink Bubbler - Classroom 5A	8/9/2018	8/17/2018	A8H0251-20	Copper	0.00893	0.00200	1.3	ppm
297-1179-N/A-001-B	Classroom Sink Bubbler - Classroom 5A	8/9/2018	8/17/2018	A8H0251-20	Lead	9.70	0.200	15	ppb

Results highlighted indicate a value at or above the PPS Action Level and that the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.