

**Portland Public Schools
Lead Water Sampling Results
Initial Flush Sample Data
Woodstock Elementary School - Test 3**

Sample Identification #	Location	Date/Time Collected	Date Analyzed	Lab ID	Analyte	Results	Detection Limit	PPS Action Level*	Units
297-CH1174-N/A-003-A	Classroom 3A	3/22/2019	3/29/2019	A9C0791-01	Lead	18.00	0.20	15	ppb
297-CH1174-N/A-003-B	Classroom 3A	3/22/2019	4/10/2019	A9C0791-02	Lead	60.00	0.20	15	ppb
297-CH1177-N/A-003-A	Classroom 4A	3/22/2019	3/29/2019	A9C0791-03	Lead	8.85	0.20	15	ppb
297-CH1170-A-003-A	Kitchen	3/22/2019	3/29/2019	A9C0791-05	Lead	ND	0.20	15	ppb
297-CH1170-A-003-B	Kitchen	3/22/2019	3/29/2019	A9C0791-06	Lead	ND	0.20	15	ppb
297-CH1170-A-003-C	Kitchen	3/22/2019	3/29/2019	A9C0791-07	Lead	ND	0.20	15	ppb
297-CH1170-A-003-D	Kitchen	3/22/2019	3/29/2019	A9C0791-08	Lead	ND	0.20	15	ppb
297-CH1170-A-003-E	Kitchen	3/22/2019	3/29/2019	A9C0791-09	Lead	ND	0.20	15	ppb
297-CH1170-A-003-F	Kitchen	3/22/2019	3/29/2019	A9C0791-10	Lead	ND	0.20	15	ppb
297-CH1170-A-003-G	Kitchen	3/22/2019	3/29/2019	A9C0791-11	Lead	ND	0.20	15	ppb
297-CH1170-B-003-A	Kitchen	3/22/2019	3/29/2019	A9C0791-12	Lead	ND	0.20	15	ppb
297-CH1170-B-003-B	Kitchen	3/22/2019	3/29/2019	A9C0791-13	Lead	ND	0.20	15	ppb
297-CH1170-B-003-C	Kitchen	3/22/2019	3/29/2019	A9C0791-14	Lead	ND	0.20	15	ppb
297-CH1170-B-003-D	Kitchen	3/22/2019	3/29/2019	A9C0791-15	Lead	ND	0.20	15	ppb
297-CH1170-B-003-E	Kitchen	3/22/2019	3/29/2019	A9C0791-16	Lead	ND	0.20	15	ppb
297-CH1170-B-003-F	Kitchen	3/22/2019	3/29/2019	A9C0791-17	Lead	ND	0.20	15	ppb
297-CH1170-B-003-G	Kitchen	3/22/2019	3/29/2019	A9C0791-18	Lead	ND	0.20	15	ppb

Analyzed by: Apex Laboratories
Reviewed by: PSI-Intertek

*OHA Action Level = 15ppb

Results highlighted indicate a value at or above PPS Action Level and the fixture is under further review. During review, the highlighted fixture(s) will remain out of service.