

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Alameda Elementary School

Sample Identification and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
004-01A	Room 200 Drinking Fountain	6/26/2016 4:40:00 AM	7/6/2016 9:01:00 AM	BB67375	Copper	0.1	1.3	ppm
004-01A	Room 200 Drinking Fountain	6/26/2016 4:40:00 AM	7/6/2016 9:01:00 AM	BB67375	Lead	2	15.0	ppb
004-02A	Room 201 Sink Faucet	6/26/2016 4:42:00 AM	7/6/2016 9:04:00 AM	BB67376	Copper	0.2	1.3	ppm
004-02A	Room 201 Sink Faucet	6/26/2016 4:42:00 AM	7/6/2016 9:04:00 AM	BB67376	Lead	11	15.0	ppb
004-03A	Room 201 Drinking Fountain	6/26/2016 4:44:00 AM	7/6/2016 9:12:00 AM	BB67377	Copper	0.1	1.3	ppm
004-03A	Room 201 Drinking Fountain	6/26/2016 4:44:00 AM	7/6/2016 9:12:00 AM	BB67377	Lead	25	15.0	ppb
004-04A	Hallway Drinking Fountain #1	6/26/2016 4:50:00 AM	7/6/2016 9:15:00 AM	BB67378	Copper	0.1	1.3	ppm
004-04A	Hallway Drinking Fountain #1	6/26/2016 4:50:00 AM	7/6/2016 9:15:00 AM	BB67378	Lead	29	15.0	ppb
004-05A	Room 202 Sink Faucet	6/26/2016 4:52:00 AM	7/11/2016 9:58:00 AM	BB67379	Copper	0.2	1.3	ppm
004-05A	Room 202 Sink Faucet	6/26/2016 4:52:00 AM	7/11/2016 9:58:00 AM	BB67379	Lead	8	15.0	ppb
004-06A	Room 203 Sink Faucet	6/26/2016 4:55:00 AM	7/11/2016 10:01:00 AM	BB67380	Copper	0.2	1.3	ppm
004-06A	Room 203 Sink Faucet	6/26/2016 4:55:00 AM	7/11/2016 10:01:00 AM	BB67380	Lead	8	15.0	ppb
004-07A	Room 203 Drinking Fountain	6/26/2016 4:57:00 AM	7/6/2016 9:18:00 AM	BB67381	Copper	0.1	1.3	ppm
004-07A	Room 203 Drinking Fountain	6/26/2016 4:57:00 AM	7/6/2016 9:18:00 AM	BB67381	Lead	3	15.0	ppb
004-08A	Room 204 Boys Bathroom Sink Faucet 1	6/26/2016 5:00:00 AM	7/6/2016 9:21:00 AM	BB67382	Copper	0.2	1.3	ppm
004-08A	Room 204 Boys Bathroom Sink Faucet 1	6/26/2016 5:00:00 AM	7/6/2016 9:21:00 AM	BB67382	Lead	3	15.0	ppb
004-09A	Room 204 Boys Bathroom Sink Faucet 2	6/26/2016 5:01:00 AM	7/6/2016 9:24:00 AM	BB67383	Copper	0.1	1.3	ppm
004-09A	Room 204 Boys Bathroom Sink Faucet 2	6/26/2016 5:01:00 AM	7/6/2016 9:24:00 AM	BB67383	Lead	1	15.0	ppb
004-10A	Room 204 Boys Bathroom Sink Faucet 3	6/26/2016 5:03:00 AM	7/6/2016 9:27:00 AM	BB67384	Copper	0.1	1.3	ppm
004-10A	Room 204 Boys Bathroom Sink Faucet 3	6/26/2016 5:03:00 AM	7/6/2016 9:27:00 AM	BB67384	Lead	1	15.0	ppb
004-11A	Room 204 Boys Bathroom Water Spigot	6/26/2016 5:06:00 AM	7/11/2016 10:05:00 AM	BB67385	Copper	0.5	1.3	ppm
004-11A	Room 204 Boys Bathroom Water Spigot	6/26/2016 5:06:00 AM	7/11/2016 10:05:00 AM	BB67385	Lead	29	15.0	ppb
004-12A	Room 204 Boys Janitor Sink	6/26/2016 5:08:00 AM	7/6/2016 9:30:00 AM	BB67386	Copper	0.1	1.3	ppm
004-12A	Room 204 Boys Janitor Sink	6/26/2016 5:08:00 AM	7/6/2016 9:30:00 AM	BB67386	Lead	5	15.0	ppb
004-13A	Room 205 Girls Bathroom Sink Faucet 1	6/26/2016 5:10:00 AM	7/6/2016 9:33:00 AM	BB67387	Copper	0.1	1.3	ppm
004-13A	Room 205 Girls Bathroom Sink Faucet 1	6/26/2016 5:10:00 AM	7/6/2016 9:33:00 AM	BB67387	Lead	2	15.0	ppb
004-14A	Room 205 Girls Bathroom Sink Faucet 2	6/26/2016 5:12:00 AM	7/6/2016 9:48:00 AM	BB67388	Copper	0.1	1.3	ppm
004-14A	Room 205 Girls Bathroom Sink Faucet 2	6/26/2016 5:12:00 AM	7/6/2016 9:48:00 AM	BB67388	Lead	3	15.0	ppb
004-15A	Room 205 Girls Bathroom Sink Faucet 3	6/26/2016 5:14:00 AM	7/6/2016 9:51:00 AM	BB67389	Copper	0.1	1.3	ppm
004-15A	Room 205 Girls Bathroom Sink Faucet 3	6/26/2016 5:14:00 AM	7/6/2016 9:51:00 AM	BB67389	Lead	4	15.0	ppb
004-16A	Room 205 Girls Bathroom Sink Faucet 4	6/26/2016 5:16:00 AM	7/6/2016 9:54:00 AM	BB67390	Copper	0.1	1.3	ppm
004-16A	Room 205 Girls Bathroom Sink Faucet 4	6/26/2016 5:16:00 AM	7/6/2016 9:54:00 AM	BB67390	Lead	4	15.0	ppb
004-17A	Room 205 Girls Bathroom Water Spigot	6/26/2016 5:18:00 AM	7/6/2016 9:57:00 AM	BB67391	Copper	0.3	1.3	ppm
004-17A	Room 205 Girls Bathroom Water Spigot	6/26/2016 5:18:00 AM	7/6/2016 9:57:00 AM	BB67391	Lead	9	15.0	ppb
004-18A	Room 209 Stairwell Janitor Sink	6/26/2016 5:20:00 AM	7/6/2016 10:00:00 AM	BB67392	Copper	0.1	1.3	ppm
004-18A	Room 209 Stairwell Janitor Sink	6/26/2016 5:20:00 AM	7/6/2016 10:00:00 AM	BB67392	Lead	12	15.0	ppb
004-19A	Room 100 Sink Faucet	6/26/2016 5:22:00 AM	7/6/2016 10:03:00 AM	BB67393	Copper	0.2	1.3	ppm
004-19A	Room 100 Sink Faucet	6/26/2016 5:22:00 AM	7/6/2016 10:03:00 AM	BB67393	Lead	6	15.0	ppb
004-20A	Room 100 Drinking Fountain	6/26/2016 5:24:00 AM	7/6/2016 10:06:00 AM	BB67394	Copper	0.0	1.3	ppm
004-20A	Room 100 Drinking Fountain	6/26/2016 5:24:00 AM	7/6/2016 10:06:00 AM	BB67394	Lead	9	15.0	ppb
004-21A	Room 101 Sink Faucet	6/26/2016 5:26:00 AM	7/6/2016 10:09:00 AM	BB67395	Copper	0.2	1.3	ppm
004-21A	Room 101 Sink Faucet	6/26/2016 5:26:00 AM	7/6/2016 10:09:00 AM	BB67395	Lead	11	15.0	ppb
004-22A	Room 101 Drinking Fountain	6/26/2016 5:28:00 AM	7/6/2016 10:12:00 AM	BB67396	Copper	0.0	1.3	ppm
004-22A	Room 101 Drinking Fountain	6/26/2016 5:28:00 AM	7/6/2016 10:12:00 AM	BB67396	Lead	5	15.0	ppb
004-23A	Room 102 Sink Faucet	6/26/2016 5:30:00 AM	7/6/2016 10:15:00 AM	BB67397	Copper	0.2	1.3	ppm
004-23A	Room 102 Sink Faucet	6/26/2016 5:30:00 AM	7/6/2016 10:15:00 AM	BB67397	Lead	6	15.0	ppb
004-24A	Room 102 Drinking Fountain	6/26/2016 5:32:00 AM	7/6/2016 10:36:00 AM	BB67398	Copper	0.0	1.3	ppm
004-24A	Room 102 Drinking Fountain	6/26/2016 5:32:00 AM	7/6/2016 10:36:00 AM	BB67398	Lead	3	15.0	ppb
004-25A	Room 103 Sink Faucet	6/26/2016 5:34:00 AM	7/6/2016 10:39:00 AM	BB67399	Copper	0.3	1.3	ppm
004-25A	Room 103 Sink Faucet	6/26/2016 5:34:00 AM	7/6/2016 10:39:00 AM	BB67399	Lead	3	15.0	ppb
004-26A	Hallway Drinking Fountain #2	6/26/2016 5:36:00 AM	7/6/2016 10:43:00 AM	BB67400	Lead	0	15.0	ppb
004-26A	Hallway Drinking Fountain #2	6/26/2016 5:36:00 AM	7/6/2016 10:43:00 AM	BB67400	Copper	0.6	1.3	ppm
004-27A	Hallway Bottle Refill	6/26/2016 5:38:00 AM	7/6/2016 10:45:00 AM	BB67401	Lead	0	15.0	ppb
004-27A	Hallway Bottle Refill	6/26/2016 5:38:00 AM	7/6/2016 10:45:00 AM	BB67401	Copper	0.5	1.3	ppm
004-28A	Room 104 Sink Faucet	6/26/2016 5:40:00 AM	7/6/2016 10:49:00 AM	BB67402	Copper	0.6	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Alameda Elementary School

Sample Identification and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
004-28A	Room 104 Sink Faucet	6/26/2016 5:40:00 AM	7/6/2016 10:49:00 AM	BB67402	Lead	4	15.0	ppb
004-29A	Room 105 Sink Faucet	6/26/2016 5:42:00 AM	7/6/2016 10:52:00 AM	BB67403	Copper	0.4	1.3	ppm
004-29A	Room 105 Sink Faucet	6/26/2016 5:42:00 AM	7/6/2016 10:52:00 AM	BB67403	Lead	6	15.0	ppb
004-30A	Room 106 Sink Faucet	6/26/2016 5:44:00 AM	7/6/2016 10:55:00 AM	BB67404	Copper	0.1	1.3	ppm
004-30A	Room 106 Sink Faucet	6/26/2016 5:44:00 AM	7/6/2016 10:55:00 AM	BB67404	Lead	1	15.0	ppb
004-31A	Room 107 Sink Faucet 1	6/26/2016 5:46:00 AM	7/6/2016 10:58:00 AM	BB67405	Copper	0.3	1.3	ppm
004-31A	Room 107 Sink Faucet 1	6/26/2016 5:46:00 AM	7/6/2016 10:58:00 AM	BB67405	Lead	3	15.0	ppb
004-32A	Room 107 Drinking Fountain	6/26/2016 5:48:00 AM	7/6/2016 11:01:00 AM	BB67406	Copper	0.5	1.3	ppm
004-32A	Room 107 Drinking Fountain	6/26/2016 5:48:00 AM	7/6/2016 11:01:00 AM	BB67406	Lead	3	15.0	ppb
004-33A	Room 107 Sink Faucet 2	6/26/2016 5:50:00 AM	7/11/2016 3:05:00 PM	BB67407	Copper	0.5	1.3	ppm
004-33A	Room 107 Sink Faucet 2	6/26/2016 5:50:00 AM	7/11/2016 3:05:00 PM	BB67407	Lead	5	15.0	ppb
004-34A	Room 108 Sink Faucet	6/26/2016 5:52:00 AM	7/7/2016 11:46:00 AM	BB67408	Copper	0.3	1.3	ppm
004-34A	Room 108 Sink Faucet	6/26/2016 5:52:00 AM	7/7/2016 11:46:00 AM	BB67408	Lead	9	15.0	ppb
004-35A	Room 111 Sink Faucet	6/26/2016 5:54:00 AM	7/7/2016 11:49:00 AM	BB67409	Copper	0.5	1.3	ppm
004-35A	Room 111 Sink Faucet	6/26/2016 5:54:00 AM	7/7/2016 11:49:00 AM	BB67409	Lead	14	15.0	ppb
004-36A	Room 111 Drinking Fountain	6/26/2016 5:56:00 AM	7/7/2016 11:52:00 AM	BB67410	Copper	0.5	1.3	ppm
004-36A	Room 111 Drinking Fountain	6/26/2016 5:56:00 AM	7/7/2016 11:52:00 AM	BB67410	Lead	2	15.0	ppb
004-37A	Room 110 Sink Faucet	6/26/2016 5:58:00 AM	7/7/2016 11:55:00 AM	BB67411	Copper	0.4	1.3	ppm
004-37A	Room 110 Sink Faucet	6/26/2016 5:58:00 AM	7/7/2016 11:55:00 AM	BB67411	Lead	2	15.0	ppb
004-38A	Room 110 Drinking Fountain	6/26/2016 6:00:00 AM	7/7/2016 11:58:00 AM	BB67412	Copper	0.7	1.3	ppm
004-38A	Room 110 Drinking Fountain	6/26/2016 6:00:00 AM	7/7/2016 11:58:00 AM	BB67412	Lead	3	15.0	ppb
004-39A	Room 115 Sink Faucet	6/26/2016 6:02:00 AM	7/7/2016 12:01:00 PM	BB67413	Copper	0.5	1.3	ppm
004-39A	Room 115 Sink Faucet	6/26/2016 6:02:00 AM	7/7/2016 12:01:00 PM	BB67413	Lead	8	15.0	ppb
004-40A	Room 115 Drinking Fountain	6/26/2016 6:04:00 AM	7/7/2016 12:04:00 PM	BB67414	Copper	0.8	1.3	ppm
004-40A	Room 115 Drinking Fountain	6/26/2016 6:04:00 AM	7/7/2016 12:04:00 PM	BB67414	Lead	2	15.0	ppb
004-41A	Hallway Drinking Fountain #3	6/26/2016 6:06:00 AM	7/7/2016 12:07:00 PM	BB67415	Copper	0.4	1.3	ppm
004-41A	Hallway Drinking Fountain #3	6/26/2016 6:06:00 AM	7/7/2016 12:07:00 PM	BB67415	Lead	1	15.0	ppb
004-42A	Room 117 Staff Sink Faucet	6/26/2016 6:08:00 AM	7/7/2016 12:10:00 PM	BB67416	Copper	0.2	1.3	ppm
004-42A	Room 117 Staff Sink Faucet	6/26/2016 6:08:00 AM	7/7/2016 12:10:00 PM	BB67416	Lead	1	15.0	ppb
004-43A	Room 117 Staff Sink Faucet	6/26/2016 6:10:00 AM	7/7/2016 12:13:00 PM	BB67417	Copper	0.1	1.3	ppm
004-43A	Room 117 Staff Sink Faucet	6/26/2016 6:10:00 AM	7/7/2016 12:13:00 PM	BB67417	Lead	3	15.0	ppb
004-44A	Room 117 Girls Bathroom Sink Faucet 1	6/26/2016 6:12:00 AM	7/7/2016 12:32:00 PM	BB67418	Copper	0.2	1.3	ppm
004-44A	Room 117 Girls Bathroom Sink Faucet 1	6/26/2016 6:12:00 AM	7/7/2016 12:32:00 PM	BB67418	Lead	3	15.0	ppb
004-45A	Room 117 Girls Bathroom Sink Faucet 2	6/26/2016 6:14:00 AM	7/7/2016 12:35:00 PM	BB67419	Copper	0.2	1.3	ppm
004-45A	Room 117 Girls Bathroom Sink Faucet 2	6/26/2016 6:14:00 AM	7/7/2016 12:35:00 PM	BB67419	Lead	6	15.0	ppb
004-46A	Room 117 Girls Bathroom Sink Faucet 3	6/26/2016 6:16:00 AM	7/7/2016 6:13:00 PM	BB67420	Copper	0.2	1.3	ppm
004-46A	Room 117 Girls Bathroom Sink Faucet 3	6/26/2016 6:16:00 AM	7/7/2016 6:13:00 PM	BB67420	Lead	3	15.0	ppb
004-47A	Room 117 Girls Bathroom Water Spigot	6/26/2016 6:18:00 AM	7/11/2016 4:40:00 PM	BB67421	Copper	2.0	1.3	ppm
004-47A	Room 117 Girls Bathroom Water Spigot	6/26/2016 6:18:00 AM	7/11/2016 3:02:00 PM	BB67421	Lead	62	15.0	ppb
004-48A	Hallway Drinking Fountain near Library 1	6/26/2016 6:20:00 AM	7/7/2016 12:41:00 PM	BB67422	Copper	0.4	1.3	ppm
004-48A	Hallway Drinking Fountain near Library 1	6/26/2016 6:20:00 AM	7/7/2016 12:41:00 PM	BB67422	Lead	4	15.0	ppb
004-49A	Hallway Drinking Fountain near Library 2	6/26/2016 6:22:00 AM	7/7/2016 6:16:00 PM	BB67423	Copper	0.2	1.3	ppm
004-49A	Hallway Drinking Fountain near Library 2	6/26/2016 6:22:00 AM	7/7/2016 6:16:00 PM	BB67423	Lead	2	15.0	ppb
004-50A	Room 125 Cafeteria Drinking Fountain	6/26/2016 6:24:00 AM	7/7/2016 12:47:00 PM	BB67424	Lead	0	15.0	ppb
004-50A	Room 125 Cafeteria Drinking Fountain	6/26/2016 6:24:00 AM	7/7/2016 6:19:00 PM	BB67424	Copper	1.34	1.3	ppm
004-51A	Room 125B Janitor Sink Faucet	6/26/2016 6:26:00 AM	7/7/2016 12:50:00 PM	BB67425	Copper	0.1	1.3	ppm
004-51A	Room 125B Janitor Sink Faucet	6/26/2016 6:26:00 AM	7/7/2016 12:50:00 PM	BB67425	Lead	4	15.0	ppb
004-52A	Room 127 Sink Faucet	6/26/2016 6:28:00 AM	7/7/2016 12:53:00 PM	BB67426	Copper	0.1	1.3	ppm
004-52A	Room 127 Sink Faucet	6/26/2016 6:28:00 AM	7/7/2016 12:53:00 PM	BB67426	Lead	1	15.0	ppb
004-53A	Room 124 Sink Faucet	6/26/2016 6:30:00 AM	7/7/2016 12:56:00 PM	BB67427	Copper	0.2	1.3	ppm
004-53A	Room 124 Sink Faucet	6/26/2016 6:30:00 AM	7/7/2016 12:56:00 PM	BB67427	Lead	2	15.0	ppb
004-54A	Room 124 Nurse Sink Faucet	6/26/2016 6:32:00 AM	7/7/2016 12:59:00 PM	BB67428	Copper	0.8	1.3	ppm
004-54A	Room 124 Nurse Sink Faucet	6/26/2016 6:32:00 AM	7/7/2016 12:59:00 PM	BB67428	Lead	4	15.0	ppb
004-55A	Room 126 Staff Bathroom Sink Faucet	6/26/2016 6:34:00 AM	7/7/2016 1:25:00 PM	BB67429	Copper	0.3	1.3	ppm
004-55A	Room 126 Staff Bathroom Sink Faucet	6/26/2016 6:34:00 AM	7/7/2016 1:25:00 PM	BB67429	Lead	1	15.0	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Alameda Elementary School

Sample Identification and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
004-56A	Room 129 Kitchen Sink Faucet 1	6/26/2016 6:36:00 AM	7/7/2016 1:28:00 PM	BB67430	Copper	0.4	1.3	ppm
004-56A	Room 129 Kitchen Sink Faucet 1	6/26/2016 6:36:00 AM	7/7/2016 1:28:00 PM	BB67430	Lead	3	15.0	ppb
004-57A	Room 129 Kitchen Sink Sprayer	6/26/2016 6:38:00 AM	7/7/2016 1:31:00 PM	BB67431	Copper	0.4	1.3	ppm
004-57A	Room 129 Kitchen Sink Sprayer	6/26/2016 6:38:00 AM	7/7/2016 1:31:00 PM	BB67431	Lead	3	15.0	ppb
004-58A	Room 129 Kitchen Sink Faucet 2	6/26/2016 6:40:00 AM	7/7/2016 1:34:00 PM	BB67432	Copper	0.6	1.3	ppm
004-58A	Room 129 Kitchen Sink Faucet 2	6/26/2016 6:40:00 AM	7/7/2016 1:34:00 PM	BB67432	Lead	5	15.0	ppb
004-59A	Hallway Drinking Fountain near Rm 131 #1	6/26/2016 6:42:00 AM	7/7/2016 1:37:00 PM	BB67433	Lead	0	15.0	ppb
004-59A	Hallway Drinking Fountain near Rm 131 #1	6/26/2016 6:42:00 AM	7/7/2016 6:37:00 PM	BB67433	Copper	2.5	1.3	ppm
004-60A	Hallway Drinking Fountain near Rm 131 #2	6/26/2016 6:44:00 AM	7/7/2016 1:41:00 PM	BB67434	Lead	0	15.0	ppb
004-60A	Hallway Drinking Fountain near Rm 131 #2	6/26/2016 6:44:00 AM	7/7/2016 6:40:00 PM	BB67434	Copper	1.7	1.3	ppm
004-61A	Hallway Bottle Refill near Rm 131	6/26/2016 6:46:00 AM	7/7/2016 1:43:00 PM	BB67435	Lead	0	15.0	ppb
004-61A	Hallway Bottle Refill near Rm 131	6/26/2016 6:46:00 AM	7/7/2016 6:43:00 PM	BB67435	Copper	1.5	1.3	ppm
004-62A	Room 134 Sink Faucet	6/26/2016 6:48:00 AM	7/7/2016 6:46:00 PM	BB67436	Copper	1.0	1.3	ppm
004-62A	Room 134 Sink Faucet	6/26/2016 6:48:00 AM	7/7/2016 1:47:00 PM	BB67436	Lead	3	15.0	ppb
004-63A	Room 133 Boys Bathroom Sink Faucet 1	6/26/2016 6:50:00 AM	7/7/2016 1:50:00 PM	BB67437	Copper	0.6	1.3	ppm
004-63A	Room 133 Boys Bathroom Sink Faucet 1	6/26/2016 6:50:00 AM	7/7/2016 1:50:00 PM	BB67437	Lead	10	15.0	ppb
004-64A	Room 133 Boys Bathroom Sink Faucet 2	6/26/2016 6:52:00 AM	7/7/2016 1:53:00 PM	BB67438	Copper	0.5	1.3	ppm
004-64A	Room 133 Boys Bathroom Sink Faucet 2	6/26/2016 6:52:00 AM	7/7/2016 1:53:00 PM	BB67438	Lead	9	15.0	ppb
004-65A	Room 133 Boys Bathroom Sink Faucet 3	6/26/2016 6:54:00 AM	7/7/2016 2:08:00 PM	BB67439	Copper	0.2	1.3	ppm
004-65A	Room 133 Boys Bathroom Sink Faucet 3	6/26/2016 6:54:00 AM	7/7/2016 2:08:00 PM	BB67439	Lead	5	15.0	ppb
004-66A	Room 133 Boys Bathroom Sink Faucet 4	6/26/2016 6:56:00 AM	7/7/2016 2:11:00 PM	BB67440	Copper	0.2	1.3	ppm
004-66A	Room 133 Boys Bathroom Sink Faucet 4	6/26/2016 6:56:00 AM	7/7/2016 2:11:00 PM	BB67440	Lead	4	15.0	ppb
004-67A	Room 133 Boys Bathroom Sink Faucet 5	6/26/2016 6:58:00 AM	7/7/2016 2:14:00 PM	BB67441	Copper	0.2	1.3	ppm
004-67A	Room 133 Boys Bathroom Sink Faucet 5	6/26/2016 6:58:00 AM	7/7/2016 2:14:00 PM	BB67441	Lead	3	15.0	ppb
004-68A	Room 133 Boys Bathroom Sink Faucet 6	6/26/2016 7:00:00 AM	7/7/2016 2:17:00 PM	BB67442	Copper	0.2	1.3	ppm
004-68A	Room 133 Boys Bathroom Sink Faucet 6	6/26/2016 7:00:00 AM	7/7/2016 2:17:00 PM	BB67442	Lead	4	15.0	ppb
004-69A	Hallway Drinking Fountain near Room 133 #1	6/26/2016 7:02:00 AM	7/7/2016 2:20:00 PM	BB67443	Copper	0.2	1.3	ppm
004-69A	Hallway Drinking Fountain near Room 133 #1	6/26/2016 7:02:00 AM	7/7/2016 2:20:00 PM	BB67443	Lead	3	15.0	ppb
004-70A	Hallway Drinking Fountain near Room 133 #2	6/26/2016 7:04:00 AM	7/7/2016 2:23:00 PM	BB67444	Copper	0.2	1.3	ppm
004-70A	Hallway Drinking Fountain near Room 133 #2	6/26/2016 7:04:00 AM	7/7/2016 2:23:00 PM	BB67444	Lead	2	15.0	ppb
004-71A	Room 135 Janitors Office Sink Faucet	6/26/2016 7:06:00 AM	7/7/2016 2:26:00 PM	BB67445	Copper	0.2	1.3	ppm
004-71A	Room 135 Janitors Office Sink Faucet	6/26/2016 7:06:00 AM	7/7/2016 2:26:00 PM	BB67445	Lead	6	15.0	ppb
004-72A	Room 140 Sink Faucet	6/26/2016 7:08:00 AM	7/7/2016 2:29:00 PM	BB67446	Copper	0.5	1.3	ppm
004-72A	Room 140 Sink Faucet	6/26/2016 7:08:00 AM	7/7/2016 2:29:00 PM	BB67446	Lead	13	15.0	ppb
004-73A	Room 139 Sink Faucet	6/26/2016 7:10:00 AM	7/7/2016 2:32:00 PM	BB67447	Copper	0.4	1.3	ppm
004-73A	Room 139 Sink Faucet	6/26/2016 7:10:00 AM	7/7/2016 2:32:00 PM	BB67447	Lead	14.7	15.0	ppb
004-74A	Room 140B Sink Faucet	6/26/2016 7:12:00 AM	7/7/2016 2:35:00 PM	BB67448	Copper	0.5	1.3	ppm
004-74A	Room 140B Sink Faucet	6/26/2016 7:12:00 AM	7/7/2016 2:35:00 PM	BB67448	Lead	1	15.0	ppb
004-75A	Hallway Drinking Fountain near 140B #1	6/26/2016 7:14:00 AM	7/11/2016 3:09:00 PM	BB67449	Copper	1.4	1.3	ppm
004-75A	Hallway Drinking Fountain near 140B #1	6/26/2016 7:14:00 AM	7/11/2016 3:09:00 PM	BB67449	Lead	4	15.0	ppb
004-76A	Hallway Drinking Fountain near 140B #2	6/26/2016 7:16:00 AM	7/7/2016 6:52:00 PM	BB67450	Copper	1.1	1.3	ppm
004-76A	Hallway Drinking Fountain near 140B #2	6/26/2016 7:16:00 AM	7/7/2016 2:56:00 PM	BB67450	Lead	2	15.0	ppb
004-77A	Room 141 Sink Faucet	6/26/2016 7:18:00 AM	7/7/2016 2:59:00 PM	BB67451	Copper	0.4	1.3	ppm
004-77A	Room 141 Sink Faucet	6/26/2016 7:18:00 AM	7/7/2016 2:59:00 PM	BB67451	Lead	3	15.0	ppb
004-78A	Room 142 Sink Faucet	6/26/2016 7:20:00 AM	7/7/2016 3:02:00 PM	BB67452	Copper	0.4	1.3	ppm
004-78A	Room 142 Sink Faucet	6/26/2016 7:20:00 AM	7/7/2016 3:02:00 PM	BB67452	Lead	4	15.0	ppb
004-79A	Room 143 Sink Faucet	6/26/2016 7:22:00 AM	7/7/2016 3:05:00 PM	BB67453	Copper	0.5	1.3	ppm
004-79A	Room 143 Sink Faucet	6/26/2016 7:22:00 AM	7/7/2016 3:05:00 PM	BB67453	Lead	2	15.0	ppb
004-80A	Room 144 Sink Faucet	6/26/2016 7:24:00 AM	7/7/2016 3:08:00 PM	BB67454	Copper	0.4	1.3	ppm
004-80A	Room 144 Sink Faucet	6/26/2016 7:24:00 AM	7/7/2016 3:08:00 PM	BB67454	Lead	3	15.0	ppb
004-81A	Hallway Drinking Fountain near Room 145	6/26/2016 7:26:00 AM	7/7/2016 3:11:00 PM	BB67455	Copper	0.6	1.3	ppm
004-81A	Hallway Drinking Fountain near Room 145	6/26/2016 7:26:00 AM	7/7/2016 3:11:00 PM	BB67455	Lead	3	15.0	ppb
004-82A	Room 145 Girls Bathroom Sink Faucet 1	6/26/2016 7:28:00 AM	7/7/2016 3:14:00 PM	BB67456	Copper	0.3	1.3	ppm
004-82A	Room 145 Girls Bathroom Sink Faucet 1	6/26/2016 7:28:00 AM	7/7/2016 3:14:00 PM	BB67456	Lead	1	15.0	ppb
004-83A	Room 145 Girls Bathroom Sink Faucet 2	6/26/2016 7:30:00 AM	7/11/2016 3:12:00 PM	BB67457	Copper	60.9	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Alameda Elementary School

Sample Identification and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
004-83A	Room 145 Girls Bathroom Sink Faucet 2	6/26/2016 7:30:00 AM	7/11/2016 5:04:00 PM	BB67457	Lead	246	15.0	ppb
004-84A	Room 145 Girls Bathroom Water Spigot	6/26/2016 7:32:00 AM	7/7/2016 3:18:00 PM	BB67458	Copper	0.7	1.3	ppm
004-84A	Room 145 Girls Bathroom Water Spigot	6/26/2016 7:32:00 AM	7/7/2016 3:18:00 PM	BB67458	Lead	12	15.0	ppb
004-85A	Room 145 Girls Bathroom Sink Faucet 3	6/26/2016 7:34:00 AM	7/7/2016 3:21:00 PM	BB67459	Copper	0.4	1.3	ppm
004-85A	Room 145 Girls Bathroom Sink Faucet 3	6/26/2016 7:34:00 AM	7/7/2016 3:21:00 PM	BB67459	Lead	3	15.0	ppb
004-86A	Room 146 Janitor Sink Faucet	6/26/2016 7:36:00 AM	7/7/2016 3:24:00 PM	BB67460	Copper	0.6	1.3	ppm
004-86A	Room 146 Janitor Sink Faucet	6/26/2016 7:36:00 AM	7/7/2016 3:24:00 PM	BB67460	Lead	2	15.0	ppb
004-87A	Room 146 Boys Bathroom Sink Faucet 1	6/26/2016 7:38:00 AM	7/7/2016 3:39:00 PM	BB67461	Copper	0.6	1.3	ppm
004-87A	Room 146 Boys Bathroom Sink Faucet 1	6/26/2016 7:38:00 AM	7/7/2016 3:39:00 PM	BB67461	Lead	3	15.0	ppb
004-88A	Room 146 Boys Bathroom Sink Faucet 2	6/26/2016 7:40:00 AM	7/7/2016 3:42:00 PM	BB67462	Copper	0.4	1.3	ppm
004-88A	Room 146 Boys Bathroom Sink Faucet 2	6/26/2016 7:40:00 AM	7/7/2016 3:42:00 PM	BB67462	Lead	2	15.0	ppb
004-89A	Room 146 Boys Bathroom Sink Faucet 3	6/26/2016 7:42:00 AM	7/7/2016 3:45:00 PM	BB67463	Copper	0.4	1.3	ppm
004-89A	Room 146 Boys Bathroom Sink Faucet 3	6/26/2016 7:42:00 AM	7/7/2016 3:45:00 PM	BB67463	Lead	1	15.0	ppb
004-90A	Room 146 Boys Bathroom Water Spigot	6/26/2016 7:44:00 AM	7/7/2016 7:05:00 PM	BB67464	Copper	1.1	1.3	ppm
004-90A	Room 146 Boys Bathroom Water Spigot	6/26/2016 7:44:00 AM	7/7/2016 3:48:00 PM	BB67464	Lead	37	15.0	ppb
004-91A	Room 148 Sink Faucet	6/26/2016 7:46:00 AM	7/7/2016 3:51:00 PM	BB67465	Copper	0.5	1.3	ppm
004-91A	Room 148 Sink Faucet	6/26/2016 7:46:00 AM	7/7/2016 3:51:00 PM	BB67465	Lead	3	15.0	ppb
004-92A	Hallway Drinking Fountain by Mechanical Room	6/26/2016 7:48:00 AM	7/7/2016 3:54:00 PM	BB67466	Copper	0.4	1.3	ppm
004-92A	Hallway Drinking Fountain by Mechanical Room	6/26/2016 7:48:00 AM	7/7/2016 3:54:00 PM	BB67466	Lead	2	15.0	ppb
004-93A	Mechanical Room Sink Faucet	6/26/2016 7:53:00 AM	7/7/2016 3:57:00 PM	BB67467	Copper	0.2	1.3	ppm
004-93A	Mechanical Room Sink Faucet	6/26/2016 7:53:00 AM	7/7/2016 3:57:00 PM	BB67467	Lead	1	15.0	ppb
004-94A	Room B44 Sink Faucet	6/26/2016 7:55:00 AM	7/7/2016 4:00:00 PM	BB67468	Copper	0.4	1.3	ppm
004-94A	Room B44 Sink Faucet	6/26/2016 7:55:00 AM	7/7/2016 4:00:00 PM	BB67468	Lead	3	15.0	ppb
004-95A	Room B43 Sink Faucet	6/26/2016 7:58:00 AM	7/7/2016 4:03:00 PM	BB67469	Copper	0.4	1.3	ppm
004-95A	Room B43 Sink Faucet	6/26/2016 7:58:00 AM	7/7/2016 4:03:00 PM	BB67469	Lead	2	15.0	ppb
004-96A	Portable Room 1 Sink Faucet	6/26/2016 9:00:00 AM	7/7/2016 4:06:00 PM	BB67470	Copper	0.2	1.3	ppm
004-96A	Portable Room 1 Sink Faucet	6/26/2016 9:00:00 AM	7/7/2016 4:06:00 PM	BB67470	Lead	6	15.0	ppb
004-97A	Portable Room 2 Sink Faucet	6/26/2016 8:55:00 AM	7/7/2016 4:27:00 PM	BB67471	Copper	0.2	1.3	ppm
004-97A	Portable Room 2 Sink Faucet	6/26/2016 8:55:00 AM	7/7/2016 4:27:00 PM	BB67471	Lead	4	15.0	ppb
004-98A	Boiler Room Hose	6/26/2016 9:07:00 AM	7/11/2016 3:16:00 PM	BB67472	Copper	0.3	1.3	ppm
004-98A	Boiler Room Hose	6/26/2016 9:07:00 AM	7/11/2016 3:16:00 PM	BB67472	Lead	5	15.0	ppb
004-99A	Boiler Room Bathroom Sink	6/26/2016 9:05:00 AM	7/6/2016 8:09:00 PM	BB67473	Copper	0.7	1.3	ppm
004-99A	Boiler Room Bathroom Sink	6/26/2016 9:05:00 AM	7/6/2016 8:09:00 PM	BB67473	Lead	6	15.0	ppb
004-100A	Exterior Spigot behind Kitchen	6/26/2016 9:12:00 AM	7/7/2016 6:25:00 PM	BB67474	Copper	0.9	1.3	ppm
004-100A	Exterior Spigot behind Kitchen	6/26/2016 9:12:00 AM	7/6/2016 8:12:00 PM	BB67474	Lead	5	15.0	ppb
004-101A	Exterior Spigot behind Room 148	6/26/2016 9:20:00 AM	7/6/2016 8:15:00 PM	BB67475	Copper	0.6	1.3	ppm
004-101A	Exterior Spigot behind Room 148	6/26/2016 9:20:00 AM	7/6/2016 8:15:00 PM	BB67475	Lead	3	15.0	ppb
004-102A	Exterior Spigot behind Room B44	6/26/2016 9:27:00 AM	7/6/2016 8:30:00 PM	BB67476	Copper	0.1	1.3	ppm
004-102A	Exterior Spigot behind Room B44	6/26/2016 9:27:00 AM	7/6/2016 8:30:00 PM	BB67476	Lead	42	15.0	ppb
004-103A	Exterior Spigot behind Room 138	6/26/2016 9:30:00 AM	7/6/2016 8:33:00 PM	BB67477	Copper	0.1	1.3	ppm
004-103A	Exterior Spigot behind Room 138	6/26/2016 9:30:00 AM	7/6/2016 8:33:00 PM	BB67477	Lead	13	15.0	ppb
004-104A	Exterior Spigot behind Room 134	6/26/2016 9:32:00 AM	7/6/2016 8:36:00 PM	BB67478	Copper	0.6	1.3	ppm
004-104A	Exterior Spigot behind Room 134	6/26/2016 9:32:00 AM	7/6/2016 8:36:00 PM	BB67478	Lead	8	15.0	ppb
004-105A	Exterior Spigot behind Office	6/26/2016 9:36:00 AM	7/7/2016 6:10:00 PM	BB67704	Copper	0.3	1.3	ppm
004-105A	Exterior Spigot behind Office	6/26/2016 9:36:00 AM	7/7/2016 6:10:00 PM	BB67704	Lead	7	15.0	ppb
004-106A	Exterior Spigot behind Library	6/26/2016 9:40:00 AM	7/7/2016 10:48:00 AM	BB67479	Copper	1.5	1.3	ppm
004-106A	Exterior Spigot behind Library	6/26/2016 9:40:00 AM	7/6/2016 8:39:00 PM	BB67479	Lead	32	15.0	ppb
004-107A	Room B46 Sink Faucet	6/26/2016 9:43:00 AM	7/6/2016 8:42:00 PM	BB67480	Copper	0.4	1.3	ppm
004-107A	Room B46 Sink Faucet	6/26/2016 9:43:00 AM	7/6/2016 8:42:00 PM	BB67480	Lead	2	15.0	ppb
004-108A	Office Sink Faucet	6/26/2016 8:34:00 AM	7/6/2016 8:45:00 PM	BB67481	Copper	0.3	1.3	ppm
004-108A	Office Sink Faucet	6/26/2016 8:34:00 AM	7/6/2016 8:45:00 PM	BB67481	Lead	2	15.0	ppb
004-109A	Library Sink Faucet	6/26/2016 8:36:00 AM	7/6/2016 8:48:00 PM	BB67482	Copper	0.3	1.3	ppm
004-109A	Library Sink Faucet	6/26/2016 8:36:00 AM	7/7/2016 6:22:00 PM	BB67482	Lead	1	15.0	ppb
004-110A	Room 200 Sink Faucet	6/26/2016 8:38:00 AM	7/6/2016 8:51:00 PM	BB67483	Copper	0.3	1.3	ppm
004-110A	Room 200 Sink Faucet	6/26/2016 8:38:00 AM	7/6/2016 8:51:00 PM	BB67483	Lead	2	15.0	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Alameda Elementary School

Sample Identification and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
004-111A	6/26/2016 8:30:00 AM	7/6/2016 8:54:00 PM	BB67484	Copper	0.1	1.3	ppm
004-111A	6/26/2016 8:30:00 AM	7/6/2016 8:54:00 PM	BB67484	Lead	1	15.0	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

ND = Non detect

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.