

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Applegate Elementary School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
006-01A	Room 3 Sink Faucet	6/26/2016 2:30:00 AM	7/1/2016 4:03:00 PM	BB67227	Copper	0.6	1.3	ppm
006-01A	Room 3 Sink Faucet	6/26/2016 2:30:00 AM	7/1/2016 4:03:00 PM	BB67227	Lead	5	15	ppb
006-02A	Room 12 Sink Faucet	6/26/2016 2:32:00 AM	7/10/2016 8:09:00 PM	BB67228	Copper	1.0	1.3	ppm
006-02A	Room 12 Sink Faucet	6/26/2016 2:32:00 AM	7/10/2016 8:09:00 PM	BB67228	Lead	76	15	ppb
006-03A	Boiler Room Office Sink Faucet	6/26/2016 12:45:00 AM	7/1/2016 4:06:00 PM	BB67229	Copper	0.5	1.3	ppm
006-03A	Boiler Room Office Sink Faucet	6/26/2016 12:45:00 AM	7/1/2016 4:06:00 PM	BB67229	Lead	5	15	ppb
006-04A	Boiler Room Bathroom Sink	6/26/2016 12:47:00 AM	7/1/2016 4:12:00 PM	BB67230	Copper	0.5	1.3	ppm
006-04A	Boiler Room Bathroom Sink	6/26/2016 12:47:00 AM	7/1/2016 4:12:00 PM	BB67230	Lead	4	15	ppb
006-05A	Staff Restroom Sink Faucet	6/26/2016 12:50:00 AM	7/1/2016 4:15:00 PM	BB67231	Copper	0.5	1.3	ppm
006-05A	Staff Restroom Sink Faucet	6/26/2016 12:50:00 AM	7/1/2016 4:15:00 PM	BB67231	Lead	2	15	ppb
006-06A	Room 7 Sink Faucet	6/26/2016 12:52:00 AM	7/1/2016 4:18:00 PM	BB67232	Copper	0.7	1.3	ppm
006-06A	Room 7 Sink Faucet	6/26/2016 12:52:00 AM	7/1/2016 4:18:00 PM	BB67232	Lead	1	15	ppb
006-07A	Room 7 Drinking Fountain	6/26/2016 12:54:00 AM	7/1/2016 4:21:00 PM	BB67233	Copper	0.8	1.3	ppm
006-07A	Room 7 Drinking Fountain	6/26/2016 12:54:00 AM	7/1/2016 4:21:00 PM	BB67233	Lead	2	15	ppb
006-08A	Boys Bathroom Sink Faucet 1	6/26/2016 12:56:00 AM	7/1/2016 4:24:00 PM	BB67234	Copper	0.8	1.3	ppm
006-08A	Boys Bathroom Sink Faucet 1	6/26/2016 12:56:00 AM	7/1/2016 4:24:00 PM	BB67234	Lead	3	15	ppb
006-09A	Boys Bathroom Sink Faucet 2	6/26/2016 12:58:00 AM	7/1/2016 4:39:00 PM	BB67235	Copper	0.7	1.3	ppm
006-09A	Boys Bathroom Sink Faucet 2	6/26/2016 12:58:00 AM	7/1/2016 4:39:00 PM	BB67235	Lead	4	15	ppb
006-10A	Room 6 Sink Faucet	6/26/2016 1:00:00 AM	7/1/2016 4:42:00 PM	BB67236	Copper	0.7	1.3	ppm
006-10A	Room 6 Sink Faucet	6/26/2016 1:00:00 AM	7/1/2016 4:42:00 PM	BB67236	Lead	1	15	ppb
006-11A	Room 6 Drinking Fountain	6/26/2016 1:03:00 AM	7/1/2016 4:45:00 PM	BB67237	Copper	0.5	1.3	ppm
006-11A	Room 6 Drinking Fountain	6/26/2016 1:03:00 AM	7/1/2016 4:45:00 PM	BB67237	Lead	3	15	ppb
006-12A	Slop Sink in Custodian 1	6/26/2016 1:05:00 AM	7/1/2016 4:48:00 PM	BB67238	Copper	0.2	1.3	ppm
006-12A	Slop Sink in Custodian 1	6/26/2016 1:05:00 AM	7/1/2016 4:48:00 PM	BB67238	Lead	27	15	ppb
006-13A	Girls Bathroom Sink Faucet 1	6/26/2016 1:07:00 AM	7/1/2016 4:51:00 PM	BB67239	Copper	0.9	1.3	ppm
006-13A	Girls Bathroom Sink Faucet 1	6/26/2016 1:07:00 AM	7/1/2016 4:51:00 PM	BB67239	Lead	4	15	ppb
006-14A	Girls Bathroom Sink Faucet 2	6/26/2016 1:09:00 AM	7/1/2016 4:54:00 PM	BB67240	Copper	0.9	1.3	ppm
006-14A	Girls Bathroom Sink Faucet 2	6/26/2016 1:09:00 AM	7/1/2016 4:54:00 PM	BB67240	Lead	7	15	ppb
006-15A	Girls Bathroom Spigot	6/26/2016 1:11:00 AM	7/10/2016 10:08:00 PM	BB67241	Copper	1.7	1.3	ppm
006-15A	Girls Bathroom Spigot	6/26/2016 1:11:00 AM	7/10/2016 10:08:00 PM	BB67241	Lead	12	15	ppb
006-16A	Boys Bathroom Spigot	6/26/2016 1:13:00 AM	7/1/2016 4:57:00 PM	BB67242	Copper	0.8	1.3	ppm
006-16A	Boys Bathroom Spigot	6/26/2016 1:13:00 AM	7/1/2016 4:57:00 PM	BB67242	Lead	8	15	ppb
006-17A	Storeroom 1 Sink Faucet	6/26/2016 1:15:00 AM	7/1/2016 8:27:00 PM	BB67243	Copper	1.0	1.3	ppm
006-17A	Storeroom 1 Sink Faucet	6/26/2016 1:15:00 AM	7/1/2016 5:00:00 PM	BB67243	Lead	2	15	ppb
006-18A	Room 5 Sink Faucet	6/26/2016 1:17:00 AM	7/1/2016 5:03:00 PM	BB67244	Copper	0.6	1.3	ppm
006-18A	Room 5 Sink Faucet	6/26/2016 1:17:00 AM	7/1/2016 5:03:00 PM	BB67244	Lead	3	15	ppb
006-19A	Room 5 Drinking Fountain	6/26/2016 1:19:00 AM	7/1/2016 5:07:00 PM	BB67245	Copper	0.4	1.3	ppm
006-19A	Room 5 Drinking Fountain	6/26/2016 1:19:00 AM	7/1/2016 5:07:00 PM	BB67245	Lead	2	15	ppb
006-20A	Conference Room Sink Faucet	6/26/2016 1:21:00 AM	7/1/2016 5:28:00 PM	BB67246	Copper	0.7	1.3	ppm
006-20A	Conference Room Sink Faucet	6/26/2016 1:21:00 AM	7/1/2016 5:28:00 PM	BB67246	Lead	8	15	ppb
006-21A	Room 4 Sink Faucet	6/26/2016 1:23:00 AM	7/1/2016 5:31:00 PM	BB67247	Copper	0.6	1.3	ppm
006-21A	Room 4 Sink Faucet	6/26/2016 1:23:00 AM	7/1/2016 5:31:00 PM	BB67247	Lead	11	15	ppb
006-22A	Room 4 Drinking Fountain	6/26/2016 1:25:00 AM	7/1/2016 5:34:00 PM	BB67248	Copper	0.4	1.3	ppm
006-22A	Room 4 Drinking Fountain	6/26/2016 1:25:00 AM	7/1/2016 5:34:00 PM	BB67248	Lead	2	15	ppb
006-23A	Family Service Room Sink Faucet	6/26/2016 1:27:00 AM	7/1/2016 5:37:00 PM	BB67249	Copper	0.7	1.3	ppm
006-23A	Family Service Room Sink Faucet	6/26/2016 1:27:00 AM	7/1/2016 5:37:00 PM	BB67249	Lead	7	15	ppb
006-24A	Library Sink Faucet	6/26/2016 1:29:00 AM	7/1/2016 5:40:00 PM	BB67250	Copper	0.6	1.3	ppm
006-24A	Library Sink Faucet	6/26/2016 1:29:00 AM	7/1/2016 5:40:00 PM	BB67250	Lead	13	15	ppb
006-25A	Room 3 Sink Faucet 2	6/26/2016 1:32:00 AM	7/1/2016 8:30:00 PM	BB67251	Copper	1.30	1.3	ppm
006-25A	Room 3 Sink Faucet 2	6/26/2016 1:32:00 AM	7/1/2016 5:43:00 PM	BB67251	Lead	9	15	ppb
006-26A	Corridor Drinking Fountain #1	6/26/2016 1:33:00 AM	7/1/2016 5:46:00 PM	BB67252	Lead	0	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Applegate Elementary School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
006-26A	Corridor Drinking Fountain #1	6/26/2016 1:33:00 AM	7/1/2016 8:33:00 PM	BB67252	Copper	1.32	1.3	ppm
006-27A	Classroom 8 Sink Faucet	6/26/2016 1:35:00 AM	7/1/2016 5:49:00 PM	BB67253	Copper	0.4	1.3	ppm
006-27A	Classroom 8 Sink Faucet	6/26/2016 1:35:00 AM	7/1/2016 5:49:00 PM	BB67253	Lead	1	15	ppb
006-28A	Classroom 8 Drinking Fountain	6/26/2016 1:37:00 AM	7/1/2016 5:52:00 PM	BB67254	Copper	0.8	1.3	ppm
006-28A	Classroom 8 Drinking Fountain	6/26/2016 1:37:00 AM	7/1/2016 5:52:00 PM	BB67254	Lead	5	15	ppb
006-29A	Classroom 9 Sink Faucet	6/26/2016 1:39:00 AM	7/1/2016 5:55:00 PM	BB67255	Copper	0.6	1.3	ppm
006-29A	Classroom 9 Sink Faucet	6/26/2016 1:39:00 AM	7/1/2016 5:55:00 PM	BB67255	Lead	1	15	ppb
006-30A	Kitchen Sink Faucet	6/26/2016 1:41:00 AM	6/30/2016 2:37:00 PM	BB67256	Copper	0.9	1.3	ppm
006-30A	Kitchen Sink Faucet	6/26/2016 1:41:00 AM	6/30/2016 2:37:00 PM	BB67256	Lead	1	15	ppb
006-31A	Classroom 10 Sink Faucet	6/26/2016 1:43:00 AM	6/30/2016 2:40:00 PM	BB67257	Copper	0.8	1.3	ppm
006-31A	Classroom 10 Sink Faucet	6/26/2016 1:43:00 AM	6/30/2016 2:40:00 PM	BB67257	Lead	2	15	ppb
006-32A	Classroom 10 Drinking Fountain	6/26/2016 1:45:00 AM	6/30/2016 2:43:00 PM	BB67258	Copper	0.7	1.3	ppm
006-32A	Classroom 10 Drinking Fountain	6/26/2016 1:45:00 AM	6/30/2016 2:43:00 PM	BB67258	Lead	3	15	ppb
006-33A	Girls Bathroom Sink Faucet 1	6/26/2016 1:47:00 AM	6/30/2016 2:46:00 PM	BB67259	Copper	0.9	1.3	ppm
006-33A	Girls Bathroom Sink Faucet 1	6/26/2016 1:47:00 AM	6/30/2016 2:46:00 PM	BB67259	Lead	5	15	ppb
006-34A	Girls Bathroom Sink Faucet 2	6/26/2016 1:49:00 AM	6/30/2016 2:49:00 PM	BB67260	Copper	0.8	1.3	ppm
006-34A	Girls Bathroom Sink Faucet 2	6/26/2016 1:49:00 AM	6/30/2016 2:49:00 PM	BB67260	Lead	3	15	ppb
006-35A	Girls Bathroom Spigot	6/26/2016 1:51:00 AM	6/30/2016 3:10:00 PM	BB67261	Copper	1.0	1.3	ppm
006-35A	Girls Bathroom Spigot	6/26/2016 1:51:00 AM	6/30/2016 3:10:00 PM	BB67261	Lead	9	15	ppb
006-36A	Custodian 2 Slop Sink	6/26/2016 1:53:00 AM	6/30/2016 3:13:00 PM	BB67262	Copper	0.2	1.3	ppm
006-36A	Custodian 2 Slop Sink	6/26/2016 1:53:00 AM	6/30/2016 3:13:00 PM	BB67262	Lead	6	15	ppb
006-37A	Classroom 11 Sink Faucet	6/26/2016 1:55:00 AM	6/30/2016 3:16:00 PM	BB67263	Copper	0.6	1.3	ppm
006-37A	Classroom 11 Sink Faucet	6/26/2016 1:55:00 AM	6/30/2016 3:16:00 PM	BB67263	Lead	6	15	ppb
006-38A	Classroom 11 Drinking Fountain	6/26/2016 1:57:00 AM	6/30/2016 3:19:00 PM	BB67264	Copper	0.8	1.3	ppm
006-38A	Classroom 11 Drinking Fountain	6/26/2016 1:57:00 AM	6/30/2016 3:19:00 PM	BB67264	Lead	6	15	ppb
006-39A	Boys Bathroom Sink Faucet 1	6/26/2016 2:00:00 AM	6/30/2016 3:22:00 PM	BB67265	Copper	0.8	1.3	ppm
006-39A	Boys Bathroom Sink Faucet 1	6/26/2016 2:00:00 AM	6/30/2016 3:22:00 PM	BB67265	Lead	4	15	ppb
006-40A	Boys Bathroom Sink Faucet 2	6/26/2016 2:01:00 AM	6/30/2016 3:25:00 PM	BB67266	Copper	0.7	1.3	ppm
006-40A	Boys Bathroom Sink Faucet 2	6/26/2016 2:01:00 AM	6/30/2016 3:25:00 PM	BB67266	Lead	2	15	ppb
006-41A	Boys Bathroom Spigot	6/26/2016 2:03:00 AM	6/30/2016 3:29:00 PM	BB67267	Copper	0.7	1.3	ppm
006-41A	Boys Bathroom Spigot	6/26/2016 2:03:00 AM	6/30/2016 3:29:00 PM	BB67267	Lead	7	15	ppb
006-42A	Corridor Drinking Fountain #2	6/26/2016 2:05:00 AM	6/30/2016 3:31:00 PM	BB67268	Copper	0.9	1.3	ppm
006-42A	Corridor Drinking Fountain #2	6/26/2016 2:05:00 AM	6/30/2016 3:31:00 PM	BB67268	Lead	1	15	ppb
006-43A	Faculty 17 Bathroom Sink Faucet	6/26/2016 2:07:00 AM	6/30/2016 3:35:00 PM	BB67269	Copper	0.6	1.3	ppm
006-43A	Faculty 17 Bathroom Sink Faucet	6/26/2016 2:07:00 AM	6/30/2016 3:35:00 PM	BB67269	Lead	11	15	ppb
006-44A	Room 17 Storage Rm Sink Faucet	6/26/2016 2:10:00 AM	7/6/2016 12:26:00 PM	BB67270	Copper	0.1	1.3	ppm
006-44A	Room 17 Storage Rm Sink Faucet	6/26/2016 2:10:00 AM	7/6/2016 12:26:00 PM	BB67270	Lead	16	15	ppb
006-45A	Room 14 Sink Faucet	6/26/2016 2:15:00 AM	7/11/2016 9:44:00 AM	BB67271	Copper	0.4	1.3	ppm
006-45A	Room 14 Sink Faucet	6/26/2016 2:15:00 AM	7/11/2016 9:44:00 AM	BB67271	Lead	20	15	ppb
006-46A	Room 12 Drinking Fountain	6/26/2016 2:17:00 AM	7/11/2016 4:36:00 PM	BB67272	Copper	3.4	1.3	ppm
006-46A	Room 12 Drinking Fountain	6/26/2016 2:17:00 AM	7/11/2016 9:47:00 AM	BB67272	Lead	64	15	ppb
006-47A	Corridor Drinking Fountain #3	6/26/2016 2:20:00 AM	7/6/2016 12:28:00 PM	BB67273	Lead	0	15	ppb
006-47A	Corridor Drinking Fountain #3	6/26/2016 2:20:00 AM	7/6/2016 12:28:00 PM	BB67273	Copper	0.5	1.3	ppm
006-48A	Annex (Modular) Sink Fountain	6/26/2016 2:46:00 AM	7/6/2016 12:31:00 PM	BB67274	Copper	0.2	1.3	ppm
006-48A	Annex (Modular) Sink Fountain	6/26/2016 2:46:00 AM	7/6/2016 12:31:00 PM	BB67274	Lead	8	15	ppb
006-49A	Annex (Modular) Drinking Fountain	6/26/2016 2:48:00 AM	7/6/2016 12:34:00 PM	BB67275	Copper	0.0	1.3	ppm
006-49A	Annex (Modular) Drinking Fountain	6/26/2016 2:48:00 AM	7/6/2016 12:34:00 PM	BB67275	Lead	20	15	ppb
006-50A	Annex (Modular) Bathroom Sink	6/26/2016 2:50:00 AM	7/6/2016 12:36:00 PM	BB67276	Copper	0.1	1.3	ppm
006-50A	Annex (Modular) Bathroom Sink	6/26/2016 2:50:00 AM	7/6/2016 12:36:00 PM	BB67276	Lead	4	15	ppb
006-51A	Exterior Spigot by Room 4	6/26/2016 3:08:00 AM	7/6/2016 12:44:00 PM	BB67277	Copper	0.2	1.3	ppm
006-51A	Exterior Spigot by Room 4	6/26/2016 3:08:00 AM	7/6/2016 12:44:00 PM	BB67277	Lead	3	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Applegate Elementary School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
006-52A	Exterior Spigot by Room 13	6/26/2016 3:10:00 AM	7/6/2016 12:52:00 PM	BB67278	Copper	0.2	1.3	ppm
006-52A	Exterior Spigot by Room 13	6/26/2016 3:10:00 AM	7/6/2016 12:52:00 PM	BB67278	Lead	3	15	ppb
006-53A	Exterior Spigot by Room 17	6/26/2016 3:12:00 AM	7/6/2016 12:54:00 PM	BB67279	Copper	0.1	1.3	ppm
006-53A	Exterior Spigot by Room 17	6/26/2016 3:12:00 AM	7/6/2016 12:54:00 PM	BB67279	Lead	45	15	ppb
006-54A	Exterior Spigot by Room 21	6/26/2016 3:15:00 AM	7/6/2016 12:57:00 PM	BB67280	Copper	0.2	1.3	ppm
006-54A	Exterior Spigot by Room 21	6/26/2016 3:15:00 AM	7/6/2016 1:21:00 PM	BB67280	Lead	239	15	ppb
006-55A	Room 3 Drinking Fountain	6/26/2016 2:38:00 AM	7/6/2016 1:28:00 PM	BB67281	Lead	1	15	ppb
006-55A	Room 3 Drinking Fountain	6/26/2016 2:38:00 AM	7/6/2016 1:26:00 PM	BB67281	Copper	1.1	1.3	ppm
006-56A	Day Care Sink Faucet 1	6/26/2016 2:42:00 AM	7/6/2016 1:05:00 PM	BB67282	Copper	0.1	1.3	ppm
006-56A	Day Care Sink Faucet 1	6/26/2016 2:42:00 AM	7/6/2016 1:05:00 PM	BB67282	Lead	1	15	ppb
006-57A	Day Care Sink Faucet 2	6/26/2016 2:53:00 AM	7/6/2016 1:54:00 PM	BB67283	Copper	0.1	1.3	ppm
006-57A	Day Care Sink Faucet 2	6/26/2016 2:53:00 AM	7/6/2016 1:54:00 PM	BB67283	Lead	1	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.