

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Arleta Elementary School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
007-01A	Boiler Room Bathroom Faucet	6/17/2016 8:35:00 AM	6/22/2016 8:31:00 AM	BB65573	Copper	0.0	1.3	PPM
007-01A	Boiler Room Bathroom Faucet	6/17/2016 8:35:00 AM	6/22/2016 8:31:00 AM	BB65573	Lead	16	15	PPB
007-02A	Art Lab Drinking Fountain 1	6/17/2016 8:45:00 AM	6/22/2016 8:34:00 AM	BB65574	Copper	0.0	1.3	PPM
007-02A	Art Lab Drinking Fountain 1	6/17/2016 8:45:00 AM	6/22/2016 8:34:00 AM	BB65574	Lead	14.5	15	PPB
007-03A	Art Lab Drinking Fountain 2	6/17/2016 8:47:00 AM	6/22/2016 8:37:00 AM	BB65575	Copper	0.0	1.3	PPM
007-03A	Art Lab Drinking Fountain 2	6/17/2016 8:47:00 AM	6/22/2016 8:37:00 AM	BB65575	Lead	7	15	PPB
007-04A	Band Room Sink Faucet	6/17/2016 8:53:00 AM	6/22/2016 8:40:00 AM	BB65576	Copper	0.0	1.3	PPM
007-04A	Band Room Sink Faucet	6/17/2016 8:53:00 AM	6/22/2016 8:40:00 AM	BB65576	Lead	190	15	PPB
007-05A	Classroom 1 Extra Room Sink Faucet	6/17/2016 8:55:00 AM	6/22/2016 8:43:00 AM	BB65577	Copper	0.3	1.3	PPM
007-05A	Classroom 1 Extra Room Sink Faucet	6/17/2016 8:55:00 AM	6/22/2016 8:43:00 AM	BB65577	Lead	121	15	PPB
007-06A	Classroom 1 Sink Faucet 1	6/17/2016 8:57:00 AM	6/22/2016 8:46:00 AM	BB65578	Copper	0.2	1.3	PPM
007-06A	Classroom 1 Sink Faucet 1	6/17/2016 8:57:00 AM	6/22/2016 8:46:00 AM	BB65578	Lead	21	15	PPB
007-07A	Classroom 1 Sink Faucet 2	6/17/2016 9:00:00 AM	6/22/2016 8:49:00 AM	BB65579	Copper	0.3	1.3	PPM
007-07A	Classroom 1 Sink Faucet 2	6/17/2016 9:00:00 AM	6/22/2016 8:49:00 AM	BB65579	Lead	20	15	PPB
007-08A	Classroom 1 Eyewash	6/17/2016 9:01:00 AM	6/22/2016 8:52:00 AM	BB65580	Copper	0.4	1.3	PPM
007-08A	Classroom 1 Eyewash	6/17/2016 9:01:00 AM	6/22/2016 8:52:00 AM	BB65580	Lead	22	15	PPB
007-09A	Drinking Foutain outside Room 1	6/17/2016 9:03:00 AM	6/22/2016 8:55:00 AM	BB65581	Copper	0.0	1.3	PPM
007-09A	Drinking Foutain outside Room 1	6/17/2016 9:03:00 AM	6/22/2016 8:55:00 AM	BB65581	Lead	17	15	PPB
007-10A	Boys Bathroom Faucet 1	6/17/2016 9:14:00 AM	6/22/2016 8:58:00 AM	BB65582	Copper	0.2	1.3	PPM
007-10A	Boys Bathroom Faucet 1	6/17/2016 9:14:00 AM	6/22/2016 8:58:00 AM	BB65582	Lead	14	15	PPB
007-11A	Boys Bathroom Water Spigot	6/17/2016 9:16:00 AM	6/22/2016 9:13:00 AM	BB65583	Copper	0.0	1.3	PPM
007-11A	Boys Bathroom Water Spigot	6/17/2016 9:16:00 AM	6/22/2016 9:13:00 AM	BB65583	Lead	2	15	PPB
007-12A	Boys Bathroom Faucet 2	6/17/2016 9:18:00 AM	6/22/2016 9:16:00 AM	BB65584	Copper	0.1	1.3	PPM
007-12A	Boys Bathroom Faucet 2	6/17/2016 9:18:00 AM	6/22/2016 9:16:00 AM	BB65584	Lead	11	15	PPB
007-13A	Boys Bathroom Faucet 3	6/17/2016 9:20:00 AM	6/22/2016 9:19:00 AM	BB65585	Copper	0.2	1.3	PPM
007-13A	Boys Bathroom Faucet 3	6/17/2016 9:20:00 AM	6/22/2016 9:19:00 AM	BB65585	Lead	11	15	PPB
007-14A	Classroom 3 Sink Faucet	6/17/2016 9:22:00 AM	6/22/2016 9:23:00 AM	BB65586	Copper	0.0	1.3	PPM
007-14A	Classroom 3 Sink Faucet	6/17/2016 9:22:00 AM	6/22/2016 9:23:00 AM	BB65586	Lead	27	15	PPB
007-15A	Classroom 4 Sink Faucet 1	6/17/2016 9:57:00 AM	6/22/2016 9:26:00 AM	BB65587	Copper	0.2	1.3	PPM
007-15A	Classroom 4 Sink Faucet 1	6/17/2016 9:57:00 AM	6/22/2016 9:26:00 AM	BB65587	Lead	27	15	PPB
007-16A	Classroom 4 Sink Faucet 2	6/17/2016 10:00:00 AM	6/22/2016 9:29:00 AM	BB65588	Copper	0.3	1.3	PPM
007-16A	Classroom 4 Sink Faucet 2	6/17/2016 10:00:00 AM	6/22/2016 9:29:00 AM	BB65588	Lead	14.9	15	PPB
007-17A	Classroom 4 Eyewash	6/17/2016 10:01:00 AM	6/22/2016 9:32:00 AM	BB65589	Copper	0.6	1.3	PPM
007-17A	Classroom 4 Eyewash	6/17/2016 10:01:00 AM	6/22/2016 9:32:00 AM	BB65589	Lead	29	15	PPB
007-18A	Drinking Fountain outside Room 3	6/17/2016 9:24:00 AM	6/22/2016 9:35:00 AM	BB65590	Copper	0.0	1.3	PPM
007-18A	Drinking Fountain outside Room 3	6/17/2016 9:24:00 AM	6/22/2016 9:35:00 AM	BB65590	Lead	2	15	PPB
007-19A	Drinking Fountain 2	6/17/2016 9:26:00 AM	6/22/2016 9:38:00 AM	BB65591	Copper	0.0	1.3	PPM
007-19A	Drinking Fountain 2	6/17/2016 9:26:00 AM	6/22/2016 9:38:00 AM	BB65591	Lead	2	15	PPB
007-20A	Staff Bathroom Faucet	6/17/2016 9:43:00 AM	6/22/2016 9:41:00 AM	BB65592	Copper	0.1	1.3	PPM
007-20A	Staff Bathroom Faucet	6/17/2016 9:43:00 AM	6/22/2016 9:41:00 AM	BB65592	Lead	24	15	PPB
007-21A	Girls Bathroom 5B Faucet 1	6/17/2016 9:45:00 AM	6/22/2016 10:02:00 AM	BB65593	Copper	0.1	1.3	PPM
007-21A	Girls Bathroom 5B Faucet 1	6/17/2016 9:45:00 AM	6/22/2016 10:02:00 AM	BB65593	Lead	14	15	PPB
007-22A	Girls Bathroom 5B Faucet 2	6/17/2016 9:47:00 AM	6/22/2016 10:05:00 AM	BB65594	Copper	0.0	1.3	PPM
007-22A	Girls Bathroom 5B Faucet 2	6/17/2016 9:47:00 AM	6/22/2016 10:05:00 AM	BB65594	Lead	7	15	PPB
007-23A	Girls Bathroom 5B Water Spigot	6/17/2016 9:49:00 AM	6/22/2016 10:08:00 AM	BB65595	Copper	0.1	1.3	PPM
007-23A	Girls Bathroom 5B Water Spigot	6/17/2016 9:49:00 AM	6/22/2016 10:08:00 AM	BB65595	Lead	12	15	PPB
007-24A	Girls Bathroom 5B Faucet 3	6/17/2016 9:51:00 AM	6/22/2016 2:14:00 PM	BB65596	Copper	0.1	1.3	PPM
007-24A	Girls Bathroom 5B Faucet 3	6/17/2016 9:51:00 AM	6/22/2016 2:14:00 PM	BB65596	Lead	15.0	15	PPB
007-25A	5C Janitors Closet Sink Faucet	6/17/2016 9:53:00 AM	6/22/2016 10:14:00 AM	BB65597	Copper	0.0	1.3	PPM
007-25A	5C Janitors Closet Sink Faucet	6/17/2016 9:53:00 AM	6/22/2016 10:14:00 AM	BB65597	Lead	43	15	PPB
007-26A	Hall Drinking Fountain Btwn Gym/Auditorium	6/17/2016 9:55:00 AM	6/22/2016 10:17:00 AM	BB65598	Copper	0.1	1.3	PPM
007-26A	Hall Drinking Fountain Btwn Gym/Auditorium	6/17/2016 9:55:00 AM	6/22/2016 10:17:00 AM	BB65598	Lead	6	15	PPB
007-27A	Sink Behind Auditorium (Literary Support)	6/17/2016 10:29:00 AM	6/22/2016 10:20:00 AM	BB65599	Copper	0.0	1.3	PPM
007-27A	Sink Behind Auditorium (Literary Support)	6/17/2016 10:29:00 AM	6/22/2016 10:20:00 AM	BB65599	Lead	13	15	PPB
007-28A	Staff Bathroom Faucet	6/17/2016 10:31:00 AM	6/22/2016 10:23:00 AM	BB65600	Copper	0.0	1.3	PPM
007-28A	Staff Bathroom Faucet	6/17/2016 10:31:00 AM	6/22/2016 10:23:00 AM	BB65600	Lead	19	15	PPB

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Arleta Elementary School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
007-29A	Staff Lounge Sink Faucet 7D	6/17/2016 10:33:00 AM	6/22/2016 10:26:00 AM	BB65601	Copper	0.2	1.3	PPM
007-29A	Staff Lounge Sink Faucet 7D	6/17/2016 10:33:00 AM	6/22/2016 10:26:00 AM	BB65601	Lead	4	15	PPB
007-30A	Staff Lounge Drinking Fountain 7D	6/17/2016 10:35:00 AM	6/22/2016 10:29:00 AM	BB65602	Copper	0.0	1.3	PPM
007-30A	Staff Lounge Drinking Fountain 7D	6/17/2016 10:35:00 AM	6/22/2016 10:29:00 AM	BB65602	Lead	0	15	PPB
007-31A	Office Sink Faucet (Library)	6/17/2016 10:37:00 AM	6/22/2016 10:44:00 AM	BB65603	Copper	0.0	1.3	PPM
007-31A	Office Sink Faucet (Library)	6/17/2016 10:37:00 AM	6/22/2016 10:44:00 AM	BB65603	Lead	20	15	PPB
007-32A	Girls Bathroom 7H Faucet 1	6/17/2016 10:39:00 AM	6/22/2016 10:47:00 AM	BB65604	Copper	0.1	1.3	PPM
007-32A	Girls Bathroom 7H Faucet 1	6/17/2016 10:39:00 AM	6/22/2016 10:47:00 AM	BB65604	Lead	26	15	PPB
007-33A	Girls Bathroom 7H Water Spigot	6/17/2016 10:41:00 AM	6/22/2016 10:50:00 AM	BB65605	Copper	0.2	1.3	PPM
007-33A	Girls Bathroom 7H Water Spigot	6/17/2016 10:41:00 AM	6/22/2016 10:50:00 AM	BB65605	Lead	41	15	PPB
007-34A	Girls Bathroom &H Faucet 2	6/17/2016 10:43:00 AM	6/22/2016 10:53:00 AM	BB65606	Copper	0.0	1.3	PPM
007-34A	Girls Bathroom &H Faucet 2	6/17/2016 10:43:00 AM	6/22/2016 10:53:00 AM	BB65606	Lead	14	15	PPB
007-35A	Girls Bathroom 7H Faucet 3	6/17/2016 10:45:00 AM	6/22/2016 2:17:00 PM	BB65607	Copper	0.1	1.3	PPM
007-35A	Girls Bathroom 7H Faucet 3	6/17/2016 10:45:00 AM	6/22/2016 2:17:00 PM	BB65607	Lead	12	15	PPB
007-36A	Drinking Fountain 7H Hall	6/17/2016 10:47:00 AM	6/22/2016 11:00:00 AM	BB65608	Copper	0.0	1.3	PPM
007-36A	Drinking Fountain 7H Hall	6/17/2016 10:47:00 AM	6/22/2016 11:00:00 AM	BB65608	Lead	4	15	PPB
007-37A	Drinking Fountain 7H Hall	6/17/2016 10:49:00 AM	6/22/2016 11:02:00 AM	BB65609	Copper	0.1	1.3	PPM
007-37A	Drinking Fountain 7H Hall	6/17/2016 10:49:00 AM	6/22/2016 11:02:00 AM	BB65609	Lead	3	15	PPB
007-38A	Boys Bathroom 8A Faucet 1	6/17/2016 11:21:00 AM	6/22/2016 11:06:00 AM	BB65610	Copper	0.0	1.3	PPM
007-38A	Boys Bathroom 8A Faucet 1	6/17/2016 11:21:00 AM	6/22/2016 11:06:00 AM	BB65610	Lead	37	15	PPB
007-39A	Boys Bathroom 8A Faucet 2	6/17/2016 11:23:00 AM	6/22/2016 11:09:00 AM	BB65611	Copper	0.0	1.3	PPM
007-39A	Boys Bathroom 8A Faucet 2	6/17/2016 11:23:00 AM	6/22/2016 11:09:00 AM	BB65611	Lead	40	15	PPB
007-40A	Boys Bathroom 8A Water Spigot	6/17/2016 11:25:00 AM	6/22/2016 11:12:00 AM	BB65612	Copper	0.0	1.3	PPM
007-40A	Boys Bathroom 8A Water Spigot	6/17/2016 11:25:00 AM	6/22/2016 11:12:00 AM	BB65612	Lead	16	15	PPB
007-41A	Boys Bathroom 8A Faucet 3	6/17/2016 11:27:00 AM	6/22/2016 11:33:00 AM	BB65613	Copper	0.0	1.3	PPM
007-41A	Boys Bathroom 8A Faucet 3	6/17/2016 11:27:00 AM	6/22/2016 11:33:00 AM	BB65613	Lead	66	15	PPB
007-42A	Janitors Closet 8B	6/17/2016 11:29:00 AM	6/22/2016 11:36:00 AM	BB65614	Copper	0.0	1.3	PPM
007-42A	Janitors Closet 8B	6/17/2016 11:29:00 AM	6/22/2016 11:36:00 AM	BB65614	Lead	12	15	PPB
007-43A	Classroom 9 Sink Faucet	6/17/2016 11:31:00 AM	6/22/2016 11:39:00 AM	BB65615	Copper	0.0	1.3	PPM
007-43A	Classroom 9 Sink Faucet	6/17/2016 11:31:00 AM	6/22/2016 11:39:00 AM	BB65615	Lead	11	15	PPB
007-44A	Classroom 10 Sink Faucet	6/17/2016 11:33:00 AM	6/22/2016 11:42:00 AM	BB65616	Copper	0.4	1.3	PPM
007-44A	Classroom 10 Sink Faucet	6/17/2016 11:33:00 AM	6/22/2016 11:42:00 AM	BB65616	Lead	13	15	PPB
007-45A	Classroom 10 Drinking Fountain	6/17/2016 11:35:00 AM	6/22/2016 11:45:00 AM	BB65617	Copper	0.3	1.3	PPM
007-45A	Classroom 10 Drinking Fountain	6/17/2016 11:35:00 AM	6/22/2016 11:45:00 AM	BB65617	Lead	17	15	PPB
007-46A	Classroom 10 Bathroom Faucet	6/17/2016 11:37:00 AM	6/22/2016 11:48:00 AM	BB65618	Copper	0.6	1.3	PPM
007-46A	Classroom 10 Bathroom Faucet	6/17/2016 11:37:00 AM	6/22/2016 11:48:00 AM	BB65618	Lead	3	15	PPB
007-47A	Library Sink Faucet	6/17/2016 11:39:00 AM	6/22/2016 11:51:00 AM	BB65619	Copper	0.0	1.3	PPM
007-47A	Library Sink Faucet	6/17/2016 11:39:00 AM	6/22/2016 11:51:00 AM	BB65619	Lead	6	15	PPB
007-48A	Drinking Fountain outside Room 10	6/17/2016 10:47:00 AM	6/22/2016 11:54:00 AM	BB65620	Copper	0.1	1.3	PPM
007-48A	Drinking Fountain outside Room 10	6/17/2016 10:47:00 AM	6/22/2016 11:54:00 AM	BB65620	Lead	19	15	PPB
007-49A	Drinking Fountain outside Room 20	6/17/2016 11:50:00 AM	6/22/2016 11:57:00 AM	BB65621	Copper	0.1	1.3	PPM
007-49A	Drinking Fountain outside Room 20	6/17/2016 11:50:00 AM	6/22/2016 11:57:00 AM	BB65621	Lead	6	15	PPB
007-50A	Boys Bathroom Faucet 1	6/17/2016 11:52:00 AM	6/22/2016 12:00:00 PM	BB65622	Copper	0.1	1.3	PPM
007-50A	Boys Bathroom Faucet 1	6/17/2016 11:52:00 AM	6/22/2016 12:00:00 PM	BB65622	Lead	55	15	PPB
007-51A	Boys Bathroom Water Spigot	6/17/2016 11:54:00 AM	6/22/2016 12:15:00 PM	BB65623	Copper	0.2	1.3	PPM
007-51A	Boys Bathroom Water Spigot	6/17/2016 11:54:00 AM	6/22/2016 12:15:00 PM	BB65623	Lead	25	15	PPB
007-52A	Boys Bathroom Faucet 2	6/17/2016 11:56:00 AM	6/22/2016 12:19:00 PM	BB65624	Copper	0.0	1.3	PPM
007-52A	Boys Bathroom Faucet 2	6/17/2016 11:56:00 AM	6/22/2016 12:19:00 PM	BB65624	Lead	38	15	PPB
007-53A	Boys Bathroom Faucet 3	6/17/2016 11:58:00 AM	6/22/2016 12:22:00 PM	BB65625	Copper	0.0	1.3	PPM
007-53A	Boys Bathroom Faucet 3	6/17/2016 11:58:00 AM	6/22/2016 12:22:00 PM	BB65625	Lead	23	15	PPB
007-54A	Janitors Closet by Room 17A Sink Faucet	6/17/2016 12:10:00 PM	6/22/2016 12:25:00 PM	BB65626	Copper	0.0	1.3	PPM
007-54A	Janitors Closet by Room 17A Sink Faucet	6/17/2016 12:10:00 PM	6/22/2016 12:25:00 PM	BB65626	Lead	32	15	PPB
007-55A	Classroom 17A Sink Faucet	6/17/2016 12:12:00 PM	6/22/2016 12:28:00 PM	BB65627	Copper	0.0	1.3	PPM
007-55A	Classroom 17A Sink Faucet	6/17/2016 12:12:00 PM	6/22/2016 12:28:00 PM	BB65627	Lead	61	15	PPB
007-56A	Girls Bathroom Faucet 1	6/17/2016 12:14:00 PM	6/22/2016 12:31:00 PM	BB65628	Copper	0.0	1.3	PPM
007-56A	Girls Bathroom Faucet 1	6/17/2016 12:14:00 PM	6/22/2016 12:31:00 PM	BB65628	Lead	20	15	PPB

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Arleta Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA	Units
						Action Level	
007-57A Girls Bathroom Water Spigot	6/17/2016 12:16:00 PM	6/22/2016 12:34:00 PM	BB65629	Copper	0.0	1.3	PPM
007-57A Girls Bathroom Water Spigot	6/17/2016 12:16:00 PM	6/22/2016 12:34:00 PM	BB65629	Lead	32	15	PPB
007-58A Girls Bathroom Faucet 2	6/17/2016 12:18:00 PM	6/22/2016 12:37:00 PM	BB65630	Copper	0.0	1.3	PPM
007-58A Girls Bathroom Faucet 2	6/17/2016 12:18:00 PM	6/22/2016 12:37:00 PM	BB65630	Lead	12	15	PPB
007-59A Girls Bathroom Faucet 3	6/17/2016 12:20:00 PM	6/22/2016 12:40:00 PM	BB65631	Copper	0.0	1.3	PPM
007-59A Girls Bathroom Faucet 3	6/17/2016 12:20:00 PM	6/22/2016 12:40:00 PM	BB65631	Lead	7	15	PPB
007-60A Drinking Fountain 1 upstairs	6/17/2016 12:22:00 PM	6/22/2016 12:43:00 PM	BB65632	Copper	0.0	1.3	PPM
007-60A Drinking Fountain 1 upstairs	6/17/2016 12:22:00 PM	6/22/2016 12:43:00 PM	BB65632	Lead	14	15	PPB
007-61A Drinking Fountain 2 upstairs	6/17/2016 12:24:00 PM	6/22/2016 1:04:00 PM	BB65633	Copper	0.0	1.3	PPM
007-61A Drinking Fountain 2 upstairs	6/17/2016 12:24:00 PM	6/22/2016 1:04:00 PM	BB65633	Lead	57	15	PPB
007-62A Janitors Closet Sink	6/17/2016 12:26:00 PM	6/22/2016 1:07:00 PM	BB65634	Copper	0.0	1.3	PPM
007-62A Janitors Closet Sink	6/17/2016 12:26:00 PM	6/22/2016 1:07:00 PM	BB65634	Lead	27	15	PPB
007-63A Girls Bathroom Faucet 1	6/17/2016 12:28:00 PM	6/22/2016 1:10:00 PM	BB65635	Copper	0.0	1.3	PPM
007-63A Girls Bathroom Faucet 1	6/17/2016 12:28:00 PM	6/22/2016 1:10:00 PM	BB65635	Lead	17	15	PPB
007-64A Girls Bathroom Faucet 2	6/17/2016 12:30:00 PM	6/22/2016 1:13:00 PM	BB65636	Copper	0.0	1.3	PPM
007-64A Girls Bathroom Faucet 2	6/17/2016 12:30:00 PM	6/22/2016 1:13:00 PM	BB65636	Lead	14	15	PPB
007-65A Girls Bathroom Water Spigot	6/17/2016 12:32:00 PM	6/22/2016 1:16:00 PM	BB65637	Copper	0.0	1.3	PPM
007-65A Girls Bathroom Water Spigot	6/17/2016 12:32:00 PM	6/22/2016 1:16:00 PM	BB65637	Lead	66	15	PPB
007-66A Girls Bathroom Faucet 3	6/17/2016 12:34:00 PM	6/22/2016 1:19:00 PM	BB65638	Copper	0.0	1.3	PPM
007-66A Girls Bathroom Faucet 3	6/17/2016 12:34:00 PM	6/22/2016 1:19:00 PM	BB65638	Lead	18	15	PPB
007-67A Drinking Fountain outside Room 15	6/17/2016 12:36:00 PM	6/22/2016 1:22:00 PM	BB65639	Copper	0.0	1.3	PPM
007-67A Drinking Fountain outside Room 15	6/17/2016 12:36:00 PM	6/22/2016 1:22:00 PM	BB65639	Lead	5	15	PPB
007-68A Drinking Fountain 2 outside Room 15	6/17/2016 12:38:00 PM	6/22/2016 1:25:00 PM	BB65640	Copper	0.0	1.3	PPM
007-68A Drinking Fountain 2 outside Room 15	6/17/2016 12:38:00 PM	6/22/2016 1:25:00 PM	BB65640	Lead	4	15	PPB
007-69A Drinking Fountain outside Room 13	6/17/2016 12:40:00 PM	6/24/2016 9:08:00 AM	BB65641	Copper	0.0	1.3	PPM
007-69A Drinking Fountain outside Room 13	6/17/2016 12:40:00 PM	6/24/2016 9:08:00 AM	BB65641	Lead	12	15	PPB
007-70A Boys Bathroom Faucet 1	6/17/2016 12:42:00 PM	6/22/2016 1:28:00 PM	BB65642	Copper	0.0	1.3	PPM
007-70A Boys Bathroom Faucet 1	6/17/2016 12:42:00 PM	6/22/2016 1:28:00 PM	BB65642	Lead	14	15	PPB
007-71A Boys Bathroom Faucet 2	6/17/2016 12:44:00 PM	6/22/2016 1:31:00 PM	BB65643	Copper	0.0	1.3	PPM
007-71A Boys Bathroom Faucet 2	6/17/2016 12:44:00 PM	6/22/2016 1:31:00 PM	BB65643	Lead	11	15	PPB
007-72A Boys Bathroom Water Spigot	6/17/2016 12:46:00 PM	6/23/2016 10:57:00 AM	BB65644	Copper	0.1	1.3	PPM
007-72A Boys Bathroom Water Spigot	6/17/2016 12:46:00 PM	6/23/2016 10:57:00 AM	BB65644	Lead	8	15	PPB
007-73A Boys Bathroom Faucet 3	6/17/2016 12:48:00 PM	6/23/2016 11:00:00 AM	BB65645	Copper	0.0	1.3	PPM
007-73A Boys Bathroom Faucet 3	6/17/2016 12:48:00 PM	6/23/2016 11:00:00 AM	BB65645	Lead	13	15	PPB
007-74A Teachers Bathroom Faucet	6/17/2016 12:50:00 PM	6/23/2016 11:03:00 AM	BB65646	Copper	0.0	1.3	PPM
007-74A Teachers Bathroom Faucet	6/17/2016 12:50:00 PM	6/23/2016 11:03:00 AM	BB65646	Lead	25	15	PPB
007-75A Teachers Sink Faucet	6/17/2016 12:52:00 PM	6/23/2016 11:07:00 AM	BB65647	Copper	0.0	1.3	PPM
007-75A Teachers Sink Faucet	6/17/2016 12:52:00 PM	6/23/2016 11:07:00 AM	BB65647	Lead	11	15	PPB
007-76A Exterior Water Spigot 1	6/17/2016 11:22:00 AM	6/23/2016 11:10:00 AM	BB65648	Copper	0.0	1.3	PPM
007-76A Exterior Water Spigot 1	6/17/2016 11:22:00 AM	6/23/2016 11:10:00 AM	BB65648	Lead	19	15	PPB
007-77A Exterior Water Spigot 2	6/17/2016 11:24:00 AM	6/23/2016 11:13:00 AM	BB65649	Copper	0.0	1.3	PPM
007-77A Exterior Water Spigot 2	6/17/2016 11:24:00 AM	6/23/2016 11:13:00 AM	BB65649	Lead	25	15	PPB
007-78A Exterior Water Spigot 3	6/17/2016 11:26:00 AM	6/23/2016 11:16:00 AM	BB65650	Copper	0.0	1.3	PPM
007-78A Exterior Water Spigot 3	6/17/2016 11:26:00 AM	6/23/2016 11:16:00 AM	BB65650	Lead	33	15	PPB
007-79A Exterior Water Spigot 4	6/17/2016 11:28:00 AM	6/23/2016 11:19:00 AM	BB65651	Copper	0.3	1.3	PPM
007-79A Exterior Water Spigot 4	6/17/2016 11:28:00 AM	6/23/2016 11:19:00 AM	BB65651	Lead	27	15	PPB
007-80A Exterior Water Spigot 5	6/17/2016 11:30:00 AM	6/23/2016 11:22:00 AM	BB65652	Copper	0.1	1.3	PPM
007-80A Exterior Water Spigot 5	6/17/2016 11:30:00 AM	6/23/2016 11:22:00 AM	BB65652	Lead	28	15	PPB
007-81A Exterior Water Spigot 6	6/17/2016 11:32:00 AM	7/3/2016 12:58:00 PM	BB65653	Copper	0.3	1.3	PPM
007-81A Exterior Water Spigot 6	6/17/2016 11:32:00 AM	7/3/2016 12:58:00 PM	BB65653	Lead	82	15	PPB
007-82A Exterior Water Spigot 7	6/17/2016 11:36:00 AM	6/23/2016 11:25:00 AM	BB65654	Copper	0.1	1.3	PPM
007-82A Exterior Water Spigot 7	6/17/2016 11:36:00 AM	6/23/2016 11:25:00 AM	BB65654	Lead	37	15	PPB
007-83A Girls Bathroom 41 Water Spigot	6/17/2016 1:11:00 PM	6/23/2016 11:40:00 AM	BB65655	Copper	0.0	1.3	PPM
007-83A Girls Bathroom 41 Water Spigot	6/17/2016 1:11:00 PM	6/23/2016 11:40:00 AM	BB65655	Lead	5	15	PPB
007-84A Girls Bathroom 41 Faucet 1	6/17/2016 1:11:00 PM	6/23/2016 11:43:00 AM	BB65656	Copper	0.0	1.3	PPM
007-84A Girls Bathroom 41 Faucet 1	6/17/2016 1:11:00 PM	6/23/2016 11:43:00 AM	BB65656	Lead	16	15	PPB

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Arleta Elementary School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
007-85A	Girls Bathroom 41 Faucet 2	6/17/2016 1:15:00 PM	6/23/2016 11:46:00 AM	BB65657	Copper	0.0	1.3	PPM
007-85A	Girls Bathroom 41 Faucet 2	6/17/2016 1:15:00 PM	6/23/2016 11:46:00 AM	BB65657	Lead	8	15	PPB
007-86A	Boys Bathroom 40 Faucet 1	6/17/2016 1:17:00 PM	6/23/2016 11:49:00 AM	BB65658	Copper	0.0	1.3	PPM
007-86A	Boys Bathroom 40 Faucet 1	6/17/2016 1:17:00 PM	6/23/2016 11:49:00 AM	BB65658	Lead	13	15	PPB
007-87A	Boys Bathroom 40 Water Spigot	6/17/2016 1:19:00 PM	6/23/2016 11:52:00 AM	BB65659	Copper	0.1	1.3	PPM
007-87A	Boys Bathroom 40 Water Spigot	6/17/2016 1:19:00 PM	6/23/2016 11:52:00 AM	BB65659	Lead	6	15	PPB
007-88A	Kitchen Bathroom Faucet	6/17/2016 1:21:00 PM	6/23/2016 11:55:00 AM	BB65660	Copper	0.2	1.3	PPM
007-88A	Kitchen Bathroom Faucet	6/17/2016 1:21:00 PM	6/23/2016 11:55:00 AM	BB65660	Lead	13	15	PPB
007-89A	Kitchen Janitorial Closet Sink	6/17/2016 1:23:00 PM	6/23/2016 11:58:00 AM	BB65661	Copper	0.1	1.3	PPM
007-89A	Kitchen Janitorial Closet Sink	6/17/2016 1:23:00 PM	6/23/2016 11:58:00 AM	BB65661	Lead	26	15	PPB
007-90A	Kitchen Food Prep Sink Faucet	6/17/2016 1:25:00 PM	6/23/2016 12:01:00 PM	BB65662	Copper	0.1	1.3	PPM
007-90A	Kitchen Food Prep Sink Faucet	6/17/2016 1:25:00 PM	6/23/2016 12:01:00 PM	BB65662	Lead	27	15	PPB
007-91A	Kitchen Sink Faucet	6/17/2016 1:27:00 PM	6/23/2016 12:04:00 PM	BB65663	Copper	0.1	1.3	PPM
007-91A	Kitchen Sink Faucet	6/17/2016 1:27:00 PM	6/23/2016 12:04:00 PM	BB65663	Lead	8	15	PPB
007-92A	Kitchen Food Prep Sink Faucet	6/17/2016 1:29:00 PM	6/23/2016 12:07:00 PM	BB65664	Copper	0.1	1.3	PPM
007-92A	Kitchen Food Prep Sink Faucet	6/17/2016 1:29:00 PM	6/23/2016 12:07:00 PM	BB65664	Lead	3	15	PPB
007-93A	Janitorial Closet 40A Sink	6/17/2016 1:52:00 PM	6/24/2016 8:44:00 AM	BB65665	Copper	0.1	1.3	PPM
007-93A	Janitorial Closet 40A Sink	6/17/2016 1:52:00 PM	6/24/2016 8:44:00 AM	BB65665	Lead	18	15	PPB
007-94A	Drinking Fountain outside Café	6/17/2016 1:44:00 PM	6/24/2016 8:47:00 AM	BB65666	Copper	0.0	1.3	PPM
007-94A	Drinking Fountain outside Café	6/17/2016 1:44:00 PM	6/24/2016 8:47:00 AM	BB65666	Lead	2	15	PPB
007-95A	Bathroom Faucet	6/17/2016 1:46:00 PM	6/24/2016 8:50:00 AM	BB65667	Copper	0.1	1.3	PPM
007-95A	Bathroom Faucet	6/17/2016 1:46:00 PM	6/24/2016 8:50:00 AM	BB65667	Lead	24	15	PPB
007-96A	Classroom 32 Sink Faucet	6/17/2016 1:39:00 PM	6/24/2016 8:53:00 AM	BB65668	Copper	0.1	1.3	PPM
007-96A	Classroom 32 Sink Faucet	6/17/2016 1:39:00 PM	6/24/2016 8:53:00 AM	BB65668	Lead	10	15	PPB
007-97A	Classroom 32 Drinking Fountain	6/17/2016 1:45:00 PM	6/24/2016 8:56:00 AM	BB65669	Copper	0.0	1.3	PPM
007-97A	Classroom 32 Drinking Fountain	6/17/2016 1:45:00 PM	6/24/2016 8:56:00 AM	BB65669	Lead	31	15	PPB
007-98A	Classroom 39 Drinking Fountain	6/17/2016 1:47:00 PM	6/24/2016 8:59:00 AM	BB65670	Copper	0.0	1.3	PPM
007-98A	Classroom 39 Drinking Fountain	6/17/2016 1:47:00 PM	6/24/2016 8:59:00 AM	BB65670	Lead	8	15	PPB
007-99A	Classroom 39 Sink Faucet	6/17/2016 1:49:00 PM	6/24/2016 9:02:00 AM	BB65671	Copper	0.1	1.3	PPM
007-99A	Classroom 39 Sink Faucet	6/17/2016 1:49:00 PM	6/24/2016 9:02:00 AM	BB65671	Lead	8	15	PPB
007-100A	Classroom 38 Drinking Fountain	6/17/2016 1:42:00 PM	6/24/2016 9:05:00 AM	BB65672	Copper	0.0	1.3	PPM
007-100A	Classroom 38 Drinking Fountain	6/17/2016 1:42:00 PM	6/24/2016 9:05:00 AM	BB65672	Lead	17	15	PPB
007-101A	Classroom 38 Sink Faucet	6/17/2016 1:44:00 PM	6/28/2016 7:57:00 PM	BB65673	Copper	0.1	1.3	PPM
007-101A	Classroom 38 Sink Faucet	6/17/2016 1:44:00 PM	6/28/2016 7:57:00 PM	BB65673	Lead	14	15	PPB
007-102A	Classroom 33 Sink Faucet	6/17/2016 1:22:00 PM	6/24/2016 9:11:00 AM	BB65674	Copper	0.1	1.3	PPM
007-102A	Classroom 33 Sink Faucet	6/17/2016 1:22:00 PM	6/24/2016 9:11:00 AM	BB65674	Lead	6	15	PPB
007-103A	Classroom 33 Drinking Fountain	6/17/2016 1:24:00 PM	6/24/2016 9:32:00 AM	BB65675	Copper	0.0	1.3	PPM
007-103A	Classroom 33 Drinking Fountain	6/17/2016 1:24:00 PM	6/24/2016 9:32:00 AM	BB65675	Lead	3	15	PPB
007-104A	Classroom 37 Drinking Fountain	6/17/2016 1:26:00 PM	6/24/2016 9:35:00 AM	BB65676	Copper	0.0	1.3	PPM
007-104A	Classroom 37 Drinking Fountain	6/17/2016 1:26:00 PM	6/24/2016 9:35:00 AM	BB65676	Lead	18	15	PPB
007-105A	Classroom 37 Sink Faucet	6/17/2016 1:28:00 PM	6/24/2016 9:38:00 AM	BB65677	Copper	0.1	1.3	PPM
007-105A	Classroom 37 Sink Faucet	6/17/2016 1:28:00 PM	6/24/2016 9:38:00 AM	BB65677	Lead	9	15	PPB
007-106A	Classroom 34 Sink Faucet	6/17/2016 1:30:00 PM	6/24/2016 9:41:00 AM	BB65678	Copper	0.0	1.3	PPM
007-106A	Classroom 34 Sink Faucet	6/17/2016 1:30:00 PM	6/24/2016 9:41:00 AM	BB65678	Lead	4	15	PPB
007-107A	Classroom 34 Drinking Fountain	6/17/2016 1:32:00 PM	6/24/2016 9:44:00 AM	BB65679	Copper	0.0	1.3	PPM
007-107A	Classroom 34 Drinking Fountain	6/17/2016 1:32:00 PM	6/24/2016 9:44:00 AM	BB65679	Lead	4	15	PPB
007-108A	Classroom 36 Sink Faucet	6/17/2016 1:34:00 PM	6/24/2016 9:47:00 AM	BB65680	Copper	0.1	1.3	PPM
007-108A	Classroom 36 Sink Faucet	6/17/2016 1:34:00 PM	6/24/2016 9:47:00 AM	BB65680	Lead	46	15	PPB
007-109A	Classroom 35 Sink Faucet	6/17/2016 1:36:00 PM	6/24/2016 9:51:00 AM	BB65681	Copper	0.0	1.3	PPM
007-109A	Classroom 35 Sink Faucet	6/17/2016 1:36:00 PM	6/24/2016 9:51:00 AM	BB65681	Lead	6	15	PPB
007-110A	Classroom 35 Drinking Fountain	6/17/2016 1:38:00 PM	6/24/2016 7:37:00 PM	BB65682	Copper	0.0	1.3	PPM
007-110A	Classroom 35 Drinking Fountain	6/17/2016 1:38:00 PM	6/24/2016 7:37:00 PM	BB65682	Lead	3	15	PPB
007-111A	Outdoor Water Spigot A1	6/17/2016 11:36:00 AM	6/24/2016 9:53:00 AM	BB65683	Copper	0.0	1.3	PPM
007-111A	Outdoor Water Spigot A1	6/17/2016 11:36:00 AM	6/24/2016 9:53:00 AM	BB65683	Lead	6	15	PPB
007-112A	Outdoor Water Spigot A2	6/17/2016 11:38:00 AM	6/24/2016 9:57:00 AM	BB65684	Copper	0.0	1.3	PPM
007-112A	Outdoor Water Spigot A2	6/17/2016 11:38:00 AM	6/24/2016 9:57:00 AM	BB65684	Lead	27	15	PPB

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Arleta Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA	Units
						Action Level	
007-113A Outdoor Water Spigot A3	6/17/2016 11:40:00 AM	6/24/2016 10:00:00 AM	BB65685	Copper	0.0	1.3	PPM
007-113A Outdoor Water Spigot A3	6/17/2016 11:40:00 AM	6/24/2016 10:00:00 AM	BB65685	Lead	6	15	PPB
007-114A Outdoor Water Spigot A4	6/17/2016 11:42:00 AM	6/24/2016 10:15:00 AM	BB65686	Copper	0.0	1.3	PPM
007-114A Outdoor Water Spigot A4	6/17/2016 11:42:00 AM	6/24/2016 10:15:00 AM	BB65686	Lead	19	15	PPB
007-115A Outdoor Water Spigot A5	6/17/2016 11:44:00 AM	6/24/2016 10:18:00 AM	BB65687	Copper	0.0	1.3	PPM
007-115A Outdoor Water Spigot A5	6/17/2016 11:44:00 AM	6/24/2016 10:18:00 AM	BB65687	Lead	3	15	PPB

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.