

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Alkinson Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA	
						Action Level	Units
009-01A Custodial Office Sink Faucet (White)	6/30/2016 20:22	7/6/2016	36951	Copper	0.2	1.3	ppm
009-01A Custodial Office Sink Faucet (White)	6/30/2016 20:22	7/6/2016	36951	Lead	ND	15	ppm
009-02A Custodial Office Round Slop Sink Faucet	6/30/2016 20:23	7/6/2016	36953	Copper	0.2	1.3	ppm
009-02A Custodial Office Round Slop Sink Faucet	6/30/2016 20:23	7/6/2016	36953	Lead	ND	15	ppm
009-03A Kitchen Janitors Sink Faucet	6/30/2016 20:25	7/7/2016	36955	Copper	1.9	1.3	ppm
009-03A Kitchen Janitors Sink Faucet	6/30/2016 20:25	7/6/2016	36955	Lead	53	15	ppm
009-04A Kitchen Bathroom Sink Faucet	6/30/2016 20:25	7/6/2016	36957	Copper	0.2	1.3	ppm
009-04A Kitchen Bathroom Sink Faucet	6/30/2016 20:25	7/6/2016	36957	Lead	11	15	ppm
009-05A Kitchen Sprayer	6/30/2016 20:26	7/7/2016	36959	Copper	0.3	1.3	ppm
009-05A Kitchen Sprayer	6/30/2016 20:26	7/7/2016	36959	Lead	7	15	ppm
009-06A Kitchen White Handwash Sink Faucet	6/30/2016 20:27	7/7/2016	36961	Copper	0.2	1.3	ppm
009-06A Kitchen White Handwash Sink Faucet	6/30/2016 20:27	7/7/2016	36961	Lead	2	15	ppm
009-07A Kitchen Sanitizer Sprayer	6/30/2016 20:28	7/7/2016	36963	Copper	0.3	1.3	ppm
009-07A Kitchen Sanitizer Sprayer	6/30/2016 20:28	7/7/2016	36963	Lead	ND	15	ppm
009-08A Kitchen Sink Faucet	6/30/2016 20:29	7/7/2016	36965	Copper	0.3	1.3	ppm
009-08A Kitchen Sink Faucet	6/30/2016 20:29	7/7/2016	36965	Lead	ND	15	ppm
009-09A Kitchen Break Room Sink Faucet	6/30/2016 20:29	7/7/2016	36967	Copper	0.4	1.3	ppm
009-09A Kitchen Break Room Sink Faucet	6/30/2016 20:29	7/7/2016	36967	Lead	1	15	ppm
009-10A Cafeteria Drinking Fountain (north wall)	6/30/2016 20:32	7/7/2016	36969	Copper	0.2	1.3	ppm
009-10A Cafeteria Drinking Fountain (north wall)	6/30/2016 20:32	7/7/2016	36969	Lead	4	15	ppm
009-11A Cafeteria Drinking Fountain (south wall)	6/30/2016 20:32	7/7/2016	36971	Copper	0.2	1.3	ppm
009-11A Cafeteria Drinking Fountain (south wall)	6/30/2016 20:32	7/7/2016	36971	Lead	13	15	ppm
009-12A Gym Drinking Fountain	6/30/2016 20:35	7/7/2016	36973	Copper	ND	1.3	ppm
009-12A Gym Drinking Fountain	6/30/2016 20:35	7/7/2016	36973	Lead	2	15	ppm
009-13A Gym 127 Room Sink Faucet	6/30/2016 20:36	7/7/2016	36975	Copper	0.4	1.3	ppm
009-13A Gym 127 Room Sink Faucet	6/30/2016 20:36	7/7/2016	36975	Lead	1	15	ppm
009-14A Gym 127 Room Drinking Fountain	6/30/2016 20:36	7/7/2016	36977	Copper	0.4	1.3	ppm
009-14A Gym 127 Room Drinking Fountain	6/30/2016 20:36	7/7/2016	36977	Lead	1	15	ppm
009-15A Room 125 Sink Faucet	6/30/2016 20:38	7/7/2016	36979	Copper	0.4	1.3	ppm
009-15A Room 125 Sink Faucet	6/30/2016 20:38	7/7/2016	36979	Lead	4	15	ppm
009-16A Room 125 Drinking Fountain	6/30/2016 20:39	7/7/2016	36981	Copper	0.3	1.3	ppm
009-16A Room 125 Drinking Fountain	6/30/2016 20:39	7/7/2016	36981	Lead	ND	15	ppm
009-17A Room 125 Sink Faucet	6/30/2016 20:40	7/7/2016	36983	Copper	0.5	1.3	ppm
009-17A Room 125 Sink Faucet	6/30/2016 20:40	7/7/2016	36983	Lead	1	15	ppm
009-18A Room 125 Drinking Fountain	6/30/2016 20:41	7/7/2016	36985	Copper	0.2	1.3	ppm
009-18A Room 125 Drinking Fountain	6/30/2016 20:41	7/7/2016	36985	Lead	1	15	ppm
009-19A Room 160 Mens Restroom Sink Faucet (left)	6/30/2016 20:41	7/7/2016	36987	Copper	0.1	1.3	ppm
009-19A Room 160 Mens Restroom Sink Faucet (left)	6/30/2016 20:41	7/7/2016	36987	Lead	15.0	15	ppm
009-20A Room 160 Mens Restroom Sink Faucet (right)	6/30/2016 20:42	7/7/2016	36989	Copper	0.2	1.3	ppm
009-20A Room 160 Mens Restroom Sink Faucet (right)	6/30/2016 20:42	7/7/2016	36989	Lead	12	15	ppm
009-21A Room 160 Mens Restroom Spigot	6/30/2016 20:43	7/7/2016	36991	Copper	0.1	1.3	ppm
009-21A Room 160 Mens Restroom Spigot	6/30/2016 20:43	7/7/2016	36991	Lead	17	15	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Alkinson Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA	
						Action	Units
009-22A Custodial Room 162 Sink Faucet	6/30/2016 20:45	7/7/2016	36993	Copper	ND	1.3	ppm
009-22A Custodial Room 162 Sink Faucet	6/30/2016 20:45	7/7/2016	36993	Lead	1	15	ppm
009-23A Room 159 Womens Restroom Sink Faucet (left)	6/30/2016 20:47	7/7/2016	36995	Copper	0.1	1.3	ppm
009-23A Room 159 Womens Restroom Sink Faucet (left)	6/30/2016 20:47	7/7/2016	36995	Lead	9	15	ppm
009-24A Room 159 Womens Restroom Sink Faucet (right)	6/30/2016 20:48	7/7/2016	36997	Copper	0.1	1.3	ppm
009-24A Room 159 Womens Restroom Sink Faucet (right)	6/30/2016 20:48	7/7/2016	36997	Lead	4	15	ppm
009-25A Room 159 Womens Restroom Spigot	6/30/2016 20:49	7/7/2016	36999	Copper	ND	1.3	ppm
009-25A Room 159 Womens Restroom Spigot	6/30/2016 20:49	7/7/2016	36999	Lead	14	15	ppm
009-26A Room 122 Sink Faucet	6/30/2016 20:52	7/7/2016	37001	Copper	0.2	1.3	ppm
009-26A Room 122 Sink Faucet	6/30/2016 20:52	7/7/2016	37001	Lead	7	15	ppm
009-27A Room 121A Boys Restroom Sink Faucet (left)	6/30/2016 20:57	7/7/2016	37003	Copper	0.1	1.3	ppm
009-27A Room 121A Boys Restroom Sink Faucet (left)	6/30/2016 20:57	7/7/2016	37003	Lead	3	15	ppm
009-28A Room 121A Boys Restroom Sink Faucet (right)	6/30/2016 20:58	7/7/2016	37005	Copper	0.1	1.3	ppm
009-28A Room 121A Boys Restroom Sink Faucet (right)	6/30/2016 20:58	7/7/2016	37005	Lead	3	15	ppm
009-29A Room 121A Boys Restroom Spigot	6/30/2016 20:59	7/7/2016	37007	Copper	0.1	1.3	ppm
009-29A Room 121A Boys Restroom Spigot	6/30/2016 20:59	7/7/2016	37007	Lead	5	15	ppm
009-30A Room 121B Girls Restroom Sink Faucet (left)	6/30/2016 21:00	7/7/2016	37009	Copper	0.1	1.3	ppm
009-30A Room 121B Girls Restroom Sink Faucet (left)	6/30/2016 21:00	7/7/2016	37009	Lead	3	15	ppm
009-31A Room 121B Girls Restroom Sink Faucet (right)	6/30/2016 21:01	7/7/2016	37011	Copper	ND	1.3	ppm
009-31A Room 121B Girls Restroom Sink Faucet (right)	6/30/2016 21:01	7/7/2016	37011	Lead	3	15	ppm
009-32A Room 121B Girls Restroom Spigot	6/30/2016 21:02	7/7/2016	37013	Copper	ND	1.3	ppm
009-32A Room 121B Girls Restroom Spigot	6/30/2016 21:02	7/7/2016	37013	Lead	7	15	ppm
009-33A Room 121C Fan Storage Sink Faucet	6/30/2016 21:03	7/7/2016	37015	Copper	0.3	1.3	ppm
009-33A Room 121C Fan Storage Sink Faucet	6/30/2016 21:03	7/7/2016	37015	Lead	2	15	ppm
009-34A Room 121 Sink Faucet (left)	6/30/2016 21:04	7/7/2016	37017	Copper	0.1	1.3	ppm
009-34A Room 121 Sink Faucet (left)	6/30/2016 21:04	7/7/2016	37017	Lead	2	15	ppm
009-35A Room 121 Sink Faucet (right)	6/30/2016 21:05	7/7/2016	37019	Copper	0.1	1.3	ppm
009-35A Room 121 Sink Faucet (right)	6/30/2016 21:05	7/7/2016	37019	Lead	3	15	ppm
009-36A Room 121 Drinking Fountain	6/30/2016 21:06	7/7/2016	37021	Copper	0.3	1.3	ppm
009-36A Room 121 Drinking Fountain	6/30/2016 21:06	7/7/2016	37021	Lead	1	15	ppm
009-37A 123B Teachers Unisex Bathroom Sink Faucet	6/30/2016 21:08	7/7/2016	37023	Copper	0.1	1.3	ppm
009-37A 123B Teachers Unisex Bathroom Sink Faucet	6/30/2016 21:08	7/7/2016	37023	Lead	4	15	ppm
009-38A 123A Teachers Unisex Bathroom Sink Faucet	6/30/2016 21:06	7/7/2016	37025	Copper	0.1	1.3	ppm
009-38A 123A Teachers Unisex Bathroom Sink Faucet	6/30/2016 21:06	7/7/2016	37025	Lead	3	15	ppm
009-39A Room 119 Sink Faucet	6/30/2016 21:10	7/7/2016	37027	Copper	0.2	1.3	ppm
009-39A Room 119 Sink Faucet	6/30/2016 21:10	7/7/2016	37027	Lead	7	15	ppm
009-40A Room 119 Drinking Fountain	6/30/2016 21:11	7/7/2016	37029	Copper	ND	1.3	ppm
009-40A Room 119 Drinking Fountain	6/30/2016 21:11	7/7/2016	37029	Lead	3	15	ppm
009-41A Room 120 Sink Faucet	6/30/2016 21:12	7/7/2016	37031	Copper	0.1	1.3	ppm
009-41A Room 120 Sink Faucet	6/30/2016 21:12	7/7/2016	37031	Lead	2	15	ppm
009-42A Room 120 Drinking Fountain	6/30/2016 21:13	7/7/2016	37033	Copper	0.1	1.3	ppm
009-42A Room 120 Drinking Fountain	6/30/2016 21:13	7/7/2016	37033	Lead	ND	15	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Alkinson Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA	
						Action	Units
						Level	
009-43A Room 118 Sink Faucet	6/30/2016 21:14	7/7/2016	37035	Copper	0.1	1.3	ppm
009-43A Room 118 Sink Faucet	6/30/2016 21:14	7/7/2016	37035	Lead	2	15	ppm
009-44A Room 119 Drinking Fountain	6/30/2016 21:15	7/7/2016	37037	Copper	0.2	1.3	ppm
009-44A Room 119 Drinking Fountain	6/30/2016 21:15	7/7/2016	37037	Lead	1	15	ppm
009-45A Room 115 Sink Faucet	6/30/2016 21:16	7/7/2016	37039	Copper	0.2	1.3	ppm
009-45A Room 115 Sink Faucet	6/30/2016 21:16	7/7/2016	37039	Lead	2	15	ppm
009-46A Room 115 Drinking Fountain	6/30/2016 21:17	7/7/2016	37041	Copper	0.1	1.3	ppm
009-46A Room 115 Drinking Fountain	6/30/2016 21:17	7/7/2016	37041	Lead	1	15	ppm
009-47A Room 116 Sink Faucet	6/30/2016 20:17	7/7/2016	37043	Copper	0.2	1.3	ppm
009-47A Room 116 Sink Faucet	6/30/2016 20:17	7/7/2016	37043	Lead	2	15	ppm
009-48A Room 116 Drinking Fountain	6/30/2016 20:18	7/7/2016	37045	Copper	0.2	1.3	ppm
009-48A Room 116 Drinking Fountain	6/30/2016 20:18	7/7/2016	37045	Lead	2	15	ppm
009-49A Room 113A Boys Bthroom Sink Faucet	6/30/2016 21:19	7/7/2016	37047	Copper	0.2	1.3	ppm
009-49A Room 113A Boys Bthroom Sink Faucet	6/30/2016 21:19	7/7/2016	37047	Lead	ND	15	ppm
009-50A Room 113A Boys Bthroom Spigot	6/30/2016 21:20	7/7/2016	37049	Copper	0.3	1.3	ppm
009-50A Room 113A Boys Bthroom Spigot	6/30/2016 21:20	7/7/2016	37049	Lead	8	15	ppm
009-51A 113B Custodial Sink Faucet	6/30/2016 21:22	7/7/2016	37051	Copper	0.2	1.3	ppm
009-51A 113B Custodial Sink Faucet	6/30/2016 21:22	7/7/2016	37051	Lead	ND	15	ppm
009-52A Room 114 Sink Faucet	6/30/2016 21:23	7/7/2016	37053	Copper	0.2	1.3	ppm
009-52A Room 114 Sink Faucet	6/30/2016 21:23	7/7/2016	37053	Lead	1	15	ppm
009-53A Room 114 Drinking Fountain	6/30/2016 21:24	7/7/2016	37055	Copper	0.1	1.3	ppm
009-53A Room 114 Drinking Fountain	6/30/2016 21:24	7/7/2016	37055	Lead	2	15	ppm
009-54A Room 113 Sink Faucet	6/30/2016 21:25	7/7/2016	37057	Copper	0.2	1.3	ppm
009-54A Room 113 Sink Faucet	6/30/2016 21:25	7/7/2016	37057	Lead	2	15	ppm
009-55A Room 113 Drinking Fountain	6/30/2016 21:26	7/7/2016	37059	Copper	0.2	1.3	ppm
009-55A Room 113 Drinking Fountain	6/30/2016 21:26	7/7/2016	37059	Lead	2	15	ppm
009-56A Room 112 Sink Faucet	6/30/2016 21:44	7/7/2016	37061	Copper	0.2	1.3	ppm
009-56A Room 112 Sink Faucet	6/30/2016 21:44	7/7/2016	37061	Lead	2	15	ppm
009-57A Room 112 Drinking Fountain	6/30/2016 21:45	7/7/2016	37063	Copper	0.2	1.3	ppm
009-57A Room 112 Drinking Fountain	6/30/2016 21:45	7/7/2016	37063	Lead	1	15	ppm
009-58A Room 111 Sink Faucet	6/30/2016 21:46	7/7/2016	37065	Copper	0.3	1.3	ppm
009-58A Room 111 Sink Faucet	6/30/2016 21:46	7/7/2016	37065	Lead	3	15	ppm
009-59A Room 111 Drinking Fountain	6/30/2016 21:47	7/7/2016	37067	Copper	0.2	1.3	ppm
009-59A Room 111 Drinking Fountain	6/30/2016 21:47	7/7/2016	37067	Lead	ND	15	ppm
009-60A Room 114A Girls Restroom Sink Faucet (left)	6/30/2016 21:48	7/7/2016	37069	Copper	0.1	1.3	ppm
009-60A Room 114A Girls Restroom Sink Faucet (left)	6/30/2016 21:48	7/7/2016	37069	Lead	2	15	ppm
009-61A Room 114A Girls Restroom Sink Faucet (right)	6/30/2016 21:49	7/7/2016	37071	Copper	0.1	1.3	ppm
009-61A Room 114A Girls Restroom Sink Faucet (right)	6/30/2016 21:49	7/7/2016	37071	Lead	3	15	ppm
009-62A Room 114A Girls Restroom Spigot	6/30/2016 21:50	7/7/2016	37073	Copper	0.3	1.3	ppm
009-62A Room 114A Girls Restroom Spigot	6/30/2016 21:50	7/7/2016	37073	Lead	0.2	15	ppm
009-63A Room 175 Adult Unisex Sink Faucet	6/30/2016 21:54	7/7/2016	37075	Copper	0.1	1.3	ppm
009-63A Room 175 Adult Unisex Sink Faucet	6/30/2016 21:54	7/7/2016	37075	Lead	3	15	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Alkinson Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA	
						Action Level	Units
009-64A Room 176 Adult Unisex Sink Faucet	6/30/2016 21:55	7/7/2016	37077	Copper	ND	1.3	ppm
009-64A Room 176 Adult Unisex Sink Faucet	6/30/2016 21:55	7/7/2016	37077	Lead	2	15	ppm
009-65A Room 168 Staff Bathroom Sink Faucet	6/30/2016 21:55	7/7/2016	37079	Copper	ND	1.3	ppm
009-65A Room 168 Staff Bathroom Sink Faucet	6/30/2016 21:55	7/7/2016	37079	Lead	2	15	ppm
009-66A Room 165 Sink Faucet	6/30/2016 21:58	7/7/2016	37081	Copper	0.2	1.3	ppm
009-66A Room 165 Sink Faucet	6/30/2016 21:58	7/7/2016	37081	Lead	1	15	ppm
009-67A Room 164 Sink Faucet	6/30/2016 22:00	7/7/2016	37083	Copper	0.1	1.3	ppm
009-67A Room 164 Sink Faucet	6/30/2016 22:00	7/7/2016	37083	Lead	4	15	ppm
009-68A Room 164 Drinking Fountain	6/30/2016 22:01	7/7/2016	37085	Copper	ND	1.3	ppm
009-68A Room 164 Drinking Fountain	6/30/2016 22:01	7/7/2016	37085	Lead	2	15	ppm
009-69A Room 109 Sink Faucet	6/30/2016 22:02	7/7/2016	37087	Copper	0.2	1.3	ppm
009-69A Room 109 Sink Faucet	6/30/2016 22:02	7/7/2016	37087	Lead	2	15	ppm
009-70A Room 109 Drinking Fountain	6/30/2016 22:03	7/7/2016	37089	Copper	0.1	1.3	ppm
009-70A Room 109 Drinking Fountain	6/30/2016 22:03	7/7/2016	37089	Lead	3	15	ppm
009-71A Room 110 Sink Faucet	6/30/2016 22:05	7/7/2016	37091	Copper	ND	1.3	ppm
009-71A Room 110 Sink Faucet	6/30/2016 22:05	7/7/2016	37091	Lead	ND	15	ppm
009-72A Room 110 Drinking Fountain	6/30/2016 22:06	7/7/2016	37093	Copper	0.2	1.3	ppm
009-72A Room 110 Drinking Fountain	6/30/2016 22:06	7/7/2016	37093	Lead	1	15	ppm
009-73A Room 110A Boys Restroom Sink Faucet (left)	6/30/2016 22:07	7/7/2016	37095	Copper	0.1	1.3	ppm
009-73A Room 110A Boys Restroom Sink Faucet (left)	6/30/2016 22:07	7/7/2016	37095	Lead	3	15	ppm
009-74A Room 110A Boys Restroom Sink Faucet (right)	6/30/2016 22:08	7/7/2016	37097	Copper	0.2	1.3	ppm
009-74A Room 110A Boys Restroom Sink Faucet (right)	6/30/2016 22:08	7/7/2016	37097	Lead	ND	15	ppm
009-75A Room 110A Boys Restroom Spigot	6/30/2016 22:09	7/7/2016	37099	Copper	ND	1.3	ppm
009-75A Room 110A Boys Restroom Spigot	6/30/2016 22:09	7/7/2016	37099	Lead	13	15	ppm
009-76A Room 109A Girls Restroom Sink Faucet (left)	6/30/2016 22:09	7/7/2016	37101	Copper	0.2	1.3	ppm
009-76A Room 109A Girls Restroom Sink Faucet (left)	6/30/2016 22:09	7/7/2016	37101	Lead	1	15	ppm
009-77A Room 109A Girls Restroom Sink Faucet (right)	6/30/2016 22:10	7/7/2016	37103	Copper	0.1	1.3	ppm
009-77A Room 109A Girls Restroom Sink Faucet (right)	6/30/2016 22:10	7/7/2016	37103	Lead	2	15	ppm
009-78A Room 109A Girls Restroom Spigot	6/30/2016 22:11	7/7/2016	37105	Copper	ND	1.3	ppm
009-78A Room 109A Girls Restroom Spigot	6/30/2016 22:11	7/7/2016	37105	Lead	10	15	ppm
009-79A 108A Mechanical Sink Faucet	6/30/2016 21:12	7/7/2016	37107	Copper	0.4	1.3	ppm
009-79A 108A Mechanical Sink Faucet	6/30/2016 21:12	7/7/2016	37107	Lead	2	15	ppm
009-80A 108 Sink Faucet	6/30/2016 21:12	7/7/2016	37109	Copper	0.2	1.3	ppm
009-80A 108 Sink Faucet	6/30/2016 21:12	7/7/2016	37109	Lead	2	15	ppm
009-81A 108 Drinking Fountain	6/30/2016 21:13	7/7/2016	37111	Copper	0.2	1.3	ppm
009-81A 108 Drinking Fountain	6/30/2016 21:13	7/7/2016	37111	Lead	1	15	ppm
009-82A Room 107 Sink Faucet	6/30/2016 22:14	7/7/2016	37113	Copper	0.2	1.3	ppm
009-82A Room 107 Sink Faucet	6/30/2016 22:14	7/7/2016	37113	Lead	4	15	ppm
009-83A Room 107 Drinking Fountain	6/30/2016 21:15	7/7/2016	37115	Copper	0.2	1.3	ppm
009-83A Room 107 Drinking Fountain	6/30/2016 21:15	7/7/2016	37115	Lead	ND	15	ppm
009-84A Room 106 Sink Faucet	6/30/2016 21:17	7/7/2016	37117	Copper	0.2	1.3	ppm
009-84A Room 106 Sink Faucet	6/30/2016 21:17	7/7/2016	37117	Lead	3	15	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Alkinson Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA	
						Action Level	Units
009-85A Room 106 Drinking Fountain	6/30/2016 21:18	7/7/2016	37119	Copper	0.1	1.3	ppm
009-85A Room 106 Drinking Fountain	6/30/2016 21:18	7/7/2016	37119	Lead	1	15	ppm
009-86A Room 105 Sink Faucet	6/30/2016 22:18	7/7/2016	37121	Copper	0.2	1.3	ppm
009-86A Room 105 Sink Faucet	6/30/2016 22:18	7/7/2016	37121	Lead	3	15	ppm
009-87A Room 105 Drinking Fountain	6/30/2016 22:19	7/7/2016	37123	Copper	0.2	1.3	ppm
009-87A Room 105 Drinking Fountain	6/30/2016 22:19	7/7/2016	37123	Lead	1	15	ppm
009-88A Room 104 Sink Faucet	6/30/2016 22:21	7/7/2016	37125	Copper	0.2	1.3	ppm
009-88A Room 104 Sink Faucet	6/30/2016 22:21	7/7/2016	37125	Lead	3	15	ppm
009-89A Room 104 Drinking Fountain	6/30/2016 22:22	7/7/2016	37127	Copper	0.2	1.3	ppm
009-89A Room 104 Drinking Fountain	6/30/2016 22:22	7/7/2016	37127	Lead	3	15	ppm
009-90A Room 105A Boys Restroom Sink Faucet (left)	6/30/2016 22:23	7/7/2016	37129	Copper	0.1	1.3	ppm
009-90A Room 105A Boys Restroom Sink Faucet (left)	6/30/2016 22:23	7/7/2016	37129	Lead	3	15	ppm
009-91A Room 105A Boys Restroom Sink Faucet (right)	6/30/2016 22:24	7/7/2016	37131	Copper	ND	1.3	ppm
009-91A Room 105A Boys Restroom Sink Faucet (right)	6/30/2016 22:24	7/7/2016	37131	Lead	3	15	ppm
009-92A Room 105A Boys Restroom Spigot	6/30/2016 22:25	7/7/2016	37133	Copper	0.2	1.3	ppm
009-92A Room 105A Boys Restroom Spigot	6/30/2016 22:25	7/7/2016	37133	Lead	ND	15	ppm
009-93A Room 104A Girls Restroom Sink Faucet (left)	6/30/2016 22:25	7/7/2016	37135	Copper	ND	1.3	ppm
009-93A Room 104A Girls Restroom Sink Faucet (left)	6/30/2016 22:25	7/7/2016	37135	Lead	3	15	ppm
009-94A Room 104A Girls Restroom Sink Faucet (right)	6/30/2016 22:26	7/7/2016	37137	Copper	ND	1.3	ppm
009-94A Room 104A Girls Restroom Sink Faucet (right)	6/30/2016 22:26	7/7/2016	37137	Lead	3	15	ppm
009-95A Room 104A Girls Restroom Spigot	6/30/2016 22:27	7/7/2016	37139	Copper	0.2	1.3	ppm
009-95A Room 104A Girls Restroom Spigot	6/30/2016 22:27	7/7/2016	37139	Lead	40	15	ppm
009-96A 103A Storeroom Sink Faucet	6/30/2016 22:28	7/7/2016	37141	Copper	0.3	1.3	ppm
009-96A 103A Storeroom Sink Faucet	6/30/2016 22:28	7/7/2016	37141	Lead	26	15	ppm
009-97A Room 103 Sink Faucet	6/30/2016 22:29	7/7/2016	37143	Copper	0.2	1.3	ppm
009-97A Room 103 Sink Faucet	6/30/2016 22:29	7/7/2016	37143	Lead	1	15	ppm
009-98A Room 103 Drinking Fountain	6/30/2016 22:30	7/7/2016	37145	Copper	0.2	1.3	ppm
009-98A Room 103 Drinking Fountain	6/30/2016 22:30	7/7/2016	37145	Lead	2	15	ppm
009-99A Room 100 Sink Faucet	6/30/2016 22:30	7/7/2016	37147	Copper	0.3	1.3	ppm
009-99A Room 100 Sink Faucet	6/30/2016 22:30	7/7/2016	37147	Lead	5	15	ppm
009-100A Room 100 Drinking Fountain	6/30/2016 22:31	7/7/2016	37149	Copper	0.2	1.3	ppm
009-100A Room 100 Drinking Fountain	6/30/2016 22:31	7/7/2016	37149	Lead	3	15	ppm
009-101A Room 101 Sink Faucet	6/30/2016 22:23	7/7/2016	37151	Copper	0.3	1.3	ppm
009-101A Room 101 Sink Faucet	6/30/2016 22:23	7/7/2016	37151	Lead	2	15	ppm
009-102A Room 102 Sink Faucet	6/30/2016 22:35	7/7/2016	37153	Copper	0.2	1.3	ppm
009-102A Room 102 Sink Faucet	6/30/2016 22:35	7/7/2016	37153	Lead	1	15	ppm
009-103A Room 102 Drinking Fountain	6/30/2016 22:36	7/7/2016	37155	Copper	0.4	1.3	ppm
009-103A Room 102 Drinking Fountain	6/30/2016 22:36	7/7/2016	37155	Lead	ND	15	ppm
009-104A Outside Spigot (east)	6/30/2016 22:42	7/7/2016	37157	Copper	0.6	1.3	ppm
009-104A Outside Spigot (east)	6/30/2016 22:42	7/7/2016	37157	Lead	7	15	ppm
009-105A Outside Spigot (south)	6/30/2016 22:45	7/7/2016	37159	Copper	0.3	1.3	ppm
009-105A Outside Spigot (south)	6/30/2016 22:45	7/7/2016	37159	Lead	1	15	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Alkinson Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
009-106A Outside Spigot (south)	6/30/2016 22:48	7/7/2016	37161	Copper	0.5	1.3	ppm
009-106A Outside Spigot (south)	6/30/2016 22:48	7/7/2016	37161	Lead	25	15	ppm
009-107A Outside Spigot (north)	6/30/2016 22:49	7/7/2016	37163	Copper	0.3	1.3	ppm
009-107A Outside Spigot (north)	6/30/2016 22:49	7/7/2016	37163	Lead	3	15	ppm
009-108A Outside Spigot (north on road)	6/30/2016 22:51	7/7/2016	37165	Copper	0.5	1.3	ppm
009-108A Outside Spigot (north on road)	6/30/2016 22:51	7/7/2016	37165	Lead	6	15	ppm
009-109A Outside Spigot (north on road under sign)	6/30/2016 22:53	7/7/2016	37167	Copper	ND	1.3	ppm
009-109A Outside Spigot (north on road under sign)	6/30/2016 22:53	7/7/2016	37167	Lead	ND	15	ppm
009-110A Outside Spigot (courtyard)	6/30/2016 22:55	7/7/2016	37169	Copper	0.2	1.3	ppm
009-110A Outside Spigot (courtyard)	6/30/2016 22:55	7/7/2016	37169	Lead	40	15	ppm

EPA Action Level for Lead of 15 ppb

ND = Non detect

EPA Action Level for Copper of 1.3 ppm

Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.