

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Beaumont Middle School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
011-01A	Boiler Room Sink Faucet	6/25/16 6:29 AM	7/5/16 1:22 PM	BB67122	Copper	0.1	1.3	ppm
011-01A	Boiler Room Sink Faucet	6/25/16 6:29 AM	7/5/16 1:22 PM	BB67122	Lead	4	15.0	ppb
011-02A	14A Sink Faucet	6/25/16 7:34 AM	7/10/16 6:49 PM	BB67123	Copper	0.8	1.3	ppm
011-02A	14A Sink Faucet	6/25/16 7:34 AM	7/10/16 6:49 PM	BB67123	Lead	23	15.0	ppb
011-03A	Hall Drinking Fountain	6/25/16 7:36 AM	7/5/16 1:33 PM	BB67124	Copper	1.6	1.3	ppm
011-03A	Hall Drinking Fountain	6/25/16 7:36 AM	7/5/16 1:25 PM	BB67124	Lead	9	15.0	ppb
011-04A	Classroom 138 Sink Faucet	6/25/16 6:40 AM	7/5/16 1:44 PM	BB67125	Copper	0.2	1.3	ppm
011-04A	Classroom 138 Sink Faucet	6/25/16 6:40 AM	7/5/16 1:44 PM	BB67125	Lead	26	15.0	ppb
011-05A	Classroom 136 Sink Faucet #1	6/25/16 6:43 AM	7/5/16 1:46 PM	BB67126	Copper	0.7	1.3	ppm
011-05A	Classroom 136 Sink Faucet #1	6/25/16 6:43 AM	7/5/16 1:46 PM	BB67126	Lead	42	15.0	ppb
011-06A	Classroom 136 Sink Faucet #2	6/25/16 6:45 AM	7/10/16 6:53 PM	BB67127	Copper	1.2	1.3	ppm
011-06A	Classroom 136 Sink Faucet #2	6/25/16 6:45 AM	7/10/16 6:53 PM	BB67127	Lead	34	15.0	ppb
011-07A	Classroom 136 Sink Faucet #3	6/25/16 6:47 AM	7/10/16 6:56 PM	BB67128	Copper	1.2	1.3	ppm
011-07A	Classroom 136 Sink Faucet #3	6/25/16 6:47 AM	7/10/16 6:56 PM	BB67128	Lead	106	15.0	ppb
011-08A	Classroom 136 Eyewash	6/25/16 6:49 AM	7/10/16 6:59 PM	BB67129	Copper	0.9	1.3	ppm
011-08A	Classroom 136 Eyewash	6/25/16 6:49 AM	7/10/16 6:59 PM	BB67129	Lead	14.5	15.0	ppb
011-09A	Classroom 134 Sink Faucet #1	6/25/16 6:51 AM	7/10/16 6:39 PM	BB67130	Copper	1.2	1.3	ppm
011-09A	Classroom 134 Sink Faucet #1	6/25/16 6:51 AM	7/10/16 6:39 PM	BB67130	Lead	107	15.0	ppb
011-10A	Classroom 134 Sink Faucet #2	6/25/16 6:53 AM	7/10/16 7:03 PM	BB67131	Copper	0.7	1.3	ppm
011-10A	Classroom 134 Sink Faucet #2	6/25/16 6:53 AM	7/10/16 7:03 PM	BB67131	Lead	42	15.0	ppb
011-11A	Classroom 134 Sink Faucet #3	6/25/16 6:55 AM	7/10/16 7:06 PM	BB67132	Copper	0.6	1.3	ppm
011-11A	Classroom 134 Sink Faucet #3	6/25/16 6:55 AM	7/10/16 7:06 PM	BB67132	Lead	45	15.0	ppb
011-12A	Classroom 134 Sink Faucet #4	6/25/16 6:57 AM	7/5/16 1:49 PM	BB67133	Copper	0.6	1.3	ppm
011-12A	Classroom 134 Sink Faucet #4	6/25/16 6:57 AM	7/5/16 1:49 PM	BB67133	Lead	26	15.0	ppb
011-13A	Classroom 134 Eyewash	6/25/16 7:00 AM	7/10/16 7:10 PM	BB67134	Copper	1.0	1.3	ppm
011-13A	Classroom 134 Eyewash	6/25/16 7:00 AM	7/10/16 7:10 PM	BB67134	Lead	129	15.0	ppb
011-14A	Girls Bathroom Water Spigot	6/25/16 7:02 AM	7/10/16 7:37 PM	BB67135	Copper	0.5	1.3	ppm
011-14A	Girls Bathroom Water Spigot	6/25/16 7:02 AM	7/10/16 7:37 PM	BB67135	Lead	195	15.0	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Beaumont Middle School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
011-15A	Girls Bathroom Sink Faucet	6/25/16 7:04 AM	7/1/16	BB67136	Copper	0.3	1.3	ppm
011-15A	Girls Bathroom Sink Faucet	6/25/16 7:04 AM	7/1/16	BB67136	Lead	7	15.0	ppb
011-16A	Gymnasium Drinking Fountain #1	6/25/16 6:32 AM	7/1/16	BB67137	Copper	0.4	1.3	ppm
011-16A	Gymnasium Drinking Fountain #1	6/25/16 6:32 AM	7/1/16	BB67137	Lead	12	15.0	ppb
011-17A	Gymnasium Drinking Fountain #2	6/25/16 7:00 AM	7/1/16	BB67138	Copper	0.1	1.3	ppm
011-17A	Gymnasium Drinking Fountain #2	6/25/16 7:00 AM	7/1/16	BB67138	Lead	8	15.0	ppb
011-18A	Hall Drinking Fountain #1	6/25/16 7:06 AM	7/1/16	BB67139	Copper	0.0	1.3	ppm
011-18A	Hall Drinking Fountain #1	6/25/16 7:06 AM	7/1/16	BB67139	Lead	8	15.0	ppb
011-19A	Hall Drinking Fountain #2	6/25/16 7:08 AM	7/1/16	BB67140	Copper	0.0	1.3	ppm
011-19A	Hall Drinking Fountain #2	6/25/16 7:08 AM	7/1/16	BB67140	Lead	3	15.0	ppb
011-20A	Boys Locker Room Sink Faucet	6/25/16 7:10 AM	7/1/16	BB67141	Copper	0.2	1.3	ppm
011-20A	Boys Locker Room Sink Faucet	6/25/16 7:10 AM	7/1/16	BB67141	Lead	8	15.0	ppb
011-21A	Boys Locker Room Water Spigot	6/25/16 7:12 AM	7/10/16 10:25 PM	BB67142	Copper	1.0	1.3	ppm
011-21A	Boys Locker Room Water Spigot	6/25/16 7:12 AM	7/10/16 10:25 PM	BB67142	Lead	169	15.0	ppb
011-22A	Room 106 Sink Faucet	6/25/16 7:14 AM	7/1/16	BB67143	Copper	0.5	1.3	ppm
011-22A	Room 106 Sink Faucet	6/25/16 7:14 AM	7/1/16	BB67143	Lead	125	15.0	ppb
011-23A	105A Custodian Sink Faucet	6/25/16 7:13 AM	7/1/16	BB67144	Copper	0.1	1.3	ppm
011-23A	105A Custodian Sink Faucet	6/25/16 7:13 AM	7/1/16	BB67144	Lead	10	15.0	ppb
011-24A	Teacher Bathroom Sink Faucet	6/25/16 7:16 AM	7/1/16	BB67145	Copper	0.4	1.3	ppm
011-24A	Teacher Bathroom Sink Faucet	6/25/16 7:16 AM	7/1/16	BB67145	Lead	7	15.0	ppb
011-25A	Boys Bathroom Sink Faucet	6/25/16 7:19 AM	7/1/16	BB67146	Copper	0.0	1.3	ppm
011-25A	Boys Bathroom Sink Faucet	6/25/16 7:19 AM	7/1/16	BB67146	Lead	1	15.0	ppb
011-26A	Boys Bathroom Water Spigot	6/25/16 7:21 AM	7/1/16	BB67147	Copper	0.6	1.3	ppm
011-26A	Boys Bathroom Water Spigot	6/25/16 7:21 AM	7/1/16	BB67147	Lead	42	15.0	ppb
011-27A	Hall Drinking Fountain #3	6/25/16 7:24 AM	7/1/16	BB67148	Copper	0.1	1.3	ppm
011-27A	Hall Drinking Fountain #3	6/25/16 7:24 AM	7/1/16	BB67148	Lead	8	15.0	ppb
011-28A	Hall Drinking Fountain #4	6/25/16 7:26 AM	7/1/16	BB67149	Copper	0.0	1.3	ppm
011-28A	Hall Drinking Fountain #4	6/25/16 7:26 AM	7/1/16	BB67149	Lead	4	15.0	ppb
011-29A	Room 101 Sink Faucet	6/25/16 7:29 AM	7/1/16	BB67150	Copper	0.2	1.3	ppm
011-29A	Room 101 Sink Faucet	6/25/16 7:29 AM	7/1/16	BB67150	Lead	21	15.0	ppb
011-30A	Classroom 227 Sink Faucet	6/25/16 7:39 AM	7/1/16	BB67151	Copper	0.5	1.3	ppm
011-30A	Classroom 227 Sink Faucet	6/25/16 7:39 AM	7/1/16	BB67151	Lead	25	15.0	ppb
011-31A	Classroom 222 Sink Faucet	6/25/16 7:42 AM	7/1/16	BB67152	Copper	0.2	1.3	ppm
011-31A	Classroom 222 Sink Faucet	6/25/16 7:42 AM	7/1/16	BB67152	Lead	10	15.0	ppb
011-32A	Classroom 228 Sink Faucet	6/25/16 7:45 AM	7/1/16	BB67153	Copper	0.4	1.3	ppm
011-32A	Classroom 228 Sink Faucet	6/25/16 7:45 AM	7/1/16	BB67153	Lead	35	15.0	ppb
011-33A	Classroom 220 Sink Faucet	6/25/16 7:47 AM	7/1/16	BB67154	Copper	0.6	1.3	ppm
011-33A	Classroom 220 Sink Faucet	6/25/16 7:47 AM	7/1/16	BB67154	Lead	35	15.0	ppb
011-34A	Boys Bathroom Sink Faucet #1	6/25/16 7:50 AM	7/1/16	BB67155	Copper	0.2	1.3	ppm
011-34A	Boys Bathroom Sink Faucet #1	6/25/16 7:50 AM	7/1/16	BB67155	Lead	9	15.0	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Beaumont Middle School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
011-35A	Boys Bathroom Sink Faucet #2	6/25/16 7:52 AM	7/1/16	BB67156	Copper	0.3	1.3	ppm
011-35A	Boys Bathroom Sink Faucet #2	6/25/16 7:52 AM	7/1/16	BB67156	Lead	10	15.0	ppb
011-36A	Boys Bathroom Water Spigot	6/25/16 7:54 AM	7/1/16	BB67157	Copper	0.6	1.3	ppm
011-36A	Boys Bathroom Water Spigot	6/25/16 7:54 AM	7/1/16	BB67157	Lead	27	15.0	ppb
011-37A	Hall Drinking Fountain #5	6/25/16 7:56 AM	7/1/16	BB67158	Copper	0.0	1.3	ppm
011-37A	Hall Drinking Fountain #5	6/25/16 7:56 AM	7/1/16	BB67158	Lead	3	15.0	ppb
011-38A	Hall Drinking Fountain #6	6/25/16 7:58 AM	7/1/16	BB67159	Copper	0.1	1.3	ppm
011-38A	Hall Drinking Fountain #6	6/25/16 7:58 AM	7/1/16	BB67159	Lead	4	15.0	ppb
011-39A	Classroom 218 Sink Faucet	6/25/16 8:00 AM	7/10/16 7:44 PM	BB67160	Copper	0.4	1.3	ppm
011-39A	Classroom 218 Sink Faucet	6/25/16 8:00 AM	7/10/16 7:44 PM	BB67160	Lead	35	15.0	ppb
011-40A	Classroom 216 Sink Faucet	6/25/16 8:03 AM	7/1/16	BB67161	Copper	0.4	1.3	ppm
011-40A	Classroom 216 Sink Faucet	6/25/16 8:03 AM	7/1/16	BB67161	Lead	27	15.0	ppb
011-41A	Classroom 214 Sink Faucet	6/25/16 8:05 AM	7/1/16	BB67162	Copper	0.5	1.3	ppm
011-41A	Classroom 214 Sink Faucet	6/25/16 8:05 AM	7/1/16	BB67162	Lead	24	15.0	ppb
011-42A	Girls Bathroom Sink Faucet #1	6/25/16 8:07 AM	7/1/16	BB67163	Copper	0.6	1.3	ppm
011-42A	Girls Bathroom Sink Faucet #1	6/25/16 8:07 AM	7/1/16	BB67163	Lead	64	15.0	ppb
011-43A	Girls Bathroom Sink Faucet #2	6/25/16 8:09 AM	7/1/16	BB67164	Copper	0.4	1.3	ppm
011-43A	Girls Bathroom Sink Faucet #2	6/25/16 8:09 AM	7/1/16	BB67164	Lead	23	15.0	ppb
011-44A	Classroom 215 Sink Faucet	6/25/16 8:11 AM	7/10/16 7:48 PM	BB67165	Copper	0.6	1.3	ppm
011-44A	Classroom 215 Sink Faucet	6/25/16 8:11 AM	7/10/16 7:48 PM	BB67165	Lead	8	15.0	ppb
011-45A	Classroom 212 Sink Faucet	6/25/16 8:14 AM	7/1/16	BB67166	Copper	0.6	1.3	ppm
011-45A	Classroom 212 Sink Faucet	6/25/16 8:14 AM	7/1/16	BB67166	Lead	75	15.0	ppb
011-46A	Media Center Sink Faucet	6/25/16 8:14 AM	7/1/16	BB67167	Copper	0.6	1.3	ppm
011-46A	Media Center Sink Faucet	6/25/16 8:14 AM	7/1/16	BB67167	Lead	65	15.0	ppb
011-47A	Media Hall Drinking Fountain #1	6/25/16 8:17 AM	7/1/16	BB67168	Lead	0.0	15.0	ppb
011-47A	Media Hall Drinking Fountain #1	6/25/16 8:17 AM	7/1/16	BB67168	Copper	0.1	1.3	ppm
011-48A	Media Hall Drinking Fountain #2	6/25/16 8:20 AM	7/1/16	BB67169	Copper	0.2	1.3	ppm
011-48A	Media Hall Drinking Fountain #2	6/25/16 8:20 AM	7/1/16	BB67169	Lead	31	15.0	ppb
011-49A	Media Hall Drinking Fountain #3	6/25/16 8:22 AM	7/1/16	BB67170	Copper	0.1	1.3	ppm
011-49A	Media Hall Drinking Fountain #3	6/25/16 8:22 AM	7/1/16	BB67170	Lead	19	15.0	ppb
011-50A	Classroom 213 Sink Faucet	6/25/16 8:27 AM	7/1/16	BB67171	Copper	0.5	1.3	ppm
011-50A	Classroom 213 Sink Faucet	6/25/16 8:27 AM	7/1/16	BB67171	Lead	36	15.0	ppb
011-51A	Room 211 Girls Bathroom Sink Faucet #1	6/25/16 8:29 AM	7/1/16	BB67172	Copper	0.1	1.3	ppm
011-51A	Room 211 Girls Bathroom Sink Faucet #1	6/25/16 8:29 AM	7/1/16	BB67172	Lead	5	15.0	ppb
011-52A	Room 211 Girls Bathroom Sink Faucet #2	6/25/16 8:31 AM	7/1/16	BB67173	Copper	0.1	1.3	ppm
011-52A	Room 211 Girls Bathroom Sink Faucet #2	6/25/16 8:31 AM	7/1/16	BB67173	Lead	7	15.0	ppb
011-53A	Classroom 208 Sink Faucet	6/25/16 8:34 AM	7/1/16	BB67174	Copper	0.6	1.3	ppm
011-53A	Classroom 208 Sink Faucet	6/25/16 8:34 AM	7/1/16	BB67174	Lead	33	15.0	ppb
011-54A	Room 207 Sink Faucet #1	6/25/16 8:36 AM	7/1/16	BB67175	Copper	0.4	1.3	ppm
011-54A	Room 207 Sink Faucet #1	6/25/16 8:36 AM	7/1/16	BB67175	Lead	13	15.0	ppb
011-55A	Room 207 Sink Faucet #2	6/25/16 8:38 AM	7/1/16	BB67176	Copper	0.5	1.3	ppm
011-55A	Room 207 Sink Faucet #2	6/25/16 8:38 AM	7/1/16	BB67176	Lead	54	15.0	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Beaumont Middle School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
011-56A	Classroom 206 Sink Faucet	6/25/16 8:36 AM	7/1/16	BB67177	Copper	0.5	1.3	ppm
011-56A	Classroom 206 Sink Faucet	6/25/16 8:36 AM	7/1/16	BB67177	Lead	32	15.0	ppb
011-57A	Classroom 204 Sink Faucet	6/25/16 8:39 AM	7/1/16	BB67178	Copper	0.7	1.3	ppm
011-57A	Classroom 204 Sink Faucet	6/25/16 8:39 AM	7/1/16	BB67178	Lead	50	15.0	ppb
011-58A	Classroom 205 Sink Faucet	6/25/16 8:41 AM	7/1/16 12:52 PM	BB67179	Copper	0.2	1.3	ppm
011-58A	Classroom 205 Sink Faucet	6/25/16 8:41 AM	7/1/16 12:52 PM	BB67179	Lead	5	15.0	ppb
011-59A	Room 203 Boys Bathroom Sink Faucet #1	6/25/16 8:44 AM	7/1/16 12:55 PM	BB67180	Copper	0.7	1.3	ppm
011-59A	Room 203 Boys Bathroom Sink Faucet #1	6/25/16 8:44 AM	7/1/16 12:55 PM	BB67180	Lead	35	15.0	ppb
011-60A	Room 203 Boys Bathroom Sink Faucet #2	6/25/16 8:46 AM	7/1/16 12:58 PM	BB67181	Copper	0.3	1.3	ppm
011-60A	Room 203 Boys Bathroom Sink Faucet #2	6/25/16 8:46 AM	7/1/16 12:58 PM	BB67181	Lead	26	15.0	ppb
011-61A	Room 203 Boys Bathroom Water Spigot	6/25/16 8:48 AM	7/1/16 1:01 PM	BB67182	Copper	0.6	1.3	ppm
011-61A	Room 203 Boys Bathroom Water Spigot	6/25/16 8:48 AM	7/1/16 1:01 PM	BB67182	Lead	17	15.0	ppb
011-62A	Classroom 202 Sink Faucet	6/25/16 8:48 AM	7/10/16 7:51 PM	BB67183	Copper	0.9	1.3	ppm
011-62A	Classroom 202 Sink Faucet	6/25/16 8:48 AM	7/10/16 7:51 PM	BB67183	Lead	30	15.0	ppb
011-63A	Classroom 200 Sink Faucet	6/25/16 8:50 AM	7/10/16 7:55 PM	BB67184	Copper	0.6	1.3	ppm
011-63A	Classroom 200 Sink Faucet	6/25/16 8:50 AM	7/10/16 7:55 PM	BB67184	Lead	8	15.0	ppb
011-64A	Classroom 201 Sink Faucet	6/25/16 8:52 AM	7/1/16 1:04 PM	BB67185	Copper	0.6	1.3	ppm
011-64A	Classroom 201 Sink Faucet	6/25/16 8:52 AM	7/1/16 1:04 PM	BB67185	Lead	41	15.0	ppb
011-65A	Nurses Office Sink Faucet #1	6/25/16 8:57 AM	7/1/16 1:07 PM	BB67186	Copper	0.5	1.3	ppm
011-65A	Nurses Office Sink Faucet #1	6/25/16 8:57 AM	7/1/16 1:07 PM	BB67186	Lead	11	15.0	ppb
011-66A	Nurses Office Sink Faucet #2	6/25/16 9:00 AM	7/10/16 7:58 PM	BB67187	Copper	0.5	1.3	ppm
011-66A	Nurses Office Sink Faucet #2	6/25/16 9:00 AM	7/10/16 7:58 PM	BB67187	Lead	26	15.0	ppb
011-67A	Office Bathroom Sink Faucet #1	6/25/16 9:02 AM	7/1/16 1:10 PM	BB67188	Copper	0.5	1.3	ppm
011-67A	Office Bathroom Sink Faucet #1	6/25/16 9:02 AM	7/1/16 1:10 PM	BB67188	Lead	17	15.0	ppb
011-68A	Office Bathroom Sink Faucet #2	6/25/16 9:04 AM	7/1/16 1:13 PM	BB67189	Copper	0.3	1.3	ppm
011-68A	Office Bathroom Sink Faucet #2	6/25/16 9:04 AM	7/1/16 1:13 PM	BB67189	Lead	12	15.0	ppb
011-69A	Office Sink Faucet	6/25/16 9:05 AM	7/1/16 1:16 PM	BB67190	Copper	0.7	1.3	ppm
011-69A	Office Sink Faucet	6/25/16 9:05 AM	7/1/16 1:16 PM	BB67190	Lead	17	15.0	ppb
011-70A	Teachers Lounge Sink Faucet	6/25/16 9:07 AM	7/1/16 1:19 PM	BB67191	Copper	0.3	1.3	ppm
011-70A	Teachers Lounge Sink Faucet	6/25/16 9:07 AM	7/1/16 1:19 PM	BB67191	Lead	84	15.0	ppb
011-71A	Teachers Lounge Water Fill	6/25/16 9:08 AM	7/1/16 1:34 PM	BB67192	Copper	0.0	1.3	ppm
011-71A	Teachers Lounge Water Fill	6/25/16 9:08 AM	7/1/16 1:34 PM	BB67192	Lead	0.0	15.0	ppb
011-72A	Kitchen Sink Faucet #1	6/25/16 9:54 AM	7/1/16 1:37 PM	BB67193	Copper	0.4	1.3	ppm
011-72A	Kitchen Sink Faucet #1	6/25/16 9:54 AM	7/1/16 1:37 PM	BB67193	Lead	3	15.0	ppb
011-73A	Kitchen Sink Faucet #2	6/25/16 9:56 AM	7/1/16 8:21 PM	BB67194	Copper	1.4	1.3	ppm
011-73A	Kitchen Sink Faucet #2	6/25/16 9:56 AM	7/1/16 1:41 PM	BB67194	Lead	36	15.0	ppb
011-74A	Kitchen Sink Faucet #3	6/25/16 9:58 AM	7/1/16 1:43 PM	BB67195	Copper	0.4	1.3	ppm
011-74A	Kitchen Sink Faucet #3	6/25/16 9:58 AM	7/1/16 1:43 PM	BB67195	Lead	5	15.0	ppb
011-75A	Kitchen Sink Faucet #4	6/25/16 10:00 AM	7/1/16 1:47 PM	BB67196	Copper	0.5	1.3	ppm
011-75A	Kitchen Sink Faucet #4	6/25/16 10:00 AM	7/1/16 1:47 PM	BB67196	Lead	15.4	15.0	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Beaumont Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA	
						Action Level	Units
011-76A	Kitchen Sink Faucet #5	6/25/16 10:02 AM	7/1/16 8:24 PM	BB67197	Copper	0.9	1.3 ppm
011-76A	Kitchen Sink Faucet #5	6/25/16 10:02 AM	7/1/16 1:50 PM	BB67197	Lead	3	15.0 ppb
011-77A	Kitchen Bathroom Sink Faucet	6/25/16 10:04 AM	7/1/16 1:53 PM	BB67198	Copper	0.7	1.3 ppm
011-77A	Kitchen Bathroom Sink Faucet	6/25/16 10:04 AM	7/1/16 1:53 PM	BB67198	Lead	6	15.0 ppb
011-78A	Café Sink Faucet	6/25/16 10:06 AM	7/1/16 1:56 PM	BB67199	Copper	0.1	1.3 ppm
011-78A	Café Sink Faucet	6/25/16 10:06 AM	7/1/16 1:56 PM	BB67199	Lead	1	15.0 ppb
011-79A	Classroom 23 Sink Faucet #1	6/25/16 9:36 AM	7/1/16 1:59 PM	BB67200	Copper	0.3	1.3 ppm
011-79A	Classroom 23 Sink Faucet #1	6/25/16 9:36 AM	7/1/16 1:59 PM	BB67200	Lead	13	15.0 ppb
011-80A	Classroom 23 Sink Faucet #2	6/25/16 9:38 AM	7/1/16 2:02 PM	BB67201	Copper	0.3	1.3 ppm
011-80A	Classroom 23 Sink Faucet #2	6/25/16 9:38 AM	7/1/16 2:02 PM	BB67201	Lead	3	15.0 ppb
011-81A	Classroom 23 Sink Faucet #3	6/25/16 9:40 AM	7/1/16 2:23 PM	BB67202	Copper	0.1	1.3 ppm
011-81A	Classroom 23 Sink Faucet #3	6/25/16 9:40 AM	7/1/16 2:23 PM	BB67202	Lead	2	15.0 ppb
011-82A	Boys Bathroom Sink Faucet #1	6/25/16 9:42 AM	7/1/16 2:26 PM	BB67203	Copper	0.3	1.3 ppm
011-82A	Boys Bathroom Sink Faucet #1	6/25/16 9:42 AM	7/1/16 2:26 PM	BB67203	Lead	3	15.0 ppb
011-83A	Boys Bathroom Sink Faucet #2	6/25/16 9:44 AM	7/1/16 2:29 PM	BB67204	Copper	0.3	1.3 ppm
011-83A	Boys Bathroom Sink Faucet #2	6/25/16 9:44 AM	7/1/16 2:29 PM	BB67204	Lead	4	15.0 ppb
011-84A	Girls Bathroom Sink Faucet #1	6/25/16 9:45 AM	7/1/16 2:32 PM	BB67205	Copper	0.6	1.3 ppm
011-84A	Girls Bathroom Sink Faucet #1	6/25/16 9:45 AM	7/1/16 2:32 PM	BB67205	Lead	4	15.0 ppb
011-85A	Girls Bathroom Sink Faucet #2	6/25/16 9:47 AM	7/1/16 2:35 PM	BB67206	Copper	0.3	1.3 ppm
011-85A	Girls Bathroom Sink Faucet #2	6/25/16 9:47 AM	7/1/16 2:35 PM	BB67206	Lead	4	15.0 ppb
011-86A	Entry Drinking Fountain	6/25/16 9:40 AM	7/1/16 2:38 PM	BB67207	Copper	0.6	1.3 ppm
011-86A	Entry Drinking Fountain	6/25/16 9:40 AM	7/1/16 2:38 PM	BB67207	Lead	3	15.0 ppb
011-87A	Gymnasium Water Spigot	6/25/16 10:08 AM	7/1/16 2:41 PM	BB67208	Copper	0.2	1.3 ppm
011-87A	Gymnasium Water Spigot	6/25/16 10:08 AM	7/1/16 2:41 PM	BB67208	Lead	10	15.0 ppb
011-88A	Cafeteria Water Spigot	6/25/16 10:12 AM	7/1/16 2:44 PM	BB67209	Copper	0.2	1.3 ppm
011-88A	Cafeteria Water Spigot	6/25/16 10:12 AM	7/1/16 2:44 PM	BB67209	Lead	14	15.0 ppb
011-89A	Courtyard Water Spigot	6/25/16 10:14 AM	7/1/16 2:47 PM	BB67210	Copper	0.3	1.3 ppm
011-89A	Courtyard Water Spigot	6/25/16 10:14 AM	7/1/16 2:47 PM	BB67210	Lead	5	15.0 ppb
011-90A	Art Room Water Spigot	6/25/16 10:22 AM	7/1/16 2:50 PM	BB67211	Copper	0.2	1.3 ppm
011-90A	Art Room Water Spigot	6/25/16 10:22 AM	7/1/16 2:50 PM	BB67211	Lead	2	15.0 ppb
011-91A	In between Annex Water Spigot	6/25/16 10:24 AM	7/1/16 3:05 PM	BB67212	Copper	0.0	1.3 ppm
011-91A	In between Annex Water Spigot	6/25/16 10:24 AM	7/1/16 3:05 PM	BB67212	Lead	29	15.0 ppb
011-92A	Facing 42nd Avenue Water Spigot	6/25/16 10:17 AM	7/1/16 3:08 PM	BB67213	Copper	0.0	1.3 ppm
011-92A	Facing 42nd Avenue Water Spigot	6/25/16 10:17 AM	7/1/16 3:08 PM	BB67213	Lead	51	15.0 ppb
011-93A	Facing Fremont Water Spigot	6/25/16 8:20 PM	7/10/16 8:02 PM	BB67214	Copper	0.1	1.3 ppm
011-93A	Facing Fremont Water Spigot	6/25/16 8:20 PM	7/10/16 8:02 PM	BB67214	Lead	63	15.0 ppb
011-94A	Facing Fremont on Gymnasium Entry Water Sp	6/25/16 10:10 AM	7/1/16 3:11 PM	BB67215	Copper	0.3	1.3 ppm
011-94A	Facing Fremont on Gymnasium Entry Water Sp	6/25/16 10:10 AM	7/1/16 3:11 PM	BB67215	Lead	19	15.0 ppb
011-95A	Annex Water Spigot	6/25/16 10:26 AM	7/1/16 3:14 PM	BB67216	Copper	0.5	1.3 ppm
011-95A	Annex Water Spigot	6/25/16 10:26 AM	7/1/16 3:14 PM	BB67216	Lead	56	15.0 ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Beaumont Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA	Units
						Action Level	
011-96A Classroom 119 Sink Faucet #1	6/25/16 10:32 AM	7/1/16 3:17 PM	BB67217	Copper	0.5	1.3	ppm
011-96A Classroom 119 Sink Faucet #1	6/25/16 10:32 AM	7/1/16 3:17 PM	BB67217	Lead	8	15.0	ppb
011-97A Classroom 119 Sink Faucet #2	6/25/16 1:34 AM	7/1/16 3:20 PM	BB67218	Copper	0.5	1.3	ppm
011-97A Classroom 119 Sink Faucet #2	6/25/16 1:34 AM	7/1/16 3:20 PM	BB67218	Lead	11	15.0	ppb
011-98A Classroom 119 Sink Faucet #3	6/25/16 10:36 AM	7/1/16 3:23 PM	BB67219	Copper	0.4	1.3	ppm
011-98A Classroom 119 Sink Faucet #3	6/25/16 10:36 AM	7/1/16 3:23 PM	BB67219	Lead	5	15.0	ppb
011-99A Classroom 119 Sink Faucet #4	6/25/16 10:38 AM	7/1/16 3:26 PM	BB67220	Copper	0.3	1.3	ppm
011-99A Classroom 119 Sink Faucet #4	6/25/16 10:38 AM	7/1/16 3:26 PM	BB67220	Lead	11	15.0	ppb
011-100A Girls Bathroom Sink Faucet #1	6/25/16 10:44 AM	7/1/16 3:30 PM	BB67221	Copper	0.2	1.3	ppm
011-100A Girls Bathroom Sink Faucet #1	6/25/16 10:44 AM	7/1/16 3:30 PM	BB67221	Lead	7	15.0	ppb
011-101A Girls Bathroom Sink Faucet #2	6/25/16 10:46 AM	7/1/16 3:32 PM	BB67222	Copper	0.2	1.3	ppm
011-101A Girls Bathroom Sink Faucet #2	6/25/16 10:46 AM	7/1/16 3:32 PM	BB67222	Lead	10	15.0	ppb
011-102A Girls Bathroom Water Spigot	6/25/16 10:48 AM	7/1/16 3:54 PM	BB67223	Copper	0.2	1.3	ppm
011-102A Girls Bathroom Water Spigot	6/25/16 10:48 AM	7/1/16 3:54 PM	BB67223	Lead	14	15.0	ppb
011-103A Hall Drinking Fountain #1	6/25/16 10:40 AM	7/1/16 3:57 PM	BB67224	Copper	0.6	1.3	ppm
011-103A Hall Drinking Fountain #1	6/25/16 10:40 AM	7/1/16 3:57 PM	BB67224	Lead	54	15.0	ppb
011-104A Hall Drinking Fountain #2	6/25/16 10:42 AM	7/1/16 4:00 PM	BB67225	Copper	0.2	1.3	ppm
011-104A Hall Drinking Fountain #2	6/25/16 10:42 AM	7/1/16 4:00 PM	BB67225	Lead	9	15.0	ppb
011-105A Classroom 140 Sink Faucet	6/25/16 10:45 AM	7/10/16 10:29 PM	BB67226	Copper	0.5	1.3	ppm
011-105A Classroom 140 Sink Faucet	6/25/16 10:45 AM	7/10/16 10:29 PM	BB67226	Lead	30	15.0	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.