

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Benson High School

| Sample Identification # and Location  | Date & Time Collected | Date & Time Analyzed | Container ID | Analyte | Results | EPA Action Limit | Units |
|---------------------------------------|-----------------------|----------------------|--------------|---------|---------|------------------|-------|
| 012-01A A203 Sink Faucet              | 6/25/16 8:27          | 7/5/16 11:34         | 606272801    | Copper  | 0.4     | 1.3              | ppm   |
| 012-01A A203 Sink Faucet              | 6/25/16 8:27          | 7/5/16 11:34         | 606272801    | Lead    | 2       | 15               | ppb   |
| 012-02A Drinking Fountain #1          | 6/25/16 8:28          | 7/5/16 11:34         | 606272802    | Copper  | 0.6     | 1.3              | ppm   |
| 012-02A Drinking Fountain #1          | 6/25/16 8:28          | 7/5/16 11:34         | 606272802    | Lead    | 2       | 15               | ppb   |
| 012-03A Drinking Fountain #2          | 6/25/16 8:31          | 7/5/16 11:34         | 606272803    | Copper  | 0.7     | 1.3              | ppm   |
| 012-03A Drinking Fountain #2          | 6/25/16 8:31          | 7/5/16 11:34         | 606272803    | Lead    | 1       | 15               | ppb   |
| 012-04A A207 Sink Faucet              | 6/25/16 8:29          | 7/5/16 11:34         | 606272804    | Copper  | 0.3     | 1.3              | ppm   |
| 012-04A A207 Sink Faucet              | 6/25/16 8:29          | 7/5/16 11:34         | 606272804    | Lead    | 36      | 15               | ppb   |
| 012-05A A233 Sink Faucet #1 (right)   | 6/25/16 8:35          | 7/5/16 11:35         | 606272805    | Copper  | 0.3     | 1.3              | ppm   |
| 012-05A A233 Sink Faucet #1 (right)   | 6/25/16 8:35          | 7/5/16 11:35         | 606272805    | Lead    | 1       | 15               | ppb   |
| 012-06A A233 Sink Faucet #2 (left)    | 6/25/16 8:35          | 7/5/16 11:34         | 606272806    | Copper  | 0.3     | 1.3              | ppm   |
| 012-06A A233 Sink Faucet #2 (left)    | 6/25/16 8:35          | 7/5/16 11:34         | 606272806    | Lead    | 2       | 15               | ppb   |
| 012-07A A233 Sink Faucet #3 (left)    | 6/25/16 8:43          | 7/5/16 11:34         | 606272807    | Copper  | 0.4     | 1.3              | ppm   |
| 012-07A A233 Sink Faucet #3 (left)    | 6/25/16 8:43          | 7/5/16 11:34         | 606272807    | Lead    | 1       | 15               | ppb   |
| 012-08A A233 Sink Faucet #4 (right)   | 6/25/16 8:43          | 7/5/16 11:34         | 606272808    | Copper  | 0.5     | 1.3              | ppm   |
| 012-08A A233 Sink Faucet #4 (right)   | 6/25/16 8:43          | 7/5/16 11:34         | 606272808    | Lead    | 2       | 15               | ppb   |
| 012-09A 240 Sink Faucet               | 6/25/16 8:35          | 7/5/16 11:34         | 606272809    | Copper  | 0.4     | 1.3              | ppm   |
| 012-09A 240 Sink Faucet               | 6/25/16 8:35          | 7/5/16 11:34         | 606272809    | Lead    | 6       | 15               | ppb   |
| 012-10A 238 Sink Faucet (front)       | 6/25/16 8:37          | 7/5/16 11:35         | 606272810    | Copper  | 0.5     | 1.3              | ppm   |
| 012-10A 238 Sink Faucet (front)       | 6/25/16 8:37          | 7/5/16 11:35         | 606272810    | Lead    | 9       | 15               | ppb   |
| 012-11A 238 Sink Faucet (middle)      | 6/25/16 8:40          | 7/5/16 11:39         | 606272811    | Copper  | 0.5     | 1.3              | ppm   |
| 012-11A 238 Sink Faucet (middle)      | 6/25/16 8:40          | 7/5/16 11:39         | 606272811    | Lead    | 14      | 15               | ppb   |
| 012-10A 238 Sink Faucet (back)        | 6/25/16 8:41          | 7/5/16 11:39         | 606272812    | Copper  | 0.4     | 1.3              | ppm   |
| 012-10A 238 Sink Faucet (back)        | 6/25/16 8:41          | 7/5/16 11:39         | 606272812    | Lead    | 14      | 15               | ppb   |
| 012-13A 237 Sink Faucet #1            | 6/25/16 8:40          | 7/5/16 11:39         | 606272813    | Copper  | 0.5     | 1.3              | ppm   |
| 012-13A 237 Sink Faucet #1            | 6/25/16 8:40          | 7/5/16 11:39         | 606272813    | Lead    | 8       | 15               | ppb   |
| 012-14A 237 Sink Faucet #2            | 6/25/16 8:44          | 7/5/16 11:39         | 606272814    | Copper  | 0.4     | 1.3              | ppm   |
| 012-14A 237 Sink Faucet #2            | 6/25/16 8:44          | 7/5/16 11:39         | 606272814    | Lead    | 7       | 15               | ppb   |
| 012-15A 237 Sink Faucet #3            | 6/25/16 8:51          | 7/5/16 11:39         | 606272815    | Copper  | 0.5     | 1.3              | ppm   |
| 012-15A 237 Sink Faucet #3            | 6/25/16 8:51          | 7/5/16 11:39         | 606272815    | Lead    | 4       | 15               | ppb   |
| 012-16A 237 Sink Faucet #4            | 6/25/16 8:49          | 7/5/16 11:39         | 606272816    | Copper  | 0.6     | 1.3              | ppm   |
| 012-16A 237 Sink Faucet #4            | 6/25/16 8:49          | 7/5/16 11:39         | 606272816    | Lead    | 5       | 15               | ppb   |
| 012-17A 237 Sink Faucet #5            | 6/25/16 8:51          | 7/5/16 11:40         | 606272817    | Copper  | 0.4     | 1.3              | ppm   |
| 012-17A 237 Sink Faucet #5            | 6/25/16 8:51          | 7/5/16 11:40         | 606272817    | Lead    | 5       | 15               | ppb   |
| 012-18A 237 Sink Faucet #6            | 6/25/16 8:52          | 7/5/16 11:40         | 606272818    | Copper  | 0.6     | 1.3              | ppm   |
| 012-18A 237 Sink Faucet #6            | 6/25/16 8:52          | 7/5/16 11:40         | 606272818    | Lead    | 5       | 15               | ppb   |
| 012-19A 237 Sink Faucet #7            | 6/25/16 8:51          | 7/5/16 11:41         | 606272819    | Copper  | 0.6     | 1.3              | ppm   |
| 012-19A 237 Sink Faucet #7            | 6/25/16 8:51          | 7/5/16 11:41         | 606272819    | Lead    | 5       | 15               | ppb   |
| 012-20A 237 Sink Faucet #8            | 6/25/16 8:47          | 7/5/16 11:41         | 606272820    | Copper  | 0.5     | 1.3              | ppm   |
| 012-20A 237 Sink Faucet #8            | 6/25/16 8:47          | 7/5/16 11:41         | 606272820    | Lead    | 6       | 15               | ppb   |
| 012-21A 237 Sink Faucet #9            | 6/25/16 8:46          | 7/5/16 11:41         | 606272821    | Copper  | 0.4     | 1.3              | ppm   |
| 012-21A 237 Sink Faucet #9            | 6/25/16 8:46          | 7/5/16 11:41         | 606272821    | Lead    | 12      | 15               | ppb   |
| 012-22A A233 Sink Faucet              | 6/25/16 8:55          | 7/5/16 11:41         | 606272822    | Copper  | 0.4     | 1.3              | ppm   |
| 012-22A A233 Sink Faucet              | 6/25/16 8:55          | 7/5/16 11:41         | 606272822    | Lead    | 2       | 15               | ppb   |
| 012-23A Hallway Drinking Fountain     | 6/25/16 8:55          | 7/5/16 11:41         | 606272823    | Copper  | 0.3     | 1.3              | ppm   |
| 012-23A Hallway Drinking Fountain     | 6/25/16 8:55          | 7/5/16 11:41         | 606272823    | Lead    | 2       | 15               | ppb   |
| 012-24A 234 Sink Faucet (back left)   | 6/25/16 9:00          | 7/5/16 11:41         | 606272824    | Copper  | 0.3     | 1.3              | ppm   |
| 012-24A 234 Sink Faucet (back left)   | 6/25/16 9:00          | 7/5/16 11:41         | 606272824    | Lead    | 28      | 15               | ppb   |
| 012-25A 234 Sink Faucet (back middle) | 6/25/16 9:00          | 7/5/16 11:41         | 606272825    | Copper  | 0.4     | 1.3              | ppm   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Benson High School

| Sample Identification # and Location                       | Date & Time Collected | Date & Time Analyzed | Container ID | Analyte | Results | EPA          | Units |
|------------------------------------------------------------|-----------------------|----------------------|--------------|---------|---------|--------------|-------|
|                                                            |                       |                      |              |         |         | Action Limit |       |
| 012-25A 234 Sink Faucet (back middle)                      | 6/25/16 9:00          | 7/5/16 11:41         | 606272825    | Lead    | 14      | 15           | ppb   |
| 012-26A 234 Sink Faucet (back right)                       | 6/25/16 9:00          | 7/5/16 11:41         | 606272826    | Copper  | 0.3     | 1.3          | ppm   |
| 012-26A 234 Sink Faucet (back right)                       | 6/25/16 9:00          | 7/5/16 11:41         | 606272826    | Lead    | 12      | 15           | ppb   |
| 012-27A 234 Sink Faucet (near door)                        | 6/25/16 8:56          | 7/5/16 11:41         | 606272827    | Copper  | 0.4     | 1.3          | ppm   |
| 012-27A 234 Sink Faucet (near door)                        | 6/25/16 8:56          | 7/5/16 11:41         | 606272827    | Lead    | 10      | 15           | ppb   |
| 012-28A 235B Sink Faucet                                   | 6/25/16 9:03          | 7/5/16 11:41         | 606272828    | Copper  | 0.3     | 1.3          | ppm   |
| 012-28A 235B Sink Faucet                                   | 6/25/16 9:03          | 7/5/16 11:41         | 606272828    | Lead    | 19      | 15           | ppb   |
| 012-29A 235B Sink Faucet (left island)                     | 6/25/16 9:04          | 7/5/16 11:43         | 606272829    | Copper  | 0.6     | 1.3          | ppm   |
| 012-29A 235B Sink Faucet (left island)                     | 6/25/16 9:04          | 7/5/16 11:43         | 606272829    | Lead    | 10      | 15           | ppb   |
| 012-30A 235B Sink Faucet (back left)                       | 6/25/16 9:04          | 7/5/16 11:43         | 606272830    | Copper  | 0.5     | 1.3          | ppm   |
| 012-30A 235B Sink Faucet (back left)                       | 6/25/16 9:04          | 7/5/16 11:43         | 606272830    | Lead    | 13      | 15           | ppb   |
| 012-31A 235B Sink Faucet (back middle)                     | 6/25/16 9:04          | 7/5/16 11:43         | 606272831    | Copper  | 0.4     | 1.3          | ppm   |
| 012-31A 235B Sink Faucet (back middle)                     | 6/25/16 9:04          | 7/5/16 11:43         | 606272831    | Lead    | 13      | 15           | ppb   |
| 012-32A 235B Sink Faucet (back right)                      | 6/25/16 9:04          | 7/5/16 11:43         | 606272832    | Copper  | 0.3     | 1.3          | ppm   |
| 012-32A 235B Sink Faucet (back right)                      | 6/25/16 9:04          | 7/5/16 11:43         | 606272832    | Lead    | 14      | 15           | ppb   |
| 012-33A 235B Sink Faucet (right island)                    | 6/25/16 9:07          | 7/5/16 11:43         | 606272833    | Copper  | 0.4     | 1.3          | ppm   |
| 012-33A 235B Sink Faucet (right island)                    | 6/25/16 9:07          | 7/5/16 11:43         | 606272833    | Lead    | 18      | 15           | ppb   |
| 012-34A 236 Sink Faucet                                    | 6/25/16 9:09          | 7/5/16 11:43         | 606272834    | Copper  | 0.5     | 1.3          | ppm   |
| 012-34A 236 Sink Faucet                                    | 6/25/16 9:09          | 7/5/16 11:43         | 606272834    | Lead    | 8       | 15           | ppb   |
| 012-35A 236 Drinking Fountain #3                           | 6/25/16 9:09          | 7/5/16 11:44         | 606272835    | Copper  | 0.2     | 1.3          | ppm   |
| 012-35A 236 Drinking Fountain #3                           | 6/25/16 9:09          | 7/5/16 11:44         | 606272835    | Lead    | 5       | 15           | ppb   |
| 012-36A 222 Outside Drinking Fountain                      | 6/25/16 9:15          | 7/5/16 11:44         | 606272836    | Copper  | 0.6     | 1.3          | ppm   |
| 012-36A 222 Outside Drinking Fountain                      | 6/25/16 9:15          | 7/5/16 11:44         | 606272836    | Lead    | 2       | 15           | ppb   |
| 012-37A 222 Sink Faucet (nearest hood)                     | 6/25/16 9:14          | 7/5/16 11:44         | 606272837    | Copper  | 0.7     | 1.3          | ppm   |
| 012-37A 222 Sink Faucet (nearest hood)                     | 6/25/16 9:14          | 7/5/16 11:44         | 606272837    | Lead    | 5       | 15           | ppb   |
| 012-38A 222 Sink Faucet (left nearest door)                | 6/25/16 9:20          | 7/5/16 11:44         | 606272838    | Copper  | 0.5     | 1.3          | ppm   |
| 012-38A 222 Sink Faucet (left nearest door)                | 6/25/16 9:20          | 7/5/16 11:44         | 606272838    | Lead    | 4       | 15           | ppb   |
| 012-39A 222 Sink Faucet (left 2nd nearest door)            | 6/25/16 9:20          | 7/5/16 11:44         | 606272839    | Copper  | 0.5     | 1.3          | ppm   |
| 012-39A 222 Sink Faucet (left 2nd nearest door)            | 6/25/16 9:20          | 7/5/16 11:44         | 606272839    | Lead    | 3       | 15           | ppb   |
| 012-40A 222 Sink Faucet (left, near hood, right)           | 6/25/16 9:16          | 7/5/16 11:45         | 606272840    | Copper  | 0.8     | 1.3          | ppm   |
| 012-40A 222 Sink Faucet (left, near hood, right)           | 6/25/16 9:16          | 7/5/16 11:45         | 606272840    | Lead    | 2       | 15           | ppb   |
| 012-41A 222 Sink Faucet (left, nearest 222A)               | 6/25/16 9:19          | 7/5/16 11:45         | 606272841    | Copper  | 0.7     | 1.3          | ppm   |
| 012-41A 222 Sink Faucet (left, nearest 222A)               | 6/25/16 9:19          | 7/5/16 11:45         | 606272841    | Lead    | 4       | 15           | ppb   |
| 012-42A 222 Sink Faucet (left, nearest 222A & window)      | 6/25/16 9:21          | 7/5/16 11:45         | 606272842    | Copper  | 0.7     | 1.3          | ppm   |
| 012-42A 222 Sink Faucet (left, nearest 222A & window)      | 6/25/16 9:21          | 7/5/16 11:45         | 606272842    | Lead    | 2       | 15           | ppb   |
| 012-43A 222 Sink Faucet (left middle, door side)           | 6/25/16 9:24          | 7/5/16 11:45         | 606272843    | Copper  | 0.5     | 1.3          | ppm   |
| 012-43A 222 Sink Faucet (left middle, door side)           | 6/25/16 9:24          | 7/5/16 11:45         | 606272843    | Lead    | 5       | 15           | ppb   |
| 012-44A 222 Sink Faucet (left middle, window side)         | 6/25/16 9:24          | 7/5/16 11:45         | 606272844    | Copper  | 0.6     | 1.3          | ppm   |
| 012-44A 222 Sink Faucet (left middle, window side)         | 6/25/16 9:24          | 7/5/16 11:45         | 606272844    | Lead    | 7       | 15           | ppb   |
| 012-45A 222 Sink Faucet (right middle, door side)          | 6/25/16 9:20          | 7/5/16 11:45         | 606272845    | Copper  | 0.4     | 1.3          | ppm   |
| 012-45A 222 Sink Faucet (right middle, door side)          | 6/25/16 9:20          | 7/5/16 11:45         | 606272845    | Lead    | 2       | 15           | ppb   |
| 012-46A 222 Sink Faucet (right middle, window side)        | 6/25/16 9:21          | 7/5/16 11:45         | 606272846    | Copper  | 0.2     | 1.3          | ppm   |
| 012-46A 222 Sink Faucet (right middle, window side)        | 6/25/16 9:21          | 7/5/16 11:45         | 606272846    | Lead    | 1       | 15           | ppb   |
| 012-47A 222 Sink Faucet (right middle, extra nearest door) | 6/25/16 9:37          | 7/5/16 11:45         | 606272847    | Copper  | 0.4     | 1.3          | ppm   |
| 012-47A 222 Sink Faucet (right middle, extra nearest door) | 6/25/16 9:37          | 7/5/16 11:45         | 606272847    | Lead    | 3       | 15           | ppb   |
| 012-48A 222 Sink Faucet (right, near window)               | 6/25/16 9:24          | 7/5/16 11:45         | 606272848    | Copper  | 0.6     | 1.3          | ppm   |
| 012-48A 222 Sink Faucet (right, near window)               | 6/25/16 9:24          | 7/5/16 11:45         | 606272848    | Lead    | 1       | 15           | ppb   |
| 012-49A 222 Sink Faucet (right, near door)                 | 6/25/16 9:25          | 7/5/16 11:46         | 606272849    | Copper  | 0.4     | 1.3          | ppm   |
| 012-49A 222 Sink Faucet (right, near door)                 | 6/25/16 9:25          | 7/5/16 11:46         | 606272849    | Lead    | 2       | 15           | ppb   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Benson High School

| Sample Identification # and Location                  | Date & Time Collected | Date & Time Analyzed | Container ID | Analyte | Results | EPA          | Units |
|-------------------------------------------------------|-----------------------|----------------------|--------------|---------|---------|--------------|-------|
|                                                       |                       |                      |              |         |         | Action Limit |       |
| 012-50A 222 Sink Faucet (with eyewash)                | 6/25/16 9:28          | 7/5/16 11:46         | 606272850    | Copper  | 0.2     | 1.3          | ppm   |
| 012-50A 222 Sink Faucet (with eyewash)                | 6/25/16 9:28          | 7/5/16 11:46         | 606272850    | Lead    | 2       | 15           | ppb   |
| 012-51A 222 Eye Wash #1                               | 6/25/16 9:30          | 7/5/16 11:46         | 606272851    | Copper  | 0.0     | 1.3          | ppm   |
| 012-51A 222 Eye Wash #1                               | 6/25/16 9:30          | 7/5/16 11:46         | 606272851    | Lead    | 1       | 15           | ppb   |
| 012-52A 222 Eye Wash #2                               | 6/25/16 9:33          | 7/5/16 11:47         | 606272852    | Copper  | 0.3     | 1.3          | ppm   |
| 012-52A 222 Eye Wash #2                               | 6/25/16 9:33          | 7/5/16 11:47         | 606272852    | Lead    | 2       | 15           | ppb   |
| 012-53A 222A Sink Faucet                              | 6/25/16 9:30          | 7/5/16 11:47         | 606272853    | Copper  | 0.1     | 1.3          | ppm   |
| 012-53A 222A Sink Faucet                              | 6/25/16 9:30          | 7/5/16 11:47         | 606272853    | Lead    | 9       | 15           | ppb   |
| 012-54A 231 Sink Faucet                               | 6/25/16 9:46          | 7/5/16 11:47         | 606272854    | Copper  | 0.6     | 1.3          | ppm   |
| 012-54A 231 Sink Faucet                               | 6/25/16 9:46          | 7/5/16 11:47         | 606272854    | Lead    | 2       | 15           | ppb   |
| 012-55A 231 Eye Wash                                  | 6/25/16 9:48          | 7/5/16 11:47         | 606272855    | Copper  | 0.6     | 1.3          | ppm   |
| 012-55A 231 Eye Wash                                  | 6/25/16 9:48          | 7/5/16 11:47         | 606272855    | Lead    | 34      | 15           | ppb   |
| 012-56A 231A Sink Faucet                              | 6/25/16 9:46          | 7/5/16 11:47         | 606272856    | Copper  | 1.1     | 1.3          | ppm   |
| 012-56A 231A Sink Faucet                              | 6/25/16 9:46          | 7/5/16 11:47         | 606272856    | Lead    | 569     | 15           | ppb   |
| 012-57A 229 Sink Faucet                               | 6/25/16 9:49          | 7/5/16 11:47         | 606272857    | Copper  | 0.0     | 1.3          | ppm   |
| 012-57A 229 Sink Faucet                               | 6/25/16 9:49          | 7/5/16 11:47         | 606272857    | Lead    | 7       | 15           | ppb   |
| 012-58A 229 Sink Faucet (front)                       | 6/25/16 9:46          | 7/6/16 9:55          | 606272858    | Copper  | 13.7    | 1.3          | ppm   |
| 012-58A 229 Sink Faucet (front)                       | 6/25/16 9:46          | 7/5/16 11:47         | 606272858    | Lead    | 78      | 15           | ppb   |
| 012-59A 224 Sink Faucet #1                            | 6/25/16 9:37          | 7/5/16 11:49         | 606272859    | Copper  | 0.5     | 1.3          | ppm   |
| 012-59A 224 Sink Faucet #1                            | 6/25/16 9:37          | 7/5/16 11:49         | 606272859    | Lead    | 79      | 15           | ppb   |
| 012-60A 224 Sink Faucet #2                            | 6/25/16 9:37          | 7/5/16 11:49         | 606272860    | Copper  | 0.8     | 1.3          | ppm   |
| 012-60A 224 Sink Faucet #2                            | 6/25/16 9:37          | 7/5/16 11:49         | 606272860    | Lead    | 44      | 15           | ppb   |
| 012-61A 224 Sink Faucet #3                            | 6/25/16 9:44          | 7/5/16 11:49         | 606272861    | Copper  | 0.5     | 1.3          | ppm   |
| 012-61A 224 Sink Faucet #3                            | 6/25/16 9:44          | 7/5/16 11:49         | 606272861    | Lead    | 100     | 15           | ppb   |
| 012-62A 224 Sink Faucet #4                            | 6/25/16 9:40          | 7/5/16 11:49         | 606272862    | Copper  | 0.6     | 1.3          | ppm   |
| 012-62A 224 Sink Faucet #4                            | 6/25/16 9:40          | 7/5/16 11:49         | 606272862    | Lead    | 132     | 15           | ppb   |
| 012-63A 224 Sink Faucet #5                            | 6/25/16 9:39          | 7/5/16 11:50         | 606272863    | Copper  | 0.5     | 1.3          | ppm   |
| 012-63A 224 Sink Faucet #5                            | 6/25/16 9:39          | 7/5/16 11:50         | 606272863    | Lead    | 18      | 15           | ppb   |
| 012-64A 224 Sink Faucet #6                            | 6/25/16 9:31          | 7/5/16 11:50         | 606272864    | Copper  | 0.8     | 1.3          | ppm   |
| 012-64A 224 Sink Faucet #6                            | 6/25/16 9:31          | 7/5/16 11:50         | 606272864    | Lead    | 37      | 15           | ppb   |
| 012-65A 224 Sink Faucet #7                            | 6/25/16 9:35          | 7/5/16 11:50         | 606272865    | Copper  | 0.8     | 1.3          | ppm   |
| 012-65A 224 Sink Faucet #7                            | 6/25/16 9:35          | 7/5/16 11:50         | 606272865    | Lead    | 8       | 15           | ppb   |
| 012-66A 224 Sink Faucet #8                            | 6/25/16 9:36          | 7/5/16 11:50         | 606272866    | Copper  | 1.5     | 1.3          | ppm   |
| 012-66A 224 Sink Faucet #8                            | 6/25/16 9:36          | 7/5/16 11:50         | 606272866    | Lead    | 51      | 15           | ppb   |
| 012-67A 224 Sink Faucet #9                            | 6/25/16 9:44          | 7/5/16 11:50         | 606272867    | Copper  | 0.6     | 1.3          | ppm   |
| 012-67A 224 Sink Faucet #9                            | 6/25/16 9:44          | 7/5/16 11:50         | 606272867    | Lead    | 1       | 15           | ppb   |
| 012-68A 224 Eye Wash                                  | 6/25/16 9:42          | 7/6/16 9:56          | 606272868    | Copper  | 2.8     | 1.3          | ppm   |
| 012-68A 224 Eye Wash                                  | 6/25/16 9:42          | 7/5/16 11:51         | 606272868    | Lead    | 37      | 15           | ppb   |
| 012-69A 226 Sink Faucet (right table left, hood side) | 6/25/16 9:56          | 7/5/16 11:51         | 606272869    | Copper  | 0.6     | 1.3          | ppm   |
| 012-69A 226 Sink Faucet (right table left, hood side) | 6/25/16 9:56          | 7/5/16 11:51         | 606272869    | Lead    | 3       | 15           | ppb   |
| 012-70A 226 Sink Faucet (right table right, hood)     | 6/25/16 9:56          | 7/5/16 11:51         | 606272870    | Copper  | 0.6     | 1.3          | ppm   |
| 012-70A 226 Sink Faucet (right table right, hood)     | 6/25/16 9:56          | 7/5/16 11:51         | 606272870    | Lead    | 7       | 15           | ppb   |
| 012-71A 226 Sink Faucet (right table right, window)   | 6/25/16 10:01         | 7/5/16 11:51         | 606272871    | Copper  | 0.9     | 1.3          | ppm   |
| 012-71A 226 Sink Faucet (right table right, window)   | 6/25/16 10:01         | 7/5/16 11:51         | 606272871    | Lead    | 9       | 15           | ppb   |
| 012-72A 226 Sink Faucet (right table left window)     | 6/25/16 10:02         | 7/5/16 11:52         | 606272872    | Copper  | 0.5     | 1.3          | ppm   |
| 012-72A 226 Sink Faucet (right table left window)     | 6/25/16 10:02         | 7/5/16 11:52         | 606272872    | Lead    | 4       | 15           | ppb   |
| 012-73A 226 Sink Faucet (left table, right window)    | 6/25/16 10:11         | 7/5/16 11:52         | 606272873    | Copper  | 1.6     | 1.3          | ppm   |
| 012-73A 226 Sink Faucet (left table, right window)    | 6/25/16 10:11         | 7/5/16 11:52         | 606272873    | Lead    | 8       | 15           | ppb   |
| 012-74A 226 Sink Faucet (left table, left window)     | 6/25/16 10:11         | 7/5/16 11:52         | 606272874    | Copper  | 1.0     | 1.3          | ppm   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Benson High School

| Sample Identification # and Location              | Date & Time Collected | Date & Time Analyzed | Container ID | Analyte | Results | EPA          |       |
|---------------------------------------------------|-----------------------|----------------------|--------------|---------|---------|--------------|-------|
|                                                   |                       |                      |              |         |         | Action Limit | Units |
| 012-74A 226 Sink Faucet (left table, left window) | 6/25/16 10:11         | 7/5/16 11:52         | 606272874    | Lead    | 7       | 15           | ppb   |
| 012-75A 226 Sink Faucet (right, near window)      | 6/25/16 10:08         | 7/5/16 11:52         | 606272875    | Copper  | 0.5     | 1.3          | ppm   |
| 012-75A 226 Sink Faucet (right, near window)      | 6/25/16 10:08         | 7/5/16 11:52         | 606272875    | Lead    | 7       | 15           | ppb   |
| 012-76A 226 Sink Faucet (middle near window)      | 6/25/16 10:04         | 7/5/16 11:52         | 606272876    | Copper  | 0.3     | 1.3          | ppm   |
| 012-76A 226 Sink Faucet (middle near window)      | 6/25/16 10:04         | 7/5/16 11:52         | 606272876    | Lead    | 1       | 15           | ppb   |
| 012-77A 226 Sink Faucet (left table, right hood)  | 6/25/16 10:08         | 7/5/16 11:52         | 606272877    | Copper  | 0.8     | 1.3          | ppm   |
| 012-77A 226 Sink Faucet (left table, right hood)  | 6/25/16 10:08         | 7/5/16 11:52         | 606272877    | Lead    | 6       | 15           | ppb   |
| 012-78A 226 Sink Faucet (left table, left hood)   | 6/25/16 10:08         | 7/5/16 11:52         | 606272878    | Copper  | 1.27    | 1.3          | ppm   |
| 012-78A 226 Sink Faucet (left table, left hood)   | 6/25/16 10:08         | 7/5/16 11:52         | 606272878    | Lead    | 10      | 15           | ppb   |
| 012-79A 226 Sink Faucet (with eyewash)            | 6/25/16 9:58          | 7/5/16 11:53         | 606272879    | Copper  | 0.2     | 1.3          | ppm   |
| 012-79A 226 Sink Faucet (with eyewash)            | 6/25/16 9:58          | 7/5/16 11:53         | 606272879    | Lead    | 26      | 15           | ppb   |
| 012-80A 226 Eye Wash                              | 6/25/16 9:59          | 7/5/16 11:53         | 606272880    | Copper  | 0.3     | 1.3          | ppm   |
| 012-80A 226 Eye Wash                              | 6/25/16 9:59          | 7/5/16 11:53         | 606272880    | Lead    | 53      | 15           | ppb   |
| 012-81A 226 Drinking Fountain                     | 6/25/16 10:15         | 7/5/16 11:53         | 606272881    | Copper  | 0.7     | 1.3          | ppm   |
| 012-81A 226 Drinking Fountain                     | 6/25/16 10:15         | 7/5/16 11:53         | 606272881    | Lead    | ND      | 15           | ppb   |
| 012-82A 228 Sink Faucet #1                        | 6/25/16 10:14         | 7/5/16 11:53         | 606272882    | Copper  | 0.6     | 1.3          | ppm   |
| 012-82A 228 Sink Faucet #1                        | 6/25/16 10:14         | 7/5/16 11:53         | 606272882    | Lead    | 1       | 15           | ppb   |
| 012-83A 228 Sink Faucet #2                        | 6/25/16 10:15         | 7/5/16 11:53         | 606272883    | Copper  | 0.2     | 1.3          | ppm   |
| 012-83A 228 Sink Faucet #2                        | 6/25/16 10:15         | 7/5/16 11:53         | 606272883    | Lead    | 5       | 15           | ppb   |
| 012-84A 207 Sink Faucet (right)                   | 6/25/16 10:19         | 7/5/16 11:53         | 606272884    | Copper  | 1.8     | 1.3          | ppm   |
| 012-84A 207 Sink Faucet (right)                   | 6/25/16 10:19         | 7/5/16 11:53         | 606272884    | Lead    | 16      | 15           | ppb   |
| 012-86A 207 Sink Faucet (left)                    | 6/25/16 10:22         | 7/5/16 11:53         | 606272885    | Copper  | 0.3     | 1.3          | ppm   |
| 012-86A 207 Sink Faucet (left)                    | 6/25/16 10:22         | 7/5/16 11:53         | 606272885    | Lead    | 9       | 15           | ppb   |
| 012-87A 207 Sink Faucet Janitor's Closet          | 6/25/16 10:20         | 7/5/16 11:53         | 606272886    | Copper  | 0.1     | 1.3          | ppm   |
| 012-87A 207 Sink Faucet Janitor's Closet          | 6/25/16 10:20         | 7/5/16 11:53         | 606272886    | Lead    | 3       | 15           | ppb   |
| 012-88A Drinking Fountain #4                      | 6/25/16 10:27         | 7/1/16 17:25         | 606272887    | Copper  | 0.4     | 1.3          | ppm   |
| 012-88A Drinking Fountain #4                      | 6/25/16 10:27         | 7/1/16 17:25         | 606272887    | Lead    | 8       | 15           | ppb   |
| 012-89A 202 Sink Faucet (left)                    | 6/25/16 10:25         | 7/5/16 11:53         | 606272888    | Copper  | 0.4     | 1.3          | ppm   |
| 012-89A 202 Sink Faucet (left)                    | 6/25/16 10:25         | 7/5/16 11:53         | 606272888    | Lead    | 2       | 15           | ppb   |
| 012-90A 202 Sink Faucet (right)                   | 6/25/16 10:26         | 7/5/16 11:56         | 606272889    | Copper  | 0.4     | 1.3          | ppm   |
| 012-90A 202 Sink Faucet (right)                   | 6/25/16 10:26         | 7/5/16 11:56         | 606272889    | Lead    | 2       | 15           | ppb   |
| 012-91A 202A Sink Faucet Janitor's Closet         | 6/25/16 10:24         | 7/5/16 11:56         | 606272890    | Copper  | 0.2     | 1.3          | ppm   |
| 012-91A 202A Sink Faucet Janitor's Closet         | 6/25/16 10:24         | 7/5/16 11:56         | 606272890    | Lead    | 15.3    | 15           | ppb   |
| 012-92A G202 Sink Faucet                          | 6/25/16 10:30         | 7/5/16 11:56         | 606272891    | Copper  | 0.0     | 1.3          | ppm   |
| 012-92A G202 Sink Faucet                          | 6/25/16 10:30         | 7/5/16 11:56         | 606272891    | Lead    | 26      | 15           | ppb   |
| 012-93A Drinking Fountain #5                      | 6/25/16 10:32         | 7/5/16 11:56         | 606272892    | Copper  | 0.8     | 1.3          | ppm   |
| 012-93A Drinking Fountain #5                      | 6/25/16 10:32         | 7/5/16 11:56         | 606272892    | Lead    | 1       | 15           | ppb   |
| 012-94A Drinking Fountain outside G209            | 6/25/16 10:35         | 7/5/16 11:56         | 606272893    | Copper  | 0.8     | 1.3          | ppm   |
| 012-94A Drinking Fountain outside G209            | 6/25/16 10:35         | 7/5/16 11:56         | 606272893    | Lead    | ND      | 15           | ppb   |
| 012-95A G205 Sink Faucet                          | 6/25/16 10:37         | 7/5/16 11:56         | 606272894    | Copper  | 0.1     | 1.3          | ppm   |
| 012-95A G205 Sink Faucet                          | 6/25/16 10:37         | 7/5/16 11:56         | 606272894    | Lead    | 26      | 15           | ppb   |
| 012-96A G207 Sink Faucet                          | 6/25/16 10:56         | 7/5/16 11:56         | 606272895    | Copper  | 0.3     | 1.3          | ppm   |
| 012-96A G207 Sink Faucet                          | 6/25/16 10:56         | 7/5/16 11:56         | 606272895    | Lead    | 26      | 15           | ppb   |
| 012-97A Staff Restroom Sink Faucet outside Gym    | 6/25/16 10:49         | 7/5/16 11:56         | 606272896    | Copper  | 0.1     | 1.3          | ppm   |
| 012-97A Staff Restroom Sink Faucet outside Gym    | 6/25/16 10:49         | 7/5/16 11:56         | 606272896    | Lead    | 2       | 15           | ppb   |
| 012-98A Sink Faucet                               | 6/25/16 10:51         | 7/5/16 11:56         | 606272897    | Copper  | 0.2     | 1.3          | ppm   |
| 012-98A Sink Faucet                               | 6/25/16 10:51         | 7/5/16 11:56         | 606272897    | Lead    | 8       | 15           | ppb   |
| 012-99A Drinking Fountain #6                      | 6/25/16 10:53         | 7/5/16 11:56         | 606272898    | Copper  | 0.5     | 1.3          | ppm   |
| 012-99A Drinking Fountain #6                      | 6/25/16 10:53         | 7/5/16 11:56         | 606272898    | Lead    | 0       | 15           | ppb   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Benson High School

| Sample Identification # and Location           | Date & Time Collected | Date & Time Analyzed | Container ID | Analyte | Results | EPA          |       |
|------------------------------------------------|-----------------------|----------------------|--------------|---------|---------|--------------|-------|
|                                                |                       |                      |              |         |         | Action Limit | Units |
| 012-101A Drinking Fountain #7                  | 6/25/16 10:49         | 7/6/16 10:02         | 606272899    | Copper  | 0.3     | 1.3          | ppm   |
| 012-101A Drinking Fountain #7                  | 6/25/16 10:49         | 7/6/16 10:02         | 606272899    | Lead    | 2       | 15           | ppb   |
| 012-102A 105 Sink Faucet                       | 6/25/16 11:00         | 7/6/16 10:02         | 6062728100   | Copper  | 0.2     | 1.3          | ppm   |
| 012-102A 105 Sink Faucet                       | 6/25/16 11:00         | 7/6/16 10:02         | 6062728100   | Lead    | 1       | 15           | ppb   |
| 012-103A Bathroom Sink Faucet (left)           | 6/25/16 10:59         | 7/6/16 10:02         | 6062728101   | Copper  | 0.3     | 1.3          | ppm   |
| 012-103A Bathroom Sink Faucet (left)           | 6/25/16 10:59         | 7/6/16 10:02         | 6062728101   | Lead    | 6       | 15           | ppb   |
| 012-104A Bathroom Sink Faucet (middle)         | 6/25/16 11:02         | 7/6/16 10:02         | 6062728102   | Copper  | 0.4     | 1.3          | ppm   |
| 012-104A Bathroom Sink Faucet (middle)         | 6/25/16 11:02         | 7/6/16 10:02         | 6062728102   | Lead    | 3       | 15           | ppb   |
| 012-105A Bathroom Sink Faucet (right)          | 6/25/16 11:03         | 7/8/16 8:43          | 6062728103   | Copper  | 0.6     | 1.3          | ppm   |
| 012-105A Bathroom Sink Faucet (right)          | 6/25/16 11:03         | 7/6/16 10:07         | 6062728103   | Lead    | 6       | 15           | ppb   |
| 012-106A G114 Sink Faucet                      | 6/25/16 11:08         | 7/6/16 10:07         | 6062728104   | Copper  | 0.1     | 1.3          | ppm   |
| 012-106A G114 Sink Faucet                      | 6/25/16 11:08         | 7/6/16 10:07         | 6062728104   | Lead    | 1       | 15           | ppb   |
| 012-107A G100 Drinking Fountain                | 6/25/16 11:05         | 7/8/16 8:44          | 6062728105   | Copper  | 1.9     | 1.3          | ppm   |
| 012-107A G100 Drinking Fountain                | 6/25/16 11:05         | 7/6/16 10:07         | 6062728105   | Lead    | ND      | 15           | ppb   |
| 012-108A G100 Bottle Refilling                 | 6/25/16 11:05         | 7/8/16 8:44          | 6062728106   | Copper  | 2.2     | 1.3          | ppm   |
| 012-108A G100 Bottle Refilling                 | 6/25/16 11:05         | 7/6/16 10:07         | 6062728106   | Lead    | ND      | 15           | ppb   |
| 012-109A Boys Sink Faucet (right)              | 6/25/16 11:07         | 7/6/16 10:07         | 6062728107   | Copper  | 0.5     | 1.3          | ppm   |
| 012-109A Boys Sink Faucet (right)              | 6/25/16 11:07         | 7/6/16 10:07         | 6062728107   | Lead    | 9       | 15           | ppb   |
| 012-110A Boys Sink Faucet (middle)             | 6/25/16 11:09         | 7/6/16 10:07         | 6062728108   | Copper  | 0.2     | 1.3          | ppm   |
| 012-110A Boys Sink Faucet (middle)             | 6/25/16 11:09         | 7/6/16 10:07         | 6062728108   | Lead    | 6       | 15           | ppb   |
| 012-111A Boys Sink Faucet (left)               | 6/25/16 11:10         | 7/6/16 10:07         | 6062728109   | Copper  | 0.1     | 1.3          | ppm   |
| 012-111A Boys Sink Faucet (left)               | 6/25/16 11:10         | 7/6/16 10:07         | 6062728109   | Lead    | 2       | 15           | ppb   |
| 012-112A Women's Lavatory Sink Faucet (right)  | 6/25/16 11:17         | 7/1/16 17:25         | 6062728110   | Copper  | 2.4     | 1.3          | ppm   |
| 012-112A Women's Lavatory Sink Faucet (right)  | 6/25/16 11:17         | 7/1/16 17:25         | 6062728110   | Lead    | 27      | 15           | ppb   |
| 012-113A Women's Lavatory Sink Faucet (middle) | 6/25/16 11:15         | 7/9/16 17:00         | 6062728111   | Copper  | 0.4     | 1.3          | ppm   |
| 012-113A Women's Lavatory Sink Faucet (middle) | 6/25/16 11:15         | 7/9/16 17:00         | 6062728111   | Lead    | 3       | 15           | ppb   |
| 012-114A Women's Lavatory Sink Faucet (left)   | 6/25/16 11:17         | 7/1/16 17:25         | 6062728112   | Copper  | 2.3     | 1.3          | ppm   |
| 012-114A Women's Lavatory Sink Faucet (left)   | 6/25/16 11:17         | 7/1/16 17:25         | 6062728112   | Lead    | 19      | 15           | ppb   |
| 012-115A Unisex Bathroom Sink Faucet           | 6/25/16 11:19         | 7/6/16 10:07         | 6062728113   | Copper  | 0.4     | 1.3          | ppm   |
| 012-115A Unisex Bathroom Sink Faucet           | 6/25/16 11:19         | 7/6/16 10:07         | 6062728113   | Lead    | 1       | 15           | ppb   |
| 012-116A Drinking Fountain #8                  | 6/25/16 11:18         | 7/6/16 10:07         | 6062728114   | Copper  | 0.3     | 1.3          | ppm   |
| 012-116A Drinking Fountain #8                  | 6/25/16 11:18         | 7/6/16 10:07         | 6062728114   | Lead    | 5       | 15           | ppb   |
| 012-117A 003 Sink Faucet                       | 6/25/16 11:25         | 7/6/16 10:08         | 6062728115   | Copper  | 0.5     | 1.3          | ppm   |
| 012-117A 003 Sink Faucet                       | 6/25/16 11:25         | 7/6/16 10:08         | 6062728115   | Lead    | 1       | 15           | ppb   |
| 012-118A 001A Sink Faucet                      | 6/25/16 11:27         | 7/6/16 10:09         | 6062728116   | Copper  | 0.4     | 1.3          | ppm   |
| 012-118A 001A Sink Faucet                      | 6/25/16 11:27         | 7/6/16 10:09         | 6062728116   | Lead    | 2       | 15           | ppb   |
| 012-119A 104A Sink Faucet                      | 6/25/16 11:24         | 7/6/16 10:10         | 6062728117   | Copper  | 0.4     | 1.3          | ppm   |
| 012-119A 104A Sink Faucet                      | 6/25/16 11:24         | 7/6/16 10:10         | 6062728117   | Lead    | 7       | 15           | ppb   |
| 012-120A Drinking Fountain #9                  | 6/25/16 11:28         | 7/8/16 8:44          | 6062728118   | Copper  | 1.9     | 1.3          | ppm   |
| 012-120A Drinking Fountain #9                  | 6/25/16 11:28         | 7/6/16 10:10         | 6062728118   | Lead    | ND      | 15           | ppb   |
| 012-121A Bottle Refilling                      | 6/25/16 11:31         | 7/8/16 8:44          | 6062728119   | Copper  | 1.4     | 1.3          | ppm   |
| 012-121A Bottle Refilling                      | 6/25/16 11:31         | 7/6/16 10:10         | 6062728119   | Lead    | ND      | 15           | ppb   |
| 012-122A 111 Sink Faucet (left)                | 6/25/16 11:37         | 7/1/16 17:27         | 6062728120   | Copper  | 3.9     | 1.3          | ppm   |
| 012-122A 111 Sink Faucet (left)                | 6/25/16 11:37         | 7/1/16 17:27         | 6062728120   | Lead    | 40      | 15           | ppb   |
| 012-123A 111 Sink Faucet (middle)              | 6/25/16 11:38         | 7/8/16 8:44          | 6062728121   | Copper  | 1.4     | 1.3          | ppm   |
| 012-123A 111 Sink Faucet (middle)              | 6/25/16 11:38         | 7/6/16 10:10         | 6062728121   | Lead    | 16      | 15           | ppb   |
| 012-124A 111 Sink Faucet (right)               | 6/25/16 11:40         | 7/6/16 10:10         | 6062728122   | Copper  | 0.3     | 1.3          | ppm   |
| 012-124A 111 Sink Faucet (right)               | 6/25/16 11:40         | 7/6/16 10:10         | 6062728122   | Lead    | 11      | 15           | ppb   |
| 012-125A 111 Sink Faucet Janitor's Closet      | 6/25/16 11:33         | 7/8/16 8:44          | 6062728123   | Copper  | 0.9     | 1.3          | ppm   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Benson High School

| Sample Identification # and Location         | Date & Time Collected | Date & Time Analyzed | Container ID | Analyte | Results | EPA Action Limit | Units |
|----------------------------------------------|-----------------------|----------------------|--------------|---------|---------|------------------|-------|
| 012-125A 111 Sink Faucet Janitor's Closet    | 6/25/16 11:33         | 7/6/16 10:11         | 6062728123   | Lead    | 51      | 15               | ppb   |
| 012-126A Drinking Fountain #10               | 6/25/16 11:41         | 7/8/16 8:44          | 6062728124   | Copper  | 1.1     | 1.3              | ppm   |
| 012-126A Drinking Fountain #10               | 6/25/16 11:41         | 7/6/16 10:11         | 6062728124   | Lead    | 1       | 15               | ppb   |
| 012-127A Drinking Fountain #11               | 6/25/16 11:44         | 7/8/16 8:44          | 6062728125   | Copper  | 0.9     | 1.3              | ppm   |
| 012-127A Drinking Fountain #11               | 6/25/16 11:44         | 7/6/16 10:11         | 6062728125   | Lead    | 2       | 15               | ppb   |
| 012-128A A102 Sink Faucet                    | 6/25/16 11:47         | 7/8/16 8:44          | 6062728126   | Copper  | 0.5     | 1.3              | ppm   |
| 012-128A A102 Sink Faucet                    | 6/25/16 11:47         | 7/6/16 10:12         | 6062728126   | Lead    | 79      | 15               | ppb   |
| 012-130A RR1A Sink Faucet                    | 6/25/16 11:44         | 7/8/16 8:46          | 6062728127   | Copper  | 0.7     | 1.3              | ppm   |
| 012-130A RR1A Sink Faucet                    | 6/25/16 11:44         | 7/6/16 10:12         | 6062728127   | Lead    | 8       | 15               | ppb   |
| 012-131A Drinking Fountain outside 130       | 6/25/16 11:50         | 7/1/16 17:27         | 6062728128   | Copper  | 4.5     | 1.3              | ppm   |
| 012-131A Drinking Fountain outside 130       | 6/25/16 11:50         | 7/1/16 17:27         | 6062728128   | Lead    | 12      | 15               | ppb   |
| 012-132A L4 Sink Faucet                      | 6/25/16 11:52         | 7/6/16 10:12         | 6062728129   | Copper  | 0.5     | 1.3              | ppm   |
| 012-132A L4 Sink Faucet                      | 6/25/16 11:52         | 7/6/16 10:12         | 6062728129   | Lead    | 5       | 15               | ppb   |
| 012-133A 130 Sink Faucet                     | 6/25/16 11:53         | 7/6/16 10:12         | 6062728130   | Copper  | 0.1     | 1.3              | ppm   |
| 012-133A 130 Sink Faucet                     | 6/25/16 11:53         | 7/6/16 10:12         | 6062728130   | Lead    | 4       | 15               | ppb   |
| 012-134A 119 Sink Faucet (right back)        | 6/25/16 11:57         | 7/8/16 8:46          | 6062728131   | Copper  | 0.5     | 1.3              | ppm   |
| 012-134A 119 Sink Faucet (right back)        | 6/25/16 11:57         | 7/6/16 10:12         | 6062728131   | Lead    | 7       | 15               | ppb   |
| 012-135A 119 Sink Faucet (left back)         | 6/25/16 11:59         | 7/8/16 8:46          | 6062728132   | Copper  | 0.7     | 1.3              | ppm   |
| 012-135A 119 Sink Faucet (left back)         | 6/25/16 11:59         | 7/6/16 10:12         | 6062728132   | Lead    | 4       | 15               | ppb   |
| 012-136A 119 Sink Faucet (w/ eyewash)        | 6/25/16 11:56         | 7/8/16 8:46          | 6062728133   | Copper  | 0.6     | 1.3              | ppm   |
| 012-136A 119 Sink Faucet (w/ eyewash)        | 6/25/16 11:56         | 7/6/16 11:44         | 6062728133   | Lead    | 2       | 15               | ppb   |
| 012-137A 119 Eye Wash                        | 6/25/16 11:57         | 7/8/16 8:46          | 6062728134   | Copper  | 0.7     | 1.3              | ppm   |
| 012-137A 119 Eye Wash                        | 6/25/16 11:57         | 7/6/16 11:44         | 6062728134   | Lead    | 46      | 15               | ppb   |
| 012-138A 123 Sink Faucet                     | 6/25/16 12:01         | 7/8/16 8:46          | 6062728135   | Copper  | 0.6     | 1.3              | ppm   |
| 012-138A 123 Sink Faucet                     | 6/25/16 12:01         | 7/6/16 11:44         | 6062728135   | Lead    | 5       | 15               | ppb   |
| 012-139A 118 Sink Faucet (left window)       | 6/25/16 12:03         | 7/8/16 8:46          | 6062728136   | Copper  | 0.7     | 1.3              | ppm   |
| 012-139A 118 Sink Faucet (left window)       | 6/25/16 12:03         | 7/6/16 11:44         | 6062728136   | Lead    | 4       | 15               | ppb   |
| 012-140A 118 Sink Faucet (right window)      | 6/25/16 12:00         | 7/11/16 11:32        | 6062728137   | Copper  | 0.7     | 1.3              | ppm   |
| 012-140A 118 Sink Faucet (right window)      | 6/25/16 12:00         | 7/6/16 11:44         | 6062728137   | Lead    | 6       | 15               | ppb   |
| 012-141A 118 Sink Faucet (right, door side)  | 6/25/16 12:04         | 7/6/16 11:44         | 6062728138   | Copper  | 0.3     | 1.3              | ppm   |
| 012-141A 118 Sink Faucet (right, door side)  | 6/25/16 12:04         | 7/6/16 11:44         | 6062728138   | Lead    | 5       | 15               | ppb   |
| 012-142A 118 Sink Faucet (left island, door) | 6/25/16 12:07         | 7/8/16 8:46          | 6062728139   | Copper  | 0.6     | 1.3              | ppm   |
| 012-142A 118 Sink Faucet (left island, door) | 6/25/16 12:07         | 7/6/16 11:45         | 6062728139   | Lead    | 6       | 15               | ppb   |
| 012-143A 118 Eyewash (back, left window)     | 6/25/16 12:03         | 7/6/16 11:45         | 6062728140   | Copper  | 0.4     | 1.3              | ppm   |
| 012-143A 118 Eyewash (back, left window)     | 6/25/16 12:03         | 7/6/16 11:45         | 6062728140   | Lead    | 43      | 15               | ppb   |
| 012-144A 117 Sink Faucet (right wall)        | 6/25/16 12:10         | 7/8/16 8:46          | 6062728141   | Copper  | 0.5     | 1.3              | ppm   |
| 012-144A 117 Sink Faucet (right wall)        | 6/25/16 12:10         | 7/6/16 11:45         | 6062728141   | Lead    | 3       | 15               | ppb   |
| 012-145A 117 Sink Faucet (near door)         | 6/25/16 12:07         | 7/8/16 8:46          | 6062728142   | Copper  | 0.7     | 1.3              | ppm   |
| 012-145A 117 Sink Faucet (near door)         | 6/25/16 12:07         | 7/6/16 11:45         | 6062728142   | Lead    | 4       | 15               | ppb   |
| 012-146A Custodian 2 Sink Faucet             | 6/25/16 12:09         | 7/6/16 11:45         | 6062728143   | Copper  | 0.3     | 1.3              | ppm   |
| 012-146A Custodian 2 Sink Faucet             | 6/25/16 12:09         | 7/6/16 11:45         | 6062728143   | Lead    | 8       | 15               | ppb   |
| 012-147A Drinking Fountain outside 117       | 6/25/16 12:11         | 7/8/16 8:46          | 6062728144   | Copper  | 0.6     | 1.3              | ppm   |
| 012-147A Drinking Fountain outside 117       | 6/25/16 12:11         | 7/6/16 11:45         | 6062728144   | Lead    | 2       | 15               | ppb   |
| 012-148A 124 Sink Faucet #1                  | 6/25/16 12:13         | 7/6/16 11:45         | 6062728145   | Copper  | 0.4     | 1.3              | ppm   |
| 012-148A 124 Sink Faucet #1                  | 6/25/16 12:13         | 7/6/16 11:45         | 6062728145   | Lead    | 2       | 15               | ppb   |
| 012-149A 124 Sink Faucet #2                  | 6/25/16 12:13         | 7/6/16 11:45         | 6062728146   | Copper  | 0.3     | 1.3              | ppm   |
| 012-149A 124 Sink Faucet #2                  | 6/25/16 12:13         | 7/6/16 11:45         | 6062728146   | Lead    | 2       | 15               | ppb   |
| 012-150A 124 Sink Faucet #3                  | 6/25/16 12:17         | 7/6/16 11:46         | 6062728147   | Copper  | 0.4     | 1.3              | ppm   |
| 012-150A 124 Sink Faucet #3                  | 6/25/16 12:17         | 7/6/16 11:46         | 6062728147   | Lead    | 7       | 15               | ppb   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Benson High School

| Sample Identification # and Location   | Date & Time Collected | Date & Time Analyzed | Container ID | Analyte | Results | EPA          | Units |
|----------------------------------------|-----------------------|----------------------|--------------|---------|---------|--------------|-------|
|                                        |                       |                      |              |         |         | Action Limit |       |
| 012-151A 124 Sink Faucet #4            | 6/25/16 12:16         | 7/8/16 8:47          | 6062728148   | Copper  | 0.7     | 1.3          | ppm   |
| 012-151A 124 Sink Faucet #4            | 6/25/16 12:16         | 7/6/16 11:46         | 6062728148   | Lead    | 2       | 15           | ppb   |
| 012-152A 124 Sink Faucet (front)       | 6/25/16 12:21         | 7/6/16 11:46         | 6062728149   | Copper  | 0.2     | 1.3          | ppm   |
| 012-152A 124 Sink Faucet (front)       | 6/25/16 12:21         | 7/6/16 11:46         | 6062728149   | Lead    | 11      | 15           | ppb   |
| 012-153A 125 Sink Faucet               | 6/25/16 12:15         | 7/8/16 8:47          | 6062728150   | Copper  | 0.8     | 1.3          | ppm   |
| 012-153A 125 Sink Faucet               | 6/25/16 12:15         | 7/6/16 11:46         | 6062728150   | Lead    | 2       | 15           | ppb   |
| 012-154A 125 Drinking Fountain         | 6/25/16 12:15         | 7/8/16 8:47          | 6062728151   | Copper  | 0.7     | 1.3          | ppm   |
| 012-154A 125 Drinking Fountain         | 6/25/16 12:15         | 7/6/16 11:46         | 6062728151   | Lead    | 12      | 15           | ppb   |
| 012-155A E102 Sink Faucet #1           | 6/25/16 12:24         | 7/6/16 11:46         | 6062728152   | Copper  | 0.1     | 1.3          | ppm   |
| 012-155A E102 Sink Faucet #1           | 6/25/16 12:24         | 7/6/16 11:46         | 6062728152   | Lead    | 5       | 15           | ppb   |
| 012-156A E102 Sink Faucet #2           | 6/25/16 12:25         | 7/6/16 14:27         | 6062728153   | Copper  | 0.1     | 1.3          | ppm   |
| 012-156A E102 Sink Faucet #2           | 6/25/16 12:25         | 7/6/16 14:27         | 6062728153   | Lead    | 8       | 15           | ppb   |
| 012-157A E102 Drinking Fountain        | 6/25/16 12:29         | 7/8/16 8:47          | 6062728154   | Copper  | 1.1     | 1.3          | ppm   |
| 012-157A E102 Drinking Fountain        | 6/25/16 12:29         | 7/6/16 11:46         | 6062728154   | Lead    | 1       | 15           | ppb   |
| 012-158A E102 Handwashing Station E105 | 6/25/16 12:42         | 7/6/16 11:46         | 6062728155   | Copper  | 0.3     | 1.3          | ppm   |
| 012-158A E102 Handwashing Station E105 | 6/25/16 12:42         | 7/6/16 11:46         | 6062728155   | Lead    | 6       | 15           | ppb   |
| 012-159A E105 Drinking Fountain        | 6/25/16 12:46         | 7/6/16 11:46         | 6062728156   | Copper  | 0.3     | 1.3          | ppm   |
| 012-159A E105 Drinking Fountain        | 6/25/16 12:46         | 7/6/16 11:46         | 6062728156   | Lead    | 4       | 15           | ppb   |
| 012-160A E105 Sink Faucet              | 6/25/16 12:40         | 7/6/16 11:47         | 6062728157   | Copper  | 0.1     | 1.3          | ppm   |
| 012-160A E105 Sink Faucet              | 6/25/16 12:40         | 7/6/16 11:47         | 6062728157   | Lead    | 5       | 15           | ppb   |
| 012-161A E103 Sink Faucet              | 6/25/16 12:39         | 7/8/16 8:47          | 6062728158   | Copper  | 0.8     | 1.3          | ppm   |
| 012-161A E103 Sink Faucet              | 6/25/16 12:39         | 7/6/16 11:47         | 6062728158   | Lead    | 3       | 15           | ppb   |
| 012-162A E103 Drinking Fountain        | 6/25/16 12:42         | 7/8/16 8:47          | 6062728159   | Copper  | 0.5     | 1.3          | ppm   |
| 012-162A E103 Drinking Fountain        | 6/25/16 12:42         | 7/6/16 11:47         | 6062728159   | Lead    | 3       | 15           | ppb   |
| 012-163A E109 Sink Faucet (right)      | 6/25/16 12:45         | 7/6/16 11:47         | 6062728160   | Copper  | 0.2     | 1.3          | ppm   |
| 012-163A E109 Sink Faucet (right)      | 6/25/16 12:45         | 7/6/16 11:47         | 6062728160   | Lead    | 4       | 15           | ppb   |
| 012-164A E109 Sink Faucet (left)       | 6/25/16 12:45         | 7/6/16 11:47         | 6062728161   | Copper  | 0.2     | 1.3          | ppm   |
| 012-164A E109 Sink Faucet (left)       | 6/25/16 12:45         | 7/6/16 11:47         | 6062728161   | Lead    | 3       | 15           | ppb   |
| 012-165A E110 Drinking Fountain        | 6/25/16 12:55         | 7/8/16 8:47          | 6062728162   | Copper  | 0.8     | 1.3          | ppm   |
| 012-165A E110 Drinking Fountain        | 6/25/16 12:55         | 7/6/16 11:47         | 6062728162   | Lead    | 1       | 15           | ppb   |
| 012-166A E110 Sink Faucet (right)      | 6/25/16 12:47         | 7/6/16 11:47         | 6062728163   | Copper  | 0.2     | 1.3          | ppm   |
| 012-166A E110 Sink Faucet (right)      | 6/25/16 12:47         | 7/6/16 11:47         | 6062728163   | Lead    | 13      | 15           | ppb   |
| 012-167A E110 Sink Faucet (left)       | 6/25/16 12:50         | 7/6/16 11:47         | 6062728164   | Copper  | 0.2     | 1.3          | ppm   |
| 012-167A E110 Sink Faucet (left)       | 6/25/16 12:50         | 7/6/16 11:47         | 6062728164   | Lead    | 10      | 15           | ppb   |
| 012-168A E110 Eyewash                  | 6/25/16 12:52         | 7/6/16 11:47         | 6062728165   | Copper  | 0.2     | 1.3          | ppm   |
| 012-168A E110 Eyewash                  | 6/25/16 12:52         | 7/6/16 11:47         | 6062728165   | Lead    | 10      | 15           | ppb   |
| 012-170A E115 Sink Faucet              | 6/25/16 12:49         | 7/1/16 17:27         | 6062728166   | Copper  | 1.1     | 1.3          | ppm   |
| 012-170A E115 Sink Faucet              | 6/25/16 12:49         | 7/1/16 17:27         | 6062728166   | Lead    | 108     | 15           | ppb   |
| 012-171A E116 Drinking Fountain        | 6/25/16 12:55         | 7/8/16 8:47          | 6062728167   | Copper  | 0.9     | 1.3          | ppm   |
| 012-171A E116 Drinking Fountain        | 6/25/16 12:55         | 7/6/16 11:47         | 6062728167   | Lead    | 2       | 15           | ppb   |
| 012-172A E116 Sink Faucet (left)       | 6/25/16 12:52         | 7/6/16 11:47         | 6062728168   | Copper  | 0.2     | 1.3          | ppm   |
| 012-172A E116 Sink Faucet (left)       | 6/25/16 12:52         | 7/6/16 11:47         | 6062728168   | Lead    | 4       | 15           | ppb   |
| 012-173A E116 Sink Faucet (right)      | 6/25/16 12:52         | 7/6/16 11:48         | 6062728169   | Copper  | 0.2     | 1.3          | ppm   |
| 012-173A E116 Sink Faucet (right)      | 6/25/16 12:52         | 7/6/16 11:48         | 6062728169   | Lead    | 8       | 15           | ppb   |
| 012-174A E116 Eyewash                  | 6/25/16 12:56         | 7/6/16 11:48         | 6062728170   | Copper  | 0.2     | 1.3          | ppm   |
| 012-174A E116 Eyewash                  | 6/25/16 12:56         | 7/6/16 11:48         | 6062728170   | Lead    | 6       | 15           | ppb   |
| 012-175A E123 Sink Faucet              | 6/25/16 12:54         | 7/8/16 8:47          | 6062728171   | Copper  | 0.6     | 1.3          | ppm   |
| 012-175A E123 Sink Faucet              | 6/25/16 12:54         | 7/6/16 11:48         | 6062728171   | Lead    | 21      | 15           | ppb   |
| 012-177A E127 Sink Faucet              | 6/25/16 13:01         | 7/8/16 8:48          | 6062728172   | Copper  | 0.7     | 1.3          | ppm   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Benson High School

| Sample Identification # and Location            | Date & Time Collected | Date & Time Analyzed | Container ID      | Analyte     | Results   | EPA          | Units      |
|-------------------------------------------------|-----------------------|----------------------|-------------------|-------------|-----------|--------------|------------|
|                                                 |                       |                      |                   |             |           | Action Limit |            |
| 012-177A E127 Sink Faucet                       | 6/25/16 13:01         | 7/6/16 11:48         | 6062728172        | Lead        | 6         | 15           | ppb        |
| 012-178A E127 Drinking Fountain                 | 6/25/16 13:01         | 7/8/16 8:48          | 6062728173        | Copper      | 0.9       | 1.3          | ppm        |
| 012-178A E127 Drinking Fountain                 | 6/25/16 13:01         | 7/6/16 11:48         | 6062728173        | Lead        | 1         | 15           | ppb        |
| 012-179A E131 Drinking Fountain                 | 6/25/16 13:04         | 7/8/16 8:48          | 6062728174        | Copper      | 0.5       | 1.3          | ppm        |
| 012-179A E131 Drinking Fountain                 | 6/25/16 13:04         | 7/6/16 11:48         | 6062728174        | Lead        | 1         | 15           | ppb        |
| 012-180A E131 Sink Faucet                       | 6/25/16 13:04         | 7/8/16 8:48          | 6062728175        | Copper      | 0.7       | 1.3          | ppm        |
| 012-180A E131 Sink Faucet                       | 6/25/16 13:04         | 7/6/16 11:48         | 6062728175        | Lead        | 3         | 15           | ppb        |
| 012-181A E136 Sink Faucet                       | 6/25/16 13:25         | 7/8/16 8:48          | 6062728176        | Copper      | 0.6       | 1.3          | ppm        |
| 012-181A E136 Sink Faucet                       | 6/25/16 13:25         | 7/6/16 11:48         | 6062728176        | Lead        | 3         | 15           | ppb        |
| 012-182A E136 Drinking Fountain                 | 6/25/16 13:25         | 7/8/16 8:48          | 6062728177        | Copper      | 0.6       | 1.3          | ppm        |
| 012-182A E136 Drinking Fountain                 | 6/25/16 13:25         | 7/6/16 11:48         | 6062728177        | Lead        | 1         | 15           | ppb        |
| 012-183A E143 Sink Faucet                       | 6/25/16 13:27         | 7/8/16 8:48          | 6062728178        | Copper      | 0.6       | 1.3          | ppm        |
| <b>012-183A E143 Sink Faucet</b>                | <b>6/25/16 13:27</b>  | <b>7/6/16 11:49</b>  | <b>6062728178</b> | <b>Lead</b> | <b>21</b> | <b>15</b>    | <b>ppb</b> |
| 012-184A E149 Drinking Fountain                 | 6/25/16 13:30         | 7/8/16 8:48          | 6062728179        | Copper      | 0.8       | 1.3          | ppm        |
| 012-184A E149 Drinking Fountain                 | 6/25/16 13:30         | 7/6/16 11:49         | 6062728179        | Lead        | 1         | 15           | ppb        |
| 012-185A E148B Drinking Fountain                | 6/25/16 13:34         | 7/8/16 8:48          | 6062728180        | Copper      | 0.8       | 1.3          | ppm        |
| 012-185A E148B Drinking Fountain                | 6/25/16 13:34         | 7/6/16 11:49         | 6062728180        | Lead        | 7         | 15           | ppb        |
| 012-186A Wellness Center Sink Faucet            | 6/25/16 13:42         | 7/8/16 8:48          | 6062728181        | Copper      | 0.5       | 1.3          | ppm        |
| 012-186A Wellness Center Sink Faucet            | 6/25/16 13:42         | 7/6/16 11:49         | 6062728181        | Lead        | 0         | 15           | ppb        |
| 012-187A GD Wellness Center Sink Faucet (right) | 6/25/16 13:38         | 7/6/16 11:49         | 6062728182        | Copper      | 0.2       | 1.3          | ppm        |
| 012-187A GD Wellness Center Sink Faucet (right) | 6/25/16 13:38         | 7/6/16 11:49         | 6062728182        | Lead        | 0         | 15           | ppb        |
| 012-188A GD Wellness Center Sink Faucet (left)  | 6/25/16 13:38         | 7/6/16 11:49         | 6062728183        | Copper      | 0.2       | 1.3          | ppm        |
| 012-188A GD Wellness Center Sink Faucet (left)  | 6/25/16 13:38         | 7/6/16 11:49         | 6062728183        | Lead        | 1         | 15           | ppb        |
| 012-189A Wellness Exam 2 Sink Faucet            | 6/25/16 13:40         | 7/6/16 11:49         | 6062728184        | Copper      | 0.3       | 1.3          | ppm        |
| 012-189A Wellness Exam 2 Sink Faucet            | 6/25/16 13:40         | 7/6/16 11:49         | 6062728184        | Lead        | 1         | 15           | ppb        |
| 012-190A Wellness Exam 1 Sink Faucet            | 6/25/16 13:38         | 7/6/16 11:49         | 6062728185        | Copper      | 0.2       | 1.3          | ppm        |
| 012-190A Wellness Exam 1 Sink Faucet            | 6/25/16 13:38         | 7/6/16 11:49         | 6062728185        | Lead        | 1         | 15           | ppb        |
| 012-191A Boiler Room Sink Faucet (Mens Staff)   | 6/25/16 13:52         | 7/6/16 11:49         | 6062728186        | Copper      | 0.5       | 1.3          | ppm        |
| 012-191A Boiler Room Sink Faucet (Mens Staff)   | 6/25/16 13:52         | 7/6/16 11:49         | 6062728186        | Lead        | 4         | 15           | ppb        |
| 012-192A Boiler Room 129 Sink Faucet            | 6/25/16 13:48         | 7/6/16 11:49         | 6062728187        | Copper      | 0.2       | 1.3          | ppm        |
| 012-192A Boiler Room 129 Sink Faucet            | 6/25/16 13:48         | 7/6/16 11:49         | 6062728187        | Lead        | 7         | 15           | ppb        |
| 012-193A Girls Sink Faucet (left)               | 6/25/16 13:51         | 7/11/16 11:32        | 6062728188        | Copper      | 0.5       | 1.3          | ppm        |
| 012-193A Girls Sink Faucet (left)               | 6/25/16 13:51         | 7/6/16 11:49         | 6062728188        | Lead        | 3         | 15           | ppb        |
| 012-194A Girls Sink Faucet (left middle)        | 6/25/16 13:53         | 7/6/16 11:49         | 6062728189        | Copper      | 0.3       | 1.3          | ppm        |
| 012-194A Girls Sink Faucet (left middle)        | 6/25/16 13:53         | 7/6/16 11:49         | 6062728189        | Lead        | 1         | 15           | ppb        |
| 012-195A Girls Sink Faucet (right middle)       | 6/25/16 13:55         | 7/8/16 8:51          | 6062728190        | Copper      | 0.6       | 1.3          | ppm        |
| 012-195A Girls Sink Faucet (right middle)       | 6/25/16 13:55         | 7/6/16 11:50         | 6062728190        | Lead        | 1         | 15           | ppb        |
| 012-196A Girls Sink Faucet (right)              | 6/25/16 13:57         | 7/8/16 8:51          | 6062728191        | Copper      | 0.6       | 1.3          | ppm        |
| 012-196A Girls Sink Faucet (right)              | 6/25/16 13:57         | 7/6/16 11:50         | 6062728191        | Lead        | 2         | 15           | ppb        |
| 012-197A Girls Sink Faucet (single stall)       | 6/25/16 13:59         | 7/6/16 11:50         | 6062728192        | Copper      | 0.3       | 1.3          | ppm        |
| 012-197A Girls Sink Faucet (single stall)       | 6/25/16 13:59         | 7/6/16 11:50         | 6062728192        | Lead        | 8         | 15           | ppb        |
| 012-198A Boys Sink Faucet (right)               | 6/25/16 14:06         | 7/6/16 11:50         | 6062728193        | Copper      | 0.2       | 1.3          | ppm        |
| 012-198A Boys Sink Faucet (right)               | 6/25/16 14:06         | 7/6/16 11:50         | 6062728193        | Lead        | 2         | 15           | ppb        |
| 012-199A Boys Sink Faucet (right middle)        | 6/25/16 14:04         | 7/6/16 11:50         | 6062728194        | Copper      | 0.5       | 1.3          | ppm        |
| 012-199A Boys Sink Faucet (right middle)        | 6/25/16 14:04         | 7/6/16 11:50         | 6062728194        | Lead        | 1         | 15           | ppb        |
| 012-200A Boys Sink Faucet (left middle)         | 6/25/16 14:04         | 7/6/16 11:50         | 6062728195        | Copper      | 0.5       | 1.3          | ppm        |
| 012-200A Boys Sink Faucet (left middle)         | 6/25/16 14:04         | 7/6/16 11:50         | 6062728195        | Lead        | 2         | 15           | ppb        |
| 012-201A Boys Sink Faucet (left)                | 6/25/16 14:04         | 7/6/16 11:50         | 6062728196        | Copper      | 0.4       | 1.3          | ppm        |
| 012-201A Boys Sink Faucet (left)                | 6/25/16 14:04         | 7/6/16 11:50         | 6062728196        | Lead        | 2         | 15           | ppb        |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Benson High School

| Sample Identification # and Location              | Date & Time Collected | Date & Time Analyzed | Container ID | Analyte | Results | EPA          | Units |
|---------------------------------------------------|-----------------------|----------------------|--------------|---------|---------|--------------|-------|
|                                                   |                       |                      |              |         |         | Action Limit |       |
| 012-202A Bookkeeper Sink Faucet                   | 6/25/16 14:11         | 7/6/16 11:50         | 6062728197   | Copper  | 0.2     | 1.3          | ppm   |
| 012-202A Bookkeeper Sink Faucet                   | 6/25/16 14:11         | 7/6/16 11:50         | 6062728197   | Lead    | 16      | 15           | ppb   |
| 012-203A 5503 Sink Faucet                         | 6/25/16 14:11         | 7/6/16 11:50         | 6062728198   | Copper  | 0.4     | 1.3          | ppm   |
| 012-203A 5503 Sink Faucet                         | 6/25/16 14:11         | 7/6/16 11:50         | 6062728198   | Lead    | 3       | 15           | ppb   |
| 012-204A C102 Sink Faucet                         | 6/25/16 14:14         | 7/6/16 11:50         | 6062728199   | Copper  | 0.4     | 1.3          | ppm   |
| 012-204A C102 Sink Faucet                         | 6/25/16 14:14         | 7/6/16 11:50         | 6062728199   | Lead    | 1       | 15           | ppb   |
| 012-205A C109 Sink Faucet                         | 6/25/16 14:15         | 7/6/16 11:50         | 6062728200   | Copper  | 0.3     | 1.3          | ppm   |
| 012-205A C109 Sink Faucet                         | 6/25/16 14:15         | 7/6/16 11:50         | 6062728200   | Lead    | 11      | 15           | ppb   |
| 012-208A C112 Handwashing Station                 | 6/25/16 14:32         | 7/6/16 11:50         | 6062728201   | Copper  | 0.2     | 1.3          | ppm   |
| 012-208A C112 Handwashing Station                 | 6/25/16 14:32         | 7/6/16 11:50         | 6062728201   | Lead    | 6       | 15           | ppb   |
| 012-209A C112 Drinking Fountain                   | 6/25/16 14:41         | 7/8/16 8:51          | 6062728202   | Copper  | 1.0     | 1.3          | ppm   |
| 012-209A C112 Drinking Fountain                   | 6/25/16 14:41         | 7/6/16 11:50         | 6062728202   | Lead    | 0       | 15           | ppb   |
| 012-210A C122 Drinking Fountain                   | 6/25/16 14:43         | 7/8/16 8:51          | 6062728203   | Copper  | 0.7     | 1.3          | ppm   |
| 012-210A C122 Drinking Fountain                   | 6/25/16 14:43         | 7/6/16 11:50         | 6062728203   | Lead    | 0       | 15           | ppb   |
| 012-211A C122 Handwash Station                    | 6/25/16 14:49         | 7/6/16 11:51         | 6062728204   | Copper  | 0.3     | 1.3          | ppm   |
| 012-211A C122 Handwash Station                    | 6/25/16 14:49         | 7/6/16 11:51         | 6062728204   | Lead    | 1       | 15           | ppb   |
| 012-212A C127 Handwash Station                    | 6/25/16 14:48         | 7/8/16 8:52          | 6062728205   | Copper  | 0.6     | 1.3          | ppm   |
| 012-212A C127 Handwash Station                    | 6/25/16 14:48         | 7/6/16 11:51         | 6062728205   | Lead    | 2       | 15           | ppb   |
| 012-213A C127 Sink Faucet                         | 6/25/16 14:52         | 7/8/16 8:52          | 6062728206   | Copper  | 0.7     | 1.3          | ppm   |
| 012-213A C127 Sink Faucet                         | 6/25/16 14:52         | 7/6/16 11:51         | 6062728206   | Lead    | 1       | 15           | ppb   |
| 012-214A C134 Handwash Station                    | 6/25/16 14:41         | 7/6/16 11:51         | 6062728207   | Copper  | 0.4     | 1.3          | ppm   |
| 012-214A C134 Handwash Station                    | 6/25/16 14:41         | 7/6/16 11:51         | 6062728207   | Lead    | 2       | 15           | ppb   |
| 012-216A Staff Sink Faucet                        | 6/25/16 14:35         | 7/8/16 9:18          | 6062728208   | Copper  | 0.1     | 1.3          | ppm   |
| 012-216A Staff Sink Faucet                        | 6/25/16 14:35         | 7/8/16 9:18          | 6062728208   | Lead    | 10      | 15           | ppb   |
| 012-217A C138 Handwash Station                    | 6/25/16 14:24         | 7/8/16 9:18          | 6062728209   | Copper  | 1.0     | 1.3          | ppm   |
| 012-217A C138 Handwash Station                    | 6/25/16 14:24         | 7/8/16 9:18          | 6062728209   | Lead    | 3       | 15           | ppb   |
| 012-218A C138 Drinking Fountain                   | 6/25/16 14:34         | 7/8/16 9:18          | 6062728210   | Copper  | 0.2     | 1.3          | ppm   |
| 012-218A C138 Drinking Fountain                   | 6/25/16 14:34         | 7/8/16 9:18          | 6062728210   | Lead    | 12      | 15           | ppb   |
| 012-219A C139 Drinking Fountain                   | 6/25/16 14:28         | 7/8/16 9:18          | 6062728211   | Copper  | 0.9     | 1.3          | ppm   |
| 012-219A C139 Drinking Fountain                   | 6/25/16 14:28         | 7/8/16 9:18          | 6062728211   | Lead    | 0       | 15           | ppb   |
| 012-220A C149 Handwash Station                    | 6/25/16 14:18         | 7/8/16 9:18          | 6062728212   | Copper  | 1.0     | 1.3          | ppm   |
| 012-220A C149 Handwash Station                    | 6/25/16 14:18         | 7/8/16 9:18          | 6062728212   | Lead    | 3       | 15           | ppb   |
| 012-221A C149 Drinking Fountain                   | 6/25/16 14:15         | 7/8/16 18:04         | 6062728213   | Copper  | 1.0     | 1.3          | ppm   |
| 012-221A C149 Drinking Fountain                   | 6/25/16 14:15         | 7/8/16 18:04         | 6062728213   | Lead    | 0       | 15           | ppb   |
| 012-222A K2 Sink Faucet (on wall)                 | 6/25/16 15:09         | 7/8/16 18:05         | 6062728214   | Copper  | 0.4     | 1.3          | ppm   |
| 012-222A K2 Sink Faucet (on wall)                 | 6/25/16 15:09         | 7/8/16 18:05         | 6062728214   | Lead    | 7       | 15           | ppb   |
| 012-223A K2 Sink Faucet (serving counter)         | 6/25/16 15:08         | 7/8/16 18:08         | 6062728215   | Copper  | 0.2     | 1.3          | ppm   |
| 012-223A K2 Sink Faucet (serving counter)         | 6/25/16 15:08         | 7/8/16 18:08         | 6062728215   | Lead    | 5       | 15           | ppb   |
| 012-224A K2 Sink Faucet (hand wash)               | 6/25/16 15:07         | 7/8/16 18:08         | 6062728216   | Copper  | 0.6     | 1.3          | ppm   |
| 012-224A K2 Sink Faucet (hand wash)               | 6/25/16 15:07         | 7/8/16 18:08         | 6062728216   | Lead    | 4       | 15           | ppb   |
| 012-225A K10 Sink Faucet                          | 6/25/16 15:01         | 7/8/16 18:08         | 6062728217   | Copper  | 0.8     | 1.3          | ppm   |
| 012-225A K10 Sink Faucet                          | 6/25/16 15:01         | 7/8/16 18:08         | 6062728217   | Lead    | 1       | 15           | ppb   |
| 012-226A K9 Sink Faucet                           | 6/25/16 15:03         | 7/8/16 9:25          | 6062728218   | Copper  | 0.8     | 1.3          | ppm   |
| 012-226A K9 Sink Faucet                           | 6/25/16 15:03         | 7/8/16 9:25          | 6062728218   | Lead    | 1       | 15           | ppb   |
| 012-227A Kitchen Sink Faucet (food preparation)   | 6/25/16 14:53         | 7/8/16 9:25          | 6062728219   | Copper  | 0.4     | 1.3          | ppm   |
| 012-227A Kitchen Sink Faucet (food preparation)   | 6/25/16 14:53         | 7/8/16 9:25          | 6062728219   | Lead    | 2       | 15           | ppb   |
| 012-228A Kitchen Sink Faucet (handwash microwave) | 6/25/16 14:56         | 7/8/16 9:25          | 6062728220   | Copper  | 0.6     | 1.3          | ppm   |
| 012-228A Kitchen Sink Faucet (handwash microwave) | 6/25/16 14:56         | 7/8/16 9:25          | 6062728220   | Lead    | 4       | 15           | ppb   |
| 012-229A K8 Kitchen Sink Left Sprayer             | 6/25/16 14:57         | 7/8/16 9:25          | 6062728221   | Copper  | 0.5     | 1.3          | ppm   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Benson High School

| Sample Identification # and Location               | Date & Time Collected | Date & Time Analyzed | Container ID | Analyte | Results | EPA          | Units |
|----------------------------------------------------|-----------------------|----------------------|--------------|---------|---------|--------------|-------|
|                                                    |                       |                      |              |         |         | Action Limit |       |
| 012-229A K8 Kitchen Sink Left Sprayer              | 6/25/16 14:57         | 7/8/16 9:25          | 6062728221   | Lead    | 10      | 15           | ppb   |
| 012-230A K8 Kitchen Sink Faucet (Sanitize)         | 6/25/16 15:03         | 7/8/16 9:25          | 6062728222   | Copper  | 0.2     | 1.3          | ppm   |
| 012-230A K8 Kitchen Sink Faucet (Sanitize)         | 6/25/16 15:03         | 7/8/16 9:25          | 6062728222   | Lead    | 7       | 15           | ppb   |
| 012-231A K8 Kitchen Sink Faucet (Rinse)            | 6/25/16 15:05         | 7/8/16 9:25          | 6062728223   | Copper  | 0.4     | 1.3          | ppm   |
| 012-231A K8 Kitchen Sink Faucet (Rinse)            | 6/25/16 15:05         | 7/8/16 9:25          | 6062728223   | Lead    | 10      | 15           | ppb   |
| 012-232A K8 Wash Sink Faucet                       | 6/25/16 15:07         | 7/8/16 9:25          | 6062728224   | Copper  | 0.4     | 1.3          | ppm   |
| 012-232A K8 Wash Sink Faucet                       | 6/25/16 15:07         | 7/8/16 9:25          | 6062728224   | Lead    | 3       | 15           | ppb   |
| 012-233A Sink Faucet                               | 6/25/16 8:27          | 7/8/16 9:25          | 6062728225   | Copper  | 0.6     | 1.3          | ppm   |
| 012-233A Sink Faucet                               | 6/25/16 8:27          | 7/8/16 9:25          | 6062728225   | Lead    | 1       | 15           | ppb   |
| 012-234A Sink Faucet (left serving area)           | 6/25/16 15:14         | 7/8/16 9:25          | 6062728226   | Copper  | 0.6     | 1.3          | ppm   |
| 012-234A Sink Faucet (left serving area)           | 6/25/16 15:14         | 7/8/16 9:25          | 6062728226   | Lead    | 4       | 15           | ppb   |
| 012-235A Sink Faucet (right serving area)          | 6/25/16 14:49         | 7/8/16 9:25          | 6062728227   | Copper  | 0.7     | 1.3          | ppm   |
| 012-235A Sink Faucet (right serving area)          | 6/25/16 14:49         | 7/8/16 9:25          | 6062728227   | Lead    | 3       | 15           | ppb   |
| 012-236A Sink Faucet (handwash near exterior door) | 6/25/16 14:50         | 7/8/16 9:25          | 6062728228   | Copper  | 0.5     | 1.3          | ppm   |
| 012-236A Sink Faucet (handwash near exterior door) | 6/25/16 14:50         | 7/8/16 9:25          | 6062728228   | Lead    | 5       | 15           | ppb   |
| 012-237A Sink Faucet (handwash red bin)            | 6/25/16 14:54         | 7/8/16 9:25          | 6062728229   | Copper  | 0.4     | 1.3          | ppm   |
| 012-237A Sink Faucet (handwash red bin)            | 6/25/16 14:54         | 7/8/16 9:25          | 6062728229   | Lead    | 4       | 15           | ppb   |
| 012-238A Sink Faucet (food preparation near ovens) | 6/25/16 14:57         | 7/8/16 9:25          | 6062728230   | Copper  | 0.7     | 1.3          | ppm   |
| 012-238A Sink Faucet (food preparation near ovens) | 6/25/16 14:57         | 7/8/16 9:25          | 6062728230   | Lead    | 3       | 15           | ppb   |
| 012-239A K5 Sink Faucet                            | 6/25/16 14:49         | 7/8/16 9:25          | 6062728231   | Copper  | 0.3     | 1.3          | ppm   |
| 012-239A K5 Sink Faucet                            | 6/25/16 14:49         | 7/8/16 9:25          | 6062728231   | Lead    | 1       | 15           | ppb   |
| 012-240A Outside G8 Drinking Fountain              | 6/25/16 15:57         | 7/8/16 9:26          | 6062728232   | Copper  | 0.5     | 1.3          | ppm   |
| 012-240A Outside G8 Drinking Fountain              | 6/25/16 15:57         | 7/8/16 9:26          | 6062728232   | Lead    | 3       | 15           | ppb   |
| 012-241A Boys Locker Sink Faucet #1 (left)         | 6/25/16 15:58         | 7/8/16 9:26          | 6062728233   | Copper  | 0.2     | 1.3          | ppm   |
| 012-241A Boys Locker Sink Faucet #1 (left)         | 6/25/16 15:58         | 7/8/16 9:26          | 6062728233   | Lead    | 4       | 15           | ppb   |
| 012-242A Boys Locker Sink Faucet #2                | 6/25/16 16:01         | 7/8/16 9:26          | 6062728234   | Copper  | 0.6     | 1.3          | ppm   |
| 012-242A Boys Locker Sink Faucet #2                | 6/25/16 16:01         | 7/8/16 9:26          | 6062728234   | Lead    | 28      | 15           | ppb   |
| 012-243A Boys Locker Sink Faucet #3                | 6/25/16 15:00         | 7/8/16 9:26          | 6062728235   | Copper  | 0.5     | 1.3          | ppm   |
| 012-243A Boys Locker Sink Faucet #3                | 6/25/16 15:00         | 7/8/16 9:26          | 6062728235   | Lead    | 5       | 15           | ppb   |
| 012-244A Boys Locker Sink Faucet #4                | 6/25/16 15:00         | 7/8/16 9:26          | 6062728236   | Copper  | 0.3     | 1.3          | ppm   |
| 012-244A Boys Locker Sink Faucet #4                | 6/25/16 15:00         | 7/8/16 9:26          | 6062728236   | Lead    | 6       | 15           | ppb   |
| 012-245A Boys Locker Drinking Fountain             | 6/25/16 15:21         | 7/8/16 9:26          | 6062728237   | Copper  | 0.2     | 1.3          | ppm   |
| 012-245A Boys Locker Drinking Fountain             | 6/25/16 15:21         | 7/8/16 9:26          | 6062728237   | Lead    | 1       | 15           | ppb   |
| 012-246A Boys Locker Room Shower #1                | 6/25/16 15:03         | 7/8/16 9:26          | 6062728238   | Copper  | 1.4     | 1.3          | ppm   |
| 012-246A Boys Locker Room Shower #1                | 6/25/16 15:03         | 7/8/16 9:26          | 6062728238   | Lead    | 11      | 15           | ppb   |
| 012-247A Boys Locker Room Shower #2                | 6/25/16 15:14         | 7/8/16 9:26          | 6062728239   | Copper  | 1.7     | 1.3          | ppm   |
| 012-247A Boys Locker Room Shower #2                | 6/25/16 15:14         | 7/8/16 9:26          | 6062728239   | Lead    | 20      | 15           | ppb   |
| 012-248A Boys Locker Room Shower #3                | 6/25/16 15:15         | 7/8/16 9:26          | 6062728240   | Copper  | 1.2     | 1.3          | ppm   |
| 012-248A Boys Locker Room Shower #3                | 6/25/16 15:15         | 7/8/16 9:26          | 6062728240   | Lead    | 27      | 15           | ppb   |
| 012-249A Boys Locker Room Shower #4                | 6/25/16 15:17         | 7/8/16 9:26          | 6062728241   | Copper  | 1.4     | 1.3          | ppm   |
| 012-249A Boys Locker Room Shower #4                | 6/25/16 15:17         | 7/8/16 9:26          | 6062728241   | Lead    | 31      | 15           | ppb   |
| 012-250A Boys Locker Room Shower #5                | 6/25/16 15:19         | 7/8/16 9:26          | 6062728242   | Copper  | 1.4     | 1.3          | ppm   |
| 012-250A Boys Locker Room Shower #5                | 6/25/16 15:19         | 7/8/16 9:26          | 6062728242   | Lead    | 90      | 15           | ppb   |
| 012-251A Boys Locker Room Shower #6                | 6/25/16 15:21         | 7/8/16 9:26          | 6062728243   | Copper  | 0.7     | 1.3          | ppm   |
| 012-251A Boys Locker Room Shower #6                | 6/25/16 15:21         | 7/8/16 9:26          | 6062728243   | Lead    | 67      | 15           | ppb   |
| 012-252A Boys Locker Room Shower #7                | 6/25/16 15:24         | 7/8/16 9:26          | 6062728244   | Copper  | 1.1     | 1.3          | ppm   |
| 012-252A Boys Locker Room Shower #7                | 6/25/16 15:24         | 7/8/16 9:26          | 6062728244   | Lead    | 56      | 15           | ppb   |
| 012-253A Boys Locker Room Shower #8                | 6/25/16 15:26         | 7/8/16 9:26          | 6062728245   | Copper  | 0.5     | 1.3          | ppm   |
| 012-253A Boys Locker Room Shower #8                | 6/25/16 15:26         | 7/8/16 9:26          | 6062728245   | Lead    | 14.5    | 15           | ppb   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Benson High School

| Sample Identification # and Location | Date & Time Collected | Date & Time Analyzed | Container ID | Analyte | Results | EPA Action Limit | Units |
|--------------------------------------|-----------------------|----------------------|--------------|---------|---------|------------------|-------|
| 012-254A Boys Locker Room Shower #9  | 6/25/16 15:28         | 7/8/16 9:26          | 6062728246   | Copper  | 0.7     | 1.3              | ppm   |
| 012-254A Boys Locker Room Shower #9  | 6/25/16 15:28         | 7/8/16 9:26          | 6062728246   | Lead    | 40      | 15               | ppb   |
| 012-255A Boys Locker Room Shower #10 | 6/25/16 15:30         | 7/8/16 9:26          | 6062728247   | Copper  | 1.8     | 1.3              | ppm   |
| 012-255A Boys Locker Room Shower #10 | 6/25/16 15:30         | 7/8/16 9:26          | 6062728247   | Lead    | 159     | 15               | ppb   |
| 012-256A Boys Locker Room Shower #11 | 6/25/16 15:33         | 7/8/16 9:26          | 6062728248   | Copper  | 0.7     | 1.3              | ppm   |
| 012-256A Boys Locker Room Shower #11 | 6/25/16 15:33         | 7/8/16 9:26          | 6062728248   | Lead    | 47      | 15               | ppb   |
| 012-258A Boys Locker Room Shower #12 | 6/25/16 15:36         | 7/8/16 9:26          | 6062728249   | Copper  | 0.8     | 1.3              | ppm   |
| 012-258A Boys Locker Room Shower #12 | 6/25/16 15:36         | 7/8/16 9:26          | 6062728249   | Lead    | 83      | 15               | ppb   |
| 012-259A Boys Locker Room Shower #13 | 6/25/16 15:40         | 7/8/16 9:26          | 6062728250   | Copper  | 1.4     | 1.3              | ppm   |
| 012-259A Boys Locker Room Shower #13 | 6/25/16 15:40         | 7/8/16 9:26          | 6062728250   | Lead    | 56      | 15               | ppb   |
| 012-260A Boys Locker Room Shower #14 | 6/25/16 15:41         | 7/8/16 9:26          | 6062728251   | Copper  | 1.1     | 1.3              | ppm   |
| 012-260A Boys Locker Room Shower #14 | 6/25/16 15:41         | 7/8/16 9:26          | 6062728251   | Lead    | 36      | 15               | ppb   |
| 012-261A Boys Locker Room Shower #15 | 6/25/16 15:43         | 7/8/16 9:26          | 6062728252   | Copper  | 1.7     | 1.3              | ppm   |
| 012-261A Boys Locker Room Shower #15 | 6/25/16 15:43         | 7/8/16 9:26          | 6062728252   | Lead    | 50      | 15               | ppb   |
| 012-262A Boys Locker Room Shower #16 | 6/25/16 15:45         | 7/8/16 9:26          | 6062728253   | Copper  | 1.4     | 1.3              | ppm   |
| 012-262A Boys Locker Room Shower #16 | 6/25/16 15:45         | 7/8/16 9:26          | 6062728253   | Lead    | 27      | 15               | ppb   |
| 012-263A Boys Locker Room Shower #17 | 6/25/16 15:46         | 7/8/16 9:27          | 6062728254   | Copper  | 1.2     | 1.3              | ppm   |
| 012-263A Boys Locker Room Shower #17 | 6/25/16 15:46         | 7/8/16 9:27          | 6062728254   | Lead    | 21      | 15               | ppb   |
| 012-264A Boys Locker Room Shower #18 | 6/25/16 15:33         | 7/8/16 9:27          | 6062728255   | Copper  | 0.5     | 1.3              | ppm   |
| 012-264A Boys Locker Room Shower #18 | 6/25/16 15:33         | 7/8/16 9:27          | 6062728255   | Lead    | 12      | 15               | ppb   |
| 012-265A Boys Locker Room Shower #19 | 6/25/16 15:36         | 7/11/16 11:33        | 6062728256   | Copper  | 4.8     | 1.3              | ppm   |
| 012-265A Boys Locker Room Shower #19 | 6/25/16 15:36         | 7/8/16 9:27          | 6062728256   | Lead    | 81      | 15               | ppb   |
| 012-267A Boys Locker Room Shower #20 | 6/25/16 15:38         | 7/8/16 9:27          | 6062728257   | Copper  | 0.5     | 1.3              | ppm   |
| 012-267A Boys Locker Room Shower #20 | 6/25/16 15:38         | 7/8/16 9:27          | 6062728257   | Lead    | 11      | 15               | ppb   |
| 012-268A Boys Locker Room Shower #21 | 6/25/16 15:43         | 7/8/16 9:27          | 6062728258   | Copper  | 1.9     | 1.3              | ppm   |
| 012-268A Boys Locker Room Shower #21 | 6/25/16 15:43         | 7/8/16 9:27          | 6062728258   | Lead    | 157     | 15               | ppb   |
| 012-269A Boys Locker Room Shower #22 | 6/25/16 15:46         | 7/8/16 9:27          | 6062728259   | Copper  | 0.5     | 1.3              | ppm   |
| 012-269A Boys Locker Room Shower #22 | 6/25/16 15:46         | 7/8/16 9:27          | 6062728259   | Lead    | 45      | 15               | ppb   |
| 012-270A Boys Locker Room Shower #23 | 6/25/16 15:47         | 7/8/16 9:27          | 6062728260   | Copper  | 0.5     | 1.3              | ppm   |
| 012-270A Boys Locker Room Shower #23 | 6/25/16 15:47         | 7/8/16 9:27          | 6062728260   | Lead    | 29      | 15               | ppb   |
| 012-271A Boys Locker Room Shower #24 | 6/25/16 15:55         | 7/8/16 9:27          | 6062728261   | Copper  | 0.5     | 1.3              | ppm   |
| 012-271A Boys Locker Room Shower #24 | 6/25/16 15:55         | 7/8/16 9:27          | 6062728261   | Lead    | 49      | 15               | ppb   |
| 012-272A Boys Locker Room Shower #25 | 6/25/16 15:57         | 7/8/16 9:27          | 6062728262   | Copper  | 0.3     | 1.3              | ppm   |
| 012-272A Boys Locker Room Shower #25 | 6/25/16 15:57         | 7/8/16 9:27          | 6062728262   | Lead    | 3       | 15               | ppb   |
| 012-273A Boys Locker Room Shower #26 | 6/25/16 16:00         | 7/8/16 9:27          | 6062728263   | Copper  | 0.3     | 1.3              | ppm   |
| 012-273A Boys Locker Room Shower #26 | 6/25/16 16:00         | 7/8/16 9:27          | 6062728263   | Lead    | 38      | 15               | ppb   |
| 012-274A Boys Locker Room Shower #27 | 6/25/16 16:03         | 7/1/16 17:27         | 6062728264   | Copper  | 1.8     | 1.3              | ppm   |
| 012-274A Boys Locker Room Shower #27 | 6/25/16 16:03         | 7/1/16 17:27         | 6062728264   | Lead    | 29      | 15               | ppb   |
| 012-275A Boys Locker Room Shower #28 | 6/25/16 16:05         | 7/1/16 17:27         | 6062728265   | Copper  | 2.4     | 1.3              | ppm   |
| 012-275A Boys Locker Room Shower #28 | 6/25/16 16:05         | 7/1/16 17:27         | 6062728265   | Lead    | 28      | 15               | ppb   |
| 012-276A Boys Locker Room Shower #29 | 6/25/16 16:07         | 7/1/16 17:27         | 6062728266   | Copper  | 1.3     | 1.3              | ppm   |
| 012-276A Boys Locker Room Shower #29 | 6/25/16 16:07         | 7/1/16 17:27         | 6062728266   | Lead    | 11      | 15               | ppb   |
| 012-277A Boys Locker Room Shower #30 | 6/25/16 16:13         | 7/8/16 9:27          | 6062728267   | Copper  | 0.9     | 1.3              | ppm   |
| 012-277A Boys Locker Room Shower #30 | 6/25/16 16:13         | 7/8/16 9:27          | 6062728267   | Lead    | 33      | 15               | ppb   |
| 012-278A Boys Locker Room Shower #31 | 6/25/16 16:07         | 7/8/16 9:27          | 6062728268   | Copper  | 0.7     | 1.3              | ppm   |
| 012-278A Boys Locker Room Shower #31 | 6/25/16 16:07         | 7/8/16 9:27          | 6062728268   | Lead    | 6       | 15               | ppb   |
| 012-279A Boys Locker Room Shower #32 | 6/25/16 16:09         | 7/1/16 17:27         | 6062728269   | Copper  | 2.2     | 1.3              | ppm   |
| 012-279A Boys Locker Room Shower #32 | 6/25/16 16:09         | 7/1/16 17:27         | 6062728269   | Lead    | 22      | 15               | ppb   |
| 012-280A G18 Sink Faucet             | 6/25/16 15:24         | 7/1/16 17:27         | 6062728270   | Copper  | 1.1     | 1.3              | ppm   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Benson High School

| Sample Identification # and Location  | Date & Time Collected | Date & Time Analyzed | Container ID | Analyte | Results | EPA Action Limit | Units |
|---------------------------------------|-----------------------|----------------------|--------------|---------|---------|------------------|-------|
| 012-280A G18 Sink Faucet              | 6/25/16 15:24         | 7/1/16 17:27         | 6062728270   | Lead    | 38      | 15               | ppb   |
| 012-281A G17T Sink Faucet             | 6/25/16 15:26         | 7/8/16 9:27          | 6062728271   | Copper  | 0.1     | 1.3              | ppm   |
| 012-281A G17T Sink Faucet             | 6/25/16 15:26         | 7/8/16 9:27          | 6062728271   | Lead    | 6       | 15               | ppb   |
| 012-282A G17T Shower #1               | 6/25/16 15:28         | 7/8/16 9:27          | 6062728272   | Copper  | 0.3     | 1.3              | ppm   |
| 012-282A G17T Shower #1               | 6/25/16 15:28         | 7/8/16 9:27          | 6062728272   | Lead    | 2       | 15               | ppb   |
| 012-283A G17T Shower #2               | 6/25/16 15:29         | 7/8/16 10:28         | 6062728273   | Copper  | 0.2     | 1.3              | ppm   |
| 012-283A G17T Shower #2               | 6/25/16 15:29         | 7/8/16 10:28         | 6062728273   | Lead    | 1       | 15               | ppb   |
| 012-284A Outside G8 Drinking Fountain | 6/25/16 16:05         | 7/8/16 10:28         | 6062728274   | Copper  | 1.0     | 1.3              | ppm   |
| 012-284A Outside G8 Drinking Fountain | 6/25/16 16:05         | 7/8/16 10:28         | 6062728274   | Lead    | 4       | 15               | ppb   |
| 012-285A Training Room Sink Faucet    | 6/25/16 15:57         | 7/8/16 10:28         | 6062728275   | Copper  | 0.7     | 1.3              | ppm   |
| 012-285A Training Room Sink Faucet    | 6/25/16 15:57         | 7/8/16 10:28         | 6062728275   | Lead    | 5       | 15               | ppb   |
| 012-286A Men Only Drinking Fountain   | 6/25/16 16:18         | 7/8/16 10:28         | 6062728276   | Copper  | 0.2     | 1.3              | ppm   |
| 012-286A Men Only Drinking Fountain   | 6/25/16 16:18         | 7/8/16 10:28         | 6062728276   | Lead    | 3       | 15               | ppb   |
| 012-287A Team Room Showers #1         | 6/25/16 15:24         | 7/8/16 10:28         | 6062728277   | Copper  | 0.6     | 1.3              | ppm   |
| 012-287A Team Room Showers #1         | 6/25/16 15:24         | 7/8/16 10:28         | 6062728277   | Lead    | 6       | 15               | ppb   |
| 012-288A Team Room Showers #2         | 6/25/16 15:26         | 7/8/16 10:28         | 6062728278   | Copper  | 0.4     | 1.3              | ppm   |
| 012-288A Team Room Showers #2         | 6/25/16 15:26         | 7/8/16 10:28         | 6062728278   | Lead    | 53      | 15               | ppb   |
| 012-289A Team Room Showers #3         | 6/25/16 15:26         | 7/8/16 10:28         | 6062728279   | Copper  | 0.8     | 1.3              | ppm   |
| 012-289A Team Room Showers #3         | 6/25/16 15:26         | 7/8/16 10:28         | 6062728279   | Lead    | 82      | 15               | ppb   |
| 012-290A Team Room Showers #4         | 6/25/16 15:28         | 7/8/16 10:28         | 6062728280   | Copper  | 0.6     | 1.3              | ppm   |
| 012-290A Team Room Showers #4         | 6/25/16 15:28         | 7/8/16 10:28         | 6062728280   | Lead    | 165     | 15               | ppb   |
| 012-291A Team Room Showers #5         | 6/25/16 15:29         | 7/8/16 10:28         | 6062728281   | Copper  | 0.5     | 1.3              | ppm   |
| 012-291A Team Room Showers #5         | 6/25/16 15:29         | 7/8/16 10:28         | 6062728281   | Lead    | 224     | 15               | ppb   |
| 012-292A Team Room Showers #6         | 6/25/16 15:30         | 7/8/16 10:28         | 6062728282   | Copper  | 1.8     | 1.3              | ppm   |
| 012-292A Team Room Showers #6         | 6/25/16 15:30         | 7/8/16 10:28         | 6062728282   | Lead    | 267     | 15               | ppb   |
| 012-293A Team Room Showers #7         | 6/25/16 15:32         | 7/8/16 10:29         | 6062728283   | Copper  | 0.7     | 1.3              | ppm   |
| 012-293A Team Room Showers #7         | 6/25/16 15:32         | 7/8/16 10:29         | 6062728283   | Lead    | 101     | 15               | ppb   |
| 012-294A Team Room Showers #8         | 6/25/16 15:35         | 7/8/16 10:29         | 6062728284   | Copper  | 0.9     | 1.3              | ppm   |
| 012-294A Team Room Showers #8         | 6/25/16 15:35         | 7/8/16 10:29         | 6062728284   | Lead    | 78      | 15               | ppb   |
| 012-295A Team Room Showers #9         | 6/25/16 15:36         | 7/8/16 10:29         | 6062728285   | Copper  | 0.6     | 1.3              | ppm   |
| 012-295A Team Room Showers #9         | 6/25/16 15:36         | 7/8/16 10:29         | 6062728285   | Lead    | 77      | 15               | ppb   |
| 012-296A Team Room Showers #10        | 6/25/16 15:37         | 7/8/16 10:29         | 6062728286   | Copper  | 1.1     | 1.3              | ppm   |
| 012-296A Team Room Showers #10        | 6/25/16 15:37         | 7/8/16 10:29         | 6062728286   | Lead    | 148     | 15               | ppb   |
| 012-297A Team Room Showers #11        | 6/25/16 15:37         | 7/8/16 10:29         | 6062728287   | Copper  | 0.5     | 1.3              | ppm   |
| 012-297A Team Room Showers #11        | 6/25/16 15:37         | 7/8/16 10:29         | 6062728287   | Lead    | 75      | 15               | ppb   |
| 012-298A Team Room Showers #12        | 6/25/16 15:39         | 7/8/16 10:29         | 6062728288   | Copper  | 0.4     | 1.3              | ppm   |
| 012-298A Team Room Showers #12        | 6/25/16 15:39         | 7/8/16 10:29         | 6062728288   | Lead    | 51      | 15               | ppb   |
| 012-299A Team Room Showers #13        | 6/25/16 15:41         | 7/8/16 10:29         | 6062728289   | Copper  | 0.5     | 1.3              | ppm   |
| 012-299A Team Room Showers #13        | 6/25/16 15:41         | 7/8/16 10:29         | 6062728289   | Lead    | 73      | 15               | ppb   |
| 012-300A Team Room Showers #14        | 6/25/16 15:42         | 7/8/16 10:29         | 6062728290   | Copper  | 0.7     | 1.3              | ppm   |
| 012-300A Team Room Showers #14        | 6/25/16 15:42         | 7/8/16 10:29         | 6062728290   | Lead    | 164     | 15               | ppb   |
| 012-301A Team Room Showers #15        | 6/25/16 15:44         | 7/8/16 10:29         | 6062728291   | Copper  | 0.7     | 1.3              | ppm   |
| 012-301A Team Room Showers #15        | 6/25/16 15:44         | 7/8/16 10:29         | 6062728291   | Lead    | 88      | 15               | ppb   |
| 012-302A Team Room Showers #16        | 6/25/16 15:45         | 7/8/16 10:29         | 6062728292   | Copper  | 0.4     | 1.3              | ppm   |
| 012-302A Team Room Showers #16        | 6/25/16 15:45         | 7/8/16 10:29         | 6062728292   | Lead    | 78      | 15               | ppb   |
| 012-303A Team Room Showers #17        | 6/25/16 15:46         | 7/11/16 21:55        | 6062728293   | Copper  | 2.5     | 1.3              | ppm   |
| 012-303A Team Room Showers #17        | 6/25/16 15:46         | 7/8/16 10:29         | 6062728293   | Lead    | 383     | 15               | ppb   |
| 012-304A Team Room Showers #18        | 6/25/16 15:48         | 7/8/16 10:30         | 6062728294   | Copper  | 1.1     | 1.3              | ppm   |
| 012-304A Team Room Showers #18        | 6/25/16 15:48         | 7/8/16 10:30         | 6062728294   | Lead    | 142     | 15               | ppb   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Benson High School

| Sample Identification # and Location                | Date & Time Collected | Date & Time Analyzed | Container ID | Analyte | Results | EPA          | Units |
|-----------------------------------------------------|-----------------------|----------------------|--------------|---------|---------|--------------|-------|
|                                                     |                       |                      |              |         |         | Action Limit |       |
| 012-305A Team Room Showers #19                      | 6/25/16 15:49         | 7/8/16 10:30         | 6062728295   | Copper  | 0.5     | 1.3          | ppm   |
| 012-305A Team Room Showers #19                      | 6/25/16 15:49         | 7/8/16 10:30         | 6062728295   | Lead    | 51      | 15           | ppb   |
| 012-306A Team Room Showers #20                      | 6/25/16 15:50         | 7/8/16 10:30         | 6062728296   | Copper  | 1.1     | 1.3          | ppm   |
| 012-306A Team Room Showers #20                      | 6/25/16 15:50         | 7/8/16 10:30         | 6062728296   | Lead    | 141     | 15           | ppb   |
| 012-307A Team Room Showers #21                      | 6/25/16 15:52         | 7/8/16 10:30         | 6062728297   | Copper  | 0.9     | 1.3          | ppm   |
| 012-307A Team Room Showers #21                      | 6/25/16 15:52         | 7/8/16 10:30         | 6062728297   | Lead    | 43      | 15           | ppb   |
| 012-308A Team Room Showers #22                      | 6/25/16 15:54         | 7/8/16 10:30         | 6062728298   | Copper  | 0.5     | 1.3          | ppm   |
| 012-308A Team Room Showers #22                      | 6/25/16 15:54         | 7/8/16 10:30         | 6062728298   | Lead    | 33      | 15           | ppb   |
| 012-309A Team Room Showers #23                      | 6/25/16 15:55         | 7/8/16 10:30         | 6062728299   | Copper  | 0.7     | 1.3          | ppm   |
| 012-309A Team Room Showers #23                      | 6/25/16 15:55         | 7/8/16 10:30         | 6062728299   | Lead    | 35      | 15           | ppb   |
| 012-310A Team Room Sink Faucet (left)               | 6/25/16 15:24         | 7/8/16 10:30         | 6062728300   | Copper  | 0.1     | 1.3          | ppm   |
| 012-310A Team Room Sink Faucet (left)               | 6/25/16 15:24         | 7/8/16 10:30         | 6062728300   | Lead    | 4       | 15           | ppb   |
| 012-311A Team Room Sink Faucet (right)              | 6/25/16 15:27         | 7/8/16 10:30         | 6062728301   | Copper  | 0.1     | 1.3          | ppm   |
| 012-311A Team Room Sink Faucet (right)              | 6/25/16 15:27         | 7/8/16 10:30         | 6062728301   | Lead    | 3       | 15           | ppb   |
| 012-312A G26 Sink Faucet                            | 6/25/16 15:27         | 7/8/16 10:30         | 6062728302   | Copper  | 0.2     | 1.3          | ppm   |
| 012-312A G26 Sink Faucet                            | 6/25/16 15:27         | 7/8/16 10:30         | 6062728302   | Lead    | 12      | 15           | ppb   |
| 012-313A Girls Shower Room #1                       | 6/25/16 15:36         | 7/11/16 22:09        | 6062728303   | Copper  | 3.1     | 1.3          | ppm   |
| 012-313A Girls Shower Room #1                       | 6/25/16 15:36         | 7/8/16 10:30         | 6062728303   | Lead    | 207     | 15           | ppb   |
| 012-314A Girls Shower Room #2                       | 6/25/16 15:38         | 7/8/16 10:30         | 6062728304   | Copper  | 0.1     | 1.3          | ppm   |
| 012-314A Girls Shower Room #2                       | 6/25/16 15:38         | 7/8/16 10:30         | 6062728304   | Lead    | 1       | 15           | ppb   |
| 012-315A Boys Locker Room Wash/Dry Room Sink Faucet | 6/25/16 15:40         | 7/8/16 10:30         | 6062728305   | Copper  | 0.3     | 1.3          | ppm   |
| 012-315A Boys Locker Room Wash/Dry Room Sink Faucet | 6/25/16 15:40         | 7/8/16 10:30         | 6062728305   | Lead    | 9       | 15           | ppb   |
| 012-316A Girls Shower Room #3                       | 6/25/16 15:42         | 7/8/16 10:30         | 6062728306   | Copper  | 0.3     | 1.3          | ppm   |
| 012-316A Girls Shower Room #3                       | 6/25/16 15:42         | 7/8/16 10:30         | 6062728306   | Lead    | 2       | 15           | ppb   |
| 012-317A Girls Shower Room #4                       | 6/25/16 15:44         | 7/8/16 10:30         | 6062728307   | Copper  | 0.1     | 1.3          | ppm   |
| 012-317A Girls Shower Room #4                       | 6/25/16 15:44         | 7/8/16 10:30         | 6062728307   | Lead    | 1       | 15           | ppb   |
| 012-318A Girls Shower Room #5                       | 6/25/16 15:46         | 7/8/16 10:30         | 6062728308   | Copper  | 0.2     | 1.3          | ppm   |
| 012-318A Girls Shower Room #5                       | 6/25/16 15:46         | 7/8/16 10:30         | 6062728308   | Lead    | 5       | 15           | ppb   |
| 012-319A Girls Shower Room Drinking Fountain        | 6/25/16 15:32         | 7/8/16 10:30         | 6062728309   | Copper  | 0.7     | 1.3          | ppm   |
| 012-319A Girls Shower Room Drinking Fountain        | 6/25/16 15:32         | 7/8/16 10:30         | 6062728309   | Lead    | 1       | 15           | ppb   |
| 012-320A D107 Handwash Station                      | 6/25/16 16:35         | 7/8/16 10:30         | 6062728310   | Copper  | 0.4     | 1.3          | ppm   |
| 012-320A D107 Handwash Station                      | 6/25/16 16:35         | 7/8/16 10:30         | 6062728310   | Lead    | 5       | 15           | ppb   |
| 012-321A D107 Drinking Fountain                     | 6/25/16 16:34         | 7/6/16 10:01         | 6062728311   | Copper  | 18.0    | 1.3          | ppm   |
| 012-321A D107 Drinking Fountain                     | 6/25/16 16:34         | 7/1/16 17:27         | 6062728311   | Lead    | 87      | 15           | ppb   |
| 012-322A D104 Sink Faucet                           | 6/25/16 16:45         | 7/8/16 10:30         | 6062728312   | Copper  | 0.1     | 1.3          | ppm   |
| 012-322A D104 Sink Faucet                           | 6/25/16 16:45         | 7/8/16 10:30         | 6062728312   | Lead    | 10      | 15           | ppb   |
| 012-323A Handwash Station                           | 6/25/16 16:35         | 7/8/16 10:30         | 6062728313   | Copper  | 0.2     | 1.3          | ppm   |
| 012-323A Handwash Station                           | 6/25/16 16:35         | 7/8/16 10:30         | 6062728313   | Lead    | 5       | 15           | ppb   |
| 012-324A Drinking Fountain                          | 6/25/16 16:38         | 7/8/16 10:30         | 6062728314   | Copper  | 1.30    | 1.3          | ppm   |
| 012-324A Drinking Fountain                          | 6/25/16 16:38         | 7/8/16 10:30         | 6062728314   | Lead    | 24      | 15           | ppb   |
| 012-325A D113 Drinking Fountain                     | 6/25/16 16:40         | 7/8/16 10:31         | 6062728315   | Copper  | 0.9     | 1.3          | ppm   |
| 012-325A D113 Drinking Fountain                     | 6/25/16 16:40         | 7/8/16 10:31         | 6062728315   | Lead    | 2       | 15           | ppb   |
| 012-327A D121 Handwash Station                      | 6/25/16 16:24         | 7/8/16 10:31         | 6062728316   | Copper  | 0.3     | 1.3          | ppm   |
| 012-327A D121 Handwash Station                      | 6/25/16 16:24         | 7/8/16 10:31         | 6062728316   | Lead    | 1       | 15           | ppb   |
| 012-328A D121 Sink Faucet                           | 6/25/16 16:53         | 7/8/16 10:31         | 6062728317   | Copper  | 0.2     | 1.3          | ppm   |
| 012-328A D121 Sink Faucet                           | 6/25/16 16:53         | 7/8/16 10:31         | 6062728317   | Lead    | 11      | 15           | ppb   |
| 012-329A D130 Handwash Station                      | 6/25/16 16:43         | 7/8/16 10:31         | 6062728318   | Copper  | 0.3     | 1.3          | ppm   |
| 012-329A D130 Handwash Station                      | 6/25/16 16:43         | 7/8/16 10:31         | 6062728318   | Lead    | 5       | 15           | ppb   |
| 012-330A D130 Drinking Fountain                     | 6/25/16 16:43         | 7/1/16 17:27         | 6062728319   | Copper  | 3.5     | 1.3          | ppm   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Benson High School

| Sample Identification # and Location        | Date & Time Collected | Date & Time Analyzed | Container ID | Analyte | Results | EPA          | Units |
|---------------------------------------------|-----------------------|----------------------|--------------|---------|---------|--------------|-------|
|                                             |                       |                      |              |         |         | Action Limit |       |
| 012-330A D130 Drinking Fountain             | 6/25/16 16:43         | 7/1/16 17:27         | 6062728319   | Lead    | 14      | 15           | ppb   |
| 012-331A D130 Sink Faucet                   | 6/25/16 16:47         | 7/8/16 10:31         | 6062728320   | Copper  | 0.2     | 1.3          | ppm   |
| 012-331A D130 Sink Faucet                   | 6/25/16 16:47         | 7/8/16 10:31         | 6062728320   | Lead    | 2       | 15           | ppb   |
| 012-332A D140 Handwash Station              | 6/25/16 16:45         | 7/8/16 10:31         | 6062728321   | Copper  | 0.4     | 1.3          | ppm   |
| 012-332A D140 Handwash Station              | 6/25/16 16:45         | 7/8/16 10:31         | 6062728321   | Lead    | 23      | 15           | ppb   |
| 012-333A D140 Drinking Fountain             | 6/25/16 16:52         | 7/6/16 10:01         | 6062728322   | Copper  | 8.2     | 1.3          | ppm   |
| 012-333A D140 Drinking Fountain             | 6/25/16 16:52         | 7/1/16 17:28         | 6062728322   | Lead    | 21      | 15           | ppb   |
| 012-334A 23 Sink Faucet                     | 6/25/16 17:21         | 7/8/16 10:31         | 6062728323   | Copper  | 0.6     | 1.3          | ppm   |
| 012-334A 23 Sink Faucet                     | 6/25/16 17:21         | 7/8/16 10:31         | 6062728323   | Lead    | 0       | 15           | ppb   |
| 012-335A 22 Drinking Fountain               | 6/25/16 17:23         | 7/8/16 10:31         | 6062728324   | Copper  | 1.0     | 1.3          | ppm   |
| 012-335A 22 Drinking Fountain               | 6/25/16 17:23         | 7/8/16 10:31         | 6062728324   | Lead    | 0       | 15           | ppb   |
| 012-336A 24 Sink Faucet                     | 6/25/16 17:24         | 7/8/16 10:31         | 6062728325   | Copper  | 0.1     | 1.3          | ppm   |
| 012-336A 24 Sink Faucet                     | 6/25/16 17:24         | 7/8/16 10:31         | 6062728325   | Lead    | 2       | 15           | ppb   |
| 012-337A 2 Sink Faucet                      | 6/25/16 17:22         | 7/8/16 10:31         | 6062728326   | Copper  | 0.5     | 1.3          | ppm   |
| 012-337A 2 Sink Faucet                      | 6/25/16 17:22         | 7/8/16 10:31         | 6062728326   | Lead    | 1       | 15           | ppb   |
| 012-338A F204 Sink Faucet                   | 6/25/16 17:08         | 7/8/16 10:32         | 6062728327   | Copper  | 0.9     | 1.3          | ppm   |
| 012-338A F204 Sink Faucet                   | 6/25/16 17:08         | 7/8/16 10:32         | 6062728327   | Lead    | 13      | 15           | ppb   |
| 012-339A F205 Sink Faucet                   | 6/25/16 17:06         | 7/8/16 10:32         | 6062728328   | Copper  | 0.5     | 1.3          | ppm   |
| 012-339A F205 Sink Faucet                   | 6/25/16 17:06         | 7/8/16 10:32         | 6062728328   | Lead    | 20      | 15           | ppb   |
| 012-340A F201 Sink Faucet                   | 6/25/16 17:05         | 7/8/16 10:32         | 6062728329   | Copper  | 0.4     | 1.3          | ppm   |
| 012-340A F201 Sink Faucet                   | 6/25/16 17:05         | 7/8/16 10:32         | 6062728329   | Lead    | 18      | 15           | ppb   |
| 012-341A F202 Sink Faucet                   | 6/25/16 17:06         | 7/8/16 10:32         | 6062728330   | Copper  | 0.6     | 1.3          | ppm   |
| 012-341A F202 Sink Faucet                   | 6/25/16 17:06         | 7/8/16 10:32         | 6062728330   | Lead    | 12      | 15           | ppb   |
| 012-342A F210 Sink Faucet                   | 6/25/16 17:09         | 7/8/16 10:32         | 6062728331   | Copper  | 0.9     | 1.3          | ppm   |
| 012-342A F210 Sink Faucet                   | 6/25/16 17:09         | 7/8/16 10:32         | 6062728331   | Lead    | 11      | 15           | ppb   |
| 012-343A F206 Sink Faucet #1                | 6/25/16 17:09         | 7/8/16 10:32         | 6062728332   | Copper  | 0.6     | 1.3          | ppm   |
| 012-343A F206 Sink Faucet #1                | 6/25/16 17:09         | 7/8/16 10:32         | 6062728332   | Lead    | 6       | 15           | ppb   |
| 012-344A F206 Sink Faucet #2                | 6/25/16 17:11         | 7/8/16 10:32         | 6062728333   | Copper  | 1.0     | 1.3          | ppm   |
| 012-344A F206 Sink Faucet #2                | 6/25/16 17:11         | 7/8/16 10:32         | 6062728333   | Lead    | 5       | 15           | ppb   |
| 012-345A F206 Sink Faucet #3                | 6/25/16 17:13         | 7/8/16 10:32         | 6062728334   | Copper  | 1.1     | 1.3          | ppm   |
| 012-345A F206 Sink Faucet #3                | 6/25/16 17:13         | 7/8/16 10:32         | 6062728334   | Lead    | 11      | 15           | ppb   |
| 012-346A Drinking Fountain                  | 6/25/16 17:10         | 7/8/16 10:32         | 6062728335   | Copper  | 1.1     | 1.3          | ppm   |
| 012-346A Drinking Fountain                  | 6/25/16 17:10         | 7/8/16 10:32         | 6062728335   | Lead    | 8       | 15           | ppb   |
| 012-347A F212 Sink Faucet                   | 6/25/16 17:13         | 7/8/16 10:58         | 6062728336   | Copper  | 1.0     | 1.3          | ppm   |
| 012-347A F212 Sink Faucet                   | 6/25/16 17:13         | 7/8/16 10:58         | 6062728336   | Lead    | 7       | 15           | ppb   |
| 012-348A F211 Sink Faucet                   | 6/25/16 17:15         | 7/8/16 10:58         | 6062728337   | Copper  | 1.1     | 1.3          | ppm   |
| 012-348A F211 Sink Faucet                   | 6/25/16 17:15         | 7/8/16 10:58         | 6062728337   | Lead    | 4       | 15           | ppb   |
| 012-349A F209 Sink Faucet                   | 6/25/16 17:11         | 7/8/16 10:58         | 6062728338   | Copper  | 0.8     | 1.3          | ppm   |
| 012-349A F209 Sink Faucet                   | 6/25/16 17:11         | 7/8/16 10:58         | 6062728338   | Lead    | 7       | 15           | ppb   |
| 012-350A Drinking Fountain outside Elevator | 6/25/16 16:54         | 7/8/16 10:58         | 6062728339   | Copper  | 0.7     | 1.3          | ppm   |
| 012-350A Drinking Fountain outside Elevator | 6/25/16 16:54         | 7/8/16 10:58         | 6062728339   | Lead    | 11      | 15           | ppb   |
| 012-351A Girls Sink Faucet                  | 6/25/16 17:00         | 7/8/16 10:58         | 6062728340   | Copper  | 0.3     | 1.3          | ppm   |
| 012-351A Girls Sink Faucet                  | 6/25/16 17:00         | 7/8/16 10:58         | 6062728340   | Lead    | 7       | 15           | ppb   |
| 012-352A Boys Sink Faucet #1                | 6/25/16 17:00         | 7/8/16 10:58         | 6062728341   | Copper  | 0.5     | 1.3          | ppm   |
| 012-352A Boys Sink Faucet #1                | 6/25/16 17:00         | 7/8/16 10:58         | 6062728341   | Lead    | 7       | 15           | ppb   |
| 012-353A Boys Sink Faucet #2                | 6/25/16 17:05         | 7/1/16 17:28         | 6062728342   | Copper  | 2.6     | 1.3          | ppm   |
| 012-353A Boys Sink Faucet #2                | 6/25/16 17:05         | 7/1/16 17:28         | 6062728342   | Lead    | 83      | 15           | ppb   |
| 012-354A Slop Sink Faucet                   | 6/25/16 16:59         | 7/8/16 10:58         | 6062728343   | Copper  | 1.0     | 1.3          | ppm   |
| 012-354A Slop Sink Faucet                   | 6/25/16 16:59         | 7/8/16 10:58         | 6062728343   | Lead    | 36      | 15           | ppb   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Benson High School

| Sample Identification # and Location      | Date & Time Collected | Date & Time Analyzed | Container ID | Analyte | Results | EPA          |       |
|-------------------------------------------|-----------------------|----------------------|--------------|---------|---------|--------------|-------|
|                                           |                       |                      |              |         |         | Action Limit | Units |
| 012-355A Water Spigot                     | 6/25/16 17:21         | 7/8/16 10:58         | 6062728344   | Copper  | 0.3     | 1.3          | ppm   |
| 012-355A Water Spigot                     | 6/25/16 17:21         | 7/8/16 10:58         | 6062728344   | Lead    | 64      | 15           | ppb   |
| 012-356A Incinerator Room Water Spigot    | 6/25/16 17:40         | 7/8/16 10:58         | 6062728345   | Copper  | 0.1     | 1.3          | ppm   |
| 012-356A Incinerator Room Water Spigot    | 6/25/16 17:40         | 7/8/16 10:58         | 6062728345   | Lead    | 1       | 15           | ppb   |
| 012-357A Water Spigot by Field            | 6/25/16 16:49         | 7/8/16 10:58         | 6062728346   | Copper  | 1.5     | 1.3          | ppm   |
| 012-357A Water Spigot by Field            | 6/25/16 16:49         | 7/8/16 10:58         | 6062728346   | Lead    | 57      | 15           | ppb   |
| 012-358A Water Spigot #1                  | 6/25/16 16:51         | 7/8/16 11:04         | 6062728347   | Copper  | 0.0     | 1.3          | ppm   |
| 012-358A Water Spigot #1                  | 6/25/16 16:51         | 7/8/16 11:04         | 6062728347   | Lead    | 12      | 15           | ppb   |
| 012-359A Water Spigot #2                  | 6/25/16 16:52         | 7/8/16 11:04         | 6062728348   | Copper  | 0.0     | 1.3          | ppm   |
| 012-359A Water Spigot #2                  | 6/25/16 16:52         | 7/8/16 11:04         | 6062728348   | Lead    | 1       | 15           | ppb   |
| 012-360A Water Spigot #3                  | 6/25/16 16:55         | 7/8/16 11:04         | 6062728349   | Copper  | 0.2     | 1.3          | ppm   |
| 012-360A Water Spigot #3                  | 6/25/16 16:55         | 7/8/16 11:04         | 6062728349   | Lead    | 86      | 15           | ppb   |
| 012-361A Water Spigot #4                  | 6/25/16 16:57         | 7/8/16 11:04         | 6062728350   | Copper  | 0.1     | 1.3          | ppm   |
| 012-361A Water Spigot #4                  | 6/25/16 16:57         | 7/8/16 11:04         | 6062728350   | Lead    | 37      | 15           | ppb   |
| 012-362A Water Spigot #5                  | 6/25/16 16:59         | 7/8/16 11:04         | 6062728351   | Copper  | 0.1     | 1.3          | ppm   |
| 012-362A Water Spigot #5                  | 6/25/16 16:59         | 7/8/16 11:04         | 6062728351   | Lead    | 6       | 15           | ppb   |
| 012-363A Water Spigot #6                  | 6/25/16 17:02         | 7/8/16 11:04         | 6062728352   | Copper  | 0.0     | 1.3          | ppm   |
| 012-363A Water Spigot #6                  | 6/25/16 17:02         | 7/8/16 11:04         | 6062728352   | Lead    | 4       | 15           | ppb   |
| 012-364A Boiler Room Bathroom Sink Faucet | 6/25/16 17:32         | 7/8/16 11:04         | 6062728353   | Copper  | 0.1     | 1.3          | ppm   |
| 012-364A Boiler Room Bathroom Sink Faucet | 6/25/16 17:32         | 7/8/16 11:04         | 6062728353   | Lead    | 1       | 15           | ppb   |
| 012-365A Boiler Room Drinking Fountain    | 6/25/16 17:29         | 7/8/16 11:04         | 6062728354   | Copper  | ND      | 1.3          | ppm   |
| 012-365A Boiler Room Drinking Fountain    | 6/25/16 17:29         | 7/8/16 11:04         | 6062728354   | Lead    | ND      | 15           | ppb   |
| 012-366A Boiler Locker Room Sink Faucet   | 6/25/16 17:32         | 7/8/16 11:05         | 6062728355   | Copper  | 0.2     | 1.3          | ppm   |
| 012-366A Boiler Locker Room Sink Faucet   | 6/25/16 17:32         | 7/8/16 11:05         | 6062728355   | Lead    | 1       | 15           | ppb   |
| 012-367A Boiler Room Water Spigot #1      | 6/25/16 17:34         | 7/9/16 15:53         | 6062728356   | Copper  | 0.6     | 1.3          | ppm   |
| 012-367A Boiler Room Water Spigot #1      | 6/25/16 17:34         | 7/9/16 15:53         | 6062728356   | Lead    | 82      | 15           | ppb   |
| 012-368A Boiler Room Water Spigot #2      | 6/25/16 17:27         | 7/8/16 11:05         | 6062728357   | Copper  | 0.1     | 1.3          | ppm   |
| 012-368A Boiler Room Water Spigot #2      | 6/25/16 17:27         | 7/8/16 11:05         | 6062728357   | Lead    | 2       | 15           | ppb   |
| 012-369A Boiler Room Water Spigot #3      | 6/25/16 17:39         | 7/9/16 15:53         | 6062728358   | Copper  | 0.1     | 1.3          | ppm   |
| 012-369A Boiler Room Water Spigot #3      | 6/25/16 17:39         | 7/9/16 15:53         | 6062728358   | Lead    | 42      | 15           | ppb   |
| 012-370A Training Room Ice                | 6/25/16 16:10         | 7/9/16 15:53         | 6062728359   | Copper  | 0.0     | 1.3          | ppm   |
| 012-370A Training Room Ice                | 6/25/16 16:10         | 7/11/16 11:17        | 6062728359   | Lead    | ND      | 15           | ppb   |

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

ND = Non detect

Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.