

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Beverly Cleary School at Hollyrood Campus

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
015-01A Boiler Room-Sink Faucet	6/21/2016 20:14	6/28/2016 11:47	10353237001	Copper	0.2	1.3	ppm
015-01A Boiler Room-Sink Faucet	6/21/2016 20:14	6/28/2016 11:47	10353237001	Lead	23	15	ppb
015-02A Custodial Room 16-Sink Faucet	6/21/2016 20:17	6/28/2016 12:03	10353237003	Copper	0.0	1.3	ppm
015-02A Custodial Room 16-Sink Faucet	6/21/2016 20:17	6/28/2016 12:03	10353237003	Lead	4	15	ppb
015-03A Girls Sink Faucet (1)	6/21/2016 20:20	6/30/2016 12:17	10353237005	Copper	0.0	1.3	ppm
015-03A Girls Sink Faucet (1)	6/21/2016 20:20	6/30/2016 12:17	10353237005	Lead	4	15	ppb
015-04A Girls Sink Faucet (2)	6/21/2016 20:20	6/30/2016 12:26	10353237007	Copper	0.1	1.3	ppm
015-04A Girls Sink Faucet (2)	6/21/2016 20:20	6/30/2016 12:26	10353237007	Lead	6	15	ppb
015-05A Mens/Womens Restroom	6/21/2016 20:23	6/28/2016 17:14	10353237009	Copper	0.5	1.3	ppm
015-05A Mens/Womens Restroom	6/21/2016 20:23	6/28/2016 12:23	10353237009	Lead	2	15	ppb
015-06A Faculty Bathroom	6/21/2016 20:25	6/28/2016 12:29	10353237011	Copper	0.0	1.3	ppm
015-06A Faculty Bathroom	6/21/2016 20:25	6/28/2016 12:29	10353237011	Lead	12	15	ppb
015-07A Room 4-Sink Faucet	6/21/2016 20:28	6/28/2016 12:36	10353237013	Copper	0.1	1.3	ppm
015-07A Room 4-Sink Faucet	6/21/2016 20:28	6/28/2016 12:36	10353237013	Lead	2	15	ppb
015-08A Boys Sink Faucet (1)	6/21/2016 20:31	6/28/2016 12:42	10353237015	Copper	0.3	1.3	ppm
015-08A Boys Sink Faucet (1)	6/21/2016 20:31	6/28/2016 12:42	10353237015	Lead	4	15	ppb
015-09A Boys Sink Faucet (2)	6/21/2016 20:31	6/28/2016 12:55	10353237017	Copper	0.2	1.3	ppm
015-09A Boys Sink Faucet (2)	6/21/2016 20:31	6/28/2016 12:55	10353237017	Lead	3	15	ppb
015-10A Room 10 Sink Faucet	6/21/2016 20:34	6/28/2016 13:02	10353237019	Copper	0.1	1.3	ppm
015-10A Room 10 Sink Faucet	6/21/2016 20:34	6/28/2016 13:02	10353237019	Lead	13	15	ppb
015-11A Room 7 Sink Faucet	6/21/2016 20:37	6/28/2016 13:18	10353237021	Copper	0.1	1.3	ppm
015-11A Room 7 Sink Faucet	6/21/2016 20:37	6/28/2016 13:18	10353237021	Lead	3	15	ppb
015-12A Room 7 Drinking Fountain	6/21/2016 20:37	6/28/2016 13:37	10353237023	Copper	0.0	1.3	ppm
015-12A Room 7 Drinking Fountain	6/21/2016 20:37	6/28/2016 13:37	10353237023	Lead	8	15	ppb
015-13A Room 8 Sink Faucet (1)	6/21/2016 20:40	6/28/2016 13:44	10353237025	Copper	0.1	1.3	ppm
015-13A Room 8 Sink Faucet (1)	6/21/2016 20:40	6/28/2016 13:44	10353237025	Lead	2	15	ppb
015-14A Room 8 Drinking Fountain	6/21/2016 20:40	6/30/2016 12:29	10353237027	Copper	0.2	1.3	ppm
015-14A Room 8 Drinking Fountain	6/21/2016 20:40	6/30/2016 12:29	10353237027	Lead	5	15	ppb
015-15A Room 8 Sink Faucet (2)	6/21/2016 20:44	6/28/2016 13:54	10353237029	Copper	0.2	1.3	ppm
015-15A Room 8 Sink Faucet (2)	6/21/2016 20:44	6/28/2016 13:54	10353237029	Lead	29	15	ppb
015-16A Room 17 Sink Faucet	6/21/2016 20:49	6/28/2016 14:00	10353237031	Copper	0.1	1.3	ppm
015-16A Room 17 Sink Faucet	6/21/2016 20:49	6/28/2016 14:00	10353237031	Lead	8	15	ppb
015-17A Room 17 Drinking Fountain	6/21/2016 20:49	6/28/2016 14:13	10353237033	Copper	0.1	1.3	ppm
015-17A Room 17 Drinking Fountain	6/21/2016 20:49	6/28/2016 14:13	10353237033	Lead	3	15	ppb
015-18A Room 3 Sink Faucet	6/21/2016 20:52	6/30/2016 12:31	10353237035	Copper	0.1	1.3	ppm
015-18A Room 3 Sink Faucet	6/21/2016 20:52	6/30/2016 12:31	10353237035	Lead	6	15	ppb
015-19A Room 3 Drinking Fountain	6/21/2016 20:52	6/28/2016 14:23	10353237037	Copper	0.0	1.3	ppm
015-19A Room 3 Drinking Fountain	6/21/2016 20:52	6/28/2016 14:23	10353237037	Lead	4	15	ppb
015-20A Room 2 Sink Faucet	6/21/2016 20:55	6/30/2016 12:32	10353237039	Copper	0.3	1.3	ppm
015-20A Room 2 Sink Faucet	6/21/2016 20:55	6/30/2016 12:32	10353237039	Lead	16	15	ppb
015-21A Room 18 Sink Faucet	6/21/2016 20:58	6/28/2016 10:06	10353237041	Copper	0.1	1.3	ppm
015-21A Room 18 Sink Faucet	6/21/2016 20:58	6/28/2016 10:06	10353237041	Lead	7	15	ppb
015-22A Room 1 Sink Faucet	6/21/2016 21:01	6/28/2016 10:29	10353237043	Copper	0.2	1.3	ppm
015-22A Room 1 Sink Faucet	6/21/2016 21:01	6/28/2016 10:29	10353237043	Lead	22	15	ppb
015-23A Room-Bathroom Sink Faucet	6/21/2016 21:03	6/28/2016 10:36	10353237045	Copper	0.1	1.3	ppm
015-23A Room-Bathroom Sink Faucet	6/21/2016 21:03	6/28/2016 10:36	10353237045	Lead	7	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Beverly Cleary School at Hollyrood Campus

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
015-24A Room 19-Sink Faucet	6/21/2016 21:06	6/28/2016 10:39	10353237047	Copper	0.0	1.3	ppm
015-24A Room 19-Sink Faucet	6/21/2016 21:06	6/28/2016 10:39	10353237047	Lead	5	15	ppb
015-25A Room 19 Drinking Fountain	6/21/2016 21:06	6/28/2016 10:59	10353237049	Copper	0.0	1.3	ppm
015-25A Room 19 Drinking Fountain	6/21/2016 21:06	6/28/2016 10:59	10353237049	Lead	2	15	ppb
015-26A Outside-Water Spigot (1)	6/21/2016 21:22	6/28/2016 11:05	10353237051	Copper	0.0	1.3	ppm
015-26A Outside-Water Spigot (1)	6/21/2016 21:22	6/28/2016 11:05	10353237051	Lead	14	15	ppb
015-27A Outside-Water Spigot (2)	6/21/2016 21:20	6/28/2016 11:11	10353237053	Copper	0.0	1.3	ppm
015-27A Outside-Water Spigot (2)	6/21/2016 21:20	6/28/2016 11:11	10353237053	Lead	14	15	ppb
015-28A Outside-Water Spigot (3)	6/21/2016 21:16	6/28/2016 11:18	10353237055	Copper	0.0	1.3	ppm
015-28A Outside-Water Spigot (3)	6/21/2016 21:16	6/28/2016 11:18	10353237055	Lead	262	15	ppb
015-29A Outside-Water Spigot (3)	6/21/2016 21:13	6/28/2016 11:24	10353237057	Copper	0.0	1.3	ppm
015-29A Outside-Water Spigot (3)	6/21/2016 21:13	6/28/2016 11:24	10353237057	Lead	2	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.