

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Beverly Cleary at Fernwood MS

Sample Identification # and Location		Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
014-01A	Boiler Room Janitors Sink Faucet	6/21/16 22:12	7/18/2016	1606D94-01A	Copper	0.7	1.3	ppm
014-01A	Boiler Room Janitors Sink Faucet	6/21/16 22:12	7/18/2016	1606D94-01A	Lead	2	15	ppb
014-02A	Boiler Room Can Wash Sink Faucet	6/21/16 22:15	7/18/2016	1606D94-02A	Copper	0.6	1.3	ppm
014-02A	Boiler Room Can Wash Sink Faucet	6/21/16 22:15	7/18/2016	1606D94-02A	Lead	1	15	ppb
014-03A	Basement Boys Bathroom Sink Faucet Sprayer	6/21/16 22:29	7/18/2016	1606D94-03A	Copper	0.2	1.3	ppm
014-03A	Basement Boys Bathroom Sink Faucet Sprayer	6/21/16 22:29	7/18/2016	1606D94-03A	Lead	2	15	ppb
014-04A	Basement Boys Bathroom Sink Faucet Sprayer	6/21/16 22:29	7/18/2016	1606D94-04A	Copper	0.2	1.3	ppm
014-04A	Basement Boys Bathroom Sink Faucet Sprayer	6/21/16 22:29	7/18/2016	1606D94-04A	Lead	ND	15	ppb
014-05A	Basement Janitors Sink Faucet	6/21/16 22:32	7/18/2016	1606D94-05A	Copper	0.4	1.3	ppm
014-05A	Basement Janitors Sink Faucet	6/21/16 22:32	7/18/2016	1606D94-05A	Lead	11	15	ppb
014-06A	Basement Girls Bathroom Sink Faucet Sprayer	6/21/16 22:20	7/18/2016	1606D94-06A	Copper	0.6	1.3	ppm
014-06A	Basement Girls Bathroom Sink Faucet Sprayer	6/21/16 22:20	7/18/2016	1606D94-06A	Lead	6	15	ppb
014-07A	Girls Bathroom Sink Faucet Sprayer	6/21/16 22:20	7/18/2016	1606D94-07A	Copper	0.4	1.3	ppm
014-07A	Girls Bathroom Sink Faucet Sprayer	6/21/16 22:20	7/18/2016	1606D94-07A	Lead	3	15	ppb
014-08A	Basement Room 7 Sink Faucet	6/21/16 22:25	7/18/2016	1606D94-08A	Copper	1.4	1.3	ppm
014-08A	Basement Room 7 Sink Faucet	6/21/16 22:25	7/18/2016	1606D94-08A	Lead	6	15	ppb
014-09A	Room 126 Sink Faucet	6/21/16 22:37	7/18/2016	1606D94-09A	Copper	1.32	1.3	ppm
014-09A	Room 126 Sink Faucet	6/21/16 22:37	7/18/2016	1606D94-09A	Lead	13	15	ppb
014-10A	Hall Drinking Fountain by Elevator	6/21/16 22:41	7/18/2016	1606D94-10A	Copper	0.9	1.3	ppm
014-10A	Hall Drinking Fountain by Elevator	6/21/16 22:41	7/18/2016	1606D94-10A	Lead	2	15	ppb
014-11A	Girls Bathroom 143 Sink Faucet 1	6/21/16 22:47	7/18/2016	1606D94-11A	Copper	0.4	1.3	ppm
014-11A	Girls Bathroom 143 Sink Faucet 1	6/21/16 22:47	7/18/2016	1606D94-11A	Lead	3	15	ppb
014-12A	Girls Bathroom 143 Sink Faucet 2	6/21/16 22:47	7/18/2016	1606D94-12A	Copper	0.6	1.3	ppm
014-12A	Girls Bathroom 143 Sink Faucet 2	6/21/16 22:47	7/18/2016	1606D94-12A	Lead	3	15	ppb
014-13A	Girls Bathroom 143 Water Spigot 1	6/21/16 22:50	7/18/2016	1606D94-13A	Copper	0.3	1.3	ppm
014-13A	Girls Bathroom 143 Water Spigot 1	6/21/16 22:50	7/18/2016	1606D94-13A	Lead	34	15	ppb
014-14A	Campfire Room Sink Faucet 1	6/21/16 22:53	7/18/2016	1606D94-14A	Copper	0.8	1.3	ppm
014-14A	Campfire Room Sink Faucet 1	6/21/16 22:53	7/18/2016	1606D94-14A	Lead	5	15	ppb
014-15A	Campfire Room Water Spigot 1	6/21/16 22:55	7/18/2016	1606D94-15A	Copper	0.5	1.3	ppm
014-15A	Campfire Room Water Spigot 1	6/21/16 22:55	7/18/2016	1606D94-15A	Lead	8	15	ppb
014-16A	Campfire Room Water Spigot 2	6/21/16 22:57	7/15/2016	1606D94-16A	Copper	1.6	1.3	ppm
014-16A	Campfire Room Water Spigot 2	6/21/16 22:57	7/15/2016	1606D94-16A	Lead	900	15	ppb
014-17A	Campfire Room Shower 1	6/21/16 23:00	7/15/2016	1606D94-17A	Copper	11.7	1.3	ppm
014-17A	Campfire Room Shower 1	6/21/16 23:00	7/15/2016	1606D94-17A	Lead	820	15	ppb
014-18A	Campfire Room Shower 2	6/21/16 23:02	7/15/2016	1606D94-18A	Copper	7.9	1.3	ppm
014-18A	Campfire Room Shower 2	6/21/16 23:02	7/15/2016	1606D94-18A	Lead	620	15	ppb
014-19A	Gymnasium East Drinking Fountain	6/21/16 23:06	7/18/2016	1606D94-19A	Copper	0.5	1.3	ppm
014-19A	Gymnasium East Drinking Fountain	6/21/16 23:06	7/18/2016	1606D94-19A	Lead	2	15	ppb
014-20A	Gymnasium West Drinking Fountain	6/21/16 23:09	7/18/2016	1606D94-20A	Copper	0.9	1.3	ppm
014-20A	Gymnasium West Drinking Fountain	6/21/16 23:09	7/18/2016	1606D94-20A	Lead	2	15	ppb
014-21A	Boys Bathroom Locker Sink Faucet	6/21/16 23:14	7/19/2016	1606D94-21A	Copper	1.4	1.3	ppm
014-21A	Boys Bathroom Locker Sink Faucet	6/21/16 23:14	7/19/2016	1606D94-21A	Lead	7	15	ppb
014-22A	Boys Bathroom Locker Water Spigot	6/21/16 23:16	7/19/2016	1606D94-22A	Copper	1.2	1.3	ppm
014-22A	Boys Bathroom Locker Water Spigot	6/21/16 23:16	7/19/2016	1606D94-22A	Lead	690	15	ppb
014-23A	Boys Bathroom 142 Sink Faucet	6/21/16 23:20	7/19/2016	1606D94-23A	Copper	0.6	1.3	ppm
014-23A	Boys Bathroom 142 Sink Faucet	6/21/16 23:20	7/19/2016	1606D94-23A	Lead	2	15	ppb
014-24A	Boys Bathroom 142 Water Spigot	6/21/16 23:22	7/19/2016	1606D94-24A	Copper	0.5	1.3	ppm
014-24A	Boys Bathroom 142 Water Spigot	6/21/16 23:22	7/19/2016	1606D94-24A	Lead	160	15	ppb
014-25A	IndustrialEducation Sink Faucet	6/21/16 23:25	7/19/2016	1606D94-25A	Copper	0.4	1.3	ppm
014-25A	IndustrialEducation Sink Faucet	6/21/16 23:25	7/19/2016	1606D94-25A	Lead	4	15	ppb
014-26A	IndustrialEducation Drinking Fountain	6/21/16 23:27	7/19/2016	1606D94-26A	Copper	0.4	1.3	ppm
014-26A	IndustrialEducation Drinking Fountain	6/21/16 23:27	7/19/2016	1606D94-26A	Lead	4	15	ppb
014-27A	Industrial Education Sink Faucet	6/21/16 23:30	7/19/2016	1606D94-27A	Copper	0.4	1.3	ppm
014-27A	Industrial Education Sink Faucet	6/21/16 23:30	7/19/2016	1606D94-27A	Lead	3	15	ppb
014-28A	Industrial Education Drinking Fountain	6/21/16 23:32	7/19/2016	1606D94-28A	Copper	0.6	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Beverly Cleary at Fernwood MS

014-28A	Industrial Education Drinking Fountain	6/21/16 23:32	7/19/2016	1606D94-28A	Lead	2	15	ppb
014-29A	Auditorium Drinking Fountain	6/21/16 23:35	7/19/2016	1606D94-29A	Copper	1.9	1.3	ppm
014-29A	Auditorium Drinking Fountain	6/21/16 23:35	7/19/2016	1606D94-29A	Lead	ND	15	ppb
014-30A	Kitchen Bath Sink Faucet	6/21/16 23:40	7/19/2016	1606D94-30A	Copper	0.2	1.3	ppm
014-30A	Kitchen Bath Sink Faucet	6/21/16 23:40	7/19/2016	1606D94-30A	Lead	4	15	ppb
014-31A	Kitchen Dish Sink Faucet	6/21/16 23:43	7/19/2016	1606D94-31A	Copper	0.2	1.3	ppm
014-31A	Kitchen Dish Sink Faucet	6/21/16 23:43	7/19/2016	1606D94-31A	Lead	8	15	ppb
014-32A	Kitchen Jan Sink Faucet	6/21/16 23:45	7/19/2016	1606D94-32A	Copper	ND	1.3	ppm
014-32A	Kitchen Jan Sink Faucet	6/21/16 23:45	7/19/2016	1606D94-32A	Lead	3	15	ppb
014-33A	Kitchen Hand Sink Faucet	6/21/16 23:48	7/19/2016	1606D94-33A	Copper	0.1	1.3	ppm
014-33A	Kitchen Hand Sink Faucet	6/21/16 23:48	7/19/2016	1606D94-33A	Lead	ND	15	ppb
014-34A	Kitchen Prep Sink F	6/21/16 22:24	7/19/2016	1606D94-34A	Copper	0.2	1.3	ppm
014-34A	Kitchen Prep Sink F	6/21/16 22:24	7/19/2016	1606D94-34A	Lead	1	15	ppb
014-35A	Office Sink Faucet	6/21/16 22:27	7/19/2016	1606D94-35A	Copper	0.6	1.3	ppm
014-35A	Office Sink Faucet	6/21/16 22:27	7/19/2016	1606D94-35A	Lead	15.0	15	ppb
014-36A	Office Water Cooler	6/21/16 22:27	7/19/2016	1606D94-36A	Copper	ND	1.3	ppm
014-36A	Office Water Cooler	6/21/16 22:27	7/19/2016	1606D94-36A	Lead	ND	15	ppb
014-37A	Princ Office Bath Sink Faucet	6/21/16 22:31	7/19/2016	1606D94-37A	Copper	0.7	1.3	ppm
014-37A	Princ Office Bath Sink Faucet	6/21/16 22:31	7/19/2016	1606D94-37A	Lead	100	15	ppb
014-38A	Hall Drinking Fountain by Office	6/21/16 22:34	7/19/2016	1606D94-38A	Copper	0.9	1.3	ppm
014-38A	Hall Drinking Fountain by Office	6/21/16 22:34	7/19/2016	1606D94-38A	Lead	ND	15	ppb
014-39A	Library Sink Faucet	6/21/16 22:37	7/19/2016	1606D94-39A	Copper	0.4	1.3	ppm
014-39A	Library Sink Faucet	6/21/16 22:37	7/19/2016	1606D94-39A	Lead	3	15	ppb
014-40A	Room 133 Sink Faucet	6/21/16 22:43	7/19/2016	1606D94-40A	Copper	0.8	1.3	ppm
014-40A	Room 133 Sink Faucet	6/21/16 22:43	7/19/2016	1606D94-40A	Lead	23	15	ppb
014-41A	Room 101 Sink Faucet	6/21/16 22:46	7/19/2016	1606D94-41A	Copper	0.3	1.3	ppm
014-41A	Room 101 Sink Faucet	6/21/16 22:46	7/19/2016	1606D94-41A	Lead	3	15	ppb
014-42A	Room 106 Bath Sink Faucet	6/21/16 22:49	7/19/2016	1606D94-42A	Copper	0.3	1.3	ppm
014-42A	Room 106 Bath Sink Faucet	6/21/16 22:49	7/19/2016	1606D94-42A	Lead	3	15	ppb
014-43A	Boys Bathroom Sink Faucet	6/21/16 22:52	7/19/2016	1606D94-43A	Copper	0.2	1.3	ppm
014-43A	Boys Bathroom Sink Faucet	6/21/16 22:52	7/19/2016	1606D94-43A	Lead	2	15	ppb
014-44A	Boys Bathroom Water Spigot	6/21/16 23:00	7/19/2016	1606D94-44A	Copper	0.2	1.3	ppm
014-44A	Boys Bathroom Water Spigot	6/21/16 23:00	7/19/2016	1606D94-44A	Lead	43	15	ppb
014-45A	Girls Bathroom Sink Faucet	6/21/16 23:02	7/19/2016	1606D94-45A	Copper	0.3	1.3	ppm
014-45A	Girls Bathroom Sink Faucet	6/21/16 23:02	7/19/2016	1606D94-45A	Lead	2	15	ppb
014-46A	Janitors Closet by Library Janitors Sink Faucet	6/21/16 23:04	7/19/2016	1606D94-46A	Copper	0.2	1.3	ppm
014-46A	Janitors Closet by Library Janitors Sink Faucet	6/21/16 23:04	7/19/2016	1606D94-46A	Lead	3	15	ppb
014-47A	Outside Courtyard Water Spigot	6/21/16 23:07	7/19/2016	1606D94-47A	Copper	ND	1.3	ppm
014-47A	Outside Courtyard Water Spigot	6/21/16 23:07	7/19/2016	1606D94-47A	Lead	ND	15	ppb
014-48A	Hall by Elevator Drinking Fountain	6/21/16 23:17	7/19/2016	1606D94-48A	Copper	0.9	1.3	ppm
014-48A	Hall by Elevator Drinking Fountain	6/21/16 23:17	7/19/2016	1606D94-48A	Lead	2	15	ppb
014-49A	Room 221 Sink Faucet	6/21/16 23:19	7/19/2016	1606D94-49A	Copper	0.4	1.3	ppm
014-49A	Room 221 Sink Faucet	6/21/16 23:19	7/19/2016	1606D94-49A	Lead	4	15	ppb
014-50A	Room 221 Back Room Sink Faucet	6/21/16 23:22	7/19/2016	1606D94-50A	Copper	0.6	1.3	ppm
014-50A	Room 221 Back Room Sink Faucet	6/21/16 23:22	7/19/2016	1606D94-50A	Lead	89	15	ppb
014-51A	Room 224B Sink Faucet 1	6/21/16 23:24	7/19/2016	1606D94-51A	Copper	0.4	1.3	ppm
014-51A	Room 224B Sink Faucet 1	6/21/16 23:24	7/19/2016	1606D94-51A	Lead	11	15	ppb
014-52A	Room 224B Sink Faucet 2	6/21/16 23:26	7/19/2016	1606D94-52A	Copper	0.3	1.3	ppm
014-52A	Room 224B Sink Faucet 2	6/21/16 23:26	7/19/2016	1606D94-52A	Lead	2	15	ppb
014-53A	Room 224B Sink Faucet 3	6/21/16 23:24	7/19/2016	1606D94-53A	Copper	0.6	1.3	ppm
014-53A	Room 224B Sink Faucet 3	6/21/16 23:24	7/19/2016	1606D94-53A	Lead	2	15	ppb
014-54A	Room 224B Sink Faucet 4	6/21/16 23:26	7/19/2016	1606D94-54A	Copper	0.7	1.3	ppm
014-54A	Room 224B Sink Faucet 4	6/21/16 23:26	7/19/2016	1606D94-54A	Lead	1	15	ppb
014-55A	Room 224B Sink Faucet 5	6/21/16 23:28	7/19/2016	1606D94-55A	Copper	0.4	1.3	ppm
014-55A	Room 224B Sink Faucet 5	6/21/16 23:28	7/19/2016	1606D94-55A	Lead	5	15	ppb
014-56A	Room 228 Sink Faucet	6/21/16 23:30	7/19/2016	1606D94-56A	Copper	0.4	1.3	ppm
014-56A	Room 228 Sink Faucet	6/21/16 23:30	7/19/2016	1606D94-56A	Lead	8	15	ppb
014-57A	Room 228 Drinking Fountain	6/21/16 23:32	7/19/2016	1606D94-57A	Copper	0.3	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Beverly Cleary at Fernwood MS

014-57A	Room 228 Drinking Fountain	6/21/16 23:32	7/19/2016	1606D94-57A	Lead	4	15	ppb
014-58A	Hall by 210 Drinking Fountain	6/21/16 23:40	7/20/2016	1606D94-58A	Copper	1.4	1.3	ppm
014-58A	Hall by 210 Drinking Fountain	6/21/16 23:40	7/19/2016	1606D94-58A	Lead	ND	15	ppb
014-59A	Room 207 Sink Faucet	6/21/16 23:42	7/20/2016	1606D94-59A	Copper	1.2	1.3	ppm
014-59A	Room 207 Sink Faucet	6/21/16 23:42	7/19/2016	1606D94-59A	Lead	93	15	ppb
014-60A	Room 207 Janitor Sink Faucet	6/21/16 23:45	7/19/2016	1606D94-60A	Copper	0.4	1.3	ppm
014-60A	Room 207 Janitor Sink Faucet	6/21/16 23:45	7/19/2016	1606D94-60A	Lead	3	15	ppb
014-61A	Room 205 Sink Faucet 1	6/21/16 23:47	7/20/2016	1606D94-61A	Copper	1.2	1.3	ppm
014-61A	Room 205 Sink Faucet 1	6/21/16 23:47	7/19/2016	1606D94-61A	Lead	7	15	ppb
014-62A	Room 205 Sink Faucet 2	6/21/16 23:47	7/20/2016	1606D94-62A	Copper	0.9	1.3	ppm
014-62A	Room 205 Sink Faucet 2	6/21/16 23:47	7/19/2016	1606D94-62A	Lead	6	15	ppb
014-63A	Room 205 Sink Faucet 3	6/21/16 23:50	7/20/2016	1606D94-63A	Copper	1.2	1.3	ppm
014-63A	Room 205 Sink Faucet 3	6/21/16 23:50	7/19/2016	1606D94-63A	Lead	3	15	ppb
014-64A	Room 210 Sink Faucet 1	6/21/16 23:52	7/19/2016	1606D94-64A	Copper	0.8	1.3	ppm
014-64A	Room 210 Sink Faucet 1	6/21/16 23:52	7/19/2016	1606D94-64A	Lead	24	15	ppb
014-65A	Room 210 Drinking Fountain	6/21/16 23:54	7/19/2016	1606D94-65A	Copper	0.4	1.3	ppm
014-65A	Room 210 Drinking Fountain	6/21/16 23:54	7/19/2016	1606D94-65A	Lead	5	15	ppb
014-66A	Room 204 Sink Faucet 1	6/21/16 23:56	7/20/2016	1606D94-66A	Copper	1.27	1.3	ppm
014-66A	Room 204 Sink Faucet 1	6/21/16 23:56	7/19/2016	1606D94-66A	Lead	6	15	ppb
014-67A	Room 204 Sink Faucet 2	6/22/16 0:01	7/20/2016	1606D94-67A	Copper	1.2	1.3	ppm
014-67A	Room 204 Sink Faucet 2	6/22/16 0:01	7/19/2016	1606D94-67A	Lead	10	15	ppb
014-68A	Room 204 Sink Faucet 3	6/22/16 0:02	7/19/2016	1606D94-68A	Copper	1.9	1.3	ppm
014-68A	Room 204 Sink Faucet 3	6/22/16 0:02	7/18/2016	1606D94-68A	Lead	16	15	ppb
014-69A	Room 204 Eyewash	6/22/16 0:04	7/20/2016	1606D94-69A	Copper	1.9	1.3	ppm
014-69A	Room 204 Eyewash	6/22/16 0:04	7/19/2016	1606D94-69A	Lead	31	15	ppb
014-70A	Room 204 Sink Faucet 4	6/22/16 0:06	7/20/2016	1606D94-70A	Copper	0.9	1.3	ppm
014-70A	Room 204 Sink Faucet 4	6/22/16 0:06	7/19/2016	1606D94-70A	Lead	5	15	ppb
014-71A	220C Sink Faucet	6/22/16 0:08	7/19/2016	1606D94-71A	Copper	0.5	1.3	ppm
014-71A	220C Sink Faucet	6/22/16 0:08	7/19/2016	1606D94-71A	Lead	2	15	ppb
014-72A	Room 208 Staff Bath Sink Faucet	6/22/16 0:08	7/19/2016	1606D94-72A	Copper	0.4	1.3	ppm
014-72A	Room 208 Staff Bath Sink Faucet	6/22/16 0:08	7/19/2016	1606D94-72A	Lead	2	15	ppb
014-73A	2nd Floor Boys Bathroom by 220 Sink Faucet	6/22/16 0:10	7/19/2016	1606D94-73A	Copper	0.2	1.3	ppm
014-73A	2nd Floor Boys Bathroom by 220 Sink Faucet	6/22/16 0:10	7/19/2016	1606D94-73A	Lead	ND	15	ppb
014-74A	Boys Bathroom Water Spigot	6/22/16 0:12	7/18/2016	1606D94-74A	Copper	0.8	1.3	ppm
014-74A	Boys Bathroom Water Spigot	6/22/16 0:12	7/18/2016	1606D94-74A	Lead	59	15	ppb
014-75A	Girls Bathroom Sink Faucet	6/22/16 0:14	7/19/2016	1606D94-75A	Copper	0.3	1.3	ppm
014-75A	Girls Bathroom Sink Faucet	6/22/16 0:14	7/19/2016	1606D94-75A	Lead	2	15	ppb
014-76A	Girls Bathroom Water Spigot	6/22/16 0:16	7/19/2016	1606D94-76A	Copper	0.3	1.3	ppm
014-76A	Girls Bathroom Water Spigot	6/22/16 0:16	7/19/2016	1606D94-76A	Lead	67	15	ppb
014-77A	Out Water Spigot	6/22/16 0:30	7/19/2016	1606D94-77A	Copper	ND	1.3	ppm
014-77A	Out Water Spigot	6/22/16 0:30	7/19/2016	1606D94-77A	Lead	ND	15	ppb
014-78A	Out Garden (In Ground)	6/22/16 0:35	7/19/2016	1606D94-78A	Copper	ND	1.3	ppm
014-78A	Out Garden (In Ground)	6/22/16 0:35	7/19/2016	1606D94-78A	Lead	ND	15	ppb

EPA Action Level for Lead of 15 ppb

ND = Non detect

EPA Action Level for Copper of 1.3 ppm

Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.