

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Beverly Cleary School at Rose City Park

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
016-01A Sink Faucet Room 17	6/22/16 16:07	7/5/2016	1606C73-01A	Copper	0.1	1.3	ppm
016-01A Sink Faucet Room 17	6/22/16 16:07	7/5/2016	1606C73-01A	Lead	13	15	ppb
016-02A Sink Faucet Room 3	6/22/16 13:27	7/5/2016	1606C73-02A	Copper	ND	1.3	ppm
016-02A Sink Faucet Room 3	6/22/16 13:27	7/5/2016	1606C73-02A	Lead	5	15	ppb
016-03A Drinking Fountain Room 3	6/22/16 13:27	7/5/2016	1606C73-03A	Copper	ND	1.3	ppm
016-03A Drinking Fountain Room 3	6/22/16 13:27	7/5/2016	1606C73-03A	Lead	3	15	ppb
016-04A Girls Bathroom Sink Faucet 1	6/22/16 13:19	7/5/2016	1606C73-04A	Copper	0.1	1.3	ppm
016-04A Girls Bathroom Sink Faucet 1	6/22/16 13:19	7/5/2016	1606C73-04A	Lead	7	15	ppb
016-05A Girls Bathroom Sink Faucet 2	6/22/16 13:19	7/5/2016	1606C73-05A	Copper	0.2	1.3	ppm
016-05A Girls Bathroom Sink Faucet 2	6/22/16 13:19	7/5/2016	1606C73-05A	Lead	14	15	ppb
016-06A Girls Bathroom Sink Faucet 3	6/22/16 13:24	7/5/2016	1606C73-06A	Copper	0.2	1.3	ppm
016-06A Girls Bathroom Sink Faucet 3	6/22/16 13:24	7/5/2016	1606C73-06A	Lead	14	15	ppb
016-07A Girls Bathroom Sink Faucet 4	6/22/16 13:24	7/5/2016	1606C73-07A	Copper	0.1	1.3	ppm
016-07A Girls Bathroom Sink Faucet 4	6/22/16 13:24	7/5/2016	1606C73-07A	Lead	7	15	ppb
016-08A Girls Bathroom Water Spigot	6/22/16 13:26	7/3/2016	1606C73-08A	Copper	2.4	1.3	ppm
016-08A Girls Bathroom Water Spigot	6/22/16 13:26	7/3/2016	1606C73-08A	Lead	160	15	ppb
016-09A Boys Bathroom Sink Faucet 1	6/22/16 13:30	7/5/2016	1606C73-09A	Copper	0.1	1.3	ppm
016-09A Boys Bathroom Sink Faucet 1	6/22/16 13:30	7/5/2016	1606C73-09A	Lead	4	15	ppb
016-10A Boys Bathroom Sink Faucet 2	6/22/16 13:30	7/5/2016	1606C73-10A	Copper	0.1	1.3	ppm
016-10A Boys Bathroom Sink Faucet 2	6/22/16 13:30	7/5/2016	1606C73-10A	Lead	7	15	ppb
016-11A Boys Bathroom Sink Faucet 3	6/22/16 13:36	7/5/2016	1606C73-11A	Copper	0.1	1.3	ppm
016-11A Boys Bathroom Sink Faucet 3	6/22/16 13:36	7/5/2016	1606C73-11A	Lead	8	15	ppb
016-12A Boys Bathroom Sink Faucet 4	6/22/16 13:38	7/5/2016	1606C73-12A	Copper	0.2	1.3	ppm
016-12A Boys Bathroom Sink Faucet 4	6/22/16 13:38	7/5/2016	1606C73-12A	Lead	7	15	ppb
016-13A Boys Bathroom Sink Faucet 5	6/22/16 13:40	7/5/2016	1606C73-13A	Copper	0.2	1.3	ppm
016-13A Boys Bathroom Sink Faucet 5	6/22/16 13:40	7/5/2016	1606C73-13A	Lead	7	15	ppb
016-14A Boys Bathroom Water Spigot	6/22/16 13:40	7/3/2016	1606C73-14A	Copper	ND	1.3	ppm
016-14A Boys Bathroom Water Spigot	6/22/16 13:40	7/3/2016	1606C73-14A	Lead	290	15	ppb
016-15A Sink Faucet Room 9	6/22/16 14:05	7/5/2016	1606C73-15A	Copper	0.1	1.3	ppm
016-15A Sink Faucet Room 9	6/22/16 14:05	7/5/2016	1606C73-15A	Lead	9	15	ppb
016-16A Custodial Slop Sink	6/22/16 13:39	7/5/2016	1606C73-16A	Copper	ND	1.3	ppm
016-16A Custodial Slop Sink	6/22/16 13:39	7/5/2016	1606C73-16A	Lead	4	15	ppb
016-17A Sink Faucet Room 2	6/22/16 13:18	7/5/2016	1606C73-17A	Copper	0.2	1.3	ppm
016-17A Sink Faucet Room 2	6/22/16 13:18	7/5/2016	1606C73-17A	Lead	35	15	ppb
016-18A Sink Faucet Left Room 1	6/22/16 13:19	7/3/2016	1606C73-18A	Copper	0.1	1.3	ppm
016-18A Sink Faucet Left Room 1	6/22/16 13:19	7/3/2016	1606C73-18A	Lead	36	15	ppb
016-19A Sink Faucet Center Room 1	6/22/16 13:30	7/3/2016	1606C73-19A	Copper	0.2	1.3	ppm
016-19A Sink Faucet Center Room 1	6/22/16 13:30	7/3/2016	1606C73-19A	Lead	46	15	ppb
016-20A Sink Faucet Right Room 1	6/22/16 13:31	7/3/2016	1606C73-20A	Copper	0.2	1.3	ppm
016-20A Sink Faucet Right Room 1	6/22/16 13:31	7/3/2016	1606C73-20A	Lead	29	15	ppb
016-21A Drinking Fountain Gymnasium	6/22/16 13:43	7/5/2016	1606C73-21A	Copper	0.8	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Beverly Cleary School at Rose City Park

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
016-21A Drinking Fountain Gymnasium	6/22/16 13:43	7/5/2016	1606C73-21A	Lead	2	15	ppb
016-22A Kitchen White Hand Wash	6/22/16 13:52	7/5/2016	1606C73-22A	Copper	0.5	1.3	ppm
016-22A Kitchen White Hand Wash	6/22/16 13:52	7/5/2016	1606C73-22A	Lead	ND	15	ppb
016-23A Kitchen Sink Spray 1	6/22/16 13:50	7/5/2016	1606C73-23A	Copper	0.3	1.3	ppm
016-23A Kitchen Sink Spray 1	6/22/16 13:50	7/5/2016	1606C73-23A	Lead	5	15	ppb
016-24A Kitchen Sink Spray 2	6/22/16 13:53	7/5/2016	1606C73-24A	Copper	0.3	1.3	ppm
016-24A Kitchen Sink Spray 2	6/22/16 13:53	7/5/2016	1606C73-24A	Lead	13	15	ppb
016-25A Kitchen Sink Faucet	6/22/16 13:53	7/5/2016	1606C73-25A	Copper	0.3	1.3	ppm
016-25A Kitchen Sink Faucet	6/22/16 13:53	7/5/2016	1606C73-25A	Lead	5	15	ppb
016-26A Kitchen Slop Sink	6/22/16 13:50	7/5/2016	1606C73-26A	Copper	0.4	1.3	ppm
016-26A Kitchen Slop Sink	6/22/16 13:50	7/5/2016	1606C73-26A	Lead	3	15	ppb
016-27A Kitchen Bathroom Sink	6/22/16 13:59	7/5/2016	1606C73-27A	Copper	0.4	1.3	ppm
016-27A Kitchen Bathroom Sink	6/22/16 13:59	7/5/2016	1606C73-27A	Lead	ND	15	ppb
016-28A Drinking Fountain Right North Wing	6/22/16 13:58	7/5/2016	1606C73-28A	Copper	ND	1.3	ppm
016-28A Drinking Fountain Right North Wing	6/22/16 13:58	7/5/2016	1606C73-28A	Lead	6	15	ppb
016-29A Drinking Fountain Left North Wing	6/22/16 13:58	7/5/2016	1606C73-29A	Copper	ND	1.3	ppm
016-29A Drinking Fountain Left North Wing	6/22/16 13:58	7/5/2016	1606C73-29A	Lead	7	15	ppb
016-30A Sink Faucet Room 16	6/22/16 14:08	7/5/2016	1606C73-30A	Copper	0.5	1.3	ppm
016-30A Sink Faucet Room 16	6/22/16 14:08	7/5/2016	1606C73-30A	Lead	8	15	ppb
016-31A Girls Bathroom Sink Faucet 1	6/22/16 14:14	7/5/2016	1606C73-31A	Copper	ND	1.3	ppm
016-31A Girls Bathroom Sink Faucet 1	6/22/16 14:14	7/5/2016	1606C73-31A	Lead	7	15	ppb
016-32A Girls Bathroom Sink Faucet 2	6/22/16 14:14	7/5/2016	1606C73-32A	Copper	0.1	1.3	ppm
016-32A Girls Bathroom Sink Faucet 2	6/22/16 14:14	7/5/2016	1606C73-32A	Lead	4	15	ppb
016-33A Girls Bathroom Sink Faucet 3	6/22/16 14:14	7/5/2016	1606C73-33A	Copper	ND	1.3	ppm
016-33A Girls Bathroom Sink Faucet 3	6/22/16 14:14	7/5/2016	1606C73-33A	Lead	2	15	ppb
016-34A Girls Bathroom Sink Faucet 4	6/22/16 14:25	7/5/2016	1606C73-34A	Copper	ND	1.3	ppm
016-34A Girls Bathroom Sink Faucet 4	6/22/16 14:25	7/5/2016	1606C73-34A	Lead	ND	15	ppb
016-35A Girls Bathroom Sink Faucet 5	6/22/16 14:25	7/5/2016	1606C73-35A	Copper	ND	1.3	ppm
016-35A Girls Bathroom Sink Faucet 5	6/22/16 14:25	7/5/2016	1606C73-35A	Lead	1	15	ppb
016-36A Girls Bathroom Water Spigot	6/22/16 14:24	7/3/2016	1606C73-36A	Copper	0.4	1.3	ppm
016-36A Girls Bathroom Water Spigot	6/22/16 14:24	7/3/2016	1606C73-36A	Lead	85	15	ppb
016-37A Custodian Slop Sink	6/22/16 14:30	7/5/2016	1606C73-37A	Copper	ND	1.3	ppm
016-37A Custodian Slop Sink	6/22/16 14:30	7/5/2016	1606C73-37A	Lead	10	15	ppb
016-38A Boys Bathroom Sink Faucet 1	6/22/16 14:23	7/5/2016	1606C73-38A	Copper	ND	1.3	ppm
016-38A Boys Bathroom Sink Faucet 1	6/22/16 14:23	7/5/2016	1606C73-38A	Lead	3	15	ppb
016-39A Boys Bathroom Sink Faucet 2	6/22/16 14:23	7/5/2016	1606C73-39A	Copper	ND	1.3	ppm
016-39A Boys Bathroom Sink Faucet 2	6/22/16 14:23	7/5/2016	1606C73-39A	Lead	3	15	ppb
016-40A Boys Bathroom Sink Faucet 3	6/22/16 14:19	7/5/2016	1606C73-40A	Copper	ND	1.3	ppm
016-40A Boys Bathroom Sink Faucet 3	6/22/16 14:19	7/5/2016	1606C73-40A	Lead	1	15	ppb
016-41A Boys Bathroom Sink Faucet 4	6/22/16 14:19	7/5/2016	1606C73-41A	Copper	ND	1.3	ppm
016-41A Boys Bathroom Sink Faucet 4	6/22/16 14:19	7/5/2016	1606C73-41A	Lead	6	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Beverly Cleary School at Rose City Park

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
016-42A Boys Bathroom Water Spigot	6/22/16 14:28	7/4/2016	1606C73-42A	Copper	3.6	1.3	ppm
016-42A Boys Bathroom Water Spigot	6/22/16 14:28	7/3/2016	1606C73-42A	Lead	980	15	ppb
016-43A Drinking Fountain 1 South Wing	6/22/16 14:11	7/5/2016	1606C73-43A	Copper	ND	1.3	ppm
016-43A Drinking Fountain 1 South Wing	6/22/16 14:11	7/5/2016	1606C73-43A	Lead	7	15	ppb
016-44A Drinking Fountain 2 South Wing	6/22/16 14:11	7/5/2016	1606C73-44A	Copper	ND	1.3	ppm
016-44A Drinking Fountain 2 South Wing	6/22/16 14:11	7/5/2016	1606C73-44A	Lead	6	15	ppb
016-45A Boiler Room Slop Sink	6/22/16 14:42	7/5/2016	1606C73-45A	Copper	0.1	1.3	ppm
016-45A Boiler Room Slop Sink	6/22/16 14:42	7/5/2016	1606C73-45A	Lead	3	15	ppb
016-46A Boiler Room Water Spigot	6/22/16 14:44	7/3/2016	1606C73-46A	Copper	2.1	1.3	ppm
016-46A Boiler Room Water Spigot	6/22/16 14:44	7/4/2016	1606C73-46A	Lead	4200	15	ppb
016-47A Drinking Fountain Corridor S. Wing 112	6/22/16 15:06	7/5/2016	1606C73-47A	Copper	ND	1.3	ppm
016-47A Drinking Fountain Corridor S. Wing 112	6/22/16 15:06	7/5/2016	1606C73-47A	Lead	4	15	ppb
016-48A Sink Faucet on Corridor S. Wing 112	6/22/16 15:06	7/5/2016	1606C73-48A	Copper	0.1	1.3	ppm
016-48A Sink Faucet on Corridor S. Wing 112	6/22/16 15:06	7/5/2016	1606C73-48A	Lead	12	15	ppb
016-49A Sink Faucet 1st Floor Room 115	6/22/16 14:53	7/5/2016	1606C73-49A	Copper	ND	1.3	ppm
016-49A Sink Faucet 1st Floor Room 115	6/22/16 14:53	7/5/2016	1606C73-49A	Lead	5	15	ppb
016-50A Drinking Fountain 1st Floor Room 115	6/22/16 14:57	7/5/2016	1606C73-50A	Copper	ND	1.3	ppm
016-50A Drinking Fountain 1st Floor Room 115	6/22/16 14:57	7/5/2016	1606C73-50A	Lead	6	15	ppb
016-51A Sink Faucet 1st Floor Room 116	6/22/16 14:59	7/5/2016	1606C73-51A	Copper	ND	1.3	ppm
016-51A Sink Faucet 1st Floor Room 116	6/22/16 14:59	7/5/2016	1606C73-51A	Lead	4	15	ppb
016-52A Drinking Fountain 1st Floor Room 116	6/22/16 15:00	7/3/2016	1606C73-52A	Copper	0.1	1.3	ppm
016-52A Drinking Fountain 1st Floor Room 116	6/22/16 15:00	7/3/2016	1606C73-52A	Lead	39	15	ppb
016-53A Custodian Slop Sink 1st Flr	6/22/16 14:58	7/5/2016	1606C73-53A	Copper	ND	1.3	ppm
016-53A Custodian Slop Sink 1st Flr	6/22/16 14:58	7/5/2016	1606C73-53A	Lead	40	15	ppb
016-54A Bathroom Sink in Room 109	6/22/16 15:08	7/5/2016	1606C73-54A	Copper	ND	1.3	ppm
016-54A Bathroom Sink in Room 109	6/22/16 15:08	7/5/2016	1606C73-54A	Lead	3	15	ppb
016-55A Drinking Fountain on Corridor Left	6/22/16 14:43	7/5/2016	1606C73-55A	Copper	ND	1.3	ppm
016-55A Drinking Fountain on Corridor Left	6/22/16 14:43	7/5/2016	1606C73-55A	Lead	2	15	ppb
016-56A Drinking Fountain on Corridor Right	6/22/16 14:43	7/5/2016	1606C73-56A	Copper	ND	1.3	ppm
016-56A Drinking Fountain on Corridor Right	6/22/16 14:43	7/5/2016	1606C73-56A	Lead	2	15	ppb
016-57A Sink Faucet Library	6/22/16 15:14	7/5/2016	1606C73-57A	Copper	ND	1.3	ppm
016-57A Sink Faucet Library	6/22/16 15:14	7/5/2016	1606C73-57A	Lead	5	15	ppb
016-58A Bathroom Sink Faucet in Office	6/22/16 15:17	7/5/2016	1606C73-58A	Copper	ND	1.3	ppm
016-58A Bathroom Sink Faucet in Office	6/22/16 15:17	7/5/2016	1606C73-58A	Lead	5	15	ppb
016-59A Cold Water Dispenser Office	6/22/16 15:17	7/5/2016	1606C73-59A	Copper	ND	1.3	ppm
016-59A Cold Water Dispenser Office	6/22/16 15:17	7/5/2016	1606C73-59A	Lead	ND	15	ppb
016-60A N-Staff Restroom Bathroom Sink Faucet	6/22/16 15:23	7/5/2016	1606C73-60A	Copper	0.1	1.3	ppm
016-60A N-Staff Restroom Bathroom Sink Faucet	6/22/16 15:23	7/5/2016	1606C73-60A	Lead	2	15	ppb
016-61A Sink Faucet Room 103	6/22/16 14:51	7/5/2016	1606C73-61A	Copper	ND	1.3	ppm
016-61A Sink Faucet Room 103	6/22/16 14:51	7/5/2016	1606C73-61A	Lead	3	15	ppb
016-62A Drinking Fountain Room 103	6/22/16 14:51	7/5/2016	1606C73-62A	Copper	ND	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Beverly Cleary School at Rose City Park

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
016-62A Drinking Fountain Room 103	6/22/16 14:51	7/5/2016	1606C73-62A	Lead	1	15	ppb
016-63A Sink Faucet Room 100	6/22/16 15:31	7/5/2016	1606C73-63A	Copper	0.1	1.3	ppm
016-63A Sink Faucet Room 100	6/22/16 15:31	7/5/2016	1606C73-63A	Lead	9	15	ppb
016-64A Drinking Fountain Room 100	6/22/16 15:32	7/5/2016	1606C73-64A	Copper	0.1	1.3	ppm
016-64A Drinking Fountain Room 100	6/22/16 15:32	7/5/2016	1606C73-64A	Lead	4	15	ppb
016-65A Sink Faucet Room 203	6/22/16 15:33	7/6/2016	1606C73-65A	Copper	ND	1.3	ppm
016-65A Sink Faucet Room 203	6/22/16 15:33	7/6/2016	1606C73-65A	Lead	4	15	ppb
016-66A Drinking Fountain Room 203	6/22/16 15:33	7/6/2016	1606C73-66A	Copper	ND	1.3	ppm
016-66A Drinking Fountain Room 203	6/22/16 15:33	7/6/2016	1606C73-66A	Lead	7	15	ppb
016-67A Sink Faucet Room 200	6/22/16 15:36	7/6/2016	1606C73-67A	Copper	0.1	1.3	ppm
016-67A Sink Faucet Room 200	6/22/16 15:36	7/6/2016	1606C73-67A	Lead	17	15	ppb
016-68A Drinking Fountain Room 200	6/22/16 15:36	7/6/2016	1606C73-68A	Copper	ND	1.3	ppm
016-68A Drinking Fountain Room 200	6/22/16 15:36	7/6/2016	1606C73-68A	Lead	9	15	ppb
016-69A Drinking Fountain on Corridor	6/22/16 15:29	7/6/2016	1606C73-69A	Copper	ND	1.3	ppm
016-69A Drinking Fountain on Corridor	6/22/16 15:29	7/6/2016	1606C73-69A	Lead	4	15	ppb
016-70A Bathroom 2nd Floor Staff	6/22/16 15:42	7/6/2016	1606C73-70A	Copper	0.1	1.3	ppm
016-70A Bathroom 2nd Floor Staff	6/22/16 15:42	7/6/2016	1606C73-70A	Lead	4	15	ppb
016-71A Sink Faucet Room 207	6/22/16 15:41	7/6/2016	1606C73-71A	Copper	ND	1.3	ppm
016-71A Sink Faucet Room 207	6/22/16 15:41	7/6/2016	1606C73-71A	Lead	6	15	ppb
016-72A 208 Custodian Slop Sink	6/22/16 15:47	7/6/2016	1606C73-72A	Copper	0.3	1.3	ppm
016-72A 208 Custodian Slop Sink	6/22/16 15:47	7/6/2016	1606C73-72A	Lead	160	15	ppb
016-73A Corridor Drinking Fountain by Room 208	6/22/16 15:47	7/6/2016	1606C73-73A	Copper	ND	1.3	ppm
016-73A Corridor Drinking Fountain by Room 208	6/22/16 15:47	7/6/2016	1606C73-73A	Lead	ND	15	ppb
016-74A Sink Faucet in 214/215	6/22/16 15:49	7/6/2016	1606C73-74A	Copper	ND	1.3	ppm
016-74A Sink Faucet in 214/215	6/22/16 15:49	7/6/2016	1606C73-74A	Lead	7	15	ppb
016-75A Drinking Fountain in 214/215	6/22/16 15:49	7/6/2016	1606C73-75A	Copper	ND	1.3	ppm
016-75A Drinking Fountain in 214/215	6/22/16 15:49	7/6/2016	1606C73-75A	Lead	2	15	ppb
016-76A Sink Faucet in 212/211	6/22/16 15:52	7/6/2016	1606C73-76A	Copper	ND	1.3	ppm
016-76A Sink Faucet in 212/211	6/22/16 15:52	7/6/2016	1606C73-76A	Lead	7	15	ppb
016-77A Drinking Fountain in 212/211	6/22/16 15:52	7/6/2016	1606C73-77A	Copper	ND	1.3	ppm
016-77A Drinking Fountain in 212/211	6/22/16 15:52	7/6/2016	1606C73-77A	Lead	5	15	ppb
016-78A Exterior Water Spigot1	6/22/16 16:03	7/6/2016	1606C73-78A	Copper	ND	1.3	ppm
016-78A Exterior Water Spigot1	6/22/16 16:03	7/6/2016	1606C73-78A	Lead	2	15	ppb
016-79A Exterior Water Spigot2	6/22/16 16:11	7/6/2016	1606C73-79A	Copper	ND	1.3	ppm
016-79A Exterior Water Spigot2	6/22/16 16:11	7/6/2016	1606C73-79A	Lead	5	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

ND = Non detect

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.