

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
BESC - Portland Public Schools

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
013-01A Sprayer #1-Central Kitchen Floor L2	7/1/2016 17:07	7/11/2016 23:33	10354477001	Copper	0.2	1.3	ppm
013-01A Sprayer #1-Central Kitchen Floor L2	7/1/2016 17:07	7/11/2016 23:33	10354477001	Lead	3	15	ppb
013-02A Sink Faucet #1-Central Kitchen Floor L2	7/1/2016 17:10	7/11/2016 23:41	10354477003	Copper	0.3	1.3	ppm
013-02A Sink Faucet #1-Central Kitchen Floor L2	7/1/2016 17:10	7/11/2016 23:41	10354477003	Lead	1	15	ppb
013-03A Water Fountain-Central Kitchen Floor L2	7/1/2016 17:14	7/11/2016 23:43	10354477005	Copper	0.4	1.3	ppm
013-03A Water Fountain-Central Kitchen Floor L2	7/1/2016 17:14	7/11/2016 23:43	10354477005	Lead	6	15	ppb
013-04A Sink Faucet (Left)-Central Kitchen Floor L2	7/1/2016 17:18	7/11/2016 23:44	10354477007	Copper	0.1	1.3	ppm
013-04A Sink Faucet (Left)-Central Kitchen Floor L2	7/1/2016 17:18	7/11/2016 23:44	10354477007	Lead	2	15	ppb
013-05A Sink Faucet (Right)-Central Kitchen Floor L2	7/1/2016 17:21	7/11/2016 23:45	10354477009	Copper	0.1	1.3	ppm
013-05A Sink Faucet (Right)-Central Kitchen Floor L2	7/1/2016 17:21	7/11/2016 23:45	10354477009	Lead	1	15	ppb
013-06A Sprayer #2-Central Kitchen Floor L2	7/1/2016 17:23	7/11/2016 23:47	10354477011	Copper	0.2	1.3	ppm
013-06A Sprayer #2-Central Kitchen Floor L2	7/1/2016 17:23	7/11/2016 23:47	10354477011	Lead	2	15	ppb
013-07A Sink Faucet #2-Central Kitchen Floor L2	7/1/2016 17:25	7/11/2016 23:48	10354477013	Copper	0.4	1.3	ppm
013-07A Sink Faucet #2-Central Kitchen Floor L2	7/1/2016 17:25	7/11/2016 23:48	10354477013	Lead	0	15	ppb
013-08A Sink Faucet #3-Central Kitchen Floor L2	7/1/2016 17:27	7/11/2016 23:50	10354477015	Copper	0.3	1.3	ppm
013-08A Sink Faucet #3-Central Kitchen Floor L2	7/1/2016 17:27	7/11/2016 23:50	10354477015	Lead	1	15	ppb
013-09A Sink Faucet #4-Central Kitchen Floor L2	7/1/2016 17:29	7/11/2016 23:51	10354477017	Copper	0.2	1.3	ppm
013-09A Sink Faucet #4-Central Kitchen Floor L2	7/1/2016 17:29	7/11/2016 23:51	10354477017	Lead	11	15	ppb
013-10A Sink Faucet #5-Central Kitchen Floor L2	7/1/2016 17:31	7/11/2016 23:52	10354477019	Copper	0.1	1.3	ppm
013-10A Sink Faucet #5-Central Kitchen Floor L2	7/1/2016 17:31	7/11/2016 23:52	10354477019	Lead	6	15	ppb
013-11A Sink Faucet #6-Central Kitchen Floor L2	7/1/2016 17:33	7/11/2016 23:54	10354477021	Copper	0.4	1.3	ppm
013-11A Sink Faucet #6-Central Kitchen Floor L2	7/1/2016 17:33	7/11/2016 23:54	10354477021	Lead	31	15	ppb
013-12A Sprayer #3-Central Kitchen Floor L2	7/1/2016 17:35	7/12/2016 08:45	10354477023	Copper	5.4	1.3	ppm
013-12A Sprayer #3-Central Kitchen Floor L2	7/1/2016 17:35	7/12/2016 01:31	10354477023	Lead	33	15	ppb
013-13A Ice Machine-Central Kitchen Floor L2	7/1/2016 17:37	7/12/2016 00:02	10354477025	Copper	0.0	1.3	ppm
013-13A Ice Machine-Central Kitchen Floor L2	7/1/2016 17:37	7/12/2016 00:02	10354477025	Lead	0	15	ppb
013-14A Sink Faucet #7-Central Kitchen Floor L2	7/1/2016 17:39	7/12/2016 00:03	10354477027	Copper	0.2	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
BESC - Portland Public Schools

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
013-14A Sink Faucet #7-Central Kitchen Floor L2	7/1/2016 17:39	7/12/2016 00:03	10354477027	Lead	2	15	ppb
013-15A Sprayer #4-Central Kitchen Floor L2	7/1/2016 17:41	7/12/2016 08:47	10354477029	Copper	0.5	1.3	ppm
013-15A Sprayer #4-Central Kitchen Floor L2	7/1/2016 17:41	7/12/2016 01:39	10354477029	Lead	40	15	ppb
013-16A Sink Faucet (Hand)-Central Kitchen Floor L2	7/1/2016 17:43	7/12/2016 08:26	10354477031	Copper	0.5	1.3	ppm
013-16A Sink Faucet (Hand)-Central Kitchen Floor L2	7/1/2016 17:43	7/12/2016 00:05	10354477031	Lead	0	15	ppb
013-17A Sink Faucet (Kitchen)-Central Kitchen Floor L2	7/1/2016 17:45	7/12/2016 00:06	10354477033	Copper	0.1	1.3	ppm
013-17A Sink Faucet (Kitchen)-Central Kitchen Floor L2	7/1/2016 17:45	7/12/2016 00:06	10354477033	Lead	1	15	ppb
013-18A Spigot-Central Kitchen Floor L2	7/1/2016 17:47	7/12/2016 01:41	10354477035	Copper	0.4	1.3	ppm
013-18A Spigot-Central Kitchen Floor L2	7/1/2016 17:47	7/12/2016 01:41	10354477035	Lead	71	15	ppb
013-19A Faucet/Floor Drain-Central Kitchen Floor L2	7/1/2016 17:49	7/12/2016 00:08	10354477037	Copper	0.2	1.3	ppm
013-19A Faucet/Floor Drain-Central Kitchen Floor L2	7/1/2016 17:49	7/12/2016 00:08	10354477037	Lead	8	15	ppb
013-20A Sink Faucet #8-Central Kitchen Floor L2	7/1/2016 17:51	7/12/2016 00:09	10354477039	Copper	0.2	1.3	ppm
013-20A Sink Faucet #8-Central Kitchen Floor L2	7/1/2016 17:51	7/12/2016 00:09	10354477039	Lead	2	15	ppb
013-21A Sprayer (at Sink Faucet #08)-Central Kitchen Floor L2	7/1/2016 17:53	7/12/2016 08:27	10354477041	Copper	1.4	1.3	ppm
013-21A Sprayer (at Sink Faucet #08)-Central Kitchen Floor L2	7/1/2016 17:53	7/12/2016 00:13	10354477041	Lead	124	15	ppb
013-22A Sink Faucet-Mens Bathroom	7/1/2016 17:55	7/12/2016 00:19	10354477043	Copper	0.4	1.3	ppm
013-22A Sink Faucet-Mens Bathroom	7/1/2016 17:55	7/12/2016 00:19	10354477043	Lead	4	15	ppb
013-23A Sink Faucet-Unisex Bathroom	7/1/2016 17:57	7/12/2016 00:20	10354477045	Copper	0.4	1.3	ppm
013-23A Sink Faucet-Unisex Bathroom	7/1/2016 17:57	7/12/2016 00:20	10354477045	Lead	4	15	ppb
013-24A Drinking Fountain-Between Men/Unisex Bathrooms	7/1/2016 17:59	7/12/2016 08:30	10354477047	Copper	5.1	1.3	ppm
013-24A Drinking Fountain-Between Men/Unisex Bathrooms	7/1/2016 17:59	7/12/2016 00:21	10354477047	Lead	26	15	ppb
013-25A Sink Faucet-South Wall Warehouse #1	7/1/2016 18:01	7/12/2016 00:23	10354477049	Copper	0.1	1.3	ppm
013-25A Sink Faucet-South Wall Warehouse #1	7/1/2016 18:01	7/12/2016 00:23	10354477049	Lead	6	15	ppb
013-26A Sprayer-South Wall Warehouse #1	7/1/2016 18:03	7/12/2016 00:24	10354477051	Copper	0.2	1.3	ppm
013-26A Sprayer-South Wall Warehouse #1	7/1/2016 18:03	7/12/2016 00:24	10354477051	Lead	14	15	ppb
013-27A Sink Faucet-South Wall Warehouse #2	7/1/2016 18:05	7/12/2016 00:25	10354477053	Copper	0.1	1.3	ppm
013-27A Sink Faucet-South Wall Warehouse #2	7/1/2016 18:05	7/12/2016 00:25	10354477053	Lead	3	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
BESC - Portland Public Schools

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
013-28A Sprayer-South Wall Warehouse #2	7/1/2016 18:07	7/12/2016 00:30	10354477055	Copper	0.1	1.3	ppm
013-28A Sprayer-South Wall Warehouse #2	7/1/2016 18:07	7/12/2016 00:30	10354477055	Lead	3	15	ppb
013-29A Spigot-South Wall Warehouse	7/1/2016 18:09	7/12/2016 00:31	10354477057	Copper	0.0	1.3	ppm
013-29A Spigot-South Wall Warehouse	7/1/2016 18:09	7/12/2016 00:31	10354477057	Lead	5	15	ppb
013-30A Sink Faucet-Room L2-65	7/1/2016 18:11	7/12/2016 08:31	10354477059	Copper	0.5	1.3	ppm
013-30A Sink Faucet-Room L2-65	7/1/2016 18:11	7/12/2016 00:32	10354477059	Lead	0	15	ppb
013-31A Drinking Fountain-Between L2-65/30	7/1/2016 18:13	7/13/2016 01:24	10354477061	Copper	3.2	1.3	ppm
013-31A Drinking Fountain-Between L2-65/30	7/1/2016 18:13	7/13/2016 01:22	10354477061	Lead	5	15	ppb
013-32A Sink Faucet-Room L2-30	7/1/2016 18:15	7/12/2016 00:36	10354477063	Copper	0.4	1.3	ppm
013-32A Sink Faucet-Room L2-30	7/1/2016 18:15	7/12/2016 00:36	10354477063	Lead	3	15	ppb
013-33A Sink Faucet-Mens Bathroom Left	7/1/2016 18:17	7/12/2016 00:38	10354477065	Copper	0.2	1.3	ppm
013-33A Sink Faucet-Mens Bathroom Left	7/1/2016 18:17	7/12/2016 00:38	10354477065	Lead	1	15	ppb
013-34A Sink Faucet-Mens Bathroom Right	7/1/2016 18:22	7/12/2016 00:39	10354477067	Copper	0.2	1.3	ppm
013-34A Sink Faucet-Mens Bathroom Right	7/1/2016 18:22	7/12/2016 00:39	10354477067	Lead	1	15	ppb
013-35A Shower-Mens Locker Room	7/1/2016 18:24	7/12/2016 00:40	10354477069	Copper	0.4	1.3	ppm
013-35A Shower-Mens Locker Room	7/1/2016 18:24	7/12/2016 00:40	10354477069	Lead	4	15	ppb
013-36A Shower-Womens Locker Room	7/1/2016 18:26	7/12/2016 00:42	10354477071	Copper	0.1	1.3	ppm
013-36A Shower-Womens Locker Room	7/1/2016 18:26	7/12/2016 00:42	10354477071	Lead	1	15	ppb
013-37A Sink Faucet-Womens Bathroom #1	7/1/2016 18:28	7/12/2016 00:49	10354477073	Copper	0.2	1.3	ppm
013-37A Sink Faucet-Womens Bathroom #1	7/1/2016 18:28	7/12/2016 00:49	10354477073	Lead	2	15	ppb
013-38A Sink Faucet-Womens Bathroom #2	7/1/2016 18:30	7/12/2016 00:50	10354477075	Copper	0.2	1.3	ppm
013-38A Sink Faucet-Womens Bathroom #2	7/1/2016 18:30	7/12/2016 00:50	10354477075	Lead	0	15	ppb
013-39A Sink Faucet-Womens Bathroom #3	7/1/2016 18:32	7/12/2016 00:51	10354477077	Copper	0.2	1.3	ppm
013-39A Sink Faucet-Womens Bathroom #3	7/1/2016 18:32	7/12/2016 00:51	10354477077	Lead	0	15	ppb
013-40A Mop Sink-Custodial Room	7/1/2016 18:40	7/12/2016 00:53	10354477079	Copper	0.4	1.3	ppm
013-40A Mop Sink-Custodial Room	7/1/2016 18:40	7/12/2016 00:53	10354477079	Lead	1	15	ppb
013-41A Sink Faucet-Print Shop #1	7/1/2016 18:42	7/12/2016 08:49	10354477081	Copper	1.9	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
BESC - Portland Public Schools

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
013-41A Sink Faucet-Print Shop #1	7/1/2016 18:42	7/12/2016 01:42	10354477081	Lead	9	15	ppb
013-42A Sink Faucet-Print Shop #2	7/1/2016 18:44	7/12/2016 08:35	10354477083	Copper	0.6	1.3	ppm
013-42A Sink Faucet-Print Shop #2	7/1/2016 18:44	7/12/2016 00:54	10354477083	Lead	3	15	ppb
013-43A Spigot-Boiler Room Clockwise #1	7/1/2016 18:51	7/12/2016 08:50	10354477085	Copper	0.8	1.3	ppm
013-43A Spigot-Boiler Room Clockwise #1	7/1/2016 18:51	7/12/2016 01:43	10354477085	Lead	20	15	ppb
013-44A Spigot-Boiler Room Clockwise #2	7/1/2016 18:53	7/12/2016 01:02	10354477087	Copper	0.2	1.3	ppm
013-44A Spigot-Boiler Room Clockwise #2	7/1/2016 18:53	7/12/2016 01:02	10354477087	Lead	18	15	ppb
013-45A Sink Faucet-Boiler	7/1/2016 18:55	7/12/2016 01:04	10354477089	Copper	0.2	1.3	ppm
013-45A Sink Faucet-Boiler	7/1/2016 18:55	7/12/2016 01:04	10354477089	Lead	3	15	ppb
013-46A Sink Faucet-Custodial Office	7/1/2016 18:57	7/12/2016 01:05	10354477091	Copper	0.3	1.3	ppm
013-46A Sink Faucet-Custodial Office	7/1/2016 18:57	7/12/2016 01:05	10354477091	Lead	2	15	ppb
013-47A Mop Sink-Custodial Office	7/1/2016 18:59	7/12/2016 01:06	10354477093	Copper	0.1	1.3	ppm
013-47A Mop Sink-Custodial Office	7/1/2016 18:59	7/12/2016 01:06	10354477093	Lead	4	15	ppb
013-48A Sink Faucet-Womens Bathroom #1	7/1/2016 19:01	7/12/2016 01:08	10354477095	Copper	0.2	1.3	ppm
013-48A Sink Faucet-Womens Bathroom #1	7/1/2016 19:01	7/12/2016 01:08	10354477095	Lead	1	15	ppb
013-49A Sink Faucet-Womens Bathroom #2	7/1/2016 09:03	7/12/2016 01:09	10354477097	Copper	0.1	1.3	ppm
013-49A Sink Faucet-Womens Bathroom #2	7/1/2016 09:03	7/12/2016 01:09	10354477097	Lead	1	15	ppb
013-50A Sink Faucet-Mens Bathroom #1	7/1/2016 19:05	7/12/2016 01:11	10354477099	Copper	0.2	1.3	ppm
013-50A Sink Faucet-Mens Bathroom #1	7/1/2016 19:05	7/12/2016 01:11	10354477099	Lead	3	15	ppb
013-51A Sink Faucet-Mens Bathroom #2	7/1/2016 19:07	7/12/2016 01:12	10354477101	Copper	0.1	1.3	ppm
013-51A Sink Faucet-Mens Bathroom #2	7/1/2016 19:07	7/12/2016 01:12	10354477101	Lead	1	15	ppb
013-53A Drinking Fountain-Outside L1-60	7/1/2016 19:12	7/12/2016 08:41	10354477105	Copper	1.1	1.3	ppm
013-53A Drinking Fountain-Outside L1-60	7/1/2016 19:12	7/12/2016 01:13	10354477105	Lead	0	15	ppb
013-54A Bottle Dispenser	7/1/2016 19:14	7/12/2016 08:42	10354477107	Copper	0.8	1.3	ppm
013-54A Bottle Dispenser	7/1/2016 19:14	7/12/2016 01:15	10354477107	Lead	0	15	ppb
013-55A Sink Faucet-Nutrition Break	7/1/2016 19:16	7/12/2016 01:23	10354477109	Copper	0.3	1.3	ppm
013-55A Sink Faucet-Nutrition Break	7/1/2016 19:16	7/12/2016 01:23	10354477109	Lead	1	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
BESC - Portland Public Schools

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
013-56A Sink Faucet-Unisex Bathroom	7/1/2016 19:25	7/12/2016 01:24	10354477111	Copper	0.1	1.3	ppm
013-56A Sink Faucet-Unisex Bathroom	7/1/2016 19:25	7/12/2016 01:24	10354477111	Lead	5	15	ppb
013-57A Mop Sink-IT Room	7/1/2016 19:27	7/12/2016 01:25	10354477113	Copper	0.3	1.3	ppm
013-57A Mop Sink-IT Room	7/1/2016 19:27	7/12/2016 01:25	10354477113	Lead	7	15	ppb
013-58A Sink Faucet-IT Breakroom	7/1/2016 19:29	7/12/2016 01:27	10354477115	Copper	0.3	1.3	ppm
013-58A Sink Faucet-IT Breakroom	7/1/2016 19:29	7/12/2016 01:27	10354477115	Lead	2	15	ppb
013-59A Sink Faucet-Asset Management	7/1/2016 19:31	7/12/2016 01:28	10354477117	Copper	0.3	1.3	ppm
013-59A Sink Faucet-Asset Management	7/1/2016 19:31	7/12/2016 01:28	10354477117	Lead	1	15	ppb
013-60 ASink Faucet-Room 140	7/1/2016 19:33	7/12/2016 08:44	10354477119	Copper	0.9	1.3	ppm
013-60 ASink Faucet-Room 140	7/1/2016 19:33	7/12/2016 01:30	10354477119	Lead	2	15	ppb
013-61A Drinking Fountain-Outside Room 150	7/1/2016 19:35	7/12/2016 08:10	10354477121	Copper	3.0	1.3	ppm
013-61A Drinking Fountain-Outside Room 150	7/1/2016 19:35	7/11/2016 22:55	10354477121	Lead	1	15	ppb
013-62A Drinking Fountain-Outside Floor 1 Elevator #1	7/1/2016 19:37	7/12/2016 08:23	10354477123	Copper	5.1	1.3	ppm
013-62A Drinking Fountain-Outside Floor 1 Elevator #1	7/1/2016 19:37	7/11/2016 22:48	10354477123	Lead	5	15	ppb
013-63A Drinking Fountain-Outside Floor 1 Elevator #2	7/1/2016 19:39	7/12/2016 08:25	10354477125	Copper	0.7	1.3	ppm
013-63A Drinking Fountain-Outside Floor 1 Elevator #2	7/1/2016 19:39	7/11/2016 23:00	10354477125	Lead	1	15	ppb
013-64A Sink Faucet-Womens Bathroom Left	7/1/2016 19:41	7/11/2016 23:02	10354477127	Copper	0.2	1.3	ppm
013-64A Sink Faucet-Womens Bathroom Left	7/1/2016 19:41	7/11/2016 23:02	10354477127	Lead	1	15	ppb
013-65A Sink Faucet-Womens Bathroom Middle	7/1/2016 19:43	7/11/2016 23:03	10354477129	Copper	0.2	1.3	ppm
013-65A Sink Faucet-Womens Bathroom Middle	7/1/2016 19:43	7/11/2016 23:03	10354477129	Lead	2	15	ppb
013-66A Sink Faucet-Womens Bathroom Right	7/1/2016 19:45	7/11/2016 23:04	10354477131	Copper	0.1	1.3	ppm
013-66A Sink Faucet-Womens Bathroom Right	7/1/2016 19:45	7/11/2016 23:04	10354477131	Lead	1	15	ppb
013-67A Sink Faucet-Mens Bathroom #1	7/1/2016 19:50	7/11/2016 23:08	10354477133	Copper	0.2	1.3	ppm
013-67A Sink Faucet-Mens Bathroom #1	7/1/2016 19:50	7/11/2016 23:08	10354477133	Lead	1	15	ppb
013-68A Sink Faucet-Mens Bathroom #2	7/1/2016 19:52	7/11/2016 23:10	10354477135	Copper	0.2	1.3	ppm
013-68A Sink Faucet-Mens Bathroom #2	7/1/2016 19:52	7/11/2016 23:10	10354477135	Lead	3	15	ppb
013-69A Sink Faucet-Mens Bathroom #3	7/1/2016 19:54	7/11/2016 23:11	10354477137	Copper	0.3	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
BESC - Portland Public Schools

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
013-69A Sink Faucet-Mens Bathroom #3	7/1/2016 19:54	7/11/2016 23:11	10354477137	Lead	1	15	ppb
013-70A Mop Sink-Outside Room 160	7/1/2016 19:58	7/11/2016 23:13	10354477139	Copper	0.3	1.3	ppm
013-70A Mop Sink-Outside Room 160	7/1/2016 19:58	7/11/2016 23:13	10354477139	Lead	4	15	ppb
013-71A Sink Faucet-Room 150 Bathroom	7/1/2016 20:00	7/11/2016 23:14	10354477141	Copper	0.4	1.3	ppm
013-71A Sink Faucet-Room 150 Bathroom	7/1/2016 20:00	7/11/2016 23:14	10354477141	Lead	14	15	ppb
013-72A Sink Faucet-Facilities Property Management	7/1/2016 20:08	7/11/2016 23:17	10354477143	Copper	0.1	1.3	ppm
013-72A Sink Faucet-Facilities Property Management	7/1/2016 20:08	7/11/2016 23:17	10354477143	Lead	9	15	ppb
013-73A Sink Faucet-Electronics Room	7/1/2016 20:10	7/11/2016 23:18	10354477145	Copper	0.3	1.3	ppm
013-73A Sink Faucet-Electronics Room	7/1/2016 20:10	7/11/2016 23:18	10354477145	Lead	2	15	ppb
013-74A Sink Faucet-Mens Bathroom Left	7/1/2016 20:12	7/11/2016 23:19	10354477147	Copper	0.0	1.3	ppm
013-74A Sink Faucet-Mens Bathroom Left	7/1/2016 20:12	7/11/2016 23:19	10354477147	Lead	0	15	ppb
013-75A Sink Faucet-Mens Bathroom Right	7/1/2016 20:14	7/11/2016 23:21	10354477149	Copper	0.0	1.3	ppm
013-75A Sink Faucet-Mens Bathroom Right	7/1/2016 20:14	7/11/2016 23:21	10354477149	Lead	1	15	ppb
013-76A Sink Faucet-Womens Bathroom	7/1/2016 20:16	7/11/2016 23:28	10354477151	Copper	0.1	1.3	ppm
013-76A Sink Faucet-Womens Bathroom	7/1/2016 20:16	7/11/2016 23:28	10354477151	Lead	1	15	ppb
013-77A Sink Faucet-Music Room	7/1/2016 20:18	7/11/2016 23:29	10354477153	Copper	0.3	1.3	ppm
013-77A Sink Faucet-Music Room	7/1/2016 20:18	7/11/2016 23:29	10354477153	Lead	4	15	ppb
013-78A Kitchen Sink Faucet-Music Room	7/1/2016 20:20	7/11/2016 23:30	10354477155	Copper	0.1	1.3	ppm
013-78A Kitchen Sink Faucet-Music Room	7/1/2016 20:20	7/11/2016 23:30	10354477155	Lead	1	15	ppb
013-79A Sprayer-Music Room	7/1/2016 20:22	7/11/2016 23:32	10354477157	Copper	0.3	1.3	ppm
013-79A Sprayer-Music Room	7/1/2016 20:22	7/11/2016 23:32	10354477157	Lead	0	15	ppb
013-80A Mop Sink-Outside Music Room	7/1/2016 20:24	7/12/2016 01:45	10354477159	Copper	0.2	1.3	ppm
013-80A Mop Sink-Outside Music Room	7/1/2016 20:24	7/12/2016 01:45	10354477159	Lead	6	15	ppb
013-81A Drinking Fountain-Outside Music Room	7/1/2016 20:26	7/10/2016 21:23	10354477161	Copper	1.9	1.3	ppm
013-81A Drinking Fountain-Outside Music Room	7/1/2016 20:26	7/10/2016 19:11	10354477161	Lead	6	15	ppb
013-82A Sink Faucet-TV Service Room	7/1/2016 20:31	7/10/2016 19:16	10354477163	Copper	0.3	1.3	ppm
013-82A Sink Faucet-TV Service Room	7/1/2016 20:31	7/10/2016 19:16	10354477163	Lead	6	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
BESC - Portland Public Schools

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
013-83A Sink Faucet-Womens Bathroom	7/1/2016 20:34	7/10/2016 19:17	10354477165	Copper	0.4	1.3	ppm
013-83A Sink Faucet-Womens Bathroom	7/1/2016 20:34	7/10/2016 19:17	10354477165	Lead	1	15	ppb
013-84A Shower-Womens Bathroom	7/1/2016 20:36	7/10/2016 19:18	10354477167	Copper	0.2	1.3	ppm
013-84A Shower-Womens Bathroom	7/1/2016 20:36	7/10/2016 19:18	10354477167	Lead	2	15	ppb
013-85A Sink Faucet-Mens Bathroom	7/1/2016 20:38	7/10/2016 19:20	10354477169	Copper	0.3	1.3	ppm
013-85A Sink Faucet-Mens Bathroom	7/1/2016 20:38	7/10/2016 19:20	10354477169	Lead	1	15	ppb
013-86A Shower-Mens Bathroom	7/1/2016 20:40	7/10/2016 19:26	10354477171	Copper	0.3	1.3	ppm
013-86A Shower-Mens Bathroom	7/1/2016 20:40	7/10/2016 19:26	10354477171	Lead	2	15	ppb
013-87A Mop Sink-Custodial	7/1/2016 20:42	7/10/2016 19:27	10354477173	Copper	0.1	1.3	ppm
013-87A Mop Sink-Custodial	7/1/2016 20:42	7/10/2016 19:27	10354477173	Lead	7	15	ppb
013-88A Sink Faucet-Womens Bathroom Left	7/1/2016 20:45	7/10/2016 19:29	10354477175	Copper	0.2	1.3	ppm
013-88A Sink Faucet-Womens Bathroom Left	7/1/2016 20:45	7/10/2016 19:29	10354477175	Lead	3	15	ppb
013-89A Sink Faucet-Womens Bathroom Right	7/1/2016 20:47	7/10/2016 19:30	10354477177	Copper	0.3	1.3	ppm
013-89A Sink Faucet-Womens Bathroom Right	7/1/2016 20:47	7/10/2016 19:30	10354477177	Lead	6	15	ppb
013-90A Sink Faucet-Mens Bathroom	7/1/2016 20:49	7/10/2016 19:31	10354477179	Copper	0.2	1.3	ppm
013-90A Sink Faucet-Mens Bathroom	7/1/2016 20:49	7/10/2016 19:31	10354477179	Lead	1	15	ppb
013-91A Sink Faucet(semi)-Mens Bathroom	7/1/2016 20:51	7/10/2016 19:32	10354477181	Copper	0.1	1.3	ppm
013-91A Sink Faucet(semi)-Mens Bathroom	7/1/2016 20:51	7/10/2016 19:32	10354477181	Lead	1	15	ppb
013-92A Shower-Mens Bathroom	7/1/2016 20:53	7/10/2016 19:34	10354477183	Copper	0.0	1.3	ppm
013-92A Shower-Mens Bathroom	7/1/2016 20:53	7/10/2016 19:34	10354477183	Lead	1	15	ppb
013-93A Sink Faucet-Storage Room	7/1/2016 20:55	7/10/2016 19:36	10354477185	Copper	0.2	1.3	ppm
013-93A Sink Faucet-Storage Room	7/1/2016 20:55	7/10/2016 19:36	10354477185	Lead	11	15	ppb
013-94A Sink Faucet-Across Dispatch	7/1/2016 20:57	7/10/2016 19:37	10354477187	Copper	0.1	1.3	ppm
013-94A Sink Faucet-Across Dispatch	7/1/2016 20:57	7/10/2016 19:37	10354477187	Lead	2	15	ppb
013-95A Sink Faucet-Metal Machinery Room	7/1/2016 21:00	7/10/2016 19:40	10354477189	Copper	0.2	1.3	ppm
013-95A Sink Faucet-Metal Machinery Room	7/1/2016 21:00	7/10/2016 19:40	10354477189	Lead	4	15	ppb
013-96A Sprayer-Metal Machinery Room	7/1/2016 21:02	7/10/2016 19:42	10354477191	Copper	0.1	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
BESC - Portland Public Schools

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
013-96A Sprayer-Metal Machinery Room	7/1/2016 21:02	7/10/2016 19:42	10354477191	Lead	4	15	ppb
013-97A Sink Faucet(semi)-Metal Machinery Room	7/1/2016 21:04	7/10/2016 19:43	10354477193	Copper	0.2	1.3	ppm
013-97A Sink Faucet(semi)-Metal Machinery Room	7/1/2016 21:04	7/10/2016 19:43	10354477193	Lead	1	15	ppb
013-98A Sprayer-Metal Machinery Room	7/1/2016 21:06	7/10/2016 19:44	10354477195	Copper	0.2	1.3	ppm
013-98A Sprayer-Metal Machinery Room	7/1/2016 21:06	7/10/2016 19:44	10354477195	Lead	24	15	ppb
013-99A Sink Faucet-Womens Bathroom #1	7/1/2016 21:10	7/10/2016 21:25	10354477197	Copper	0.7	1.3	ppm
013-99A Sink Faucet-Womens Bathroom #1	7/1/2016 21:10	7/10/2016 19:45	10354477197	Lead	2	15	ppb
013-100A Sink Faucet-Womens Bathroom #2	7/1/2016 21:12	7/10/2016 21:26	10354477199	Copper	0.8	1.3	ppm
013-100A Sink Faucet-Womens Bathroom #2	7/1/2016 21:12	7/10/2016 19:46	10354477199	Lead	4	15	ppb
013-101A Shower-Womens Bathroom	7/1/2016 21:14	7/10/2016 19:50	10354477201	Copper	0.2	1.3	ppm
013-101A Shower-Womens Bathroom	7/1/2016 21:14	7/10/2016 19:50	10354477201	Lead	1	15	ppb
013-102A Mop Sink-Between Men/Womens Bathroom	7/1/2016 21:16	7/12/2016 08:52	10354477203	Copper	0.5	1.3	ppm
013-102A Mop Sink-Between Men/Womens Bathroom	7/1/2016 21:16	7/12/2016 01:46	10354477203	Lead	16	15	ppb
013-103A Sink Faucet(Semi)-Mens Bathroom	7/1/2016 21:18	7/10/2016 19:57	10354477205	Copper	0.3	1.3	ppm
013-103A Sink Faucet(Semi)-Mens Bathroom	7/1/2016 21:18	7/10/2016 19:57	10354477205	Lead	2	15	ppb
013-104A Showers-Mens Bathroom	7/1/2016 21:20	7/10/2016 21:32	10354477207	Copper	0.5	1.3	ppm
013-104A Showers-Mens Bathroom	7/1/2016 21:20	7/10/2016 19:59	10354477207	Lead	1	15	ppb
013-105A Drinking Fountain-Metal/Machine Shop	7/1/2016 21:22	7/10/2016 20:00	10354477209	Copper	0.1	1.3	ppm
013-105A Drinking Fountain-Metal/Machine Shop	7/1/2016 21:22	7/10/2016 20:00	10354477209	Lead	0	15	ppb
013-106A Sink Faucet-Metal/Machine Shop	7/1/2016 21:24	7/10/2016 20:02	10354477211	Copper	0.1	1.3	ppm
013-106A Sink Faucet-Metal/Machine Shop	7/1/2016 21:24	7/10/2016 20:02	10354477211	Lead	7	15	ppb
013-107A Drinking Fountain-Multnomah County Hallway	7/1/2016 21:26	7/10/2016 20:03	10354477213	Copper	0.4	1.3	ppm
013-107A Drinking Fountain-Multnomah County Hallway	7/1/2016 21:26	7/10/2016 20:03	10354477213	Lead	0	15	ppb
013-108A Water Dispenser-Multnomah County Hallway	7/1/2016 21:28	7/10/2016 20:04	10354477215	Copper	0.4	1.3	ppm
013-108A Water Dispenser-Multnomah County Hallway	7/1/2016 21:28	7/10/2016 20:04	10354477215	Lead	0	15	ppb
013-109A Sink Faucet-Glazing Room #1	7/1/2016 21:30	7/10/2016 20:05	10354477217	Copper	0.3	1.3	ppm
013-109A Sink Faucet-Glazing Room #1	7/1/2016 21:30	7/10/2016 20:05	10354477217	Lead	12	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
BESC - Portland Public Schools

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
013-110A Sprayer-Glazing Room	7/1/2016 21:32	7/10/2016 20:06	10354477219	Copper	0.1	1.3	ppm
013-110A Sprayer-Glazing Room	7/1/2016 21:32	7/10/2016 20:06	10354477219	Lead	25	15	ppb
013-111A Sink Faucet-Glazing Room #2	7/1/2016 21:34	7/10/2016 20:10	10354477221	Copper	0.2	1.3	ppm
013-111A Sink Faucet-Glazing Room #2	7/1/2016 21:34	7/10/2016 20:10	10354477221	Lead	7	15	ppb
013-112A Sink Faucet-Carpentry Room #1	7/1/2016 21:40	7/10/2016 20:12	10354477223	Copper	0.3	1.3	ppm
013-112A Sink Faucet-Carpentry Room #1	7/1/2016 21:40	7/10/2016 20:12	10354477223	Lead	5	15	ppb
013-113A Drinking Fountain-Carpentry Room	7/1/2016 21:42	7/10/2016 21:33	10354477225	Copper	2.0	1.3	ppm
013-113A Drinking Fountain-Carpentry Room	7/1/2016 21:42	7/10/2016 20:14	10354477225	Lead	12	15	ppb
013-114A Spigot-Carpentry Room	7/1/2016 21:44	7/10/2016 20:15	10354477227	Copper	0.2	1.3	ppm
013-114A Spigot-Carpentry Room	7/1/2016 21:44	7/10/2016 20:15	10354477227	Lead	7	15	ppb
013-115A Sink Faucet-Carpentry Room #2	7/1/2016 21:46	7/10/2016 20:16	10354477229	Copper	0.3	1.3	ppm
013-115A Sink Faucet-Carpentry Room #2	7/1/2016 21:46	7/10/2016 20:16	10354477229	Lead	16	15	ppb
013-116A Sprayer-Carpentry Room	7/1/2016 21:48	7/10/2016 20:17	10354477231	Copper	0.1	1.3	ppm
013-116A Sprayer-Carpentry Room	7/1/2016 21:48	7/10/2016 20:17	10354477231	Lead	5	15	ppb
013-117A Drinking Fountain-Room 203 Human Resources	7/1/2016 21:55	7/10/2016 21:34	10354477233	Copper	0.7	1.3	ppm
013-117A Drinking Fountain-Room 203 Human Resources	7/1/2016 21:55	7/10/2016 20:19	10354477233	Lead	0	15	ppb
013-118A Water Dispenser-Room 203 Human Resources	7/1/2016 21:57	7/10/2016 21:35	10354477235	Copper	0.8	1.3	ppm
013-118A Water Dispenser-Room 203 Human Resources	7/1/2016 21:57	7/10/2016 20:20	10354477235	Lead	0	15	ppb
013-119A Sink Faucet-Unisex Bathroom	7/1/2016 22:00	7/10/2016 20:21	10354477237	Copper	0.3	1.3	ppm
013-119A Sink Faucet-Unisex Bathroom	7/1/2016 22:00	7/10/2016 20:21	10354477237	Lead	1	15	ppb
013-120A Sink Faucet-Outside Unisex Bathroom	7/1/2016 22:02	7/10/2016 20:31	10354477239	Copper	0.3	1.3	ppm
013-120A Sink Faucet-Outside Unisex Bathroom	7/1/2016 22:02	7/10/2016 20:31	10354477239	Lead	3	15	ppb
013-121A Sink Faucet-Room Adjacent to Sign	7/1/2016 22:04	7/12/2016 02:30	10354477241	Copper	0.4	1.3	ppm
013-121A Sink Faucet-Room Adjacent to Sign	7/1/2016 22:04	7/12/2016 02:30	10354477241	Lead	4	15	ppb
013-122A Drinking Fountain-Adjacent to Sign	7/1/2016 22:07	7/12/2016 09:25	10354477243	Copper	1.30	1.3	ppm
013-122A Drinking Fountain-Adjacent to Sign	7/1/2016 22:07	7/12/2016 02:35	10354477243	Lead	0	15	ppb
013-123A Water Bottle Dispenser-Adjacent to Sign	7/1/2016 22:09	7/12/2016 09:29	10354477245	Copper	1.1	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
BESC - Portland Public Schools

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
013-123A Water Bottle Dispenser-Adjacent to Sign	7/1/2016 22:09	7/12/2016 02:37	10354477245	Lead	0	15	ppb
013-124A Sink Faucet-Print Room	7/1/2016 22:11	7/12/2016 02:41	10354477247	Copper	0.2	1.3	ppm
013-124A Sink Faucet-Print Room	7/1/2016 22:11	7/12/2016 02:41	10354477247	Lead	2	15	ppb
013-125A Sink Faucet-Womens Bathroom	7/1/2016 22:15	7/12/2016 02:42	10354477249	Copper	0.1	1.3	ppm
013-125A Sink Faucet-Womens Bathroom	7/1/2016 22:15	7/12/2016 02:42	10354477249	Lead	0	15	ppb
013-126A Drinking Fountain-Between Men/Womens	7/1/2016 22:17	7/12/2016 09:30	10354477251	Copper	2.0	1.3	ppm
013-126A Drinking Fountain-Between Men/Womens	7/1/2016 22:17	7/12/2016 02:44	10354477251	Lead	16	15	ppb
013-127A Sink/Faucet-Men Bathroom	7/1/2016 22:19	7/12/2016 02:45	10354477253	Copper	0.3	1.3	ppm
013-127A Sink/Faucet-Men Bathroom	7/1/2016 22:19	7/12/2016 02:45	10354477253	Lead	2	15	ppb
013-128A Sink/Faucet-Mahonda Conference Room	7/1/2016 22:21	7/12/2016 09:32	10354477255	Copper	0.8	1.3	ppm
013-128A Sink/Faucet-Mahonda Conference Room	7/1/2016 22:21	7/12/2016 02:46	10354477255	Lead	28	15	ppb
013-129A Sink/Faucet-Roof Access Room adjacent to Elevator 2	7/1/2016 22:23	7/12/2016 02:48	10354477257	Copper	0.3	1.3	ppm
013-129A Sink/Faucet-Roof Access Room adjacent to Elevator 2	7/1/2016 22:23	7/12/2016 02:48	10354477257	Lead	7	15	ppb
013-130A Mop Sink-Roof Access Room adjacent to Elevator 2	7/1/2016 22:25	7/12/2016 02:49	10354477259	Copper	0.4	1.3	ppm
013-130A Mop Sink-Roof Access Room adjacent to Elevator 2	7/1/2016 22:25	7/12/2016 02:49	10354477259	Lead	2	15	ppb
013-131A Sink Faucet-Men Bathroom #1	7/1/2016 22:27	7/12/2016 02:50	10354477261	Copper	0.2	1.3	ppm
013-131A Sink Faucet-Men Bathroom #1	7/1/2016 22:27	7/12/2016 02:50	10354477261	Lead	1	15	ppb
013-132A Sink Faucet-Men Bathroom #2	7/1/2016 22:29	7/12/2016 02:53	10354477263	Copper	0.2	1.3	ppm
013-132A Sink Faucet-Men Bathroom #2	7/1/2016 22:29	7/12/2016 02:53	10354477263	Lead	3	15	ppb
013-133A Sink Faucet-Men Bathroom #3	7/1/2016 22:33	7/12/2016 03:00	10354477265	Copper	0.2	1.3	ppm
013-133A Sink Faucet-Men Bathroom #3	7/1/2016 22:33	7/12/2016 03:00	10354477265	Lead	6	15	ppb
013-134A Sink Faucet-Womens Bathroom Left	7/1/2016 22:35	7/12/2016 03:01	10354477267	Copper	0.2	1.3	ppm
013-134A Sink Faucet-Womens Bathroom Left	7/1/2016 22:35	7/12/2016 03:01	10354477267	Lead	3	15	ppb
013-135A Sink Faucet-Womens Bathroom Middle	7/1/2016 22:37	7/12/2016 03:03	10354477269	Copper	0.2	1.3	ppm
013-135A Sink Faucet-Womens Bathroom Middle	7/1/2016 22:37	7/12/2016 03:03	10354477269	Lead	5	15	ppb
013-136A Sink Faucet-Womens Bathroom Right	7/1/2016 22:39	7/12/2016 03:04	10354477271	Copper	0.2	1.3	ppm
013-136A Sink Faucet-Womens Bathroom Right	7/1/2016 22:39	7/12/2016 03:04	10354477271	Lead	3	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
BESC - Portland Public Schools

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
013-137A Sink Faucet-Deli Room	7/1/2016 22:41	7/12/2016 03:05	10354477273	Copper	0.3	1.3	ppm
013-137A Sink Faucet-Deli Room	7/1/2016 22:41	7/12/2016 03:05	10354477273	Lead	0	15	ppb
013-138A Sprayer-Deli Room	7/1/2016 22:43	7/12/2016 03:07	10354477275	Copper	0.1	1.3	ppm
013-138A Sprayer-Deli Room	7/1/2016 22:43	7/12/2016 03:07	10354477275	Lead	1	15	ppb
013-139A Water Dispenser (Soda)	7/1/2016 22:45	7/12/2016 03:08	10354477277	Copper	0.0	1.3	ppm
013-139A Water Dispenser (Soda)	7/1/2016 22:45	7/12/2016 03:08	10354477277	Lead	0	15	ppb
013-140A Ice Dispenser (Soda)	7/1/2016 22:47	7/12/2016 03:09	10354477279	Copper	0.0	1.3	ppm
013-140A Ice Dispenser (Soda)	7/1/2016 22:47	7/12/2016 03:09	10354477279	Lead	0	15	ppb
013-141A Spigot-Fleet Garage #1	7/1/2016 22:50	7/12/2016 08:56	10354477281	Copper	0.9	1.3	ppm
013-141A Spigot-Fleet Garage #1	7/1/2016 22:50	7/12/2016 01:47	10354477281	Lead	36	15	ppb
013-142A Eye Wash Sprayer-Fleet Garage #1	7/1/2016 22:52	7/12/2016 09:40	10354477283	Copper	0.4	1.3	ppm
013-142A Eye Wash Sprayer-Fleet Garage #1	7/1/2016 22:52	7/12/2016 01:52	10354477283	Lead	14.7	15	ppb
013-143A Spigot-Fleet Garage #2	7/1/2016 22:54	7/12/2016 08:58	10354477285	Copper	0.6	1.3	ppm
013-143A Spigot-Fleet Garage #2	7/1/2016 22:54	7/12/2016 01:53	10354477285	Lead	76	15	ppb
013-144A Eye Wash Sprayer-Fleet Garage #2	7/1/2016 22:56	7/12/2016 09:00	10354477287	Copper	1.5	1.3	ppm
013-144A Eye Wash Sprayer-Fleet Garage #2	7/1/2016 22:56	7/12/2016 01:54	10354477287	Lead	74	15	ppb
013-145A Spigot-Fleet Garage #3	7/1/2016 22:58	7/12/2016 09:01	10354477289	Copper	0.1	1.3	ppm
013-145A Spigot-Fleet Garage #3	7/1/2016 22:58	7/12/2016 09:01	10354477289	Lead	2	15	ppb
013-146A Spigot-Fleet Garage #4	7/1/2016 23:00	7/12/2016 09:36	10354477291	Copper	0.7	1.3	ppm
013-146A Spigot-Fleet Garage #4	7/1/2016 23:00	7/12/2016 03:24	10354477291	Lead	13	15	ppb
013-147A Spigot-Fleet Garage #5	7/1/2016 23:02	7/12/2016 03:26	10354477293	Copper	0.2	1.3	ppm
013-147A Spigot-Fleet Garage #5	7/1/2016 23:02	7/12/2016 03:26	10354477293	Lead	2	15	ppb
013-148A Sink Faucet-Breakroom Upstairs	7/1/2016 23:04	7/12/2016 09:04	10354477295	Copper	2.4	1.3	ppm
013-148A Sink Faucet-Breakroom Upstairs	7/1/2016 23:04	7/12/2016 09:04	10354477295	Lead	607	15	ppb
013-149A Sink Faucet-Bathroom Upstairs	7/1/2016 23:06	7/12/2016 09:37	10354477297	Copper	0.9	1.3	ppm
013-149A Sink Faucet-Bathroom Upstairs	7/1/2016 23:06	7/12/2016 03:27	10354477297	Lead	6	15	ppb
013-150A Spigot-401 Dixon Loading Docks	7/1/2016 23:20	7/12/2016 03:31	10354477299	Copper	0.5	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
BESC - Portland Public Schools

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
013-150A Spigot-401 Dixon Loading Docks	7/1/2016 23:20	7/12/2016 03:31	10354477299	Lead	32	15	ppb
013-151A Spigot-Loading Dock L2 Bay 10/11	7/1/2016 23:22	7/12/2016 09:39	10354477301	Copper	0.8	1.3	ppm
013-151A Spigot-Loading Dock L2 Bay 10/11	7/1/2016 23:22	7/12/2016 03:33	10354477301	Lead	17	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

ND = Non detect

Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.