

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Boise-Eliot Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
017-01A Boiler Room Restroom Sink	6/23/16 8:55	7/1/16 17:01	606242701	Copper	0.2	1.3	ppm
017-01A Boiler Room Restroom Sink	6/23/16 8:55	7/1/16 17:01	606242701	Lead	1	15	ppb
017-02A Kitchen Sink Faucet	6/23/16 8:58	7/1/16 17:01	606242702	Copper	0.3	1.3	ppm
017-02A Kitchen Sink Faucet	6/23/16 8:58	7/1/16 17:01	606242702	Lead	4	15	ppb
017-03A Kitchen Spray	6/23/16 9:00	7/1/16 17:01	606242703	Copper	0.2	1.3	ppm
017-03A Kitchen Spray	6/23/16 9:00	7/1/16 17:01	606242703	Lead	2	15	ppb
017-04A Kitchen Sink Spray	6/23/16 9:05	7/1/16 17:01	606242704	Copper	0.2	1.3	ppm
017-04A Kitchen Sink Spray	6/23/16 9:05	7/1/16 17:01	606242704	Lead	9	15	ppb
017-05A Locker Room Sink	6/23/16 9:01	7/1/16 17:01	606242705	Copper	0.5	1.3	ppm
017-05A Locker Room Sink	6/23/16 9:01	7/1/16 17:01	606242705	Lead	4	15	ppb
017-06A 111B Staff Restroom Sink	6/23/16 9:07	7/1/16 17:01	606242706	Copper	0.6	1.3	ppm
017-06A 111B Staff Restroom Sink	6/23/16 9:07	7/1/16 17:01	606242706	Lead	3	15	ppb
017-07A Janitors Closet	6/23/16 9:11	7/1/16 17:02	606242707	Copper	0.2	1.3	ppm
017-07A Janitors Closet	6/23/16 9:11	7/1/16 17:02	606242707	Lead	13	15	ppb
017-08A Girls Restroom Sink	6/23/16 9:16	7/1/16 17:02	606242708	Copper	0.3	1.3	ppm
017-08A Girls Restroom Sink	6/23/16 9:16	7/1/16 17:02	606242708	Lead	1	15	ppb
017-09A Girls Restroom Sink	6/23/16 9:16	7/1/16 17:02	606242709	Copper	0.2	1.3	ppm
017-09A Girls Restroom Sink	6/23/16 9:16	7/1/16 17:02	606242709	Lead	4	15	ppb
017-10A Girls Restroom Spigot	6/23/16 9:21	6/30/16 18:40	606242710	Copper	6.7	1.3	ppm
017-10A Girls Restroom Spigot	6/23/16 9:21	6/30/16 18:40	606242710	Lead	306	15	ppb
017-11A Boys Restroom Sink	6/23/16 9:15	7/1/16 17:02	606242711	Copper	0.4	1.3	ppm
017-11A Boys Restroom Sink	6/23/16 9:15	7/1/16 17:02	606242711	Lead	5	15	ppb
017-12A Boys Restroom Sink	6/23/16 9:15	7/1/16 17:02	606242712	Copper	0.3	1.3	ppm
017-12A Boys Restroom Sink	6/23/16 9:15	7/1/16 17:02	606242712	Lead	5	15	ppb
017-13A Boys Restroom Spigot	6/23/16 9:24	7/1/16 17:24	606242713	Copper	2.1	1.3	ppm
017-13A Boys Restroom Spigot	6/23/16 9:24	7/1/16 17:24	606242713	Lead	163	15	ppb
017-14A Hallway Sink	6/23/16 9:19	7/1/16 17:02	606242714	Copper	0.4	1.3	ppm
017-14A Hallway Sink	6/23/16 9:19	7/1/16 17:02	606242714	Lead	14	15	ppb
017-15A Room 100 Sink	6/23/16 9:23	7/1/16 17:02	606242715	Copper	0.3	1.3	ppm
017-15A Room 100 Sink	6/23/16 9:23	7/1/16 17:02	606242715	Lead	11	15	ppb
017-16A Room 100 Drinking Fountain	6/23/16 9:23	7/1/16 17:02	606242716	Copper	0.5	1.3	ppm
017-16A Room 100 Drinking Fountain	6/23/16 9:23	7/1/16 17:02	606242716	Lead	4	15	ppb
017-17A Room 102 Sink	6/23/16 9:28	7/1/16 17:02	606242717	Copper	0.4	1.3	ppm
017-17A Room 102 Sink	6/23/16 9:28	7/1/16 17:02	606242717	Lead	14.7	15	ppb
017-18A Room 102 Drinking Fountain	6/23/16 9:28	7/1/16 17:02	606242718	Copper	0.5	1.3	ppm
017-18A Room 102 Drinking Fountain	6/23/16 9:28	7/1/16 17:02	606242718	Lead	5	15	ppb
017-19A Room 104 Sink	6/23/16 9:29	7/1/16 17:02	606242719	Copper	0.4	1.3	ppm
017-19A Room 104 Sink	6/23/16 9:29	7/1/16 17:02	606242719	Lead	13	15	ppb
017-20A Room 104 Drinking Fountain	6/23/16 9:30	7/1/16 17:03	606242720	Copper	0.2	1.3	ppm
017-20A Room 104 Drinking Fountain	6/23/16 9:30	7/1/16 17:03	606242720	Lead	5	15	ppb
017-21A Faculty Work Room Sink	6/23/16 9:45	7/1/16 17:03	606242721	Copper	0.4	1.3	ppm
017-21A Faculty Work Room Sink	6/23/16 9:45	7/1/16 17:03	606242721	Lead	9	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Boise-Eliot Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
017-22A Faculty Work Room Drinking Fountain	6/23/16 9:45	7/1/16 17:03	606242722	Copper	0.6	1.3	ppm
017-22A Faculty Work Room Drinking Fountain	6/23/16 9:45	7/1/16 17:03	606242722	Lead	6	15	ppb
017-23A Staff Restroom Sink	6/23/16 9:52	7/1/16 17:03	606242723	Copper	0.3	1.3	ppm
017-23A Staff Restroom Sink	6/23/16 9:52	7/1/16 17:03	606242723	Lead	4	15	ppb
017-24A Media Center Sink	6/23/16 9:49	7/1/16 17:03	606242724	Copper	0.4	1.3	ppm
017-24A Media Center Sink	6/23/16 9:49	7/1/16 17:03	606242724	Lead	29	15	ppb
017-25A Room 120 Sink	6/23/16 9:57	7/1/16 17:03	606242725	Copper	0.4	1.3	ppm
017-25A Room 120 Sink	6/23/16 9:57	7/1/16 17:03	606242725	Lead	4	15	ppb
017-26A Room 120 Drinking Fountain	6/23/16 9:57	7/1/16 17:03	606242726	Copper	0.5	1.3	ppm
017-26A Room 120 Drinking Fountain	6/23/16 9:57	7/1/16 17:03	606242726	Lead	2	15	ppb
017-27A Room 122 Sink	6/23/16 9:57	7/1/16 17:04	606242727	Copper	0.6	1.3	ppm
017-27A Room 122 Sink	6/23/16 9:57	7/1/16 17:04	606242727	Lead	7	15	ppb
017-28A Room 122 Drinking Fountain	6/23/16 9:57	7/1/16 17:04	606242728	Copper	0.6	1.3	ppm
017-28A Room 122 Drinking Fountain	6/23/16 9:57	7/1/16 17:04	606242728	Lead	4	15	ppb
017-29A Room 124 Sink	6/23/16 10:03	7/1/16 17:04	606242729	Copper	0.5	1.3	ppm
017-29A Room 124 Sink	6/23/16 10:03	7/1/16 17:04	606242729	Lead	6	15	ppb
017-30A Room 124 Drinking Fountain	6/23/16 10:03	7/1/16 17:04	606242730	Copper	0.7	1.3	ppm
017-30A Room 124 Drinking Fountain	6/23/16 10:03	7/1/16 17:04	606242730	Lead	5	15	ppb
017-31A Room 126 Sink	6/23/16 10:03	7/1/16 17:04	606242731	Copper	0.4	1.3	ppm
017-31A Room 126 Sink	6/23/16 10:03	7/1/16 17:04	606242731	Lead	10	15	ppb
017-32A Room 126 Drinking Fountain	6/23/16 10:03	7/1/16 17:04	606242732	Copper	0.6	1.3	ppm
017-32A Room 126 Drinking Fountain	6/23/16 10:03	7/1/16 17:04	606242732	Lead	4	15	ppb
017-33A Room 128 Sink	6/23/16 10:08	7/1/16 17:04	606242733	Copper	0.4	1.3	ppm
017-33A Room 128 Sink	6/23/16 10:08	7/1/16 17:04	606242733	Lead	4	15	ppb
017-34A Room 128 Drinking Fountain	6/23/16 10:08	7/1/16 17:04	606242734	Copper	0.5	1.3	ppm
017-34A Room 128 Drinking Fountain	6/23/16 10:08	7/1/16 17:04	606242734	Lead	3	15	ppb
017-35A Room 138 Sink	6/23/16 10:08	7/1/16 17:05	606242735	Copper	0.2	1.3	ppm
017-35A Room 138 Sink	6/23/16 10:08	7/1/16 17:05	606242735	Lead	6	15	ppb
017-36A Room 138 Drinking Fountain	6/23/16 10:08	7/1/16 17:05	606242736	Copper	0.5	1.3	ppm
017-36A Room 138 Drinking Fountain	6/23/16 10:08	7/1/16 17:05	606242736	Lead	3	15	ppb
017-37A Room 132 Sink	6/23/16 10:18	7/1/16 17:05	606242737	Copper	0.4	1.3	ppm
017-37A Room 132 Sink	6/23/16 10:18	7/1/16 17:05	606242737	Lead	5	15	ppb
017-38A Room 132 Drinking Fountain	6/23/16 10:18	7/1/16 17:05	606242738	Copper	0.5	1.3	ppm
017-38A Room 132 Drinking Fountain	6/23/16 10:18	7/1/16 17:05	606242738	Lead	4	15	ppb
017-39A Room 10 Day Care Sink	6/23/16 10:26	7/1/16 17:05	606242739	Copper	0.3	1.3	ppm
017-39A Room 10 Day Care Sink	6/23/16 10:26	7/1/16 17:05	606242739	Lead	6	15	ppb
017-40A Room 10 Day Care Restroom Sink	6/23/16 10:27	7/1/16 17:05	606242740	Copper	0.3	1.3	ppm
017-40A Room 10 Day Care Restroom Sink	6/23/16 10:27	7/1/16 17:05	606242740	Lead	1	15	ppb
017-41A Room 10 Day Care Office Sink	6/23/16 10:26	7/1/16 17:05	606242741	Copper	0.3	1.3	ppm
017-41A Room 10 Day Care Office Sink	6/23/16 10:26	7/1/16 17:05	606242741	Lead	25	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Boise-Eliot Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA	Units
						Action Limit	
017-42A Room 142 Sink	6/23/16 10:36	7/1/16 17:06	606242742	Copper	0.2	1.3	ppm
017-42A Room 142 Sink	6/23/16 10:36	7/1/16 17:06	606242742	Lead	6	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Boise-Eliot Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
017-43A Room 142 Drinking Fountain	6/23/16 10:36	7/1/16 17:06	606242743	Copper	0.5	1.3	ppm
017-43A Room 142 Drinking Fountain	6/23/16 10:36	7/1/16 17:06	606242743	Lead	3	15	ppb
017-44A Open Area Sink	6/23/16 10:18	7/1/16 17:06	606242744	Copper	0.3	1.3	ppm
017-44A Open Area Sink	6/23/16 10:18	7/1/16 17:06	606242744	Lead	8	15	ppb
017-45A Open Area Sink	6/23/16 10:25	7/1/16 17:12	606242745	Copper	0.3	1.3	ppm
017-45A Open Area Sink	6/23/16 10:25	7/1/16 17:12	606242745	Lead	4	15	ppb
017-46A Open Area Sink	6/23/16 10:18	7/1/16 17:13	606242746	Copper	0.4	1.3	ppm
017-46A Open Area Sink	6/23/16 10:18	7/1/16 17:13	606242746	Lead	6	15	ppb
017-47A Custodian Room Sink	6/23/16 10:21	7/1/16 17:13	606242747	Copper	0.2	1.3	ppm
017-47A Custodian Room Sink	6/23/16 10:21	7/1/16 17:13	606242747	Lead	8	15	ppb
017-48A Room 139 Sink	6/23/16 10:32	7/1/16 17:13	606242748	Copper	0.3	1.3	ppm
017-48A Room 139 Sink	6/23/16 10:32	7/1/16 17:13	606242748	Lead	10	15	ppb
017-49A Room 139 Drinking Fountain	6/23/16 10:32	7/1/16 17:13	606242749	Copper	0.3	1.3	ppm
017-49A Room 139 Drinking Fountain	6/23/16 10:32	7/1/16 17:13	606242749	Lead	4	15	ppb
017-50A Room 137 Sink	6/23/16 10:42	7/1/16 17:13	606242750	Copper	0.5	1.3	ppm
017-50A Room 137 Sink	6/23/16 10:42	7/1/16 17:13	606242750	Lead	5	15	ppb
017-51A Room 137 Drinking Fountain	6/23/16 10:42	7/1/16 17:13	606242751	Copper	0.7	1.3	ppm
017-51A Room 137 Drinking Fountain	6/23/16 10:42	7/1/16 17:13	606242751	Lead	3	15	ppb
017-52A Open Area Sink	6/23/16 10:40	7/1/16 17:13	606242752	Copper	0.3	1.3	ppm
017-52A Open Area Sink	6/23/16 10:40	7/1/16 17:13	606242752	Lead	9	15	ppb
017-53A Staff Restroom Sink	6/23/16 10:47	7/1/16 17:13	606242753	Copper	0.3	1.3	ppm
017-53A Staff Restroom Sink	6/23/16 10:47	7/1/16 17:13	606242753	Lead	1	15	ppb
017-54A Janitors Closet Sink	6/23/16 10:52	7/1/16 17:13	606242754	Copper	0.2	1.3	ppm
017-54A Janitors Closet Sink	6/23/16 10:52	7/1/16 17:13	606242754	Lead	6	15	ppb
017-55A Janitors Closet Pipe	6/23/16 10:54	7/1/16 17:14	606242755	Copper	0.1	1.3	ppm
017-55A Janitors Closet Pipe	6/23/16 10:54	7/1/16 17:14	606242755	Lead	21	15	ppb
017-56A Boys Restroom Sink	6/23/16 10:54	7/1/16 17:15	606242756	Copper	0.2	1.3	ppm
017-56A Boys Restroom Sink	6/23/16 10:54	7/1/16 17:15	606242756	Lead	3	15	ppb
017-57A Boys Restroom Spigot	6/23/16 10:52	7/6/16 9:55	606242757	Copper	3.8	1.3	ppm
017-57A Boys Restroom Spigot	6/23/16 10:52	7/1/16 17:15	606242757	Lead	162	15	ppb
017-58A Girls Restroom Sink	6/23/16 10:53	7/1/16 17:15	606242758	Copper	0.1	1.3	ppm
017-58A Girls Restroom Sink	6/23/16 10:53	7/1/16 17:15	606242758	Lead	5	15	ppb
017-59A Girls Restroom Sink	6/23/16 10:53	7/1/16 17:15	606242759	Copper	0.2	1.3	ppm
017-59A Girls Restroom Sink	6/23/16 10:53	7/1/16 17:15	606242759	Lead	3	15	ppb
017-60A Girls Restroom Spigot	6/23/16 10:52	7/1/16 17:24	606242760	Copper	2.2	1.3	ppm
017-60A Girls Restroom Spigot	6/23/16 10:52	7/1/16 17:24	606242760	Lead	262	15	ppb
017-61A Entry Drinking Drinking Fountains	6/23/16 11:00	7/1/16 17:15	606242761	Copper	0.4	1.3	ppm
017-61A Entry Drinking Drinking Fountains	6/23/16 11:00	7/1/16 17:15	606242761	Lead	ND	15	ppb
017-62A Entry Drinking Drinking Fountains	6/23/16 11:04	7/1/16 17:15	606242762	Copper	0.3	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Boise-Eliot Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
017-62A Entry Drinking Drinking Fountains	6/23/16 11:04	7/1/16 17:15	606242762	Lead	ND	15	ppb
017-63A Room 211 Sink	6/23/16 11:11	7/1/16 17:15	606242763	Copper	0.4	1.3	ppm
017-63A Room 211 Sink	6/23/16 11:11	7/1/16 17:15	606242763	Lead	10	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Boise-Eliot Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
017-64A Room 211 Drinking Fountain	6/23/16 11:11	7/1/16 17:15	606242764	Copper	0.7	1.3	ppm
017-64A Room 211 Drinking Fountain	6/23/16 11:11	7/1/16 17:15	606242764	Lead	4	15	ppb
017-65A Open Area Sink	6/23/16 11:15	7/1/16 17:15	606242765	Copper	0.3	1.3	ppm
017-65A Open Area Sink	6/23/16 11:15	7/1/16 17:15	606242765	Lead	20	15	ppb
017-66A Open Area Drinking Fountain	6/23/16 11:15	7/1/16 17:28	606242766	Copper	0.4	1.3	ppm
017-66A Open Area Drinking Fountain	6/23/16 11:15	7/1/16 17:28	606242766	Lead	9	15	ppb
017-67A Janitors Closet Sink	6/23/16 11:15	7/1/16 17:28	606242767	Copper	0.2	1.3	ppm
017-67A Janitors Closet Sink	6/23/16 11:15	7/1/16 17:28	606242767	Lead	5	15	ppb
017-68A Girls Restroom Sink	6/23/16 11:19	7/1/16 17:28	606242768	Copper	0.1	1.3	ppm
017-68A Girls Restroom Sink	6/23/16 11:19	7/1/16 17:28	606242768	Lead	6	15	ppb
017-69A Girls Restroom Sink	6/23/16 11:20	7/1/16 17:28	606242769	Copper	0.3	1.3	ppm
017-69A Girls Restroom Sink	6/23/16 11:20	7/1/16 17:28	606242769	Lead	7	15	ppb
017-70A Girls Restroom Spigot	6/23/16 11:21	7/1/16 17:30	606242770	Copper	0.3	1.3	ppm
017-70A Girls Restroom Spigot	6/23/16 11:21	7/1/16 17:30	606242770	Lead	59	15	ppb
017-71A Boys Restroom Sink	6/23/16 11:21	7/1/16 17:30	606242771	Copper	0.2	1.3	ppm
017-71A Boys Restroom Sink	6/23/16 11:21	7/1/16 17:30	606242771	Lead	4	15	ppb
017-72A Staff Restroom Sink	6/23/16 11:29	7/1/16 17:30	606242772	Copper	0.3	1.3	ppm
017-72A Staff Restroom Sink	6/23/16 11:29	7/1/16 17:30	606242772	Lead	6	15	ppb
017-73A Room 203 Sink	6/23/16 11:31	7/1/16 17:30	606242773	Copper	0.4	1.3	ppm
017-73A Room 203 Sink	6/23/16 11:31	7/1/16 17:30	606242773	Lead	17	15	ppb
017-74A Room 203 Drinking Fountain	6/23/16 11:31	7/1/16 17:31	606242774	Copper	0.6	1.3	ppm
017-74A Room 203 Drinking Fountain	6/23/16 11:31	7/1/16 17:31	606242774	Lead	5	15	ppb
017-75A Room 201 Sink	6/23/16 11:33	7/1/16 17:32	606242775	Copper	0.3	1.3	ppm
017-75A Room 201 Sink	6/23/16 11:33	7/1/16 17:32	606242775	Lead	7	15	ppb
017-76A Room 201 Drinking Fountain	6/23/16 11:33	7/1/16 17:32	606242776	Copper	0.2	1.3	ppm
017-76A Room 201 Drinking Fountain	6/23/16 11:33	7/1/16 17:32	606242776	Lead	2	15	ppb
017-77A Room 202 Sink	6/23/16 11:39	7/1/16 17:33	606242777	Copper	0.3	1.3	ppm
017-77A Room 202 Sink	6/23/16 11:39	7/1/16 17:33	606242777	Lead	6	15	ppb
017-78A Room 202 Drinking Fountain	6/23/16 11:39	7/1/16 17:33	606242778	Copper	0.2	1.3	ppm
017-78A Room 202 Drinking Fountain	6/23/16 11:39	7/1/16 17:33	606242778	Lead	3	15	ppb
017-79A Room 204 Sink	6/23/16 11:43	7/1/16 17:33	606242779	Copper	0.3	1.3	ppm
017-79A Room 204 Sink	6/23/16 11:43	7/1/16 17:33	606242779	Lead	7	15	ppb
017-80A Room 204 Drinking Fountain	6/23/16 11:43	7/1/16 17:33	606242780	Copper	0.1	1.3	ppm
017-80A Room 204 Drinking Fountain	6/23/16 11:43	7/1/16 17:33	606242780	Lead	3	15	ppb
017-81A Room 205 Sink	6/23/16 12:03	7/1/16 17:33	606242781	Copper	0.4	1.3	ppm
017-81A Room 205 Sink	6/23/16 12:03	7/1/16 17:33	606242781	Lead	5	15	ppb
017-82A Room 205 Drinking Fountain	6/23/16 12:03	7/1/16 17:33	606242782	Copper	0.3	1.3	ppm
017-82A Room 205 Drinking Fountain	6/23/16 12:03	7/1/16 17:33	606242782	Lead	3	15	ppb
017-83A Room 212 Sink	6/23/16 11:37	7/1/16 17:34	606242783	Copper	0.3	1.3	ppm
017-83A Room 212 Sink	6/23/16 11:37	7/1/16 17:34	606242783	Lead	5	15	ppb
017-84A Room 212 Drinking Fountain	6/23/16 11:37	7/1/16 17:37	606242784	Copper	0.4	1.3	ppm
017-84A Room 212 Drinking Fountain	6/23/16 11:37	7/1/16 17:37	606242784	Lead	2	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Boise-Eliot Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
017-85A Room 214 Sink	6/23/16 11:09	7/1/16 17:37	606242785	Copper	0.3	1.3	ppm
017-85A Room 214 Sink	6/23/16 11:09	7/1/16 17:37	606242785	Lead	5	15	ppb
017-86A Room 214 Drinking Fountain	6/23/16 11:09	7/1/16 17:37	606242786	Copper	0.6	1.3	ppm
017-86A Room 214 Drinking Fountain	6/23/16 11:09	7/1/16 17:37	606242786	Lead	2	15	ppb
017-87A Hallway Drinking Drinking Fountain	6/23/16 11:26	7/1/16 17:37	606242787	Copper	0.8	1.3	ppm
017-87A Hallway Drinking Drinking Fountain	6/23/16 11:26	7/1/16 17:37	606242787	Lead	1	15	ppb
017-88A Hallway Drinking Drinking Fountain	6/23/16 11:26	7/1/16 17:37	606242788	Copper	1.0	1.3	ppm
017-88A Hallway Drinking Drinking Fountain	6/23/16 11:26	7/1/16 17:37	606242788	Lead	0	15	ppb
017-89A Room 220 Sink	6/23/16 11:56	7/1/16 17:37	606242789	Copper	0.4	1.3	ppm
017-89A Room 220 Sink	6/23/16 11:56	7/1/16 17:37	606242789	Lead	5	15	ppb
017-90A Room 220 Drinking Fountain	6/23/16 11:56	7/1/16 17:37	606242790	Copper	0.9	1.3	ppm
017-90A Room 220 Drinking Fountain	6/23/16 11:56	7/1/16 17:37	606242790	Lead	3	15	ppb
017-91A Room 222 Sink	6/23/16 11:58	7/1/16 17:37	606242791	Copper	0.3	1.3	ppm
017-91A Room 222 Sink	6/23/16 11:58	7/1/16 17:37	606242791	Lead	8	15	ppb
017-92A Room 222 Drinking Fountain	6/23/16 11:58	7/1/16 17:37	606242792	Copper	0.5	1.3	ppm
017-92A Room 222 Drinking Fountain	6/23/16 11:58	7/1/16 17:37	606242792	Lead	2	15	ppb
017-93A Janitors Closet Sink	6/23/16 12:35	7/1/16 17:37	606242793	Copper	0.3	1.3	ppm
017-93A Janitors Closet Sink	6/23/16 12:35	7/1/16 17:37	606242793	Lead	11	15	ppb
017-94A Room 226 Sink	6/23/16 12:10	7/1/16 17:38	606242794	Copper	0.4	1.3	ppm
017-94A Room 226 Sink	6/23/16 12:10	7/1/16 17:38	606242794	Lead	8	15	ppb
017-95A Room 226 Drinking Fountain	6/23/16 12:10	7/1/16 17:38	606242795	Copper	0.4	1.3	ppm
017-95A Room 226 Drinking Fountain	6/23/16 12:10	7/1/16 17:38	606242795	Lead	3	15	ppb
017-96A Room 228 Sink	6/23/16 12:17	7/1/16 17:38	606242796	Copper	0.3	1.3	ppm
017-96A Room 228 Sink	6/23/16 12:17	7/1/16 17:38	606242796	Lead	9	15	ppb
017-97A Room 228 Drinking Fountain	6/23/16 12:17	7/1/16 17:38	606242797	Copper	0.0	1.3	ppm
017-97A Room 228 Drinking Fountain	6/23/16 12:17	7/1/16 17:38	606242797	Lead	1	15	ppb
017-98A Room 230 Sink	6/23/16 12:25	7/1/16 17:38	606242798	Copper	0.4	1.3	ppm
017-98A Room 230 Sink	6/23/16 12:25	7/1/16 17:38	606242798	Lead	0	15	ppb
017-99A Room 230 Drinking Fountain	6/23/16 12:25	7/1/16 17:38	606242799	Copper	0.4	1.3	ppm
017-99A Room 230 Drinking Fountain	6/23/16 12:25	7/1/16 17:38	606242799	Lead	1	15	ppb
017-101A Room 232 Sink	6/23/16 12:42	7/1/16 17:38	6062427100	Copper	0.2	1.3	ppm
017-101A Room 232 Sink	6/23/16 12:42	7/1/16 17:38	6062427100	Lead	0	15	ppb
017-102A Room 232 Sink	6/23/16 12:42	7/1/16 17:38	6062427101	Copper	0.3	1.3	ppm
017-102A Room 232 Sink	6/23/16 12:42	7/1/16 17:38	6062427101	Lead	0	15	ppb
017-103A Room 232 Drinking Fountain	6/23/16 12:43	7/6/16 10:01	6062427102	Copper	1.1	1.3	ppm
017-103A Room 232 Drinking Fountain	6/23/16 12:43	7/1/16 17:38	6062427102	Lead	0	15	ppb
017-105A Room 229 Sink	6/23/16 12:41	7/1/16 17:38	6062427103	Copper	0.4	1.3	ppm
017-105A Room 229 Sink	6/23/16 12:41	7/1/16 17:38	6062427103	Lead	6	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Boise-Eliot Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA	Units
						Action Limit	
017-106A Room 229 Drinking Fountain	6/23/16 12:41	7/5/16 11:27	6062427104	Copper	0.5	1.3	ppm
017-106A Room 229 Drinking Fountain	6/23/16 12:41	7/5/16 11:27	6062427104	Lead	3	15	ppb
017-107A Room 227 Sink	6/23/16 12:47	7/5/16 11:27	6062427105	Copper	0.4	1.3	ppm
017-107A Room 227 Sink	6/23/16 12:47	7/5/16 11:27	6062427105	Lead	16	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Boise-Eliot Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
017-108A Room 227 Drinking Fountain	6/23/16 12:47	7/5/16 11:49	6062427106	Copper	0.3	1.3	ppm
017-108A Room 227 Drinking Fountain	6/23/16 12:47	7/5/16 11:49	6062427106	Lead	3	15	ppb
017-109A Room 225 Sink	6/23/16 12:49	7/5/16 11:28	6062427107	Copper	0.4	1.3	ppm
017-109A Room 225 Sink	6/23/16 12:49	7/5/16 11:28	6062427107	Lead	7	15	ppb
017-110A Room 225 Drinking Fountain	6/23/16 12:49	7/5/16 11:29	6062427108	Copper	0.6	1.3	ppm
017-110A Room 225 Drinking Fountain	6/23/16 12:49	7/5/16 11:29	6062427108	Lead	2	15	ppb
017-111A Room 223 Sink	6/23/16 12:24	7/5/16 11:29	6062427109	Copper	0.4	1.3	ppm
017-111A Room 223 Sink	6/23/16 12:24	7/5/16 11:29	6062427109	Lead	13	15	ppb
017-112A Room 223 Drinking Fountain	6/23/16 12:24	7/5/16 11:29	6062427110	Copper	0.7	1.3	ppm
017-112A Room 223 Drinking Fountain	6/23/16 12:24	7/5/16 11:29	6062427110	Lead	6	15	ppb
017-113A Boys Restroom Sink	6/23/16 12:09	7/5/16 11:29	6062427111	Copper	0.4	1.3	ppm
017-113A Boys Restroom Sink	6/23/16 12:09	7/5/16 11:29	6062427111	Lead	5	15	ppb
017-114A Boys Restroom Sink	6/23/16 12:09	7/5/16 11:29	6062427112	Copper	0.5	1.3	ppm
017-114A Boys Restroom Sink	6/23/16 12:09	7/5/16 11:29	6062427112	Lead	7	15	ppb
017-115A Girls Restroom Sink	6/23/16 12:13	7/5/16 11:29	6062427113	Copper	0.2	1.3	ppm
017-115A Girls Restroom Sink	6/23/16 12:13	7/5/16 11:29	6062427113	Lead	7	15	ppb
017-116A Girls Restroom Sink	6/23/16 12:13	7/5/16 11:29	6062427114	Copper	0.3	1.3	ppm
017-116A Girls Restroom Sink	6/23/16 12:13	7/5/16 11:29	6062427114	Lead	6	15	ppb
017-117A Girls Restroom Spigot	6/23/16 12:13	7/6/16 9:56	6062427115	Copper	32.1	1.3	ppm
017-117A Girls Restroom Spigot	6/23/16 12:13	7/1/16 17:25	6062427115	Lead	2030	15	ppb
017-118A Staff Restroom Sink	6/23/16 12:20	7/5/16 11:29	6062427116	Copper	0.3	1.3	ppm
017-118A Staff Restroom Sink	6/23/16 12:20	7/5/16 11:29	6062427116	Lead	13	15	ppb
017-119A Faculty Room Sink	6/23/16 12:51	7/5/16 11:29	6062427117	Copper	0.4	1.3	ppm
017-119A Faculty Room Sink	6/23/16 12:51	7/5/16 11:29	6062427117	Lead	18	15	ppb
017-120A Janitors Closet Sink	6/23/16 13:02	7/5/16 11:32	6062427118	Copper	0.1	1.3	ppm
017-120A Janitors Closet Sink	6/23/16 13:02	7/5/16 11:32	6062427118	Lead	5	15	ppb
017-121A Outside Faucet	6/23/16 13:26	7/5/16 11:32	6062427119	Copper	0.3	1.3	ppm
017-121A Outside Faucet	6/23/16 13:26	7/5/16 11:32	6062427119	Lead	4	15	ppb
017-122A Storage Building Outside	6/23/16 13:33	7/1/16 17:25	6062427120	Copper	0.2	1.3	ppm
017-122A Storage Building Outside	6/23/16 13:33	7/1/16 17:25	6062427120	Lead	124	15	ppb
017-123A Outside Faucet	6/23/16 13:15	7/5/16 11:32	6062427121	Copper	0.1	1.3	ppm
017-123A Outside Faucet	6/23/16 13:15	7/5/16 11:32	6062427121	Lead	348	15	ppb
017-124A Outside Faucet	6/23/16 13:18	7/5/16 11:33	6062427122	Copper	0.2	1.3	ppm
017-124A Outside Faucet	6/23/16 13:18	7/5/16 11:33	6062427122	Lead	61	15	ppb
017-125A Outside Faucet	6/23/16 13:23	7/1/16 17:25	6062427123	Copper	0.2	1.3	ppm
017-125A Outside Faucet	6/23/16 13:23	7/1/16 17:25	6062427123	Lead	36	15	ppb
017-126A Room 224 Sink	6/23/16 12:02	7/5/16 11:33	6062427124	Copper	0.3	1.3	ppm
017-126A Room 224 Sink	6/23/16 12:02	7/5/16 11:33	6062427124	Lead	6	15	ppb
017-127A Room 224 Drinking Fountain	6/23/16 12:02	7/5/16 11:33	6062427125	Copper	0.5	1.3	ppm
017-127A Room 224 Drinking Fountain	6/23/16 12:02	7/5/16 11:33	6062427125	Lead	4	15	ppb
017-128A Room 210 Sink	6/23/16 13:05	7/5/16 11:33	6062427126	Copper	0.2	1.3	ppm
017-128A Room 210 Sink	6/23/16 13:05	7/5/16 11:33	6062427126	Lead	7	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Boise-Eliot Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
017-129A Room 210 Drinking Fountain	6/23/16 13:05	7/5/16 11:33	6062427127	Copper	0.3	1.3	ppm
017-129A Room 210 Drinking Fountain	6/23/16 13:05	7/5/16 11:33	6062427127	Lead	2	15	ppb
017-130A Room 103 Sink Faucet	6/23/16 9:39	7/5/16 11:33	6062427128	Copper	0.5	1.3	ppm
017-130A Room 103 Sink Faucet	6/23/16 9:39	7/5/16 11:33	6062427128	Lead	3	15	ppb
017-131A Room 103 Drinking Drinking Fountain	6/23/16 9:39	7/5/16 11:33	6062427129	Copper	0.7	1.3	ppm
017-131A Room 103 Drinking Drinking Fountain	6/23/16 9:39	7/5/16 11:33	6062427129	Lead	2	15	ppb
017-132A Room 101 Sink Faucet	6/23/16 9:39	7/5/16 11:33	6062427130	Copper	0.5	1.3	ppm
017-132A Room 101 Sink Faucet	6/23/16 9:39	7/5/16 11:33	6062427130	Lead	4	15	ppb
017-133A Room 101 Drinking Drinking Fountain	6/23/16 9:39	7/5/16 11:34	6062427131	Copper	0.7	1.3	ppm
017-133A Room 101 Drinking Drinking Fountain	6/23/16 9:39	7/5/16 11:34	6062427131	Lead	2	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

ND = Non detect

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.