

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Bridger Elementary School

Sample Identification # and Location		Date & Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA	
							Action Limit	Units
018-01A	Gym Storage Room Drinking Fountain	6/23/16 12:52	7/10/2016	1606C84-01A	Copper	0.1	1.3	ppm
018-01A	Gym Storage Room Drinking Fountain	6/23/16 12:52	7/10/2016	1606C84-01A	Lead	18	15	ppb
018-02A	Room 33 Sink Sink Faucet	6/23/16 13:00	7/10/2016	1606C84-02A	Copper	0.4	1.3	ppm
018-02A	Room 33 Sink Sink Faucet	6/23/16 13:00	7/10/2016	1606C84-02A	Lead	2	15	ppb
018-03A	Boiler Room Bathroom Sink Faucet	6/23/16 13:01	7/10/2016	1606C84-03A	Copper	ND	1.3	ppm
018-03A	Boiler Room Bathroom Sink Faucet	6/23/16 13:01	7/10/2016	1606C84-03A	Lead	ND	15	ppb
018-04A	Room 12 Sink Faucet	6/23/16 15:03	7/10/2016	1606C84-04A	Copper	0.1	1.3	ppm
018-04A	Room 12 Sink Faucet	6/23/16 15:03	7/10/2016	1606C84-04A	Lead	27	15	ppb
018-05A	Room 12 Drinking Fountain	6/23/16 15:03	7/10/2016	1606C84-05A	Copper	ND	1.3	ppm
018-05A	Room 12 Drinking Fountain	6/23/16 15:03	7/10/2016	1606C84-05A	Lead	3	15	ppb
018-06A	Room 1 Sink Sink Faucet	6/23/16 13:06	7/10/2016	1606C84-06A	Copper	0.1	1.3	ppm
018-06A	Room 1 Sink Sink Faucet	6/23/16 13:06	7/10/2016	1606C84-06A	Lead	10	15	ppb
018-07A	Room 1 Drinking Fountain	6/23/16 13:07	7/10/2016	1606C84-07A	Copper	0.8	1.3	ppm
018-07A	Room 1 Drinking Fountain	6/23/16 13:07	7/10/2016	1606C84-07A	Lead	4	15	ppb
018-08A	Girls Bathroom Left Sink Faucet	6/23/16 13:13	7/10/2016	1606C84-08A	Copper	ND	1.3	ppm
018-08A	Girls Bathroom Left Sink Faucet	6/23/16 13:13	7/10/2016	1606C84-08A	Lead	3	15	ppb
018-09A	Girls Bathroom Middle Sink Faucet	6/23/16 13:14	7/10/2016	1606C84-09A	Copper	ND	1.3	ppm
018-09A	Girls Bathroom Middle Sink Faucet	6/23/16 13:14	7/10/2016	1606C84-09A	Lead	2	15	ppb
018-10A	Girls Bathroom Right Sink Faucet	6/23/16 13:15	7/8/2016	1606C84-10A	Copper	0.1	1.3	ppm
018-10A	Girls Bathroom Right Sink Faucet	6/23/16 13:15	7/8/2016	1606C84-10A	Lead	12	15	ppb
018-11A	Girls Bathroom Water Spigot	6/23/16 13:17	7/10/2016	1606C84-11A	Copper	ND	1.3	ppm
018-11A	Girls Bathroom Water Spigot	6/23/16 13:17	7/10/2016	1606C84-11A	Lead	7	15	ppb
018-12A	Boys Bathroom Left Sink Faucet	6/23/16 13:14	7/10/2016	1606C84-12A	Copper	ND	1.3	ppm
018-12A	Boys Bathroom Left Sink Faucet	6/23/16 13:14	7/10/2016	1606C84-12A	Lead	11	15	ppb
018-13A	Boys Bathroom Middle Sink Faucet	6/23/16 13:16	7/10/2016	1606C84-13A	Copper	ND	1.3	ppm
018-13A	Boys Bathroom Middle Sink Faucet	6/23/16 13:16	7/10/2016	1606C84-13A	Lead	6	15	ppb
018-14A	Boys Bathroom Right Sink Faucet	6/23/16 13:18	7/10/2016	1606C84-14A	Copper	0.1	1.3	ppm
018-14A	Boys Bathroom Right Sink Faucet	6/23/16 13:18	7/10/2016	1606C84-14A	Lead	30	15	ppb
018-15A	Boys Bathroom Water Spigot	6/23/16 13:23	7/8/2016	1606C84-15A	Copper	0.2	1.3	ppm
018-15A	Boys Bathroom Water Spigot	6/23/16 13:23	7/8/2016	1606C84-15A	Lead	22	15	ppb
018-16A	Drinking Fountain Between Boys Bathroom/Room 4	6/23/16 13:30	7/10/2016	1606C84-16A	Copper	1.2	1.3	ppm
018-16A	Drinking Fountain Between Boys Bathroom/Room 4	6/23/16 13:30	7/10/2016	1606C84-16A	Lead	ND	15	ppb
018-17A	Room 10 Sink Faucet	6/23/16 13:30	7/10/2016	1606C84-17A	Copper	ND	1.3	ppm
018-17A	Room 10 Sink Faucet	6/23/16 13:30	7/10/2016	1606C84-17A	Lead	6	15	ppb
018-18A	Room 10 Drinking Fountain	6/23/16 13:32	7/10/2016	1606C84-18A	Copper	0.7	1.3	ppm
018-18A	Room 10 Drinking Fountain	6/23/16 13:32	7/10/2016	1606C84-18A	Lead	1	15	ppb
018-19A	Room 4 Sink Faucet	6/23/16 13:26	7/10/2016	1606C84-19A	Copper	ND	1.3	ppm
018-19A	Room 4 Sink Faucet	6/23/16 13:26	7/10/2016	1606C84-19A	Lead	7	15	ppb
018-20A	Room 4 Drinking Fountain	6/23/16 13:27	7/10/2016	1606C84-20A	Copper	0.7	1.3	ppm
018-20A	Room 4 Drinking Fountain	6/23/16 13:27	7/10/2016	1606C84-20A	Lead	2	15	ppb
018-21A	Storage Between Room 4/Room 6	6/23/16 13:34	7/10/2016	1606C84-21A	Copper	0.7	1.3	ppm
018-21A	Storage Between Room 4/Room 6	6/23/16 13:34	7/10/2016	1606C84-21A	Lead	79	15	ppb
018-22A	Room 6 Sink Faucet	6/23/16 13:36	7/10/2016	1606C84-22A	Copper	0.5	1.3	ppm
018-22A	Room 6 Sink Faucet	6/23/16 13:36	7/10/2016	1606C84-22A	Lead	7	15	ppb
018-23A	Room 6 Drinking Fountain	6/23/16 13:38	7/10/2016	1606C84-23A	Copper	0.3	1.3	ppm
018-23A	Room 6 Drinking Fountain	6/23/16 13:38	7/10/2016	1606C84-23A	Lead	4	15	ppb
018-24A	Room 7 Sink Faucet	6/23/16 13:40	7/10/2016	1606C84-24A	Copper	0.5	1.3	ppm
018-24A	Room 7 Sink Faucet	6/23/16 13:40	7/10/2016	1606C84-24A	Lead	8	15	ppb
018-25A	Room 7 Drinking Fountain	6/23/16 13:40	7/10/2016	1606C84-25A	Copper	0.4	1.3	ppm
018-25A	Room 7 Drinking Fountain	6/23/16 13:40	7/10/2016	1606C84-25A	Lead	5	15	ppb
018-26A	Room 8 Bathroom Sink Faucet	6/23/16 13:42	7/10/2016	1606C84-26A	Copper	0.3	1.3	ppm
018-26A	Room 8 Bathroom Sink Faucet	6/23/16 13:42	7/10/2016	1606C84-26A	Lead	14	15	ppb
018-27A	Room 8 Sink Faucet	6/23/16 13:44	7/10/2016	1606C84-27A	Copper	0.5	1.3	ppm
018-27A	Room 8 Sink Faucet	6/23/16 13:44	7/10/2016	1606C84-27A	Lead	12	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Bridger Elementary School

Sample Identification # and Location		Date & Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA	
							Action Limit	Units
018-28A	Room 8 Drinking Fountain	6/23/16 13:44	7/10/2016	1606C84-28A	Copper	0.3	1.3	ppm
018-28A	Room 8 Drinking Fountain	6/23/16 13:44	7/10/2016	1606C84-28A	Lead	4	15	ppb
018-29A	Portable 1 Sink Faucet	6/23/16 13:52	7/10/2016	1606C84-29A	Copper	0.1	1.3	ppm
018-29A	Portable 1 Sink Faucet	6/23/16 13:52	7/10/2016	1606C84-29A	Lead	36	15	ppb
018-30A	Portable 2 Bathroom Sink	6/23/16 13:56	7/10/2016	1606C84-30A	Copper	ND	1.3	ppm
018-30A	Portable 2 Bathroom Sink	6/23/16 13:56	7/10/2016	1606C84-30A	Lead	5	15	ppb
018-31A	Portable 2 Sink Faucet	6/23/16 13:54	7/10/2016	1606C84-31A	Copper	0.1	1.3	ppm
018-31A	Portable 2 Sink Faucet	6/23/16 13:54	7/10/2016	1606C84-31A	Lead	8	15	ppb
018-32A	Portable 2 Drinking Fountain	6/23/16 13:55	7/10/2016	1606C84-32A	Copper	ND	1.3	ppm
018-32A	Portable 2 Drinking Fountain	6/23/16 13:55	7/10/2016	1606C84-32A	Lead	8	15	ppb
018-33A	Portable 3 Sink Faucet	6/23/16 13:58	7/10/2016	1606C84-33A	Copper	ND	1.3	ppm
018-33A	Portable 3 Sink Faucet	6/23/16 13:58	7/10/2016	1606C84-33A	Lead	2	15	ppb
018-34A	Portable 3 Drinking Fountain	6/23/16 14:00	7/10/2016	1606C84-34A	Copper	ND	1.3	ppm
018-34A	Portable 3 Drinking Fountain	6/23/16 14:00	7/10/2016	1606C84-34A	Lead	1	15	ppb
018-35A	Portable 4 Sink Faucet	6/23/16 14:02	7/10/2016	1606C84-35A	Copper	ND	1.3	ppm
018-35A	Portable 4 Sink Faucet	6/23/16 14:02	7/10/2016	1606C84-35A	Lead	2	15	ppb
018-36A	Portable 4 Drinking Fountain	6/23/16 14:03	7/10/2016	1606C84-36A	Copper	ND	1.3	ppm
018-36A	Portable 4 Drinking Fountain	6/23/16 14:03	7/10/2016	1606C84-36A	Lead	2	15	ppb
018-37A	Office-Nurse Sink Faucet	6/23/16 14:09	7/10/2016	1606C84-37A	Copper	0.3	1.3	ppm
018-37A	Office-Nurse Sink Faucet	6/23/16 14:09	7/10/2016	1606C84-37A	Lead	9	15	ppb
018-38A	Office-Main Sink Faucet	6/23/16 14:13	7/10/2016	1606C84-38A	Copper	ND	1.3	ppm
018-38A	Office-Main Sink Faucet	6/23/16 14:13	7/10/2016	1606C84-38A	Lead	2	15	ppb
018-39A	Staff Restroom Sink Faucet	6/23/16 14:18	7/10/2016	1606C84-39A	Copper	ND	1.3	ppm
018-39A	Staff Restroom Sink Faucet	6/23/16 14:18	7/10/2016	1606C84-39A	Lead	8	15	ppb
018-40A	Room 17 Custodial Storage	6/23/16 14:25	7/10/2016	1606C84-40A	Copper	0.2	1.3	ppm
018-40A	Room 17 Custodial Storage	6/23/16 14:25	7/10/2016	1606C84-40A	Lead	58	15	ppb
018-41A	Room 18 Sink Faucet	6/23/16 14:14	7/10/2016	1606C84-41A	Copper	0.4	1.3	ppm
018-41A	Room 18 Sink Faucet	6/23/16 14:14	7/10/2016	1606C84-41A	Lead	2	15	ppb
018-42A	Room 18 Sprayer	6/23/16 14:18	7/10/2016	1606C84-42A	Copper	ND	1.3	ppm
018-42A	Room 18 Sprayer	6/23/16 14:18	7/10/2016	1606C84-42A	Lead	ND	15	ppb
018-43A	Room 45 Sink Faucet	6/23/16 14:21	7/10/2016	1606C84-43A	Copper	0.4	1.3	ppm
018-43A	Room 45 Sink Faucet	6/23/16 14:21	7/10/2016	1606C84-43A	Lead	94	15	ppb
018-44A	Room 45 Drinking Fountain	6/23/16 14:23	7/10/2016	1606C84-44A	Copper	0.8	1.3	ppm
018-44A	Room 45 Drinking Fountain	6/23/16 14:23	7/10/2016	1606C84-44A	Lead	2	15	ppb
018-45A	Room 19 Sink Faucet	6/23/16 14:23	7/10/2016	1606C84-45A	Copper	ND	1.3	ppm
018-45A	Room 19 Sink Faucet	6/23/16 14:23	7/10/2016	1606C84-45A	Lead	2	15	ppb
018-46A	Room 19 Drinking Fountain	6/23/16 14:25	7/10/2016	1606C84-46A	Copper	7.3	1.3	ppm
018-46A	Room 19 Drinking Fountain	6/23/16 14:25	7/8/2016	1606C84-46A	Lead	24	15	ppb
018-47A	Boys Bathroom Sink Faucet Between 19/21 Left	6/23/16 14:26	7/10/2016	1606C84-47A	Copper	ND	1.3	ppm
018-47A	Boys Bathroom Sink Faucet Between 19/21 Left	6/23/16 14:26	7/10/2016	1606C84-47A	Lead	3	15	ppb
018-48A	Boys Bathroom Sink Faucet Between 19/21 Right	6/23/16 14:26	7/10/2016	1606C84-48A	Copper	ND	1.3	ppm
018-48A	Boys Bathroom Sink Faucet Between 19/21 Right	6/23/16 14:26	7/10/2016	1606C84-48A	Lead	8	15	ppb
018-49A	Boys Bathroom Sink Faucet Between 19/21 Water Spigot	6/23/16 14:27	7/10/2016	1606C84-49A	Copper	0.2	1.3	ppm
018-49A	Boys Bathroom Sink Faucet Between 19/21 Water Spigot	6/23/16 14:27	7/10/2016	1606C84-49A	Lead	23	15	ppb
018-50A	Girls Bathroom Sink Faucet Between 43/45 Left	6/23/16 14:27	7/8/2016	1606C84-50A	Copper	0.1	1.3	ppm
018-50A	Girls Bathroom Sink Faucet etween 43/45 Left	6/23/16 14:27	7/8/2016	1606C84-50A	Lead	51	15	ppb
018-51A	Girls Bathroom Sink Faucet Between 43/45 Right	6/23/16 14:27	7/10/2016	1606C84-51A	Copper	ND	1.3	ppm
018-51A	Girls Bathroom Sink Faucet Between 43/45 Right	6/23/16 14:27	7/10/2016	1606C84-51A	Lead	24	15	ppb
018-52A	Girls Bathroom Sink Faucet Between 43/45 Water Spigot	6/23/16 14:30	7/8/2016	1606C84-52A	Copper	0.2	1.3	ppm
018-52A	Girls Bathroom Sink Faucet Between 43/45 Water Spigot	6/23/16 14:30	7/8/2016	1606C84-52A	Lead	100	15	ppb
018-53A	Drinking Fountain Between Boys Bathroom/Room 21	6/23/16 14:33	7/10/2016	1606C84-53A	Copper	0.3	1.3	ppm
018-53A	Drinking Fountain Between Boys Bathroom/Room 21	6/23/16 14:33	7/10/2016	1606C84-53A	Lead	ND	15	ppb
018-54A	Room 43 Sink Faucet	6/23/16 14:35	7/10/2016	1606C84-54A	Copper	ND	1.3	ppm
018-54A	Room 43 Sink Faucet	6/23/16 14:35	7/10/2016	1606C84-54A	Lead	1	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Bridger Elementary School

Sample Identification # and Location		Date & Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA	
							Action Limit	Units
018-55A	Room 43 Drinking Fountain	6/23/16 14:36	7/10/2016	1606C84-55A	Copper	0.8	1.3	ppm
018-55A	Room 43 Drinking Fountain	6/23/16 14:36	7/10/2016	1606C84-55A	Lead	5	15	ppb
018-56A	Room 21 Sink Faucet	6/23/16 14:38	7/10/2016	1606C85-01A	Copper	0.1	1.3	ppm
018-56A	Room 21 Sink Faucet	6/23/16 14:38	7/10/2016	1606C85-01A	Lead	8	15	ppb
018-57A	Room 21 Drinking Fountain	6/23/16 14:38	7/10/2016	1606C85-02A	Copper	1.4	1.3	ppm
018-57A	Room 21 Drinking Fountain	6/23/16 14:38	7/10/2016	1606C85-02A	Lead	3	15	ppb
018-58A	Room 42 Sink Faucet	6/23/16 14:38	7/10/2016	1606C85-03A	Copper	0.3	1.3	ppm
018-58A	Room 42 Sink Faucet	6/23/16 14:38	7/10/2016	1606C85-03A	Lead	10	15	ppb
018-59A	Room 42 Drinking Fountain	6/23/16 14:39	7/10/2016	1606C85-04A	Copper	0.3	1.3	ppm
018-59A	Room 42 Drinking Fountain	6/23/16 14:39	7/10/2016	1606C85-04A	Lead	2	15	ppb
018-60A	Room 22 Sink Faucet	6/23/16 14:39	7/10/2016	1606C85-05A	Copper	0.2	1.3	ppm
018-60A	Room 22 Sink Faucet	6/23/16 14:39	7/10/2016	1606C85-05A	Lead	4	15	ppb
018-61A	Room 22 Drinking Fountain	6/23/16 14:39	7/10/2016	1606C85-06A	Copper	ND	1.3	ppm
018-61A	Room 22 Drinking Fountain	6/23/16 14:39	7/10/2016	1606C85-06A	Lead	2	15	ppb
018-62A	Room 41 Sink Faucet	6/23/16 14:40	7/10/2016	1606C85-07A	Copper	0.4	1.3	ppm
018-62A	Room 41 Sink Faucet	6/23/16 14:40	7/10/2016	1606C85-07A	Lead	20	15	ppb
018-63A	Room 41 Drinking Fountain	6/23/16 14:41	7/10/2016	1606C85-08A	Copper	0.2	1.3	ppm
018-63A	Room 41 Drinking Fountain	6/23/16 14:41	7/10/2016	1606C85-08A	Lead	2	15	ppb
018-64A	Room 23 Sink Faucet	6/23/16 14:42	7/10/2016	1606C85-09A	Copper	0.2	1.3	ppm
018-64A	Room 23 Sink Faucet	6/23/16 14:42	7/10/2016	1606C85-09A	Lead	8	15	ppb
018-65A	Room 23 Drinking Fountain	6/23/16 14:42	7/10/2016	1606C85-10A	Copper	0.3	1.3	ppm
018-65A	Room 23 Drinking Fountain	6/23/16 14:42	7/10/2016	1606C85-10A	Lead	4	15	ppb
018-66A	Room 40 Sink Faucet	6/23/16 14:45	7/10/2016	1606C85-11A	Copper	0.4	1.3	ppm
018-66A	Room 40 Sink Faucet	6/23/16 14:45	7/10/2016	1606C85-11A	Lead	10	15	ppb
018-67A	Room 40 Drinking Fountain	6/23/16 14:45	7/10/2016	1606C85-12A	Copper	0.3	1.3	ppm
018-67A	Room 40 Drinking Fountain	6/23/16 14:45	7/10/2016	1606C85-12A	Lead	2	15	ppb
018-68A	Boys Bathroom Sink Faucet Across Room 40 Left	6/23/16 14:47	7/10/2016	1606C85-13A	Copper	0.1	1.3	ppm
018-68A	Boys Bathroom Sink Faucet Across Room 40 Left	6/23/16 14:47	7/10/2016	1606C85-13A	Lead	5	15	ppb
018-69A	Boys Bathroom Sink Faucet Across Room 40 Middle	6/23/16 14:49	7/10/2016	1606C85-14A	Copper	ND	1.3	ppm
018-69A	Boys Bathroom Sink Faucet Across Room 40 Middle	6/23/16 14:49	7/10/2016	1606C85-14A	Lead	3	15	ppb
018-70A	Boys Bathroom Sink Faucet Across Room 40 Right	6/23/16 14:51	7/10/2016	1606C85-15A	Copper	0.1	1.3	ppm
018-70A	Boys Bathroom Sink Faucet Across Room 40 Right	6/23/16 14:51	7/10/2016	1606C85-15A	Lead	10	15	ppb
018-71A	Boys Bathroom Sink Faucet Across Room 40 Water Spigot	6/23/16 14:52	7/10/2016	1606C85-16A	Copper	0.1	1.3	ppm
018-71A	Boys Bathroom Sink Faucet Across Room 40 Water Spigot	6/23/16 14:52	7/10/2016	1606C85-16A	Lead	13	15	ppb
018-72A	Kitchen Main Sink Sink Faucet	6/23/16 14:44	7/10/2016	1606C85-17A	Copper	0.1	1.3	ppm
018-72A	Kitchen Main Sink Sink Faucet	6/23/16 14:44	7/10/2016	1606C85-17A	Lead	110	15	ppb
018-73A	Kitchen Main Sink Faucet Sprayer	6/23/16 14:49	7/10/2016	1606C85-18A	Copper	0.1	1.3	ppm
018-73A	Kitchen Main Sink Faucet Sprayer	6/23/16 14:49	7/10/2016	1606C85-18A	Lead	0.2	15	ppb
018-74A	Kitchen Main Sink Faucet Eyewash	6/23/16 14:51	7/10/2016	1606C85-19A	Copper	0.2	1.3	ppm
018-74A	Kitchen Main Sink Faucet Eyewash	6/23/16 14:51	7/10/2016	1606C85-19A	Lead	23	15	ppb
018-75A	Kitchen Custodial Sink Faucet	6/23/16 14:51	7/10/2016	1606C85-20A	Copper	0.2	1.3	ppm
018-75A	Kitchen Custodial Sink Faucet	6/23/16 14:51	7/10/2016	1606C85-20A	Lead	33	15	ppb
018-76A	Kitchen Bathroom Sink Faucet	6/23/16 14:53	7/14/2016	1606C85-21A	Copper	0.2	1.3	ppm
018-76A	Kitchen Bathroom Sink Faucet	6/23/16 14:53	7/14/2016	1606C85-21A	Lead	17	15	ppb
018-77A	Kitchen Hand Sink Faucet	6/23/16 14:55	7/14/2016	1606C85-22A	Copper	ND	1.3	ppm
018-77A	Kitchen Hand Sink Faucet	6/23/16 14:55	7/14/2016	1606C85-22A	Lead	8	15	ppb
018-78A	Kitchen Back Sprayer	6/23/16 14:56	7/14/2016	1606C85-23A	Copper	0.2	1.3	ppm
018-78A	Kitchen Back Sprayer	6/23/16 14:56	7/14/2016	1606C85-23A	Lead	5	15	ppb
018-79A	Kitchen Back Water Spigot	6/23/16 15:01	7/10/2016	1606C85-24A	Copper	0.5	1.3	ppm
018-79A	Kitchen Back Water Spigot	6/23/16 15:01	7/10/2016	1606C85-24A	Lead	26	15	ppb
018-80A	Drinking Fountain Across Room 25 Girls Bathroom	6/23/16 14:55	7/14/2016	1606C85-25A	Copper	1.8	1.3	ppm
018-80A	Drinking Fountain Across Room 25 Girls Bathroom	6/23/16 14:55	7/14/2016	1606C85-25A	Lead	ND	15	ppb
018-81A	Room 25 Girls Bathroom Left Sink Faucet	6/23/16 14:57	7/14/2016	1606C85-26A	Copper	0.1	1.3	ppm
018-81A	Room 25 Girls Bathroom Left Sink Faucet	6/23/16 14:57	7/14/2016	1606C85-26A	Lead	1	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Bridger Elementary School

Sample Identification # and Location		Date & Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA	
							Action Limit	Units
018-83A	Room 23 Girls Bathroom Right Sink Faucet	6/23/16 14:59	7/14/2016	1606C85-27A	Copper	0.1	1.3	ppm
018-83A	Room 23 Girls Bathroom Right Sink Faucet	6/23/16 14:59	7/14/2016	1606C85-27A	Lead	5	15	ppb
018-84A	Room 23 Girls Bathroom Water Spigot	6/23/16 15:01	7/10/2016	1606C85-28A	Copper	1.2	1.3	ppm
018-84A	Room 23 Girls Bathroom Water Spigot	6/23/16 15:01	7/10/2016	1606C85-28A	Lead	280	15	ppb
018-85A	Staff Bathroom Sink Faucet 1	6/23/16 14:59	7/14/2016	1606C85-29A	Copper	0.1	1.3	ppm
018-85A	Staff Bathroom Sink Faucet 1	6/23/16 14:59	7/14/2016	1606C85-29A	Lead	6	15	ppb
018-86A	Staff Bathroom Sink Faucet 2	6/23/16 15:03	7/14/2016	1606C85-30A	Copper	0.1	1.3	ppm
018-86A	Staff Bathroom Sink Faucet 2	6/23/16 15:03	7/14/2016	1606C85-30A	Lead	4	15	ppb
018-87A	Room 29 Sink Faucet	6/23/16 15:06	7/14/2016	1606C85-31A	Copper	0.4	1.3	ppm
018-87A	Room 29 Sink Faucet	6/23/16 15:06	7/14/2016	1606C85-31A	Lead	8	15	ppb
018-88A	Room 29 Drinking Fountain	6/23/16 15:06	7/14/2016	1606C85-32A	Copper	0.1	1.3	ppm
018-88A	Room 29 Drinking Fountain	6/23/16 15:06	7/14/2016	1606C85-32A	Lead	4	15	ppb
018-89A	Room 30 Custodian Sink	6/23/16 15:07	7/14/2016	1606C85-33A	Copper	0.1	1.3	ppm
018-89A	Room 30 Custodian Sink	6/23/16 15:07	7/14/2016	1606C85-33A	Lead	9	15	ppb
018-90A	Room 32 Left Sink Faucet	6/23/16 15:09	7/14/2016	1606C85-34A	Copper	0.3	1.3	ppm
018-90A	Room 32 Left Sink Faucet	6/23/16 15:09	7/14/2016	1606C85-34A	Lead	3	15	ppb
018-91A	Room 32 Middle Sink Faucet	6/23/16 15:09	7/14/2016	1606C85-35A	Copper	0.4	1.3	ppm
018-91A	Room 32 Middle Sink Faucet	6/23/16 15:09	7/14/2016	1606C85-35A	Lead	4	15	ppb
018-92A	Room 32 Right Sink Faucet	6/23/16 15:11	7/14/2016	1606C85-36A	Copper	0.3	1.3	ppm
018-92A	Room 32 Right Sink Faucet	6/23/16 15:11	7/14/2016	1606C85-36A	Lead	4	15	ppb
018-93A	Room 33 Sink Faucet with Eyewash	6/23/16 15:11	7/14/2016	1606C85-37A	Copper	0.3	1.3	ppm
018-93A	Room 33 Sink Faucet with Eyewash	6/23/16 15:11	7/14/2016	1606C85-37A	Lead	ND	15	ppb
018-94A	Room 33 Eyewash	6/23/16 15:13	7/14/2016	1606C85-38A	Copper	0.2	1.3	ppm
018-94A	Room 33 Eyewash	6/23/16 15:13	7/14/2016	1606C85-38A	Lead	7	15	ppb
018-95A	Room 33 Middle Sink	6/23/16 15:11	7/14/2016	1606C85-39A	Copper	0.3	1.3	ppm
018-95A	Room 33 Middle Sink	6/23/16 15:11	7/14/2016	1606C85-39A	Lead	ND	15	ppb
018-96A	Room 33 Drinking Fountain	6/23/16 15:13	7/14/2016	1606C85-40A	Copper	0.3	1.3	ppm
018-96A	Room 33 Drinking Fountain	6/23/16 15:13	7/14/2016	1606C85-40A	Lead	3	15	ppb
018-97A	Drinking Fountain End of Hall	6/23/16 15:16	7/10/2016	1606C85-41A	Copper	0.8	1.3	ppm
018-97A	Drinking Fountain End of Hall	6/23/16 15:16	7/10/2016	1606C85-41A	Lead	ND	15	ppb
018-98A	Gym Office Sink	6/23/16 15:16	7/10/2016	1606C85-42A	Copper	0.3	1.3	ppm
018-98A	Gym Office Sink	6/23/16 15:16	7/10/2016	1606C85-42A	Lead	4	15	ppb
018-99A	Outside Water Spigot South Side Gym	6/23/16 14:14	7/10/2016	1606C85-43A	Copper	0.3	1.3	ppm
018-99A	Outside Water Spigot South Side Gym	6/23/16 14:14	7/10/2016	1606C85-43A	Lead	60	15	ppb
018-100A	Outside Water Spigot Room 33	6/23/16 14:11	7/10/2016	1606C85-44A	Copper	0.0	1.3	ppm
018-100A	Outside Water Spigot Room 33	6/23/16 14:11	7/10/2016	1606C85-44A	Lead	2	15	ppb
018-101A	Outside Water Spigot Room 12	6/23/16 14:11	7/10/2016	1606C85-45A	Copper	ND	1.3	ppm
018-101A	Outside Water Spigot Room 12	6/23/16 14:11	7/10/2016	1606C85-45A	Lead	4	15	ppb
018-102A	Outside Water Spigot North Side	6/23/16 14:20	7/10/2016	1606C85-46A	Copper	0.1	1.3	ppm
018-102A	Outside Water Spigot North Side	6/23/16 14:20	7/10/2016	1606C85-46A	Lead	10	15	ppb
018-103A	Outside Water Spigot West Side	6/23/16 14:17	7/10/2016	1606C85-47A	Copper	0.1	1.3	ppm
018-103A	Outside Water Spigot West Side	6/23/16 14:17	7/10/2016	1606C85-47A	Lead	46	15	ppb
018-104A	Drinking Fountain By Girls Bathroom 25 Bottle Fill	6/23/16 15:00	7/10/2016	1606C85-48A	Copper	1.0	1.3	ppm
018-104A	Drinking Fountain By Girls Bathroom 25 Bottle Fill	6/23/16 15:00	7/10/2016	1606C85-48A	Lead	ND	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

ND = Non detect

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.