

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Bridlemile Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
019-01A Boiler Room Bathroom - Sink Faucet	6/26/2016 19:40	7/6/2016 09:26	10353834001	Copper	0.2	1.3	ppm
019-01A Boiler Room Bathroom - Sink Faucet	6/26/2016 19:40	7/6/2016 09:26	10353834001	Lead	8	15	ppb
019-02A Boiler Room-Custodial Sink-Sink Faucet	6/26/2016 19:42	7/6/2016 09:32	10353834003	Copper	0.2	1.3	ppm
019-02A Boiler Room-Custodial Sink-Sink Faucet	6/26/2016 19:42	7/6/2016 09:32	10353834003	Lead	29	15	ppb
019-03A Boiler Room Water Spigot (1)	6/26/2016 19:44	7/6/2016 09:33	10353834005	Copper	0.1	1.3	ppm
019-03A Boiler Room Water Spigot (1)	6/26/2016 19:44	7/6/2016 09:33	10353834005	Lead	22	15	ppb
019-04A Boiler Room Water Spigot (2)	6/26/2016 19:46	7/6/2016 09:34	10353834007	Copper	0.0	1.3	ppm
019-04A Boiler Room Water Spigot (2)	6/26/2016 19:46	7/6/2016 09:34	10353834007	Lead	9	15	ppb
019-05A Boiler Room Water Spigot (3)	6/26/2016 19:48	7/6/2016 09:36	10353834009	Copper	0.1	1.3	ppm
019-05A Boiler Room Water Spigot (3)	6/26/2016 19:48	7/6/2016 09:36	10353834009	Lead	3	15	ppb
019-06A Boiler Room Water Spigot (4)	6/26/2016 19:50	7/6/2016 09:40	10353834011	Copper	0.3	1.3	ppm
019-06A Boiler Room Water Spigot (4)	6/26/2016 19:50	7/6/2016 09:40	10353834011	Lead	49	15	ppb
019-07A Boiler Room Water Spigot (5)	6/26/2016 19:52	7/6/2016 09:42	10353834013	Copper	0.0	1.3	ppm
019-07A Boiler Room Water Spigot (5)	6/26/2016 19:52	7/6/2016 09:42	10353834013	Lead	3	15	ppb
019-08A Room 35 - Sink Faucet	6/26/2016 19:54	7/6/2016 09:43	10353834015	Copper	0.2	1.3	ppm
019-08A Room 35 - Sink Faucet	6/26/2016 19:54	7/6/2016 09:43	10353834015	Lead	12	15	ppb
019-09A Room 35 - Drinking Fountain	6/26/2016 19:56	7/6/2016 09:44	10353834017	Copper	0.1	1.3	ppm
019-09A Room 35 - Drinking Fountain	6/26/2016 19:56	7/6/2016 09:44	10353834017	Lead	6	15	ppb
019-10A Hall - Drinking Fountain	6/26/2016 19:59	7/1/2016 04:28	10353834019	Copper	0.1	1.3	ppm
019-10A Hall - Drinking Fountain	6/26/2016 19:59	7/1/2016 04:28	10353834019	Lead	6	15	ppb
019-11A Room 36 - Sink Faucet	6/26/2016 20:02	7/1/2016 04:59	10353834021	Copper	0.0	1.3	ppm
019-11A Room 36 - Sink Faucet	6/26/2016 20:02	7/1/2016 04:59	10353834021	Lead	7	15	ppb
019-12A Room 46 - Sink Faucet	6/26/2016 20:05	7/6/2016 09:46	10353834023	Copper	0.0	1.3	ppm
019-12A Room 46 - Sink Faucet	6/26/2016 20:05	7/6/2016 09:46	10353834023	Lead	9	15	ppb
019-13A Room 46 - Drinking Fountain	6/26/2016 20:07	7/1/2016 05:02	10353834025	Copper	0.2	1.3	ppm
019-13A Room 46 - Drinking Fountain	6/26/2016 20:07	7/1/2016 05:02	10353834025	Lead	2	15	ppb
019-14A Girls Bathroom (Room 37) - Sink Faucet (1)	6/26/2016 20:08	7/6/2016 09:47	10353834027	Copper	0.1	1.3	ppm
019-14A Girls Bathroom (Room 37) - Sink Faucet (1)	6/26/2016 20:08	7/6/2016 09:47	10353834027	Lead	6	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Bridlemile Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
019-15A Girls Bathroom (Room 37) - Sink Faucet (2)	6/26/2016 20:10	7/1/2016 05:09	10353834029	Copper	0.1	1.3	ppm
019-15A Girls Bathroom (Room 37) - Sink Faucet (2)	6/26/2016 20:10	7/1/2016 05:09	10353834029	Lead	5	15	ppb
019-16A Girls Bathroom (Room 37) - Sink Faucet (3)	6/26/2016 20:12	7/6/2016 09:50	10353834031	Copper	0.1	1.3	ppm
019-16A Girls Bathroom (Room 37) - Sink Faucet (3)	6/26/2016 20:12	7/6/2016 09:50	10353834031	Lead	2	15	ppb
019-17A Girls Bathroom (Room 37) - Water Spigot	6/26/2016 20:14	7/6/2016 09:51	10353834033	Copper	0.1	1.3	ppm
019-17A Girls Bathroom (Room 37) - Water Spigot	6/26/2016 20:14	7/6/2016 09:51	10353834033	Lead	6	15	ppb
019-18A Room 38 Custodial Sink Faucet	6/26/2016 20:16	7/6/2016 10:13	10353834035	Copper	0.0	1.3	ppm
019-18A Room 38 Custodial Sink Faucet	6/26/2016 20:16	7/6/2016 10:13	10353834035	Lead	2	15	ppb
019-19A Boys Bathroom (Room 39) - Sink Faucet (1)	6/26/2016 20:18	7/6/2016 10:19	10353834037	Copper	0.1	1.3	ppm
019-19A Boys Bathroom (Room 39) - Sink Faucet (1)	6/26/2016 20:18	7/6/2016 10:19	10353834037	Lead	11	15	ppb
019-20A Boys Bathroom (Room 39) - Sink Faucet (2)	6/26/2016 20:20	7/6/2016 10:20	10353834039	Copper	0.1	1.3	ppm
019-20A Boys Bathroom (Room 39) - Sink Faucet (2)	6/26/2016 20:20	7/6/2016 10:20	10353834039	Lead	6	15	ppb
019-21A Boys Bathroom (Room 39) - Sink Faucet (3)	6/26/2016 20:22	7/6/2016 07:38	10353834041	Copper	0.1	1.3	ppm
019-21A Boys Bathroom (Room 39) - Sink Faucet (3)	6/26/2016 20:22	7/6/2016 07:38	10353834041	Lead	1	15	ppb
019-22A Boys Bathroom (Room 39) - Water Spigot	6/26/2016 20:24	7/6/2016 10:22	10353834043	Copper	0.2	1.3	ppm
019-22A Boys Bathroom (Room 39) - Water Spigot	6/26/2016 20:24	7/6/2016 10:22	10353834043	Lead	9	15	ppb
019-23A Room 45 - Sink Faucet	6/26/2016 20:27	7/6/2016 10:23	10353834045	Copper	0.1	1.3	ppm
019-23A Room 45 - Sink Faucet	6/26/2016 20:27	7/6/2016 10:23	10353834045	Lead	7	15	ppb
019-24A Room 45 - Drinking Fountain	6/26/2016 20:29	7/6/2016 07:50	10353834047	Copper	0.1	1.3	ppm
019-24A Room 45 - Drinking Fountain	6/26/2016 20:29	7/6/2016 07:50	10353834047	Lead	3	15	ppb
019-25A Room 40 - Sink Faucet	6/26/2016 20:31	7/6/2016 10:27	10353834049	Copper	0.0	1.3	ppm
019-25A Room 40 - Sink Faucet	6/26/2016 20:31	7/6/2016 10:27	10353834049	Lead	5	15	ppb
019-26A Room 40 - Drinking Fountain	6/26/2016 20:33	7/6/2016 07:54	10353834051	Copper	0.2	1.3	ppm
019-26A Room 40 - Drinking Fountain	6/26/2016 20:33	7/6/2016 07:54	10353834051	Lead	6	15	ppb
019-27A Room 44 - Sink Faucet	6/26/2016 20:35	7/6/2016 07:57	10353834053	Copper	0.1	1.3	ppm
019-27A Room 44 - Sink Faucet	6/26/2016 20:35	7/6/2016 07:57	10353834053	Lead	7	15	ppb
019-28A Room 44 - Drinking Fountain	6/26/2016 20:37	7/6/2016 08:00	10353834055	Copper	0.1	1.3	ppm
019-28A Room 44 - Drinking Fountain	6/26/2016 20:37	7/6/2016 08:00	10353834055	Lead	3	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Bridlemile Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
019-29A Room 41 - Sink Faucet	6/26/2016 20:39	7/6/2016 08:03	10353834057	Copper	0.1	1.3	ppm
019-29A Room 41 - Sink Faucet	6/26/2016 20:39	7/6/2016 08:03	10353834057	Lead	4	15	ppb
019-30A Room 41 - Drinking Fountain	6/26/2016 20:41	7/6/2016 08:06	10353834059	Copper	0.0	1.3	ppm
019-30A Room 41 - Drinking Fountain	6/26/2016 20:41	7/6/2016 08:06	10353834059	Lead	2	15	ppb
019-31A Hall by Room 42 - Drinking Fountain	6/26/2016 20:44	7/6/2016 12:31	10353834061	Copper	0.0	1.3	ppm
019-31A Hall by Room 42 - Drinking Fountain	6/26/2016 20:44	7/6/2016 12:31	10353834061	Lead	6	15	ppb
019-32A Room 42 - Sink Faucet	6/26/2016 20:46	7/6/2016 12:36	10353834063	Copper	0.1	1.3	ppm
019-32A Room 42 - Sink Faucet	6/26/2016 20:46	7/6/2016 12:36	10353834063	Lead	11	15	ppb
019-33A Room 42 - Drinking Fountain	6/26/2016 20:48	6/30/2016 16:13	10353834065	Copper	0.2	1.3	ppm
019-33A Room 42 - Drinking Fountain	6/26/2016 20:48	6/30/2016 16:13	10353834065	Lead	2	15	ppb
019-34A Room 43 - Sink Faucet	6/26/2016 20:50	7/6/2016 12:37	10353834067	Copper	0.1	1.3	ppm
019-34A Room 43 - Sink Faucet	6/26/2016 20:50	7/6/2016 12:37	10353834067	Lead	2	15	ppb
019-35A Room 43 - Drinking Fountain	6/26/2016 20:52	6/30/2016 16:17	10353834069	Copper	0.1	1.3	ppm
019-35A Room 43 - Drinking Fountain	6/26/2016 20:52	6/30/2016 16:17	10353834069	Lead	1	15	ppb
019-36A Room 34 - Sink Faucet	6/26/2016 20:56	7/6/2016 12:39	10353834071	Copper	0.1	1.3	ppm
019-36A Room 34 - Sink Faucet	6/26/2016 20:56	7/6/2016 12:39	10353834071	Lead	22	15	ppb
019-37A Room 34 - Drinking Fountain	6/26/2016 20:58	7/6/2016 12:40	10353834073	Copper	0.0	1.3	ppm
019-37A Room 34 - Drinking Fountain	6/26/2016 20:58	7/6/2016 12:40	10353834073	Lead	4	15	ppb
019-38A Room 33 - Sink Faucet	6/26/2016 21:01	6/30/2016 16:21	10353834075	Copper	0.0	1.3	ppm
019-38A Room 33 - Sink Faucet	6/26/2016 21:01	6/30/2016 16:21	10353834075	Lead	1	15	ppb
019-39A Room 33 - Drinking Fountain	6/26/2016 21:03	6/30/2016 16:27	10353834077	Copper	0.1	1.3	ppm
019-39A Room 33 - Drinking Fountain	6/26/2016 21:03	6/30/2016 16:27	10353834077	Lead	1	15	ppb
019-40A Girls Bathroom - Sink Faucet (1)	6/26/2016 21:10	7/6/2016 12:44	10353834079	Copper	0.1	1.3	ppm
019-40A Girls Bathroom - Sink Faucet (1)	6/26/2016 21:10	7/6/2016 12:44	10353834079	Lead	21	15	ppb
019-41A Girls Bathroom - Sink Faucet (2)	6/26/2016 21:12	7/6/2016 12:46	10353834081	Copper	0.1	1.3	ppm
019-41A Girls Bathroom - Sink Faucet (2)	6/26/2016 21:12	7/6/2016 12:46	10353834081	Lead	21	15	ppb
019-42A Girls Bathroom - Sink Faucet (3)	6/26/2016 21:14	7/6/2016 12:47	10353834083	Copper	0.1	1.3	ppm
019-42A Girls Bathroom - Sink Faucet (3)	6/26/2016 21:14	7/6/2016 12:47	10353834083	Lead	11	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Bridlemile Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
019-43A Girls Bathroom - Sink Faucet (4)	6/26/2016 21:16	7/6/2016 12:48	10353834085	Copper	0.2	1.3	ppm
019-43A Girls Bathroom - Sink Faucet (4)	6/26/2016 21:16	7/6/2016 12:48	10353834085	Lead	10	15	ppb
019-44A Girls Bathroom - Water Spigot	6/26/2016 21:18	7/6/2016 12:50	10353834087	Copper	0.1	1.3	ppm
019-44A Girls Bathroom - Water Spigot	6/26/2016 21:18	7/6/2016 12:50	10353834087	Lead	6	15	ppb
019-45A Room 32 - Sink Faucet	6/26/2016 21:21	7/6/2016 12:51	10353834089	Copper	0.1	1.3	ppm
019-45A Room 32 - Sink Faucet	6/26/2016 21:21	7/6/2016 12:51	10353834089	Lead	41	15	ppb
019-46A Room 32 - Drinking Fountain	6/26/2016 21:23	7/6/2016 08:16	10353834091	Copper	0.1	1.3	ppm
019-46A Room 32 - Drinking Fountain	6/26/2016 21:23	7/6/2016 08:16	10353834091	Lead	8	15	ppb
019-47A Room 26 - Sink Faucet	6/26/2016 21:26	7/6/2016 12:52	10353834093	Copper	0.0	1.3	ppm
019-47A Room 26 - Sink Faucet	6/26/2016 21:26	7/6/2016 12:52	10353834093	Lead	28	15	ppb
019-48A Room 26 - Drinking Fountain	6/26/2016 21:28	7/6/2016 08:19	10353834095	Copper	0.1	1.3	ppm
019-48A Room 26 - Drinking Fountain	6/26/2016 21:28	7/6/2016 08:19	10353834095	Lead	3	15	ppb
019-49A Room 31 - Sink Faucet	6/26/2016 21:31	7/6/2016 12:55	10353834097	Copper	0.1	1.3	ppm
019-49A Room 31 - Sink Faucet	6/26/2016 21:31	7/6/2016 12:55	10353834097	Lead	23	15	ppb
019-50A Room 31 - Drinking Fountain	6/26/2016 21:33	7/6/2016 08:22	10353834099	Copper	0.2	1.3	ppm
019-50A Room 31 - Drinking Fountain	6/26/2016 21:33	7/6/2016 08:22	10353834099	Lead	5	15	ppb
019-51A Room 30 - Sink Faucet	6/26/2016 21:36	7/6/2016 12:57	10353834101	Copper	0.1	1.3	ppm
019-51A Room 30 - Sink Faucet	6/26/2016 21:36	7/6/2016 12:57	10353834101	Lead	68	15	ppb
019-52A Room 30 - Drinking Fountain	6/26/2016 21:38	6/30/2016 15:56	10353834103	Copper	0.0	1.3	ppm
019-52A Room 30 - Drinking Fountain	6/26/2016 21:38	6/30/2016 15:56	10353834103	Lead	5	15	ppb
019-53A Room 27 - Sink Faucet	6/26/2016 21:40	7/6/2016 13:03	10353834105	Copper	0.2	1.3	ppm
019-53A Room 27 - Sink Faucet	6/26/2016 21:40	7/6/2016 13:03	10353834105	Lead	37	15	ppb
019-54A Room 28 - Sink Faucet	6/26/2016 21:43	7/6/2016 13:05	10353834107	Copper	0.2	1.3	ppm
019-54A Room 28 - Sink Faucet	6/26/2016 21:43	7/6/2016 13:05	10353834107	Lead	50	15	ppb
019-55A Room 28 - Drinking Fountain	6/26/2016 21:45	6/30/2016 16:02	10353834109	Copper	0.0	1.3	ppm
019-55A Room 28 - Drinking Fountain	6/26/2016 21:45	6/30/2016 16:02	10353834109	Lead	3	15	ppb
019-56A Room 29 - Sink Faucet	6/26/2016 21:48	7/6/2016 09:53	10353834111	Copper	0.2	1.3	ppm
019-56A Room 29 - Sink Faucet	6/26/2016 21:48	7/6/2016 09:53	10353834111	Lead	39	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Bridlemile Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
019-57A Room 29 - Drinking Fountain	6/26/2016 21:50	7/7/2016 16:27	10353834113	Copper	0.0	1.3	ppm
019-57A Room 29 - Drinking Fountain	6/26/2016 21:50	7/7/2016 16:27	10353834113	Lead	7	15	ppb
019-58A Boys Bathroom (Room 22) - Sink Faucet (1)	6/26/2016 21:53	7/6/2016 09:57	10353834115	Copper	0.1	1.3	ppm
019-58A Boys Bathroom (Room 22) - Sink Faucet (1)	6/26/2016 21:53	7/6/2016 09:57	10353834115	Lead	10	15	ppb
019-59A Boys Bathroom (Room 22) - Sink Faucet (2)	6/26/2016 21:55	7/6/2016 09:58	10353834117	Copper	0.1	1.3	ppm
019-59A Boys Bathroom (Room 22) - Sink Faucet (2)	6/26/2016 21:55	7/6/2016 09:58	10353834117	Lead	9	15	ppb
019-60A Boys Bathroom (Room 22) - Sink Faucet (3)	6/26/2016 21:57	7/6/2016 10:00	10353834119	Copper	0.1	1.3	ppm
019-60A Boys Bathroom (Room 22) - Sink Faucet (3)	6/26/2016 21:57	7/6/2016 10:00	10353834119	Lead	13	15	ppb
019-61A Boys Bathroom (Room 22) - Water Spigot	6/26/2016 21:59	7/6/2016 13:06	10353834121	Copper	0.1	1.3	ppm
019-61A Boys Bathroom (Room 22) - Water Spigot	6/26/2016 21:59	7/6/2016 13:06	10353834121	Lead	7	15	ppb
019-62A Cafeteria - Drinking Fountain	6/26/2016 22:07	7/6/2016 18:33	10353834123	Copper	0.0	1.3	ppm
019-62A Cafeteria - Drinking Fountain	6/26/2016 22:07	7/6/2016 18:33	10353834123	Lead	7	15	ppb
019-63A Kitchen - Dish - Sink Faucet	6/26/2016 22:10	7/6/2016 13:08	10353834125	Copper	0.2	1.3	ppm
019-63A Kitchen - Dish - Sink Faucet	6/26/2016 22:10	7/6/2016 13:08	10353834125	Lead	14	15	ppb
019-64A Kitchen - Hand - Sink Faucet	6/26/2016 22:12	7/6/2016 13:09	10353834127	Copper	0.1	1.3	ppm
019-64A Kitchen - Hand - Sink Faucet	6/26/2016 22:12	7/6/2016 13:09	10353834127	Lead	7	15	ppb
019-65A Kitchen - Bathroom - Sink Faucet	6/26/2016 22:14	7/6/2016 13:10	10353834129	Copper	0.1	1.3	ppm
019-65A Kitchen - Bathroom - Sink Faucet	6/26/2016 22:14	7/6/2016 13:10	10353834129	Lead	7	15	ppb
019-66A Kitchen - Custodial - Sink Faucet	6/26/2016 22:16	7/7/2016 08:24	10353834131	Copper	0.0	1.3	ppm
019-66A Kitchen - Custodial - Sink Faucet	6/26/2016 22:16	7/7/2016 08:24	10353834131	Lead	2	15	ppb
019-67A Kitchen - Food Preparation Sink - Water Spigot	6/26/2016 22:18	7/6/2016 18:35	10353834133	Copper	0.2	1.3	ppm
019-67A Kitchen - Food Preparation Sink - Water Spigot	6/26/2016 22:18	7/6/2016 18:35	10353834133	Lead	32	15	ppb
019-68A Kitchen - Food Preparation Sink - Sink Faucet (1)	6/26/2016 22:20	7/6/2016 18:37	10353834135	Copper	0.1	1.3	ppm
019-68A Kitchen - Food Preparation Sink - Sink Faucet (1)	6/26/2016 22:20	7/6/2016 18:37	10353834135	Lead	2	15	ppb
019-69A Kitchen - Food Preparation Sink - Sink Faucet (2)	6/26/2016 22:22	7/6/2016 18:38	10353834137	Copper	0.1	1.3	ppm
019-69A Kitchen - Food Preparation Sink - Sink Faucet (2)	6/26/2016 22:22	7/6/2016 18:38	10353834137	Lead	6	15	ppb
019-70A Women's Bathroom (Room 18) - Sink Faucet	6/26/2016 22:25	7/7/2016 08:29	10353834139	Copper	0.1	1.3	ppm
019-70A Women's Bathroom (Room 18) - Sink Faucet	6/26/2016 22:25	7/7/2016 08:29	10353834139	Lead	3	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Bridlemile Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
019-71A Men's Bathroom (Room 17) - Sink Faucet	6/26/2016 22:27	7/6/2016 10:01	10353834141	Copper	0.2	1.3	ppm
019-71A Men's Bathroom (Room 17) - Sink Faucet	6/26/2016 22:27	7/6/2016 10:01	10353834141	Lead	7	15	ppb
019-72A Faculty Room 51 - Sink Faucet	6/26/2016 22:29	6/30/2016 16:33	10353834143	Copper	0.0	1.3	ppm
019-72A Faculty Room 51 - Sink Faucet	6/26/2016 22:29	6/30/2016 16:33	10353834143	Lead	1	15	ppb
019-73A Hall Drinking Fountain By Room 51	6/26/2016 22:31	6/30/2016 16:40	10353834145	Copper	0.0	1.3	ppm
019-73A Hall Drinking Fountain By Room 51	6/26/2016 22:31	6/30/2016 16:40	10353834145	Lead	1	15	ppb
019-74A Nurse Bathroom - Sink Faucet	6/26/2016 22:34	7/6/2016 10:02	10353834147	Copper	0.1	1.3	ppm
019-74A Nurse Bathroom - Sink Faucet	6/26/2016 22:34	7/6/2016 10:02	10353834147	Lead	39	15	ppb
019-75A Office - Sink Faucet	6/26/2016 22:36	6/30/2016 16:43	10353834149	Copper	0.1	1.3	ppm
019-75A Office - Sink Faucet	6/26/2016 22:36	6/30/2016 16:43	10353834149	Lead	9	15	ppb
019-76A Office - Drinking Fountain	6/26/2016 22:38	6/30/2016 16:46	10353834151	Copper	0.0	1.3	ppm
019-76A Office - Drinking Fountain	6/26/2016 22:38	6/30/2016 16:46	10353834151	Lead	3	15	ppb
019-77A Office - Drinking Fountain (Cooler)	6/26/2016 22:40	6/30/2016 16:48	10353834153	Copper	0.0	1.3	ppm
019-77A Office - Drinking Fountain (Cooler)	6/26/2016 22:40	6/30/2016 16:48	10353834153	Lead	5	15	ppb
019-78A Room 15 - Sink Faucet	6/26/2016 22:57	7/6/2016 10:04	10353834155	Copper	0.2	1.3	ppm
019-78A Room 15 - Sink Faucet	6/26/2016 22:57	7/6/2016 10:04	10353834155	Lead	47	15	ppb
019-79A Room 15 - Drinking Fountain	6/26/2016 22:59	6/30/2016 16:56	10353834157	Copper	0.0	1.3	ppm
019-79A Room 15 - Drinking Fountain	6/26/2016 22:59	6/30/2016 16:56	10353834157	Lead	1	15	ppb
019-80A Room 5 - Sink Faucet	6/26/2016 23:02	7/5/2016 16:47	10353834159	Copper	0.1	1.3	ppm
019-80A Room 5 - Sink Faucet	6/26/2016 23:02	7/5/2016 16:47	10353834159	Lead	30	15	ppb
019-81A Room 5 - Drinking Fountain	6/26/2016 23:04	6/30/2016 17:00	10353834161	Copper	0.2	1.3	ppm
019-81A Room 5 - Drinking Fountain	6/26/2016 23:04	6/30/2016 17:00	10353834161	Lead	3	15	ppb
019-82A Room 14A - Sink Faucet	6/26/2016 23:07	6/30/2016 17:03	10353834163	Copper	0.2	1.3	ppm
019-82A Room 14A - Sink Faucet	6/26/2016 23:07	6/30/2016 17:03	10353834163	Lead	17	15	ppb
019-83A Room 6 - Sink Faucet	6/26/2016 23:09	7/6/2016 10:29	10353834165	Copper	0.1	1.3	ppm
019-83A Room 6 - Sink Faucet	6/26/2016 23:09	7/6/2016 10:29	10353834165	Lead	46	15	ppb
019-84A Room 6 - Drinking Fountain	6/26/2016 23:11	6/30/2016 17:06	10353834167	Copper	0.0	1.3	ppm
019-84A Room 6 - Drinking Fountain	6/26/2016 23:11	6/30/2016 17:06	10353834167	Lead	3	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Bridlemile Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
019-85A Hall - Drinking Fountain	6/26/2016 23:14	6/30/2016 17:13	10353834169	Copper	0.1	1.3	ppm
019-85A Hall - Drinking Fountain	6/26/2016 23:14	6/30/2016 17:13	10353834169	Lead	0	15	ppb
019-86A Room 14B - Sink Faucet	6/26/2016 23:17	6/30/2016 17:16	10353834171	Copper	0.1	1.3	ppm
019-86A Room 14B - Sink Faucet	6/26/2016 23:17	6/30/2016 17:16	10353834171	Lead	11	15	ppb
019-87A Boys Bathroom - Sink Faucet (1)	6/26/2016 23:20	6/30/2016 17:26	10353834173	Copper	0.1	1.3	ppm
019-87A Boys Bathroom - Sink Faucet (1)	6/26/2016 23:20	6/30/2016 17:26	10353834173	Lead	6	15	ppb
019-88A Boys Bathroom - Sink Faucet (2)	6/26/2016 23:22	6/30/2016 17:29	10353834175	Copper	0.1	1.3	ppm
019-88A Boys Bathroom - Sink Faucet (2)	6/26/2016 23:22	6/30/2016 17:29	10353834175	Lead	3	15	ppb
019-89A Boys Bathroom - Sink Faucet (3)	6/26/2016 23:24	6/30/2016 17:31	10353834177	Copper	0.1	1.3	ppm
019-89A Boys Bathroom - Sink Faucet (3)	6/26/2016 23:24	6/30/2016 17:31	10353834177	Lead	3	15	ppb
019-90A Boys Bathroom - Water Spigot	6/26/2016 23:26	7/5/2016 16:53	10353834179	Copper	0.1	1.3	ppm
019-90A Boys Bathroom - Water Spigot	6/26/2016 23:26	7/5/2016 16:53	10353834179	Lead	6	15	ppb
019-91A Room 12-Custodial Closet-Sink Faucet	6/26/2016 23:29	7/6/2016 11:20	10353834181	Copper	0.1	1.3	ppm
019-91A Room 12-Custodial Closet-Sink Faucet	6/26/2016 23:29	7/6/2016 11:20	10353834181	Lead	3	15	ppb
019-92A Girls Bathroom - Sink Faucet (1)	6/26/2016 23:31	6/30/2016 17:37	10353834183	Copper	0.1	1.3	ppm
019-92A Girls Bathroom - Sink Faucet (1)	6/26/2016 23:31	6/30/2016 17:37	10353834183	Lead	5	15	ppb
019-93A Girls Bathroom - Sink Faucet (2)	6/26/2016 23:33	7/6/2016 11:22	10353834185	Copper	0.1	1.3	ppm
019-93A Girls Bathroom - Sink Faucet (2)	6/26/2016 23:33	7/6/2016 11:22	10353834185	Lead	3	15	ppb
019-94A Girls Bathroom - Sink Faucet (3)	6/26/2016 23:35	6/30/2016 17:43	10353834187	Copper	0.1	1.3	ppm
019-94A Girls Bathroom - Sink Faucet (3)	6/26/2016 23:35	6/30/2016 17:43	10353834187	Lead	5	15	ppb
019-95A Girls Bathroom - Sink Faucet (4)	6/26/2016 23:37	6/30/2016 17:46	10353834189	Copper	0.1	1.3	ppm
019-95A Girls Bathroom - Sink Faucet (4)	6/26/2016 23:37	6/30/2016 17:46	10353834189	Lead	3	15	ppb
019-96A Girls Bathroom - Water Spigot	6/26/2016 23:39	7/5/2016 16:54	10353834191	Copper	0.2	1.3	ppm
019-96A Girls Bathroom - Water Spigot	6/26/2016 23:39	7/5/2016 16:54	10353834191	Lead	10	15	ppb
019-97A Room 10 - Sink Faucet	6/26/2016 23:42	6/30/2016 17:48	10353834193	Copper	0.1	1.3	ppm
019-97A Room 10 - Sink Faucet	6/26/2016 23:42	6/30/2016 17:48	10353834193	Lead	8	15	ppb
019-98A Room 7 - Sink Faucet	6/26/2016 23:44	6/30/2016 18:00	10353834195	Copper	0.1	1.3	ppm
019-98A Room 7 - Sink Faucet	6/26/2016 23:44	6/30/2016 18:00	10353834195	Lead	8	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Bridlemile Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
019-99A Room 7 - Drinking Fountain	6/26/2016 23:46	6/30/2016 18:03	10353834197	Copper	0.0	1.3	ppm
019-99A Room 7 - Drinking Fountain	6/26/2016 23:46	6/30/2016 18:03	10353834197	Lead	1	15	ppb
019-100A Room 8 - Sink Faucet	6/26/2016 23:49	6/30/2016 18:08	10353834199	Copper	0.0	1.3	ppm
019-100A Room 8 - Sink Faucet	6/26/2016 23:49	6/30/2016 18:08	10353834199	Lead	3	15	ppb
019-101A Room 8 - Drinking Fountain	6/26/2016 23:51	6/30/2016 18:11	10353834201	Copper	0.1	1.3	ppm
019-101A Room 8 - Drinking Fountain	6/26/2016 23:51	6/30/2016 18:11	10353834201	Lead	2	15	ppb
019-102A Gymnasium - Drinking Fountain	6/26/2016 23:54	7/7/2016 09:18	10353834203	Copper	0.0	1.3	ppm
019-102A Gymnasium - Drinking Fountain	6/26/2016 23:54	7/7/2016 09:18	10353834203	Lead	15.3	15	ppb
019-103A Gymnasium Office - Sink Faucet	6/26/2016 23:56	6/30/2016 18:14	10353834205	Copper	0.0	1.3	ppm
019-103A Gymnasium Office - Sink Faucet	6/26/2016 23:56	6/30/2016 18:14	10353834205	Lead	7	15	ppb
019-104A Gymnasium Office - Shower	6/26/2016 23:58	6/30/2016 18:18	10353834207	Copper	0.0	1.3	ppm
019-104A Gymnasium Office - Shower	6/26/2016 23:58	6/30/2016 18:18	10353834207	Lead	77	15	ppb
019-105A Boys Bathroom Locker Room - Spigot	6/27/2016 00:00	7/7/2016 09:30	10353834209	Copper	0.0	1.3	ppm
019-105A Boys Bathroom Locker Room - Spigot	6/27/2016 00:00	7/7/2016 09:30	10353834209	Lead	261	15	ppb
019-106A Boys Locker Room Custodial Closet - Sink	6/27/2016 00:02	7/7/2016 09:31	10353834211	Copper	0.0	1.3	ppm
019-106A Boys Locker Room Custodial Closet - Sink Faucet	6/27/2016 00:02	7/7/2016 09:31	10353834211	Lead	1	15	ppb
019-107A Girls Bathroom Locker Room - Sink Faucet	6/27/2016 00:05	7/7/2016 09:32	10353834213	Copper	0.0	1.3	ppm
019-107A Girls Bathroom Locker Room - Sink Faucet	6/27/2016 00:05	7/7/2016 09:32	10353834213	Lead	82	15	ppb
019-108A Girls Bathroom Locker Room - Drinking	6/27/2016 00:07	6/30/2016 18:27	10353834215	Copper	0.0	1.3	ppm
019-108A Girls Bathroom Locker Room - Drinking Fountain	6/27/2016 00:07	6/30/2016 18:27	10353834215	Lead	16	15	ppb
019-109A Outside Water Spigot (1)	6/27/2016 00:10	7/7/2016 14:37	10353834217	Copper	0.7	1.3	ppm
019-109A Outside Water Spigot (1)	6/27/2016 00:10	7/7/2016 09:33	10353834217	Lead	126	15	ppb
019-110A Outside Water Spigot (2)	6/27/2016 00:12	6/30/2016 18:37	10353834219	Copper	0.1	1.3	ppm
019-110A Outside Water Spigot (2)	6/27/2016 00:12	6/30/2016 18:37	10353834219	Lead	13	15	ppb
019-111A Outside Water Spigot (3)	6/27/2016 00:14	6/30/2016 18:43	10353834221	Copper	0.0	1.3	ppm
019-111A Outside Water Spigot (3)	6/27/2016 00:14	6/30/2016 18:43	10353834221	Lead	1	15	ppb
019-112A Outside Water Spigot (4)	6/27/2016 00:17	6/30/2016 18:46	10353834223	Copper	0.0	1.3	ppm
019-112A Outside Water Spigot (4)	6/27/2016 00:17	6/30/2016 18:46	10353834223	Lead	2	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Bridlemile Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
019-113A Portable - Sink Faucet	6/27/2016 00:19	6/30/2016 18:50	10353834225	Copper	0.1	1.3	ppm
019-113A Portable - Sink Faucet	6/27/2016 00:19	6/30/2016 18:50	10353834225	Lead	25	15	ppb
019-114A Portable - Drinking Fountain	6/27/2016 00:22	6/30/2016 18:52	10353834227	Copper	0.0	1.3	ppm
019-114A Portable - Drinking Fountain	6/27/2016 00:22	6/30/2016 18:52	10353834227	Lead	40	15	ppb
019-115A Outside Water Spigot (5)	6/27/2016 00:24	7/7/2016 09:37	10353834229	Copper	0.3	1.3	ppm
019-115A Outside Water Spigot (5)	6/27/2016 00:24	7/7/2016 09:37	10353834229	Lead	56	15	ppb
019-116A Library - Sink Faucet	6/27/2016 22:53	6/30/2016 18:57	10353834231	Copper	0.0	1.3	ppm
019-116A Library - Sink Faucet	6/27/2016 22:53	6/30/2016 18:57	10353834231	Lead	2	15	ppb
019-117A Library - Drinking Fountain	6/27/2016 22:55	6/30/2016 19:00	10353834233	Copper	0.0	1.3	ppm
019-117A Library - Drinking Fountain	6/27/2016 22:55	6/30/2016 19:00	10353834233	Lead	1	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.