

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Buckman Arts Magnet Elementary School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
020-01A	Boiler room Sink Faucet	6/25/16 8:32 PM	7/6/16 11:04 AM	BB67498	Copper	0.0	1.3	ppm
020-01A	Boiler room Sink Faucet	6/25/16 8:32 PM	7/6/16 11:04 AM	BB67498	Lead	1	15	ppb
020-02A	Boiler room Main Level Sink Faucet	6/25/16 9:51 PM	7/11/16 3:19 PM	BB67499	Copper	0.1	1.3	ppm
020-02A	Boiler room Main Level Sink Faucet	6/25/16 9:51 PM	7/11/16 3:19 PM	BB67499	Lead	6	15	ppb
020-03A	Gymnasium Drinking Fountain #1	6/25/16 9:54 PM	7/6/16 11:19 AM	BB67500	Copper	0.0	1.3	ppm
020-03A	Gymnasium Drinking Fountain #1	6/25/16 9:54 PM	7/6/16 11:19 AM	BB67500	Lead	2	15	ppb
020-04A	Gymnasium Drinking Fountain #2	6/25/16 9:55 PM	7/6/16 11:22 AM	BB67501	Copper	0.0	1.3	ppm
020-04A	Gymnasium Drinking Fountain #2	6/25/16 9:55 PM	7/6/16 11:22 AM	BB67501	Lead	2	15	ppb
020-05A	Gymnasium Drinking Fountain #3	6/25/16 9:56 PM	7/6/16 11:25 AM	BB67502	Copper	0.0	1.3	ppm
020-05A	Gymnasium Drinking Fountain #3	6/25/16 9:56 PM	7/6/16 11:25 AM	BB67502	Lead	4	15	ppb
020-06A	Gymnasium Drinking Fountain #4	6/25/16 9:58 PM	7/6/16 11:28 AM	BB67503	Copper	0.0	1.3	ppm
020-06A	Gymnasium Drinking Fountain #4	6/25/16 9:58 PM	7/6/16 11:28 AM	BB67503	Lead	2	15	ppb
020-07A	Gymnasium Drinking Fountain #5	6/25/16 10:00 PM	7/6/16 11:31 AM	BB67504	Copper	0.0	1.3	ppm
020-07A	Gymnasium Drinking Fountain #5	6/25/16 10:00 PM	7/6/16 11:31 AM	BB67504	Lead	2	15	ppb
020-08A	Classroom 100 Sink Faucet	6/25/16 10:07 PM	7/6/16 11:34 AM	BB67505	Copper	0.7	1.3	ppm
020-08A	Classroom 100 Sink Faucet	6/25/16 10:07 PM	7/6/16 11:34 AM	BB67505	Lead	11	15	ppb
020-09A	Classroom 100 Drinking Fountain	6/25/16 10:08 PM	7/6/16 11:37 AM	BB67506	Copper	0.2	1.3	ppm
020-09A	Classroom 100 Drinking Fountain	6/25/16 10:08 PM	7/6/16 11:37 AM	BB67506	Lead	6	15	ppb
020-10A	Classroom 100 Bathroom Sink Faucet	6/25/16 10:10 PM	7/6/16 11:40 AM	BB67507	Copper	0.3	1.3	ppm
020-10A	Classroom 100 Bathroom Sink Faucet	6/25/16 10:10 PM	7/6/16 11:40 AM	BB67507	Lead	5	15	ppb
020-11A	Kitchen Dishwash Sink Faucet	6/25/16 10:25 PM	7/6/16 11:43 AM	BB67508	Copper	0.5	1.3	ppm
020-11A	Kitchen Dishwash Sink Faucet	6/25/16 10:25 PM	7/6/16 11:43 AM	BB67508	Lead	4	15	ppb
020-12A	Kitchen Utility Closet Sink Faucet	6/25/16 10:28 PM	7/11/16 4:29 PM	BB67509	Copper	0.1	1.3	ppm
020-12A	Kitchen Utility Closet Sink Faucet	6/25/16 10:28 PM	7/11/16 4:33 PM	BB67509	Lead	1550	15	ppb
020-13A	Kitchen Bathroom Sink Faucet	6/25/16 10:29 PM	7/6/16 11:46 AM	BB67510	Copper	0.1	1.3	ppm
020-13A	Kitchen Bathroom Sink Faucet	6/25/16 10:29 PM	7/6/16 11:46 AM	BB67510	Lead	18	15	ppb
020-14A	Kitchen Sink Faucet	6/25/16 10:31 PM	7/6/16 12:07 PM	BB67511	Copper	0.1	1.3	ppm
020-14A	Kitchen Sink Faucet	6/25/16 10:31 PM	7/6/16 12:07 PM	BB67511	Lead	5	15	ppb
020-15A	Kitchen Food Preparation Sink Faucet	6/25/16 10:32 PM	7/6/16 12:10 PM	BB67512	Copper	0.2	1.3	ppm
020-15A	Kitchen Food Preparation Sink Faucet	6/25/16 10:32 PM	7/6/16 12:10 PM	BB67512	Lead	11	15	ppb
020-16A	Classroom 101 Sink Faucet	6/25/16 10:36 PM	7/6/16 12:13 PM	BB67513	Copper	0.2	1.3	ppm
020-16A	Classroom 101 Sink Faucet	6/25/16 10:36 PM	7/6/16 12:13 PM	BB67513	Lead	7	15	ppb
020-17A	Classroom 101 Drinking Fountain	6/25/16 10:37 PM	7/6/16 12:16 PM	BB67514	Copper	0.0	1.3	ppm
020-17A	Classroom 101 Drinking Fountain	6/25/16 10:37 PM	7/6/16 12:16 PM	BB67514	Lead	1	15	ppb
020-18A	Classroom 102 Sink Faucet	6/25/16 10:41 PM	7/7/16 10:51 AM	BB67515	Copper	1.0	1.3	ppm
020-18A	Classroom 102 Sink Faucet	6/25/16 10:41 PM	7/6/16 12:20 PM	BB67515	Lead	6	15	ppb
020-19A	Classroom 102 Drinking Fountain	6/25/16 10:42 PM	7/7/16 10:54 AM	BB67516	Copper	1.0	1.3	ppm
020-19A	Classroom 102 Drinking Fountain	6/25/16 10:42 PM	7/6/16 12:22 PM	BB67516	Lead	3	15	ppb
020-20A	Drinking Fountain Bottle (103)	6/25/16 10:16 PM	7/7/16 10:18 AM	BB67517	Copper	2.3	1.3	ppm
020-20A	Drinking Fountain Bottle (103)	6/25/16 10:16 PM	7/6/16 12:26 PM	BB67517	Lead	3	15	ppb
020-21A	Drinking Fountain #1 (103)	6/25/16 10:17 PM	7/6/16 12:29 PM	BB67518	Copper	0.5	1.3	ppm
020-21A	Drinking Fountain #1 (103)	6/25/16 10:17 PM	7/6/16 12:29 PM	BB67518	Lead	1	15	ppb
020-22A	Drinking Fountain #2 (103)	6/25/16 10:18 PM	7/6/16 12:32 PM	BB67519	Copper	0.8	1.3	ppm
020-22A	Drinking Fountain #2 (103)	6/25/16 10:18 PM	7/6/16 12:32 PM	BB67519	Lead	1	15	ppb
020-23A	Classroom 103 Sink Faucet	6/25/16 10:46 PM	7/6/16 12:35 PM	BB67520	Copper	0.7	1.3	ppm
020-23A	Classroom 103 Sink Faucet	6/25/16 10:46 PM	7/6/16 12:35 PM	BB67520	Lead	15.6	15	ppb
020-24A	Classroom 103 Drinking Fountain	6/25/16 10:47 PM	7/6/16 12:50 PM	BB67521	Copper	0.0	1.3	ppm
020-24A	Classroom 103 Drinking Fountain	6/25/16 10:47 PM	7/6/16 12:50 PM	BB67521	Lead	3	15	ppb
020-25A	Classroom 104 Sink Faucet	6/25/16 10:51 PM	7/6/16 12:53 PM	BB67522	Copper	0.7	1.3	ppm
020-25A	Classroom 104 Sink Faucet	6/25/16 10:51 PM	7/6/16 12:53 PM	BB67522	Lead	14.5	15	ppb
020-26A	Classroom 104 Drinking Fountain	6/25/16 10:52 PM	7/6/16 12:56 PM	BB67523	Copper	0.6	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Buckman Arts Magnet Elementary School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
020-26A	Classroom 104 Drinking Fountain	6/25/16 10:52 PM	7/6/16 12:56 PM	BB67523	Lead	8	15	ppb
020-27A	Classroom 105 Sink Faucet	6/25/16 10:56 PM	7/7/16 11:07 AM	BB67524	Copper	1.0	1.3	ppm
020-27A	Classroom 105 Sink Faucet	6/25/16 10:56 PM	7/6/16 12:59 PM	BB67524	Lead	6	15	ppb
020-28A	Classroom 105 Drinking Fountain	6/25/16 10:57 PM	7/6/16 1:02 PM	BB67525	Copper	0.0	1.3	ppm
020-28A	Classroom 105 Drinking Fountain	6/25/16 10:57 PM	7/6/16 1:02 PM	BB67525	Lead	2	15	ppb
020-29A	Girls Bathroom Sink Faucet	6/25/16 11:01 PM	7/6/16 1:05 PM	BB67526	Copper	0.7	1.3	ppm
020-29A	Girls Bathroom Sink Faucet	6/25/16 11:01 PM	7/6/16 1:05 PM	BB67526	Lead	3	15	ppb
020-30A	Girls Bathroom Water Spigot	6/25/16 11:02 PM	7/6/16 1:08 PM	BB67527	Copper	0.9	1.3	ppm
020-30A	Girls Bathroom Water Spigot	6/25/16 11:02 PM	7/6/16 1:08 PM	BB67527	Lead	38	15	ppb
020-31A	Boys Bathroom Sink Faucet #1	6/25/16 11:08 PM	7/6/16 1:11 PM	BB67528	Copper	0.8	1.3	ppm
020-31A	Boys Bathroom Sink Faucet #1	6/25/16 11:08 PM	7/6/16 1:11 PM	BB67528	Lead	2	15	ppb
020-32A	Boys Bathroom Sink Faucet #2	6/25/16 11:09 PM	7/11/16 3:26 PM	BB67529	Copper	0.7	1.3	ppm
020-32A	Boys Bathroom Sink Faucet #2	6/25/16 11:09 PM	7/11/16 3:26 PM	BB67529	Lead	2	15	ppb
020-33A	Boys Bathroom Water Spigot	6/25/16 11:11 PM	7/7/16 11:04 AM	BB67530	Copper	1.8	1.3	ppm
020-33A	Boys Bathroom Water Spigot	6/25/16 11:11 PM	7/6/16 1:14 PM	BB67530	Lead	53	15	ppb
020-34A	Cafeteria Sink Faucet #1	6/25/16 11:14 PM	7/6/16 1:17 PM	BB67531	Copper	0.6	1.3	ppm
020-34A	Cafeteria Sink Faucet #1	6/25/16 11:14 PM	7/6/16 1:17 PM	BB67531	Lead	8	15	ppb
020-35A	Cafeteria Sink Faucet #2	6/25/16 11:15 PM	7/6/16 1:38 PM	BB67532	Copper	0.4	1.3	ppm
020-35A	Cafeteria Sink Faucet #2	6/25/16 11:15 PM	7/6/16 1:38 PM	BB67532	Lead	8	15	ppb
020-36A	Cafeteria Drinking Fountain #1	6/25/16 11:18 PM	7/6/16 1:41 PM	BB67533	Copper	0.0	1.3	ppm
020-36A	Cafeteria Drinking Fountain #1	6/25/16 11:18 PM	7/6/16 1:41 PM	BB67533	Lead	2	15	ppb
020-37A	Cafeteria Drinking Fountain #2	6/25/16 11:19 PM	7/6/16 1:44 PM	BB67534	Copper	0.0	1.3	ppm
020-37A	Cafeteria Drinking Fountain #2	6/25/16 11:19 PM	7/6/16 1:44 PM	BB67534	Lead	3	15	ppb
020-38A	Classroom 106 Sink Faucet	6/25/16 11:22 PM	7/6/16 1:47 PM	BB67535	Copper	0.7	1.3	ppm
020-38A	Classroom 106 Sink Faucet	6/25/16 11:22 PM	7/6/16 1:47 PM	BB67535	Lead	4	15	ppb
020-39A	Classroom 106 Drinking Fountain	6/25/16 11:23 PM	7/6/16 3:55 PM	BB67536	Copper	0.0	1.3	ppm
020-39A	Classroom 106 Drinking Fountain	6/25/16 11:23 PM	7/6/16 3:55 PM	BB67536	Lead	1	15	ppb
020-40A	Faculty Bathroom Sink Faucet #1	6/25/16 11:25 PM	7/6/16 3:58 PM	BB67537	Copper	0.6	1.3	ppm
020-40A	Faculty Bathroom Sink Faucet #1	6/25/16 11:25 PM	7/6/16 3:58 PM	BB67537	Lead	2	15	ppb
020-41A	Faculty Bathroom Sink Faucet #2	6/25/16 11:28 PM	7/7/16 11:10 AM	BB67538	Copper	1.0	1.3	ppm
020-41A	Faculty Bathroom Sink Faucet #2	6/25/16 11:28 PM	7/6/16 4:01 PM	BB67538	Lead	2	15	ppb
020-42A	Office Bathroom Sink Faucet	6/25/16 11:33 PM	7/11/16 3:29 PM	BB67539	Copper	0.0	1.3	ppm
020-42A	Office Bathroom Sink Faucet	6/25/16 11:33 PM	7/11/16 3:29 PM	BB67539	Lead	10	15	ppb
020-43A	Office Workroom Sink Faucet	6/25/16 11:36 PM	7/6/16 4:04 PM	BB67540	Copper	0.5	1.3	ppm
020-43A	Office Workroom Sink Faucet	6/25/16 11:36 PM	7/6/16 4:04 PM	BB67540	Lead	2	15	ppb
020-44A	Girls Bathroom Sink Faucet 1	6/25/16 11:39 PM	7/7/16 11:13 AM	BB67541	Copper	1.0	1.3	ppm
020-44A	Girls Bathroom Sink Faucet 1	6/25/16 11:39 PM	7/6/16 4:07 PM	BB67541	Lead	3	15	ppb
020-45A	Girls Bathroom Sink Faucet 2	6/25/16 11:40 PM	7/6/16 4:10 PM	BB67542	Copper	0.8	1.3	ppm
020-45A	Girls Bathroom Sink Faucet 2	6/25/16 11:40 PM	7/6/16 4:10 PM	BB67542	Lead	3	15	ppb
020-46A	Girls Bathroom Water Spigot	6/25/16 11:42 PM	7/6/16 4:13 PM	BB67543	Copper	0.8	1.3	ppm
020-46A	Girls Bathroom Water Spigot	6/25/16 11:42 PM	7/6/16 4:13 PM	BB67543	Lead	20	15	ppb
020-47A	Boys Bathroom Sink Faucet 1	6/25/16 11:46 PM	7/6/16 4:17 PM	BB67544	Copper	0.6	1.3	ppm
020-47A	Boys Bathroom Sink Faucet 1	6/25/16 11:46 PM	7/6/16 4:17 PM	BB67544	Lead	3	15	ppb
020-48A	Boys Bathroom Sink Faucet 2	6/25/16 11:47 PM	7/6/16 4:19 PM	BB67545	Copper	0.7	1.3	ppm
020-48A	Boys Bathroom Sink Faucet 2	6/25/16 11:47 PM	7/6/16 4:19 PM	BB67545	Lead	3	15	ppb
020-49A	Boys Bathroom Water Spigot	6/25/16 11:49 PM	7/7/16 11:16 AM	BB67546	Copper	1.2	1.3	ppm
020-49A	Boys Bathroom Water Spigot	6/25/16 11:49 PM	7/6/16 4:41 PM	BB67546	Lead	47	15	ppb
020-50A	Classroom 107 Sink Faucet	6/26/16 12:01 AM	7/6/16 4:44 PM	BB67547	Copper	0.8	1.3	ppm
020-50A	Classroom 107 Sink Faucet	6/26/16 12:01 AM	7/6/16 4:44 PM	BB67547	Lead	2	15	ppb
020-51A	Classroom 107 Drinking Fountain	6/26/16 12:02 AM	7/6/16 4:47 PM	BB67548	Copper	0.8	1.3	ppm
020-51A	Classroom 107 Drinking Fountain	6/26/16 12:02 AM	7/6/16 4:47 PM	BB67548	Lead	4	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Buckman Arts Magnet Elementary School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
020-52A	Classroom 108 Sink Faucet	6/26/16 12:06 AM	7/6/16 4:50 PM	BB67549	Copper	0.8	1.3	ppm
020-52A	Classroom 108 Sink Faucet	6/26/16 12:06 AM	7/6/16 4:50 PM	BB67549	Lead	90	15	ppb
020-53A	Classroom 108 Drinking Fountain	6/26/16 12:07 AM	7/6/16 4:53 PM	BB67550	Copper	0.8	1.3	ppm
020-53A	Classroom 108 Drinking Fountain	6/26/16 12:07 AM	7/6/16 4:53 PM	BB67550	Lead	4	15	ppb
020-54A	Classroom 109 Sink Faucet	6/26/16 12:12 AM	7/6/16 4:56 PM	BB67551	Copper	0.7	1.3	ppm
020-54A	Classroom 109 Sink Faucet	6/26/16 12:12 AM	7/6/16 4:56 PM	BB67551	Lead	5	15	ppb
020-55A	Classroom 109 Drinking Fountain	6/26/16 12:13 AM	7/6/16 4:59 PM	BB67552	Copper	0.6	1.3	ppm
020-55A	Classroom 109 Drinking Fountain	6/26/16 12:13 AM	7/6/16 4:59 PM	BB67552	Lead	4	15	ppb
020-56A	Classroom 110 Drinking Fountain	6/26/16 12:17 AM	7/7/16 11:25 AM	BB67553	Copper	1.29	1.3	ppm
020-56A	Classroom 110 Drinking Fountain	6/26/16 12:17 AM	7/6/16 5:02 PM	BB67553	Lead	2	15	ppb
020-57A	Music 114 Sink Faucet	6/26/16 12:20 AM	7/6/16 5:05 PM	BB67554	Copper	0.5	1.3	ppm
020-57A	Music 114 Sink Faucet	6/26/16 12:20 AM	7/6/16 5:05 PM	BB67554	Lead	7	15	ppb
020-58A	Music 114 Drinking Fountain	6/26/16 12:21 AM	7/6/16 5:08 PM	BB67555	Copper	0.5	1.3	ppm
020-58A	Music 114 Drinking Fountain	6/26/16 12:21 AM	7/6/16 5:08 PM	BB67555	Lead	4	15	ppb
020-59A	Room 112 Drinking Fountain #1	6/26/16 12:24 AM	7/6/16 5:23 PM	BB67556	Copper	0.0	1.3	ppm
020-59A	Room 112 Drinking Fountain #1	6/26/16 12:24 AM	7/6/16 5:23 PM	BB67556	Lead	29	15	ppb
020-60A	Room 112 Drinking Fountain #2	6/26/16 12:26 AM	7/6/16 5:26 PM	BB67557	Copper	0.0	1.3	ppm
020-60A	Room 112 Drinking Fountain #2	6/26/16 12:26 AM	7/6/16 5:26 PM	BB67557	Lead	15.6	15	ppb
020-61A	Classroom 113 Sink Faucet	6/26/16 12:28 AM	7/6/16 5:29 PM	BB67558	Copper	0.8	1.3	ppm
020-61A	Classroom 113 Sink Faucet	6/26/16 12:28 AM	7/6/16 5:29 PM	BB67558	Lead	5	15	ppb
020-62A	Classroom 113 Drinking Fountain	6/26/16 12:29 AM	7/6/16 5:32 PM	BB67559	Copper	0.4	1.3	ppm
020-62A	Classroom 113 Drinking Fountain	6/26/16 12:29 AM	7/6/16 5:32 PM	BB67559	Lead	7	15	ppb
020-63A	South Gymnasium Drinking Fountain #1	6/26/16 12:34 AM	7/6/16 5:35 PM	BB67560	Copper	0.2	1.3	ppm
020-63A	South Gymnasium Drinking Fountain #1	6/26/16 12:34 AM	7/6/16 5:35 PM	BB67560	Lead	3	15	ppb
020-64A	South Gymnasium Drinking Fountain #2	6/26/16 12:35 AM	7/6/16 5:38 PM	BB67561	Copper	0.0	1.3	ppm
020-64A	South Gymnasium Drinking Fountain #2	6/26/16 12:35 AM	7/6/16 5:38 PM	BB67561	Lead	4	15	ppb
020-65A	South Gymnasium Drinking Fountain #3	6/26/16 12:36 AM	7/6/16 5:41 PM	BB67562	Copper	0.1	1.3	ppm
020-65A	South Gymnasium Drinking Fountain #3	6/26/16 12:36 AM	7/6/16 5:41 PM	BB67562	Lead	3	15	ppb
020-66A	South Gymnasium Drinking Fountain #4	6/26/16 12:37 AM	7/6/16 5:44 PM	BB67563	Copper	0.2	1.3	ppm
020-66A	South Gymnasium Drinking Fountain #4	6/26/16 12:37 AM	7/6/16 5:44 PM	BB67563	Lead	4	15	ppb
020-67A	South Gymnasium Drinking Fountain #5	6/26/16 12:39 AM	7/6/16 5:48 PM	BB67564	Copper	0.0	1.3	ppm
020-67A	South Gymnasium Drinking Fountain #5	6/26/16 12:39 AM	7/6/16 5:48 PM	BB67564	Lead	12	15	ppb
020-68A	South Gymnasium Drinking Fountain #6	6/26/16 12:40 AM	7/6/16 5:51 PM	BB67565	Copper	0.0	1.3	ppm
020-68A	South Gymnasium Drinking Fountain #6	6/26/16 12:40 AM	7/6/16 5:51 PM	BB67565	Lead	13	15	ppb
020-69A	Classroom 216 Sink Faucet	6/26/16 12:46 AM	7/6/16 6:12 PM	BB67566	Copper	0.5	1.3	ppm
020-69A	Classroom 216 Sink Faucet	6/26/16 12:46 AM	7/6/16 6:12 PM	BB67566	Lead	6	15	ppb
020-70A	Classroom 216 Drinking Fountain	6/26/16 12:46 AM	7/6/16 6:15 PM	BB67567	Copper	0.3	1.3	ppm
020-70A	Classroom 216 Drinking Fountain	6/26/16 12:46 AM	7/6/16 6:15 PM	BB67567	Lead	5	15	ppb
020-71A	Girls Bathroom Sink Faucet #1	6/26/16 12:51 AM	7/6/16 6:18 PM	BB67568	Copper	0.8	1.3	ppm
020-71A	Girls Bathroom Sink Faucet #1	6/26/16 12:51 AM	7/6/16 6:18 PM	BB67568	Lead	6	15	ppb
020-72A	Girls Bathroom Sink Faucet #2	6/26/16 12:51 AM	7/6/16 6:21 PM	BB67569	Copper	0.8	1.3	ppm
020-72A	Girls Bathroom Sink Faucet #2	6/26/16 12:51 AM	7/6/16 6:21 PM	BB67569	Lead	3	15	ppb
020-73A	Girls Bathroom Water Spigot	6/26/16 12:53 AM	7/6/16 6:24 PM	BB67570	Copper	0.9	1.3	ppm
020-73A	Girls Bathroom Water Spigot	6/26/16 12:53 AM	7/6/16 6:24 PM	BB67570	Lead	21	15	ppb
020-74A	Boys Bathroom Sink Faucet #1	6/26/16 12:55 AM	7/6/16 6:27 PM	BB67571	Copper	0.8	1.3	ppm
020-74A	Boys Bathroom Sink Faucet #1	6/26/16 12:55 AM	7/6/16 6:27 PM	BB67571	Lead	2	15	ppb
020-75A	Boys Bathroom Sink Faucet #2	6/26/16 12:55 AM	7/6/16 6:30 PM	BB67572	Copper	0.6	1.3	ppm
020-75A	Boys Bathroom Sink Faucet #2	6/26/16 12:55 AM	7/6/16 6:30 PM	BB67572	Lead	2	15	ppb
020-76A	Boys Bathroom Water Spigot	6/26/16 12:57 AM	7/6/16 6:33 PM	BB67573	Copper	0.8	1.3	ppm
020-76A	Boys Bathroom Water Spigot	6/26/16 12:57 AM	7/6/16 6:33 PM	BB67573	Lead	73	15	ppb
020-77A	Teacher's Bathroom Sink Faucet	6/26/16 12:59 AM	7/6/16 6:36 PM	BB67574	Copper	0.4	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Buckman Arts Magnet Elementary School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
020-77A	Teacher's Bathroom Sink Faucet	6/26/16 12:59 AM	7/6/16 6:36 PM	BB67574	Lead	4	15	ppb
020-78A	Classroom 213 Sink Faucet	6/26/16 1:02 AM	7/6/16 6:39 PM	BB67575	Copper	0.5	1.3	ppm
020-78A	Classroom 213 Sink Faucet	6/26/16 1:02 AM	7/6/16 6:39 PM	BB67575	Lead	4	15	ppb
020-79A	Classroom 213 Drinking Fountain	6/26/16 1:02 AM	7/6/16 6:54 PM	BB67576	Copper	0.5	1.3	ppm
020-79A	Classroom 213 Drinking Fountain	6/26/16 1:02 AM	7/6/16 6:54 PM	BB67576	Lead	5	15	ppb
020-80A	Classroom 212 Sink Faucet	6/26/16 1:06 AM	7/6/16 6:57 PM	BB67577	Copper	0.6	1.3	ppm
020-80A	Classroom 212 Sink Faucet	6/26/16 1:06 AM	7/6/16 6:57 PM	BB67577	Lead	3	15	ppb
020-81A	Classroom 212 Drinking Fountain	6/26/16 1:06 AM	7/11/16 3:33 PM	BB67578	Copper	1.34	1.3	ppm
020-81A	Classroom 212 Drinking Fountain	6/26/16 1:06 AM	7/11/16 3:33 PM	BB67578	Lead	14.6	15	ppb
020-82A	Classroom 211 Sink Faucet	6/26/16 1:09 AM	7/6/16 7:00 PM	BB67579	Copper	0.6	1.3	ppm
020-82A	Classroom 211 Sink Faucet	6/26/16 1:09 AM	7/6/16 7:00 PM	BB67579	Lead	3	15	ppb
020-83A	Classroom 211 Drinking Fountain	6/26/16 1:09 AM	7/6/16 7:03 PM	BB67580	Lead	1	15	ppb
020-83A	Classroom 211 Drinking Fountain	6/26/16 1:09 AM	7/6/16 7:03 PM	BB67580	Copper	0.9	1.3	ppm
020-84A	Classroom 210 Sink Faucet	6/26/16 1:12 AM	7/6/16 7:06 PM	BB67581	Copper	0.9	1.3	ppm
020-84A	Classroom 210 Sink Faucet	6/26/16 1:12 AM	7/6/16 7:06 PM	BB67581	Lead	5	15	ppb
020-85A	Classroom 210 Drinking Fountain	6/26/16 1:12 AM	7/6/16 7:09 PM	BB67582	Copper	0.0	1.3	ppm
020-85A	Classroom 210 Drinking Fountain	6/26/16 1:12 AM	7/6/16 7:09 PM	BB67582	Lead	2	15	ppb
020-86A	Classroom 208 Sink Faucet	6/26/16 1:15 AM	7/6/16 7:12 PM	BB67583	Copper	0.2	1.3	ppm
020-86A	Classroom 208 Sink Faucet	6/26/16 1:15 AM	7/6/16 7:12 PM	BB67583	Lead	9	15	ppb
020-87A	Classroom 208 Drinking Fountain	6/26/16 1:15 AM	7/6/16 7:15 PM	BB67584	Copper	0.4	1.3	ppm
020-87A	Classroom 208 Drinking Fountain	6/26/16 1:15 AM	7/6/16 7:15 PM	BB67584	Lead	32	15	ppb
020-88A	Classroom 207 Sink Faucet	6/26/16 1:17 AM	7/6/16 7:18 PM	BB67585	Copper	0.9	1.3	ppm
020-88A	Classroom 207 Sink Faucet	6/26/16 1:17 AM	7/6/16 7:18 PM	BB67585	Lead	6	15	ppb
020-89A	Custodial Closet Sink Faucet	6/26/16 1:20 AM	7/6/16 7:21 PM	BB67586	Copper	0.2	1.3	ppm
020-89A	Custodial Closet Sink Faucet	6/26/16 1:20 AM	7/6/16 7:21 PM	BB67586	Lead	1	15	ppb
020-90A	Drinking Fountain (207)	6/26/16 1:20 AM	7/6/16 7:43 PM	BB67587	Copper	0.0	1.3	ppm
020-90A	Drinking Fountain (207)	6/26/16 1:20 AM	7/6/16 7:43 PM	BB67587	Lead	7	15	ppb
020-91A	Classroom 206 Sink Faucet	6/26/16 1:24 AM	7/6/16 7:46 PM	BB67588	Copper	0.5	1.3	ppm
020-91A	Classroom 206 Sink Faucet	6/26/16 1:24 AM	7/6/16 7:46 PM	BB67588	Lead	2	15	ppb
020-92A	Classroom 206 Drinking Fountain	6/26/16 1:24 AM	7/6/16 7:49 PM	BB67589	Copper	0.9	1.3	ppm
020-92A	Classroom 206 Drinking Fountain	6/26/16 1:24 AM	7/6/16 7:49 PM	BB67589	Lead	2	15	ppb
020-93A	Classroom 205 Sink Faucet	6/26/16 1:27 AM	7/6/16 7:52 PM	BB67590	Copper	0.8	1.3	ppm
020-93A	Classroom 205 Sink Faucet	6/26/16 1:27 AM	7/6/16 7:52 PM	BB67590	Lead	11	15	ppb
020-94A	Classroom 205 Drinking Fountain	6/26/16 1:27 AM	7/6/16 7:55 PM	BB67591	Copper	0.8	1.3	ppm
020-94A	Classroom 205 Drinking Fountain	6/26/16 1:27 AM	7/6/16 7:55 PM	BB67591	Lead	3	15	ppb
020-95A	Teacher's Bathroom Sink Faucet	6/26/16 1:30 AM	7/6/16 8:03 PM	BB67592	Copper	0.2	1.3	ppm
020-95A	Teacher's Bathroom Sink Faucet	6/26/16 1:30 AM	7/6/16 8:03 PM	BB67592	Lead	4	15	ppb
020-96A	Boys Bathroom Sink Faucet #1	6/26/16 1:33 AM	7/7/16 6:34 PM	BB67593	Copper	1.0	1.3	ppm
020-96A	Boys Bathroom Sink Faucet #1	6/26/16 1:33 AM	7/6/16 8:06 PM	BB67593	Lead	3	15	ppb
020-97A	Boys Bathroom Sink Faucet #2	6/26/16 1:33 AM	7/7/16 10:33 AM	BB67594	Copper	0.9	1.3	ppm
020-97A	Boys Bathroom Sink Faucet #2	6/26/16 1:33 AM	7/6/16 1:50 PM	BB67594	Lead	2	15	ppb
020-98A	Boys Bathroom Water Spigot	6/26/16 1:43 AM	7/11/16 4:08 PM	BB67595	Copper	1.1	1.3	ppm
020-98A	Boys Bathroom Water Spigot	6/26/16 1:43 AM	7/11/16 4:08 PM	BB67595	Lead	60	15	ppb
020-99A	Girls Bathroom Sink Faucet	6/26/16 1:36 AM	7/6/16 1:54 PM	BB67596	Copper	0.7	1.3	ppm
020-99A	Girls Bathroom Sink Faucet	6/26/16 1:36 AM	7/6/16 1:54 PM	BB67596	Lead	2	15	ppb
020-100A	Girls Bathroom Water Spigot	6/26/16 1:45 AM	7/6/16 1:57 PM	BB67597	Copper	0.7	1.3	ppm
020-100A	Girls Bathroom Water Spigot	6/26/16 1:45 AM	7/6/16 1:57 PM	BB67597	Lead	30	15	ppb
020-101A	Classroom 204 Sink Faucet	6/26/16 1:40 AM	7/6/16 2:00 PM	BB67598	Copper	0.7	1.3	ppm
020-101A	Classroom 204 Sink Faucet	6/26/16 1:40 AM	7/6/16 2:00 PM	BB67598	Lead	15.4	15	ppb
020-102A	Classroom 204 Drinking Fountain	6/26/16 1:40 AM	7/6/16 2:03 PM	BB67599	Copper	0.7	1.3	ppm
020-102A	Classroom 204 Drinking Fountain	6/26/16 1:40 AM	7/6/16 2:03 PM	BB67599	Lead	4	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Buckman Arts Magnet Elementary School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
020-103A	Classroom 203 Sink Faucet	6/26/16 1:48 AM	7/6/16 2:06 PM	BB67600	Copper	0.7	1.3	ppm
020-103A	Classroom 203 Sink Faucet	6/26/16 1:48 AM	7/6/16 2:06 PM	BB67600	Lead	14	15	ppb
020-104A	Classroom 203 Drinking Fountain	6/26/16 1:48 AM	7/7/16 10:36 AM	BB67601	Copper	0.9	1.3	ppm
020-104A	Classroom 203 Drinking Fountain	6/26/16 1:48 AM	7/6/16 2:21 PM	BB67601	Lead	1	15	ppb
020-105A	Classroom 202 Sink Faucet	6/26/16 1:52 AM	7/6/16 2:24 PM	BB67602	Copper	0.9	1.3	ppm
020-105A	Classroom 202 Sink Faucet	6/26/16 1:52 AM	7/6/16 2:24 PM	BB67602	Lead	11	15	ppb
020-106A	Classroom 202 Drinking Fountain	6/26/16 1:52 AM	7/7/16 10:45 AM	BB67603	Copper	1.1	1.3	ppm
020-106A	Classroom 202 Drinking Fountain	6/26/16 1:52 AM	7/6/16 2:27 PM	BB67603	Lead	3	15	ppb
020-107A	Classroom 201 Sink Faucet	6/26/16 1:55 AM	7/6/16 2:30 PM	BB67604	Copper	0.3	1.3	ppm
020-107A	Classroom 201 Sink Faucet	6/26/16 1:55 AM	7/6/16 2:30 PM	BB67604	Lead	81	15	ppb
020-108A	Classroom 201 Drinking Fountain	6/26/16 1:55 AM	7/6/16 2:33 PM	BB67605	Copper	0.0	1.3	ppm
020-108A	Classroom 201 Drinking Fountain	6/26/16 1:55 AM	7/6/16 2:33 PM	BB67605	Lead	5	15	ppb
020-109A	Pool Area Drinking Fountain #1	6/25/16 9:32 PM	7/6/16 2:36 PM	BB67606	Copper	0.5	1.3	ppm
020-109A	Pool Area Drinking Fountain #1	6/25/16 9:32 PM	7/6/16 2:36 PM	BB67606	Lead	1	15	ppb
020-110A	Pool Area Drinking Fountain #2	6/25/16 9:25 PM	7/6/16 2:39 PM	BB67607	Copper	0.4	1.3	ppm
020-110A	Pool Area Drinking Fountain #2	6/25/16 9:25 PM	7/6/16 2:39 PM	BB67607	Lead	2	15	ppb
020-111A	Girls Locker Room Shower #1	6/25/16 9:27 PM	7/6/16 2:42 PM	BB67608	Copper	0.2	1.3	ppm
020-111A	Girls Locker Room Shower #1	6/25/16 9:27 PM	7/6/16 2:42 PM	BB67608	Lead	5	15	ppb
020-112A	Girls Locker Room Shower #2	6/25/16 9:28 PM	7/6/16 2:46 PM	BB67609	Copper	0.5	1.3	ppm
020-112A	Girls Locker Room Shower #2	6/25/16 9:28 PM	7/6/16 2:46 PM	BB67609	Lead	12	15	ppb
020-113A	Girls Locker Room Shower #3	6/25/16 9:29 PM	7/6/16 2:49 PM	BB67610	Copper	0.5	1.3	ppm
020-113A	Girls Locker Room Shower #3	6/25/16 9:29 PM	7/6/16 2:49 PM	BB67610	Lead	11	15	ppb
020-114A	Girls Locker Room Shower #4	6/25/16 9:30 PM	7/11/16 4:05 PM	BB67611	Copper	0.5	1.3	ppm
020-114A	Girls Locker Room Shower #4	6/25/16 9:30 PM	7/11/16 4:05 PM	BB67611	Lead	14	15	ppb
020-115A	Girls Locker Room Shower #5	6/25/16 9:31 PM	7/6/16 3:10 PM	BB67612	Copper	0.5	1.3	ppm
020-115A	Girls Locker Room Shower #5	6/25/16 9:31 PM	7/6/16 3:10 PM	BB67612	Lead	13	15	ppb
020-116A	Girls Locker Room Shower #6	6/25/16 9:32 PM	7/11/16 4:12 PM	BB67613	Copper	0.6	1.3	ppm
020-116A	Girls Locker Room Shower #6	6/25/16 9:32 PM	7/11/16 4:12 PM	BB67613	Lead	13	15	ppb
020-117A	Girls Locker Room Sink Faucet	6/25/16 9:33 PM	7/11/16 4:15 PM	BB67614	Copper	0.3	1.3	ppm
020-117A	Girls Locker Room Sink Faucet	6/25/16 9:33 PM	7/11/16 4:15 PM	BB67614	Lead	3	15	ppb
020-118A	Girls Locker Room Water Spigot	6/25/16 9:35 PM	7/6/16 3:13 PM	BB67615	Copper	0.7	1.3	ppm
020-118A	Girls Locker Room Water Spigot	6/25/16 9:35 PM	7/6/16 3:13 PM	BB67615	Lead	7	15	ppb
020-119A	Boys Locker Room Shower #1	6/25/16 9:09 PM	7/6/16 3:16 PM	BB67616	Copper	0.6	1.3	ppm
020-119A	Boys Locker Room Shower #1	6/25/16 9:09 PM	7/6/16 3:16 PM	BB67616	Lead	7	15	ppb
020-120A	Boys Locker Room Shower #2	6/25/16 9:12 PM	7/6/16 3:19 PM	BB67617	Copper	0.7	1.3	ppm
020-120A	Boys Locker Room Shower #2	6/25/16 9:12 PM	7/6/16 3:19 PM	BB67617	Lead	5	15	ppb
020-121A	Boys Locker Room Shower #3	6/25/16 9:13 PM	7/6/16 3:22 PM	BB67618	Copper	0.6	1.3	ppm
020-121A	Boys Locker Room Shower #3	6/25/16 9:13 PM	7/6/16 3:22 PM	BB67618	Lead	7	15	ppb
020-122A	Boys Locker Room Shower #4	6/25/16 9:13 PM	7/6/16 3:25 PM	BB67619	Copper	0.7	1.3	ppm
020-122A	Boys Locker Room Shower #4	6/25/16 9:13 PM	7/6/16 3:25 PM	BB67619	Lead	4	15	ppb
020-123A	Boys Locker Room Shower #5	6/25/16 9:13 PM	7/6/16 3:28 PM	BB67620	Copper	0.7	1.3	ppm
020-123A	Boys Locker Room Shower #5	6/25/16 9:13 PM	7/6/16 3:28 PM	BB67620	Lead	8	15	ppb
020-124A	Boys Locker Room Shower #6	6/25/16 9:14 PM	7/6/16 3:31 PM	BB67621	Copper	0.7	1.3	ppm
020-124A	Boys Locker Room Shower #6	6/25/16 9:14 PM	7/6/16 3:31 PM	BB67621	Lead	9	15	ppb
020-125A	Boys Locker Room Shower #7	6/25/16 9:16 PM	7/6/16 3:34 PM	BB67622	Copper	0.6	1.3	ppm
020-125A	Boys Locker Room Shower #7	6/25/16 9:16 PM	7/6/16 3:34 PM	BB67622	Lead	8	15	ppb
020-126A	Boys Locker Room Shower #8	6/25/16 9:17 PM	7/6/16 3:37 PM	BB67623	Copper	0.6	1.3	ppm
020-126A	Boys Locker Room Shower #8	6/25/16 9:17 PM	7/6/16 3:37 PM	BB67623	Lead	7	15	ppb
020-127A	Boys Locker Room Water Spigot	6/25/16 9:20 PM	7/11/16 4:19 PM	BB67624	Copper	0.3	1.3	ppm
020-127A	Boys Locker Room Water Spigot	6/25/16 9:20 PM	7/11/16 4:19 PM	BB67624	Lead	3	15	ppb
020-128A	Boys Locker Room Sink Faucet	6/25/16 9:21 PM	7/6/16 3:52 PM	BB67625	Copper	0.3	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Buckman Arts Magnet Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
020-128A Boys Locker Room Sink Faucet	6/25/16 9:21 PM	7/6/16 3:52 PM	BB67625	Lead	3	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.