

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Capitol Hill Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	ContainerID	Analyte	Result	EPA Action	
						Limit	Units
021-01A Boiler Room Sink	6/20/16 13:49	7/5/16 13:17	606220201	Copper	0.3	1.3	ppm
021-01A Boiler Room Sink	6/20/16 13:49	7/5/16 13:17	606220201	Lead	3	15	ppb
021-02A Drinking Fountain Outside Boiler Room 1	6/20/16 13:51	7/5/16 13:17	606220202	Copper	0.0	1.3	ppm
021-02A Drinking Fountain Outside Boiler Room 1	6/20/16 13:51	7/5/16 13:17	606220202	Lead	10	15	ppb
021-039A Mens Room Sink	6/20/16 15:13	7/5/16 13:24	606220238	Copper	0.1	1.3	ppm
021-039A Mens Room Sink	6/20/16 15:13	7/5/16 13:24	606220238	Lead	10	15	ppb
021-03A Drinking Fountain Outside Boiler Room 2	6/20/16 13:52	7/5/16 13:17	606220203	Copper	0.0	1.3	ppm
021-03A Drinking Fountain Outside Boiler Room 2	6/20/16 13:52	7/5/16 13:17	606220203	Lead	5	15	ppb
021-04A Girls Bathroom Near Storeroom B Sink 1	6/20/16 13:56	7/5/16 13:17	606220204	Copper	0.0	1.3	ppm
021-04A Girls Bathroom Near Storeroom B Sink 1	6/20/16 13:56	7/5/16 13:17	606220204	Lead	1	15	ppb
021-05A Girls Bathroom Near Storeroom B Sink 2	6/20/16 13:57	7/5/16 13:17	606220205	Copper	0.1	1.3	ppm
021-05A Girls Bathroom Near Storeroom B Sink 2	6/20/16 13:57	7/5/16 13:17	606220205	Lead	2	15	ppb
021-06A Girls Bathroom Near Storeroom B Spigot	6/20/16 13:59	6/30/16 18:39	606220206	Copper	0.2	1.3	ppm
021-06A Girls Bathroom Near Storeroom B Spigot	6/20/16 13:59	6/30/16 18:39	606220206	Lead	57	15	ppb
021-07A Womens Bathroom Outside Storeroom A Sink	6/20/16 14:04	7/5/16 13:18	606220207	Copper	0.3	1.3	ppm
021-07A Womens Bathroom Outside Storeroom A Sink	6/20/16 14:04	7/5/16 13:18	606220207	Lead	5	15	ppb
021-08A Classroom 104 Sink	6/20/16 14:02	7/5/16 13:18	606220208	Copper	0.4	1.3	ppm
021-08A Classroom 104 Sink	6/20/16 14:02	7/5/16 13:18	606220208	Lead	3	15	ppb
021-09A Classroom 102 Sink	6/20/16 14:04	7/5/16 13:18	606220209	Copper	0.2	1.3	ppm
021-09A Classroom 102 Sink	6/20/16 14:04	7/5/16 13:18	606220209	Lead	32	15	ppb
021-10A Classroom 102 Drinking Fountain	6/20/16 14:06	7/5/16 13:19	606220210	Copper	0.1	1.3	ppm
021-10A Classroom 102 Drinking Fountain	6/20/16 14:06	7/5/16 13:19	606220210	Lead	4	15	ppb
021-11A Boys Bathroom Near 102 Sink	6/20/16 14:10	7/5/16 13:19	606220211	Copper	0.1	1.3	ppm
021-11A Boys Bathroom Near 102 Sink	6/20/16 14:10	7/5/16 13:19	606220211	Lead	10	15	ppb
021-12A Boys Bathroom Near 102 Sink	6/20/16 14:10	7/5/16 13:19	606220212	Copper	0.1	1.3	ppm
021-12A Boys Bathroom Near 102 Sink	6/20/16 14:10	7/5/16 13:19	606220212	Lead	13	15	ppb
021-13A Drinking Fountain Near 102	6/20/16 14:13	7/5/16 13:19	606220213	Copper	0.0	1.3	ppm
021-13A Drinking Fountain Near 102	6/20/16 14:13	7/5/16 13:19	606220213	Lead	3	15	ppb
021-14A Classroom 101 Sink	6/20/16 14:15	7/5/16 13:19	606220214	Copper	0.1	1.3	ppm
021-14A Classroom 101 Sink	6/20/16 14:15	7/5/16 13:19	606220214	Lead	4	15	ppb
021-15A Classroom 100 Bathroom Sink 1	6/20/16 14:17	7/5/16 13:19	606220215	Copper	0.1	1.3	ppm
021-15A Classroom 100 Bathroom Sink 1	6/20/16 14:17	7/5/16 13:19	606220215	Lead	11	15	ppb
021-16A Classroom 100 Bathroom Sink 2	6/20/16 14:18	7/5/16 13:19	606220216	Copper	0.1	1.3	ppm
021-16A Classroom 100 Bathroom Sink 2	6/20/16 14:18	7/5/16 13:19	606220216	Lead	9	15	ppb
021-17A Classroom 100 Drinking Fountain	6/20/16 14:20	7/5/16 13:20	606220217	Copper	0.0	1.3	ppm
021-17A Classroom 100 Drinking Fountain	6/20/16 14:20	7/5/16 13:20	606220217	Lead	17	15	ppb
021-18A Classroom 100 Sink	6/20/16 14:22	7/5/16 13:20	606220218	Copper	0.0	1.3	ppm
021-18A Classroom 100 Sink	6/20/16 14:22	7/5/16 13:20	606220218	Lead	3	15	ppb
021-19A Classroom 105 Sink	6/20/16 14:24	7/5/16 13:20	606220219	Copper	0.1	1.3	ppm
021-19A Classroom 105 Sink	6/20/16 14:24	7/5/16 13:20	606220219	Lead	32	15	ppb
021-20A Classroom 106 Sink	6/20/16 14:26	7/5/16 13:20	606220220	Copper	0.0	1.3	ppm
021-20A Classroom 106 Sink	6/20/16 14:26	7/5/16 13:20	606220220	Lead	3	15	ppb
021-21A Classroom 107 Sink	6/20/16 14:28	7/5/16 13:20	606220221	Copper	0.1	1.3	ppm
021-21A Classroom 107 Sink	6/20/16 14:28	7/5/16 13:20	606220221	Lead	9	15	ppb
021-22A Boys Bathroom Sink Near 107	6/20/16 14:35	7/5/16 13:20	606220222	Copper	0.1	1.3	ppm
021-22A Boys Bathroom Sink Near 107	6/20/16 14:35	7/5/16 13:20	606220222	Lead	4	15	ppb
021-23A Boys Bathroom Sink Near 107	6/20/16 14:37	7/5/16 13:20	606220223	Copper	0.0	1.3	ppm
021-23A Boys Bathroom Sink Near 107	6/20/16 14:37	7/5/16 13:20	606220223	Lead	20	15	ppb
021-24A Drinking Fountain Near 107	6/20/16 14:33	7/5/16 13:20	606220224	Copper	0.5	1.3	ppm
021-24A Drinking Fountain Near 107	6/20/16 14:33	7/5/16 13:20	606220224	Lead	1	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Capitol Hill Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	ContainerID	Analyte	Result	EPA Action	
						Limit	Units
021-25A Drinking Fountain Near 107	6/20/16 14:33	7/5/16 13:20	606220225	Copper	0.2	1.3	ppm
021-25A Drinking Fountain Near 107	6/20/16 14:33	7/5/16 13:20	606220225	Lead	2	15	ppb
021-26A Classroom 108 Sink	6/20/16 14:38	7/5/16 13:20	606220226	Copper	0.4	1.3	ppm
021-26A Classroom 108 Sink	6/20/16 14:38	7/5/16 13:20	606220226	Lead	5	15	ppb
021-27A Custodial Sink Near 109	6/20/16 14:40	7/5/16 13:21	606220227	Copper	0.1	1.3	ppm
021-27A Custodial Sink Near 109	6/20/16 14:40	7/5/16 13:21	606220227	Lead	6	15	ppb
021-28A Women Bathroom Sink Near 109	6/20/16 14:43	7/5/16 13:21	606220228	Copper	0.2	1.3	ppm
021-28A Women Bathroom Sink Near 109	6/20/16 14:43	7/5/16 13:21	606220228	Lead	13	15	ppb
021-29A Library Sink in Staff/Parent Workroom	6/20/16 14:44	7/5/16 13:21	606220229	Copper	0.2	1.3	ppm
021-29A Library Sink in Staff/Parent Workroom	6/20/16 14:44	7/5/16 13:21	606220229	Lead	24	15	ppb
021-30A Drinking Fountain Outside Library	6/20/16 14:39	7/5/16 13:21	606220230	Copper	0.0	1.3	ppm
021-30A Drinking Fountain Outside Library	6/20/16 14:39	7/5/16 13:21	606220230	Lead	5	15	ppb
021-31A Girls Bathroom Near Library Sink 1	6/20/16 14:49	7/5/16 13:21	606220231	Copper	0.1	1.3	ppm
021-31A Girls Bathroom Near Library Sink 1	6/20/16 14:49	7/5/16 13:21	606220231	Lead	5	15	ppb
021-32A Girls Bathroom Near Library Sink 2	6/20/16 14:51	7/5/16 13:21	606220232	Copper	0.1	1.3	ppm
021-32A Girls Bathroom Near Library Sink 2	6/20/16 14:51	7/5/16 13:21	606220232	Lead	12	15	ppb
021-33A Girls Bathroom Near Library Sink 3	6/20/16 14:53	7/5/16 13:21	606220233	Copper	0.1	1.3	ppm
021-33A Girls Bathroom Near Library Sink 3	6/20/16 14:53	7/5/16 13:21	606220233	Lead	5	15	ppb
021-34A Girls Bathroom Near Library Sink 4	6/20/16 14:55	7/5/16 13:21	606220234	Copper	0.0	1.3	ppm
021-34A Girls Bathroom Near Library Sink 4	6/20/16 14:55	7/5/16 13:21	606220234	Lead	3	15	ppb
021-35A Classroom 111 Sink	6/20/16 14:57	7/5/16 13:21	606220235	Copper	0.1	1.3	ppm
021-35A Classroom 111 Sink	6/20/16 14:57	7/5/16 13:21	606220235	Lead	7	15	ppb
021-36A Classroom 112 Sink	6/20/16 15:03	7/5/16 14:54	606220293	Copper	0.0	1.3	ppm
021-36A Classroom 112 Sink	6/20/16 15:03	7/5/16 14:54	606220293	Lead	5	15	ppb
021-37A Classroom 112 Drinking Fountain	6/20/16 15:04	7/5/16 13:21	606220236	Copper	0.0	1.3	ppm
021-37A Classroom 112 Drinking Fountain	6/20/16 15:04	7/5/16 13:21	606220236	Lead	2	15	ppb
021-38A Classroom 112A Sink	6/20/16 15:07	7/5/16 13:24	606220237	Copper	0.1	1.3	ppm
021-38A Classroom 112A Sink	6/20/16 15:07	7/5/16 13:24	606220237	Lead	23	15	ppb
021-40A Mens Room Spigot	6/20/16 13:15	6/30/16 18:39	606220239	Copper	0.2	1.3	ppm
021-40A Mens Room Spigot	6/20/16 13:15	6/30/16 18:39	606220239	Lead	1980	15	ppb
021-41A Faculty Room Sink	6/20/16 15:17	7/5/16 13:24	606220240	Copper	0.1	1.3	ppm
021-41A Faculty Room Sink	6/20/16 15:17	7/5/16 13:24	606220240	Lead	5	15	ppb
021-42A Faculty Room Bathroom Sink	6/20/16 15:19	7/5/16 13:24	606220241	Copper	0.1	1.3	ppm
021-42A Faculty Room Bathroom Sink	6/20/16 15:19	7/5/16 13:24	606220241	Lead	5	15	ppb
021-43A Faculty Storeroom Sink	6/20/16 15:21	7/5/16 13:24	606220242	Copper	0.1	1.3	ppm
021-43A Faculty Storeroom Sink	6/20/16 15:21	7/5/16 13:24	606220242	Lead	12	15	ppb
021-44A Drinking Fountain Near Nurses Office	6/20/16 15:23	7/5/16 13:24	606220243	Copper	0.1	1.3	ppm
021-44A Drinking Fountain Near Nurses Office	6/20/16 15:23	7/5/16 13:24	606220243	Lead	2	15	ppb
021-45A Kitchen Food Prep Sink 1	6/20/16 15:29	7/5/16 13:24	606220244	Copper	0.1	1.3	ppm
021-45A Kitchen Food Prep Sink 1	6/20/16 15:29	7/5/16 13:24	606220244	Lead	43	15	ppb
021-46A Kitchen Custodian Closet Sink	6/20/16 15:51	7/5/16 13:24	606220245	Copper	0.2	1.3	ppm
021-46A Kitchen Custodian Closet Sink	6/20/16 15:51	7/5/16 13:24	606220245	Lead	14	15	ppb
021-47A Kitchen Bathroom Sink	6/20/16 15:53	7/5/16 13:25	606220246	Copper	0.1	1.3	ppm
021-47A Kitchen Bathroom Sink	6/20/16 15:53	7/5/16 13:25	606220246	Lead	40	15	ppb
021-48A Kitchen Handwash Sink	6/20/16 15:32	7/5/16 13:25	606220247	Copper	0.4	1.3	ppm
021-48A Kitchen Handwash Sink	6/20/16 15:32	7/5/16 13:25	606220247	Lead	3	15	ppb
021-49A Kitchen Spigot Into Sink	6/20/16 15:30	7/5/16 13:27	606220248	Copper	0.0	1.3	ppm
021-49A Kitchen Spigot Into Sink	6/20/16 15:30	7/5/16 13:27	606220248	Lead	105	15	ppb
021-50A Kitchen Food Prep Sink	6/20/16 15:28	7/5/16 13:27	606220249	Copper	0.1	1.3	ppm
021-50A Kitchen Food Prep Sink	6/20/16 15:28	7/5/16 13:27	606220249	Lead	2	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Capitol Hill Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	ContainerID	Analyte	Result	EPA Action	
						Limit	Units
021-51A Cafetorium Drinking Fountain	6/20/16 15:28	7/5/16 13:27	606220250	Copper	0.1	1.3	ppm
021-51A Cafetorium Drinking Fountain	6/20/16 15:28	7/5/16 13:27	606220250	Lead	17	15	ppb
021-52A Gym Drinking Fountain	6/20/16 16:07	7/5/16 13:27	606220251	Copper	0.0	1.3	ppm
021-52A Gym Drinking Fountain	6/20/16 16:07	7/5/16 13:27	606220251	Lead	2	15	ppb
021-53A Drinking Fountain Outside Gym	6/20/16 16:14	7/5/16 13:27	606220252	Copper	0.0	1.3	ppm
021-53A Drinking Fountain Outside Gym	6/20/16 16:14	7/5/16 13:27	606220252	Lead	21	15	ppb
021-54A Custodian Closet Sink Near 113	6/20/16 16:16	7/5/16 13:27	606220253	Copper	0.1	1.3	ppm
021-54A Custodian Closet Sink Near 113	6/20/16 16:16	7/5/16 13:27	606220253	Lead	3	15	ppb
021-55A Boys Bathroom Near 113 Sink	6/20/16 16:18	7/5/16 13:27	606220254	Copper	0.2	1.3	ppm
021-55A Boys Bathroom Near 113 Sink	6/20/16 16:18	7/5/16 13:27	606220254	Lead	13	15	ppb
021-56A Boys Bathroom Near 113 Water Spigot	6/20/16 16:19	6/30/16 18:39	606220255	Copper	0.1	1.3	ppm
021-56A Boys Bathroom Near 113 Water Spigot	6/20/16 16:19	6/30/16 18:39	606220255	Lead	164	15	ppb
021-57A Girls bathroom Near 113 Sink	6/20/16 16:39	7/5/16 13:27	606220256	Copper	0.1	1.3	ppm
021-57A Girls bathroom Near 113 Sink	6/20/16 16:39	7/5/16 13:27	606220256	Lead	59	15	ppb
021-58A Girls Bathroom Near 113 Sink	6/20/16 16:39	6/30/16 18:39	606220257	Copper	0.2	1.3	ppm
021-58A Girls Bathroom Near 113 Sink	6/20/16 16:39	6/30/16 18:39	606220257	Lead	256	15	ppb
021-59A Womens Bathroom Sink	6/20/16 16:33	7/5/16 13:27	606220258	Copper	0.1	1.3	ppm
021-59A Womens Bathroom Sink	6/20/16 16:33	7/5/16 13:27	606220258	Lead	5	15	ppb
021-60A Womens Bathroom Spigot	6/20/16 16:34	7/5/16 13:27	606220259	Copper	0.1	1.3	ppm
021-60A Womens Bathroom Spigot	6/20/16 16:34	7/5/16 13:27	606220259	Lead	120	15	ppb
021-61A Mens Bathroom Sink	6/20/16 16:36	7/5/16 14:53	606220260	Copper	0.1	1.3	ppm
021-61A Mens Bathroom Sink	6/20/16 16:36	7/5/16 14:53	606220260	Lead	7	15	ppb
021-62A Mens Bathroom Spigot	6/20/16 16:47	7/5/16 14:53	606220261	Copper	0.1	1.3	ppm
021-62A Mens Bathroom Spigot	6/20/16 16:47	7/5/16 14:53	606220261	Lead	80	15	ppb
021-63A Classroom 113 Drinking Fountain	6/20/16 16:42	7/5/16 14:53	606220262	Copper	0.0	1.3	ppm
021-63A Classroom 113 Drinking Fountain	6/20/16 16:42	7/5/16 14:53	606220262	Lead	2	15	ppb
021-64A Classroom 113 Sink	6/20/16 16:45	7/5/16 14:53	606220263	Copper	0.1	1.3	ppm
021-64A Classroom 113 Sink	6/20/16 16:45	7/5/16 14:53	606220263	Lead	17	15	ppb
021-65A Classroom 114 Sink	6/20/16 16:38	7/5/16 14:53	606220264	Copper	0.1	1.3	ppm
021-65A Classroom 114 Sink	6/20/16 16:38	7/5/16 14:53	606220264	Lead	4	15	ppb
021-66A Classroom 114 Drinking Fountain	6/20/16 16:40	7/5/16 14:53	606220265	Copper	0.1	1.3	ppm
021-66A Classroom 114 Drinking Fountain	6/20/16 16:40	7/5/16 14:53	606220265	Lead	5	15	ppb
021-67A Classroom 115 Drinking Fountain	6/20/16 16:40	7/5/16 14:53	606220266	Copper	0.0	1.3	ppm
021-67A Classroom 115 Drinking Fountain	6/20/16 16:40	7/5/16 14:53	606220266	Lead	5	15	ppb
021-68A Classroom 115 Sink	6/20/16 16:39	7/5/16 14:53	606220267	Copper	0.1	1.3	ppm
021-68A Classroom 115 Sink	6/20/16 16:39	7/5/16 14:53	606220267	Lead	5	15	ppb
021-69A Classroom 116 Sink	6/20/16 16:41	7/5/16 14:53	606220268	Copper	0.2	1.3	ppm
021-69A Classroom 116 Sink	6/20/16 16:41	7/5/16 14:53	606220268	Lead	7	15	ppb
021-70A Drinking Fountain at Top of Stairs	6/20/16 15:06	7/5/16 14:53	606220269	Copper	0.0	1.3	ppm
021-70A Drinking Fountain at Top of Stairs	6/20/16 15:06	7/5/16 14:53	606220269	Lead	6	15	ppb
021-72A Womens room Sink	6/20/16 15:13	7/5/16 14:53	606220271	Copper	0.1	1.3	ppm
021-72A Womens room Sink	6/20/16 15:13	7/5/16 14:53	606220271	Lead	5	15	ppb
021-73A Mens Room Sink	6/20/16 15:13	7/5/16 14:53	606220272	Copper	0.2	1.3	ppm
021-73A Mens Room Sink	6/20/16 15:13	7/5/16 14:53	606220272	Lead	19	15	ppb
021-74A Boys Bathroom Sink	6/20/16 15:18	7/5/16 14:54	606220273	Copper	0.1	1.3	ppm
021-74A Boys Bathroom Sink	6/20/16 15:18	7/5/16 14:54	606220273	Lead	13	15	ppb
021-75A Boys Bathroom Spigot	6/20/16 15:22	7/5/16 14:54	606220274	Copper	0.0	1.3	ppm
021-75A Boys Bathroom Spigot	6/20/16 15:22	7/5/16 14:54	606220274	Lead	17	15	ppb
021-76A Girls Bathroom Sink 1	6/20/16 15:24	7/5/16 14:54	606220275	Copper	0.1	1.3	ppm
021-76A Girls Bathroom Sink 1	6/20/16 15:24	7/5/16 14:54	606220275	Lead	10	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Capitol Hill Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	ContainerID	Analyte	Result	EPA Action	
						Limit	Units
021-77A Girls Bathroom Sink 2	6/20/16 15:27	7/5/16 14:54	606220276	Copper	0.0	1.3	ppm
021-77A Girls Bathroom Sink 2	6/20/16 15:27	7/5/16 14:54	606220276	Lead	7	15	ppb
021-78A Girls Bathroom Spigot	6/20/16 15:30	7/5/16 14:54	606220277	Copper	0.0	1.3	ppm
021-78A Girls Bathroom Spigot	6/20/16 15:30	7/5/16 14:54	606220277	Lead	22	15	ppb
021-79A Classroom 200 Drinking Fountain	6/20/16 15:33	7/5/16 14:54	606220278	Copper	0.0	1.3	ppm
021-79A Classroom 200 Drinking Fountain	6/20/16 15:33	7/5/16 14:54	606220278	Lead	2	15	ppb
021-80A Classroom 200 Sink	6/20/16 15:36	7/5/16 14:54	606220279	Copper	0.1	1.3	ppm
021-80A Classroom 200 Sink	6/20/16 15:36	7/5/16 14:54	606220279	Lead	12	15	ppb
021-81A Classroom 201 Sink	6/20/16 15:39	7/5/16 14:54	606220280	Copper	0.1	1.3	ppm
021-81A Classroom 201 Sink	6/20/16 15:39	7/5/16 14:54	606220280	Lead	4	15	ppb
021-82A Classroom 202 Sink	6/20/16 15:43	7/5/16 14:54	606220281	Copper	0.1	1.3	ppm
021-82A Classroom 202 Sink	6/20/16 15:43	7/5/16 14:54	606220281	Lead	18	15	ppb
021-83A Classroom 203 Drinking Fountain	6/20/16 15:45	7/5/16 14:54	606220282	Copper	0.0	1.3	ppm
021-83A Classroom 203 Drinking Fountain	6/20/16 15:45	7/5/16 14:54	606220282	Lead	2	15	ppb
021-84A Classroom 203 Sink	6/20/16 15:48	7/5/16 14:54	606220283	Copper	0.0	1.3	ppm
021-84A Classroom 203 Sink	6/20/16 15:48	7/5/16 14:54	606220283	Lead	2	15	ppb
021-85A Water Spigot 1	6/20/16 15:01	7/5/16 14:54	606220284	Copper	0.0	1.3	ppm
021-85A Water Spigot 1	6/20/16 15:01	7/5/16 14:54	606220284	Lead	12	15	ppb
021-86A Water Spigot 2	6/20/16 15:05	7/5/16 14:54	606220285	Copper	0.0	1.3	ppm
021-86A Water Spigot 2	6/20/16 15:05	7/5/16 14:54	606220285	Lead	3	15	ppb
021-87A Water Spigot 3	6/20/16 15:09	7/5/16 14:54	606220286	Copper	0.3	1.3	ppm
021-87A Water Spigot 3	6/20/16 15:09	7/5/16 14:54	606220286	Lead	39	15	ppb
021-88A Water Spigot 4	6/20/16 15:14	7/5/16 14:54	606220287	Copper	0.0	1.3	ppm
021-88A Water Spigot 4	6/20/16 15:14	7/5/16 14:54	606220287	Lead	7	15	ppb
021-89A Water Spigot 5	6/20/16 15:19	7/5/16 14:54	606220288	Copper	0.4	1.3	ppm
021-89A Water Spigot 5	6/20/16 15:19	7/5/16 14:54	606220288	Lead	22	15	ppb
021-90A Water Spigot 6	6/20/16 15:24	7/5/16 14:54	606220289	Copper	0.4	1.3	ppm
021-90A Water Spigot 6	6/20/16 15:24	7/5/16 14:54	606220289	Lead	93	15	ppb
021-91A Water Spigot 7	6/20/16 15:28	7/5/16 14:54	606220294	Copper	0.2	1.3	ppm
021-91A Water Spigot 7	6/20/16 15:28	7/5/16 14:54	606220294	Lead	27	15	ppb
021-92A Portable Building Sink	6/20/16 15:48	7/5/16 14:54	606220290	Copper	0.0	1.3	ppm
021-92A Portable Building Sink	6/20/16 15:48	7/5/16 14:54	606220290	Lead	7	15	ppb
021-93A Water Spigot 8	6/20/16 15:32	7/5/16 14:54	606220291	Copper	0.0	1.3	ppm
021-93A Water Spigot 8	6/20/16 15:32	7/5/16 14:54	606220291	Lead	9	15	ppb
021-94A Water Spigot 9	6/20/16 15:41	7/5/16 14:54	606220292	Copper	0.0	1.3	ppm
021-94A Water Spigot 9	6/20/16 15:41	7/5/16 14:54	606220292	Lead	2	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

ND = Non detect

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.