

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Chief Joseph Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
024-01A Boiler Room Sink Faucet	6/18/16 15:04	7/1/16 15:54	606212101	Copper	0.0	1.3	ppm
024-01A Boiler Room Sink Faucet	6/18/16 15:04	7/1/16 15:54	606212101	Lead	2	15	ppb
024-03A Library Sink Faucet	6/18/16 15:07	7/1/16 15:54	606212102	Copper	0.3	1.3	ppm
024-03A Library Sink Faucet	6/18/16 15:07	7/1/16 15:54	606212102	Lead	47	15	ppb
024-04A Custodian Closet 30 Sink Faucet	6/18/16 15:12	7/1/16 15:54	606212103	Copper	0.0	1.3	ppm
024-04A Custodian Closet 30 Sink Faucet	6/18/16 15:12	7/1/16 15:54	606212103	Lead	14	15	ppb
024-05A Room 28 Sink Faucet	6/18/16 15:14	7/1/16 15:54	606212104	Copper	0.2	1.3	ppm
024-05A Room 28 Sink Faucet	6/18/16 15:14	7/1/16 15:54	606212104	Lead	23	15	ppb
024-06A Room 28 Drinking Faucet	6/18/16 15:16	7/1/16 15:54	606212105	Copper	0.0	1.3	ppm
024-06A Room 28 Drinking Faucet	6/18/16 15:16	7/1/16 15:54	606212105	Lead	6	15	ppb
024-07A Room 27 Sink Faucet	6/18/16 15:19	7/1/16 15:54	606212106	Copper	0.1	1.3	ppm
024-07A Room 27 Sink Faucet	6/18/16 15:19	7/1/16 15:54	606212106	Lead	7	15	ppb
024-08A Room 27 Drinking Fountain	6/18/16 15:21	7/1/16 15:54	606212107	Copper	0.0	1.3	ppm
024-08A Room 27 Drinking Fountain	6/18/16 15:21	7/1/16 15:54	606212107	Lead	3	15	ppb
024-09A Room 26 Sink Faucet	6/18/16 15:16	7/1/16 15:54	606212108	Copper	0.1	1.3	ppm
024-09A Room 26 Sink Faucet	6/18/16 15:16	7/1/16 15:54	606212108	Lead	7	15	ppb
024-10A Room 26 Drinking Fountain	6/18/16 15:16	7/1/16 15:54	606212109	Copper	0.0	1.3	ppm
024-10A Room 26 Drinking Fountain	6/18/16 15:16	7/1/16 15:54	606212109	Lead	7	15	ppb
024-11A Room 25 Sink Faucet	6/18/16 15:14	7/1/16 15:54	606212110	Copper	0.2	1.3	ppm
024-11A Room 25 Sink Faucet	6/18/16 15:14	7/1/16 15:54	606212110	Lead	21	15	ppb
024-12A Room 6 Sink Faucet	6/18/16 15:25	7/1/16 15:55	606212111	Copper	0.1	1.3	ppm
024-12A Room 6 Sink Faucet	6/18/16 15:25	7/1/16 15:55	606212111	Lead	3	15	ppb
024-13A Room 5 Sink Faucet	6/18/16 15:26	7/1/16 15:55	606212112	Copper	0.1	1.3	ppm
024-13A Room 5 Sink Faucet	6/18/16 15:26	7/1/16 15:55	606212112	Lead	8	15	ppb
024-14A Boys Bathroom Sink Faucet	6/18/16 15:34	7/1/16 15:55	606212113	Copper	0.1	1.3	ppm
024-14A Boys Bathroom Sink Faucet	6/18/16 15:34	7/1/16 15:55	606212113	Lead	7	15	ppb
024-15A Boys Bathroom Sink Faucet	6/18/16 15:35	7/1/16 15:55	606212114	Copper	0.3	1.3	ppm
024-15A Boys Bathroom Sink Faucet	6/18/16 15:35	7/1/16 15:55	606212114	Lead	62	15	ppb
024-16A Boys Bathroom Water Spigot	6/18/16 15:31	6/30/16 18:34	606212115	Copper	0.1	1.3	ppm
024-16A Boys Bathroom Water Spigot	6/18/16 15:31	6/30/16 18:34	606212115	Lead	62	15	ppb
024-17A Girls Room Sink Faucet	6/18/16 15:59	7/1/16 15:55	606212116	Copper	0.1	1.3	ppm
024-17A Girls Room Sink Faucet	6/18/16 15:59	7/1/16 15:55	606212116	Lead	14	15	ppb
024-18A Girls Room Sink Faucet	6/18/16 15:59	7/1/16 15:55	606212117	Copper	0.1	1.3	ppm
024-18A Girls Room Sink Faucet	6/18/16 15:59	7/1/16 15:55	606212117	Lead	56	15	ppb
024-19A Girls Room Water Spigot	6/18/16 15:56	6/30/16 18:34	606212118	Copper	0.3	1.3	ppm
024-19A Girls Room Water Spigot	6/18/16 15:56	6/30/16 18:34	606212118	Lead	441	15	ppb
024-20A Hallway Drinking Fountain	6/18/16 15:43	7/1/16 15:56	606212119	Copper	0.0	1.3	ppm
024-20A Hallway Drinking Fountain	6/18/16 15:43	7/1/16 15:56	606212119	Lead	4	15	ppb
024-21A Room 8 Sink Faucet	6/18/16 16:02	7/1/16 15:56	606212120	Copper	0.0	1.3	ppm
024-21A Room 8 Sink Faucet	6/18/16 16:02	7/1/16 15:56	606212120	Lead	9	15	ppb
024-22A Room 8 Drinking Fountain	6/18/16 16:01	7/1/16 15:56	606212121	Copper	0.1	1.3	ppm
024-22A Room 8 Drinking Fountain	6/18/16 16:01	7/1/16 15:56	606212121	Lead	27	15	ppb
024-23A Room 5 Drinking Fountain	6/18/16 15:41	7/1/16 15:56	606212122	Copper	0.0	1.3	ppm
024-23A Room 5 Drinking Fountain	6/18/16 15:41	7/1/16 15:56	606212122	Lead	1	15	ppb
024-24A Room 6 Drinking Fountain	6/18/16 15:39	7/1/16 15:56	606212123	Copper	0.1	1.3	ppm
024-24A Room 6 Drinking Fountain	6/18/16 15:39	7/1/16 15:56	606212123	Lead	22	15	ppb
024-25A Room 7 Sink Faucet	6/18/16 16:05	7/1/16 15:57	606212124	Copper	0.1	1.3	ppm
024-25A Room 7 Sink Faucet	6/18/16 16:05	7/1/16 15:57	606212124	Lead	3	15	ppb
024-26A Room 7 Drinking Fountain	6/18/16 16:04	7/1/16 15:57	606212125	Copper	0.0	1.3	ppm
024-26A Room 7 Drinking Fountain	6/18/16 16:04	7/1/16 15:57	606212125	Lead	27	15	ppb
024-27A Room 9 Sink Faucet	6/18/16 16:07	7/1/16 15:57	606212126	Copper	0.1	1.3	ppm
024-27A Room 9 Sink Faucet	6/18/16 16:07	7/1/16 15:57	606212126	Lead	34	15	ppb
024-28A Room 9 Drinking Fountain	6/18/16 16:09	7/1/16 15:57	606212127	Copper	0.0	1.3	ppm
024-28A Room 9 Drinking Fountain	6/18/16 16:09	7/1/16 15:57	606212127	Lead	ND	15	ppb
024-29A Room 10 Sink Faucet	6/18/16 16:09	7/1/16 15:57	606212128	Copper	0.1	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Chief Joseph Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
024-29A Room 10 Sink Faucet	6/18/16 16:09	7/1/16 15:57	606212128	Lead	21	15	ppb
024-30A Room 10 Drinking Fountain	6/18/16 16:11	7/1/16 15:57	606212129	Copper	0.0	1.3	ppm
024-30A Room 10 Drinking Fountain	6/18/16 16:11	7/1/16 15:57	606212129	Lead	7	15	ppb
024-31A Room 11 Sink Faucet	6/18/16 16:16	7/1/16 15:57	606212130	Copper	0.1	1.3	ppm
024-31A Room 11 Sink Faucet	6/18/16 16:16	7/1/16 15:57	606212130	Lead	8	15	ppb
024-32A Room 11 Drinking Fountain	6/18/16 16:13	7/1/16 15:57	606212131	Copper	0.0	1.3	ppm
024-32A Room 11 Drinking Fountain	6/18/16 16:13	7/1/16 15:57	606212131	Lead	2	15	ppb
024-33A Room 12 Sink Faucet	6/18/16 16:14	7/1/16 15:57	606212132	Copper	0.2	1.3	ppm
024-33A Room 12 Sink Faucet	6/18/16 16:14	7/1/16 15:57	606212132	Lead	15	15	ppb
024-34A Room 12 Drinking Fountain	6/18/16 16:15	7/1/16 16:01	606212133	Copper	0.7	1.3	ppm
024-34A Room 12 Drinking Fountain	6/18/16 16:15	7/1/16 16:01	606212133	Lead	14	15	ppb
024-35A Room 13 Sink Faucet	6/18/16 16:17	7/1/16 16:01	606212134	Copper	0.0	1.3	ppm
024-35A Room 13 Sink Faucet	6/18/16 16:17	7/1/16 16:01	606212134	Lead	3	15	ppb
024-36A Room 14 Sink Faucet	6/18/16 16:22	7/1/16 16:01	606212135	Copper	0.1	1.3	ppm
024-36A Room 14 Sink Faucet	6/18/16 16:22	7/1/16 16:01	606212135	Lead	1	15	ppb
024-37A Room 14 Sink Faucet	6/18/16 16:23	7/1/16 16:01	606212136	Copper	0.1	1.3	ppm
024-37A Room 14 Sink Faucet	6/18/16 16:23	7/1/16 16:01	606212136	Lead	2	15	ppb
024-39A Room 14 Water Spigot	6/18/16 16:20	7/1/16 16:01	606212137	Copper	0.2	1.3	ppm
024-39A Room 14 Water Spigot	6/18/16 16:20	7/1/16 16:01	606212137	Lead	20	15	ppb
024-40A Room 15 Sink Faucet	6/18/16 16:20	7/1/16 16:01	606212138	Copper	0.1	1.3	ppm
024-40A Room 15 Sink Faucet	6/18/16 16:20	7/1/16 16:01	606212138	Lead	4	15	ppb
024-41A Room 16 Sink Faucet	6/18/16 16:33	7/1/16 16:01	606212139	Copper	0.1	1.3	ppm
024-41A Room 16 Sink Faucet	6/18/16 16:33	7/1/16 16:01	606212139	Lead	5	15	ppb
024-42A Room 16 Sink Faucet	6/18/16 16:34	7/1/16 16:01	606212140	Copper	0.1	1.3	ppm
024-42A Room 16 Sink Faucet	6/18/16 16:34	7/1/16 16:01	606212140	Lead	20	15	ppb
024-43A Room 16 Sink Faucet	6/18/16 16:35	7/1/16 16:01	606212141	Copper	0.1	1.3	ppm
024-43A Room 16 Sink Faucet	6/18/16 16:35	7/1/16 16:01	606212141	Lead	6	15	ppb
024-44A Room 16 Water Spigot	6/18/16 16:31	7/1/16 16:01	606212142	Copper	0.2	1.3	ppm
024-44A Room 16 Water Spigot	6/18/16 16:31	7/1/16 16:01	606212142	Lead	11	15	ppb
024-45A Hallway Drinking Fountain	6/18/16 16:23	7/1/16 16:01	606212143	Copper	0.0	1.3	ppm
024-45A Hallway Drinking Fountain	6/18/16 16:23	7/1/16 16:01	606212143	Lead	16	15	ppb
024-46A Boys Locker Room Bathroom Sink Faucet	6/18/16 16:29	7/1/16 16:02	606212144	Copper	0.0	1.3	ppm
024-46A Boys Locker Room Bathroom Sink Faucet	6/18/16 16:29	7/1/16 16:02	606212144	Lead	16	15	ppb
024-47A Room 19 Sink Faucet	6/18/16 16:39	7/1/16 16:02	606212145	Copper	0.1	1.3	ppm
024-47A Room 19 Sink Faucet	6/18/16 16:39	7/1/16 16:02	606212145	Lead	43	15	ppb
024-48A Room 21 Sink Faucet	6/18/16 16:48	7/1/16 16:02	606212146	Copper	0.1	1.3	ppm
024-48A Room 21 Sink Faucet	6/18/16 16:48	7/1/16 16:02	606212146	Lead	14	15	ppb
024-49A Custodian Room Sink Faucet	6/18/16 16:41	7/1/16 16:02	606212147	Copper	0.1	1.3	ppm
024-49A Custodian Room Sink Faucet	6/18/16 16:41	7/1/16 16:02	606212147	Lead	6	15	ppb
024-50A Kitchen Food Prep Sink Faucet	6/18/16 16:38	7/1/16 16:02	606212148	Copper	0.1	1.3	ppm
024-50A Kitchen Food Prep Sink Faucet	6/18/16 16:38	7/1/16 16:02	606212148	Lead	4	15	ppb
024-51A Kitchen Sink Faucet	6/18/16 16:43	7/1/16 16:02	606212149	Copper	0.1	1.3	ppm
024-51A Kitchen Sink Faucet	6/18/16 16:43	7/1/16 16:02	606212149	Lead	15	15	ppb
024-52A Kitchen Closet Sink Faucet	6/18/16 16:42	7/1/16 16:02	606212150	Copper	0.0	1.3	ppm
024-52A Kitchen Closet Sink Faucet	6/18/16 16:42	7/1/16 16:02	606212150	Lead	8	15	ppb
024-53A Kitchen Dishwash Sink Faucet	6/18/16 16:40	7/1/16 16:02	606212151	Copper	0.3	1.3	ppm
024-53A Kitchen Dishwash Sink Faucet	6/18/16 16:40	7/1/16 16:02	606212151	Lead	29	15	ppb
024-54A Sink Faucet in Room	6/18/16 16:45	7/1/16 16:02	606212152	Copper	0.0	1.3	ppm
024-54A Sink Faucet in Room	6/18/16 16:45	7/1/16 16:02	606212152	Lead	6	15	ppb
024-55A Office Sink Faucet	6/18/16 17:09	7/1/16 16:03	606212153	Copper	0.1	1.3	ppm
024-55A Office Sink Faucet	6/18/16 17:09	7/1/16 16:03	606212153	Lead	2	15	ppb
024-56A Custodial Sink Faucet	6/18/16 16:52	7/1/16 16:03	606212154	Copper	0.0	1.3	ppm
024-56A Custodial Sink Faucet	6/18/16 16:52	7/1/16 16:03	606212154	Lead	0	15	ppb
024-57A Restroom 25 Sink Faucet	6/18/16 16:56	7/1/16 16:03	606212155	Copper	0.1	1.3	ppm
024-57A Restroom 25 Sink Faucet	6/18/16 16:56	7/1/16 16:03	606212155	Lead	4	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Chief Joseph Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
024-58A Hallway Drinking Fountain	6/18/16 16:53	7/1/16 16:03	606212156	Copper	0.1	1.3	ppm
024-58A Hallway Drinking Fountain	6/18/16 16:53	7/1/16 16:03	606212156	Lead	50	15	ppb
024-59A Restroom Sink Faucet (Next to Drinking Fountain)	6/18/16 16:54	7/1/16 16:03	606212157	Copper	0.1	1.3	ppm
024-59A Restroom Sink Faucet (Next to Drinking Fountain)	6/18/16 16:54	7/1/16 16:03	606212157	Lead	7	15	ppb
024-60A Room Staff Lunch A Sink Faucet	6/18/16 16:55	7/1/16 16:03	606212158	Copper	0.1	1.3	ppm
024-60A Room Staff Lunch A Sink Faucet	6/18/16 16:55	7/1/16 16:03	606212158	Lead	1	15	ppb
024-61A Boys Restroom Sink Faucet	6/18/16 17:00	7/1/16 16:03	606212159	Copper	0.2	1.3	ppm
024-61A Boys Restroom Sink Faucet	6/18/16 17:00	7/1/16 16:03	606212159	Lead	57	15	ppb
024-62A Boys Bathroom Sink Faucet	6/18/16 17:00	7/1/16 16:03	606212160	Copper	0.1	1.3	ppm
024-62A Boys Bathroom Sink Faucet	6/18/16 17:00	7/1/16 16:03	606212160	Lead	30	15	ppb
024-63A Boys Bathroom Water Spigot	6/18/16 16:23	6/30/16 18:34	606212161	Copper	0.2	1.3	ppm
024-63A Boys Bathroom Water Spigot	6/18/16 16:23	6/30/16 18:34	606212161	Lead	320	15	ppb
024-64A Girls Bathroom Sink Faucet	6/18/16 17:04	7/1/16 16:03	606212162	Copper	0.1	1.3	ppm
024-64A Girls Bathroom Sink Faucet	6/18/16 17:04	7/1/16 16:03	606212162	Lead	16	15	ppb
024-65A Girls Bathroom Sink Faucet	6/18/16 17:06	7/1/16 16:03	606212163	Copper	0.1	1.3	ppm
024-65A Girls Bathroom Sink Faucet	6/18/16 17:06	7/1/16 16:03	606212163	Lead	4	15	ppb
024-66A Room 3 Sink Faucet	6/18/16 16:59	7/1/16 16:05	606212164	Copper	0.1	1.3	ppm
024-66A Room 3 Sink Faucet	6/18/16 16:59	7/1/16 16:05	606212164	Lead	5	15	ppb
024-67A Room 3 Sink Faucet	6/18/16 17:01	7/1/16 16:05	606212165	Copper	0.0	1.3	ppm
024-67A Room 3 Sink Faucet	6/18/16 17:01	7/1/16 16:05	606212165	Lead	3	15	ppb
024-68A Room 4 Sink Faucet	6/18/16 17:07	7/1/16 16:05	606212166	Copper	0.1	1.3	ppm
024-68A Room 4 Sink Faucet	6/18/16 17:07	7/1/16 16:05	606212166	Lead	3	15	ppb
024-69A Room 4 Drinking Fountain	6/18/16 17:09	7/1/16 16:05	606212167	Copper	0.0	1.3	ppm
024-69A Room 4 Drinking Fountain	6/18/16 17:09	7/1/16 16:05	606212167	Lead	4	15	ppb
024-70A Room 1 Sink Faucet	6/18/16 17:14	7/1/16 16:05	606212168	Copper	0.0	1.3	ppm
024-70A Room 1 Sink Faucet	6/18/16 17:14	7/1/16 16:05	606212168	Lead	8	15	ppb
024-71A Room 1 Drinking Fountain	6/18/16 17:15	7/1/16 16:05	606212169	Copper	0.1	1.3	ppm
024-71A Room 1 Drinking Fountain	6/18/16 17:15	7/1/16 16:05	606212169	Lead	2	15	ppb
024-72A Room 2 Drinking Fountain	6/18/16 17:19	7/1/16 16:05	606212170	Copper	0.0	1.3	ppm
024-72A Room 2 Drinking Fountain	6/18/16 17:19	7/1/16 16:05	606212170	Lead	3	15	ppb
024-73A Room 2 Sink Faucet	6/18/16 17:20	7/1/16 16:05	606212171	Copper	0.1	1.3	ppm
024-73A Room 2 Sink Faucet	6/18/16 17:20	7/1/16 16:05	606212171	Lead	5	15	ppb
024-74A Outside Water Spigot	6/18/16 17:37	7/1/16 16:05	606212172	Copper	0.0	1.3	ppm
024-74A Outside Water Spigot	6/18/16 17:37	7/1/16 16:05	606212172	Lead	2	15	ppb
024-75A Outside Water Spigot	6/18/16 17:34	7/1/16 16:05	606212173	Copper	0.0	1.3	ppm
024-75A Outside Water Spigot	6/18/16 17:34	7/1/16 16:05	606212173	Lead	2	15	ppb
024-76A Outside Water Spigot	6/18/16 17:32	7/1/16 16:06	606212174	Copper	0.1	1.3	ppm
024-76A Outside Water Spigot	6/18/16 17:32	7/1/16 16:06	606212174	Lead	79	15	ppb
024-77A Outside Water Spigot	6/18/16 17:30	7/1/16 16:06	606212175	Copper	0.1	1.3	ppm
024-77A Outside Water Spigot	6/18/16 17:30	7/1/16 16:06	606212175	Lead	6	15	ppb
024-78A Outside Water Spigot	6/18/16 17:27	7/1/16 16:06	606212176	Copper	0.0	1.3	ppm
024-78A Outside Water Spigot	6/18/16 17:27	7/1/16 16:06	606212176	Lead	34	15	ppb
024-79A Outside Water Spigot	6/18/16 17:52	7/1/16 16:06	606212177	Copper	0.0	1.3	ppm
024-79A Outside Water Spigot	6/18/16 17:52	7/1/16 16:06	606212177	Lead	2	15	ppb
024-80A Outside Water Spigot	6/18/16 17:56	7/1/16 16:06	606212178	Copper	0.1	1.3	ppm
024-80A Outside Water Spigot	6/18/16 17:56	7/1/16 16:06	606212178	Lead	23	15	ppb
024-81A Outside Water Spigot	6/18/16 17:49	7/1/16 16:06	606212179	Copper	0.1	1.3	ppm
024-81A Outside Water Spigot	6/18/16 17:49	7/1/16 16:06	606212179	Lead	11	15	ppb
024-82A Outside Water Spigot	6/18/16 17:46	7/1/16 16:06	606212180	Copper	0.1	1.3	ppm
024-82A Outside Water Spigot	6/18/16 17:46	7/1/16 16:06	606212180	Lead	10	15	ppb
024-83A Outside Water Spigot	6/18/16 17:43	7/1/16 16:06	606212181	Copper	0.0	1.3	ppm
024-83A Outside Water Spigot	6/18/16 17:43	7/1/16 16:06	606212181	Lead	24	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Chief Joseph Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
EPA Action Level for Lead of 15 ppb							ND = Non detect
EPA Action Level for Copper of 1.3 ppm							

Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.