

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Cleveland High School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
026 01A Boiler Sink Faucet	7/3/2016 02:12	7/19/2016 11:42	10354587001	Copper	0.1	1.3	ppm
026 01A Boiler Sink Faucet	7/3/2016 02:12	7/19/2016 11:42	10354587001	Lead	4	15	ppb
026 02A Boiler Water Spigot	7/3/2016 02:14	7/19/2016 11:48	10354587003	Copper	0.0	1.3	ppm
026 02A Boiler Water Spigot	7/3/2016 02:14	7/19/2016 11:48	10354587003	Lead	2	15	ppb
026 03A Room 132 Sink Faucet	7/3/2016 02:16	7/19/2016 08:13	10354587005	Copper	0.1	1.3	ppm
026 03A Room 132 Sink Faucet	7/3/2016 02:16	7/19/2016 08:14	10354587005	Lead	547	15	ppb
026 04A Office Sink Faucet	7/3/2016 02:18	7/19/2016 11:49	10354587007	Copper	0.2	1.3	ppm
026 04A Office Sink Faucet	7/3/2016 02:18	7/19/2016 11:49	10354587007	Lead	26	15	ppb
026 05A Office Small Sink Faucet	7/3/2016 02:20	7/19/2016 11:51	10354587009	Copper	0.5	1.3	ppm
026 05A Office Small Sink Faucet	7/3/2016 02:20	7/19/2016 11:51	10354587009	Lead	24	15	ppb
026 06A Cafeteria Drinking Fountain #1	7/3/2016 02:25	7/19/2016 11:52	10354587011	Copper	0.8	1.3	ppm
026 06A Cafeteria Drinking Fountain #1	7/3/2016 02:25	7/19/2016 11:52	10354587011	Lead	23	15	ppb
026 07A Cafeteria Drinking Fountain #2	7/3/2016 02:27	7/19/2016 11:59	10354587013	Copper	0.9	1.3	ppm
026 07A Cafeteria Drinking Fountain #2	7/3/2016 02:27	7/19/2016 11:59	10354587013	Lead	18	15	ppb
026 08A Kitchen Adult Restroom Sink Faucet	7/3/2016 02:29	7/19/2016 08:18	10354587015	Copper	0.2	1.3	ppm
026 08A Kitchen Adult Restroom Sink Faucet	7/3/2016 02:29	7/19/2016 08:18	10354587015	Lead	11	15	ppb
026 09A Kitchen Sink Faucet Hand Wash	7/3/2016 02:31	7/19/2016 12:00	10354587017	Copper	1.4	1.3	ppm
026 09A Kitchen Sink Faucet Hand Wash	7/3/2016 02:31	7/19/2016 12:00	10354587017	Lead	105	15	ppb
026 10A Kitchen Sink Faucet #1	7/3/2016 02:33	7/19/2016 12:53	10354587019	Copper	0.4	1.3	ppm
026 10A Kitchen Sink Faucet #1	7/3/2016 02:33	7/19/2016 12:02	10354587019	Lead	9	15	ppb
026 11A Kitchen Sprayer #1	7/3/2016 02:35	7/19/2016 12:03	10354587021	Copper	0.1	1.3	ppm
026 11A Kitchen Sprayer #1	7/3/2016 02:35	7/19/2016 12:03	10354587021	Lead	2	15	ppb
026 12A Kitchen Sink Faucet #2	7/3/2016 02:37	7/19/2016 12:04	10354587023	Copper	0.1	1.3	ppm
026 12A Kitchen Sink Faucet #2	7/3/2016 02:37	7/19/2016 12:04	10354587023	Lead	8	15	ppb
026 13A Kitchen Sink Faucet #3	7/3/2016 02:39	7/19/2016 12:06	10354587025	Copper	0.2	1.3	ppm
026 13A Kitchen Sink Faucet #3	7/3/2016 02:39	7/19/2016 12:06	10354587025	Lead	36	15	ppb
026 14A Kitchen Sink Faucet #4	7/3/2016 02:41	7/19/2016 12:09	10354587027	Copper	0.6	1.3	ppm
026 14A Kitchen Sink Faucet #4	7/3/2016 02:41	7/19/2016 12:09	10354587027	Lead	7	15	ppb
026 15A Kitchen Water Spigot #1	7/3/2016 02:43	7/19/2016 12:10	10354587029	Copper	1.1	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Cleveland High School

026 15A Kitchen Water Spigot #1	7/3/2016 02:43	7/19/2016 12:10	10354587029	Lead	113	15	ppb
026 16A Kitchen Sink Faucet #5	7/3/2016 02:45	7/19/2016 12:11	10354587031	Copper	0.1	1.3	ppm
026 16A Kitchen Sink Faucet #5	7/3/2016 02:45	7/19/2016 12:11	10354587031	Lead	9	15	ppb
026 17A Kitchen Sprayer #2	7/3/2016 02:47	7/19/2016 12:19	10354587033	Copper	0.1	1.3	ppm
026 17A Kitchen Sprayer #2	7/3/2016 02:47	7/19/2016 12:19	10354587033	Lead	14	15	ppb
026 18A Kitchen Sink Faucet #6	7/3/2016 02:49	7/19/2016 08:20	10354587035	Copper	0.2	1.3	ppm
026 18A Kitchen Sink Faucet #6	7/3/2016 02:49	7/19/2016 08:20	10354587035	Lead	34	15	ppb
026 19A Kitchen Sink Faucet #7	7/3/2016 02:51	7/19/2016 12:21	10354587037	Copper	0.0	1.3	ppm
026 19A Kitchen Sink Faucet #7	7/3/2016 02:51	7/19/2016 12:21	10354587037	Lead	18	15	ppb
026 20A Kitchen Sink Faucet #8	7/3/2016 02:53	7/19/2016 12:22	10354587039	Copper	0.0	1.3	ppm
026 20A Kitchen Sink Faucet #8	7/3/2016 02:53	7/19/2016 12:22	10354587039	Lead	8	15	ppb
026 21A Kitchen Water Spigot #2	7/3/2016 02:55	7/19/2016 08:55	10354587041	Copper	4.1	1.3	ppm
026 21A Kitchen Water Spigot #2	7/3/2016 02:55	7/19/2016 08:21	10354587041	Lead	225	15	ppb
026 22A Hallway Drinking Fountain	7/3/2016 02:57	7/19/2016 11:10	10354587043	Copper	0.1	1.3	ppm
026 22A Hallway Drinking Fountain	7/3/2016 02:57	7/19/2016 11:10	10354587043	Lead	7	15	ppb
026 23A Room 106 Sink Faucet	7/3/2016 02:59	7/19/2016 08:23	10354587045	Copper	0.3	1.3	ppm
026 23A Room 106 Sink Faucet	7/3/2016 02:59	7/19/2016 08:23	10354587045	Lead	366	15	ppb
026 24A Janitor's Closet Sink Faucet	7/3/2016 03:01	7/19/2016 11:16	10354587047	Copper	0.0	1.3	ppm
026 24A Janitor's Closet Sink Faucet	7/3/2016 03:01	7/19/2016 11:16	10354587047	Lead	1	15	ppb
026 25A Hallway Drinking Fountain	7/3/2016 03:03	7/19/2016 11:17	10354587049	Copper	0.0	1.3	ppm
026 25A Hallway Drinking Fountain	7/3/2016 03:03	7/19/2016 11:17	10354587049	Lead	61	15	ppb
026 26A Girls Restroom Sink Faucet #1	7/3/2016 03:05	7/19/2016 11:19	10354587051	Copper	0.2	1.3	ppm
026 26A Girls Restroom Sink Faucet #1	7/3/2016 03:05	7/19/2016 11:19	10354587051	Lead	21	15	ppb
026 27A Girls Restroom Sink Faucet #2	7/3/2016 03:07	7/19/2016 11:20	10354587053	Copper	0.0	1.3	ppm
026 27A Girls Restroom Sink Faucet #2	7/3/2016 03:07	7/19/2016 11:20	10354587053	Lead	9	15	ppb
026 28A Girls Restroom Sink Faucet #3	7/3/2016 03:09	7/19/2016 11:24	10354587055	Copper	0.2	1.3	ppm
026 28A Girls Restroom Sink Faucet #3	7/3/2016 03:09	7/19/2016 11:24	10354587055	Lead	29	15	ppb
026 29A Girls Restroom Water Spigot	7/3/2016 03:11	7/19/2016 08:57	10354587057	Copper	0.6	1.3	ppm
026 29A Girls Restroom Water Spigot	7/3/2016 03:11	7/19/2016 08:27	10354587057	Lead	91	15	ppb
026 30A Janitor's Closet Sink Faucet	7/3/2016 03:13	7/19/2016 11:26	10354587059	Copper	0.1	1.3	ppm
026 30A Janitor's Closet Sink Faucet	7/3/2016 03:13	7/19/2016 11:26	10354587059	Lead	11	15	ppb
026 31A Boys Restroom Sink Faucet #1	7/3/2016 03:15	7/19/2016 11:27	10354587061	Copper	0.1	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Cleveland High School

026 31A Boys Restroom Sink Faucet #1	7/3/2016 03:15	7/19/2016 11:27	10354587061	Lead	25	15	ppb
026 32A Boys Restroom Sink Faucet #2	7/3/2016 03:17	7/19/2016 11:28	10354587063	Copper	0.1	1.3	ppm
026 32A Boys Restroom Sink Faucet #2	7/3/2016 03:17	7/19/2016 11:28	10354587063	Lead	12	15	ppb
026 33A Boys Restroom Water Spigot	7/3/2016 03:19	7/19/2016 08:28	10354587065	Copper	0.2	1.3	ppm
026 33A Boys Restroom Water Spigot	7/3/2016 03:19	7/19/2016 08:28	10354587065	Lead	161	15	ppb
026 34A Nurse Sink Faucet #1	7/3/2016 03:21	7/19/2016 11:30	10354587067	Copper	0.5	1.3	ppm
026 34A Nurse Sink Faucet #1	7/3/2016 03:21	7/19/2016 11:30	10354587067	Lead	10	15	ppb
026 35A Nurse Sink Faucet #2	7/3/2016 03:23	7/19/2016 11:31	10354587069	Copper	0.4	1.3	ppm
026 35A Nurse Sink Faucet #2	7/3/2016 03:23	7/19/2016 11:31	10354587069	Lead	2	15	ppb
026 36A Nurse Sink Faucet #3	7/3/2016 03:25	7/19/2016 08:30	10354587071	Copper	0.2	1.3	ppm
026 36A Nurse Sink Faucet #3	7/3/2016 03:25	7/19/2016 08:30	10354587071	Lead	33	15	ppb
026 37A Nurse Sink Faucet #4	7/3/2016 03:27	7/19/2016 11:34	10354587073	Copper	0.3	1.3	ppm
026 37A Nurse Sink Faucet #4	7/3/2016 03:27	7/19/2016 11:34	10354587073	Lead	42	15	ppb
026 38A Nurse Sink Faucet #5	7/3/2016 03:29	7/19/2016 11:35	10354587075	Copper	0.9	1.3	ppm
026 38A Nurse Sink Faucet #5	7/3/2016 03:29	7/19/2016 11:35	10354587075	Lead	4	15	ppb
026 39A Nurse Sink Faucet #6	7/3/2016 03:31	7/19/2016 09:44	10354587077	Copper	0.6	1.3	ppm
026 39A Nurse Sink Faucet #6	7/3/2016 03:31	7/19/2016 09:44	10354587077	Lead	14	15	ppb
026 40A Nurse Sink Faucet #7	7/3/2016 03:33	7/19/2016 09:46	10354587079	Copper	0.5	1.3	ppm
026 40A Nurse Sink Faucet #7	7/3/2016 03:33	7/19/2016 09:46	10354587079	Lead	8	15	ppb
026 41A Nurse Sprayer	7/3/2016 03:35	7/19/2016 09:20	10354587081	Copper	0.3	1.3	ppm
026 41A Nurse Sprayer	7/3/2016 03:35	7/19/2016 09:20	10354587081	Lead	8	15	ppb
026 42A Nurse Sink Faucet #8	7/3/2016 03:37	7/19/2016 09:25	10354587083	Copper	0.4	1.3	ppm
026 42A Nurse Sink Faucet #8	7/3/2016 03:37	7/19/2016 09:25	10354587083	Lead	8	15	ppb
026 43A Locker Room Sink Faucet #1	7/3/2016 03:39	7/19/2016 09:27	10354587085	Copper	0.0	1.3	ppm
026 43A Locker Room Sink Faucet #1	7/3/2016 03:39	7/19/2016 09:27	10354587085	Lead	8	15	ppb
026 44A Locker Room Water Spigot #1	7/3/2016 03:41	7/19/2016 09:28	10354587087	Copper	0.0	1.3	ppm
026 44A Locker Room Water Spigot #1	7/3/2016 03:41	7/19/2016 09:28	10354587087	Lead	34	15	ppb
026 45A Locker Room Shower #1	7/3/2016 03:44	7/19/2016 09:29	10354587089	Copper	1.1	1.3	ppm
026 45A Locker Room Shower #1	7/3/2016 03:44	7/19/2016 09:29	10354587089	Lead	10	15	ppb
026 46A Locker Room Shower #2	7/3/2016 03:46	7/19/2016 09:34	10354587091	Copper	0.8	1.3	ppm
026 46A Locker Room Shower #2	7/3/2016 03:46	7/19/2016 09:34	10354587091	Lead	16	15	ppb
026 47A Locker Room Shower #3	7/3/2016 03:48	7/19/2016 08:58	10354587093	Copper	0.9	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Cleveland High School

026 47A Locker Room Shower #3	7/3/2016 03:48	7/19/2016 08:31	10354587093	Lead	33	15	ppb
026 48A Locker Room Shower #4	7/3/2016 03:50	7/19/2016 09:02	10354587095	Copper	0.7	1.3	ppm
026 48A Locker Room Shower #4	7/3/2016 03:50	7/19/2016 08:33	10354587095	Lead	28	15	ppb
026 49A Locker Room Shower #5	7/3/2016 03:52	7/19/2016 09:04	10354587097	Copper	0.6	1.3	ppm
026 49A Locker Room Shower #5	7/3/2016 03:52	7/19/2016 08:34	10354587097	Lead	28	15	ppb
026 50A Locker Room Shower #6	7/3/2016 03:54	7/19/2016 09:35	10354587099	Copper	0.8	1.3	ppm
026 50A Locker Room Shower #6	7/3/2016 03:54	7/19/2016 09:35	10354587099	Lead	55	15	ppb
026 51A Locker Room Shower #7	7/3/2016 03:56	7/19/2016 09:05	10354587101	Copper	0.9	1.3	ppm
026 51A Locker Room Shower #7	7/3/2016 03:56	7/19/2016 08:37	10354587101	Lead	16	15	ppb
026 52A Locker Room Shower #8	7/3/2016 03:58	7/19/2016 09:06	10354587103	Copper	0.9	1.3	ppm
026 52A Locker Room Shower #8	7/3/2016 03:58	7/19/2016 08:38	10354587103	Lead	39	15	ppb
026 53A Locker Room Shower #9	7/3/2016 04:00	7/19/2016 09:36	10354587105	Copper	1.0	1.3	ppm
026 53A Locker Room Shower #9	7/3/2016 04:00	7/19/2016 09:36	10354587105	Lead	31	15	ppb
026 54A Locker Room Sink Faucet #2	7/3/2016 04:02	7/19/2016 09:38	10354587107	Copper	0.1	1.3	ppm
026 54A Locker Room Sink Faucet #2	7/3/2016 04:02	7/19/2016 09:38	10354587107	Lead	8	15	ppb
026 55A Locker Room Water Spigot #2	7/3/2016 04:04	7/19/2016 09:39	10354587109	Copper	0.0	1.3	ppm
026 55A Locker Room Water Spigot #2	7/3/2016 04:04	7/19/2016 09:39	10354587109	Lead	12	15	ppb
026 56A Locker Room Shower #10	7/3/2016 04:06	7/19/2016 09:40	10354587111	Copper	0.7	1.3	ppm
026 56A Locker Room Shower #10	7/3/2016 04:06	7/19/2016 09:40	10354587111	Lead	30	15	ppb
026 57A Locker Room Shower #11	7/3/2016 04:08	7/19/2016 09:43	10354587113	Copper	0.9	1.3	ppm
026 57A Locker Room Shower #11	7/3/2016 04:08	7/19/2016 09:43	10354587113	Lead	20	15	ppb
026 58A Locker Room Shower #12	7/3/2016 04:10	7/19/2016 09:07	10354587115	Copper	0.8	1.3	ppm
026 58A Locker Room Shower #12	7/3/2016 04:10	7/19/2016 08:40	10354587115	Lead	39	15	ppb
026 59A Locker Room Shower #13	7/3/2016 04:12	7/19/2016 09:09	10354587117	Copper	0.5	1.3	ppm
026 59A Locker Room Shower #13	7/3/2016 04:12	7/19/2016 08:45	10354587117	Lead	40	15	ppb
026 60A Locker Room Shower #14	7/3/2016 04:15	7/19/2016 09:10	10354587119	Copper	0.7	1.3	ppm
026 60A Locker Room Shower #14	7/3/2016 04:15	7/19/2016 08:47	10354587119	Lead	60	15	ppb
026 61A Locker Room Shower #15	7/3/2016 04:17	7/19/2016 09:11	10354587121	Copper	1.1	1.3	ppm
026 61A Locker Room Shower #15	7/3/2016 04:17	7/19/2016 08:48	10354587121	Lead	62	15	ppb
026 62A Locker Room Shower #16	7/3/2016 04:19	7/19/2016 10:40	10354587123	Copper	0.6	1.3	ppm
026 62A Locker Room Shower #16	7/3/2016 04:19	7/19/2016 10:40	10354587123	Lead	30	15	ppb
026 63A Locker Room Shower #17	7/3/2016 04:21	7/19/2016 10:46	10354587125	Copper	0.9	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Cleveland High School

026 63A Locker Room Shower #17	7/3/2016 04:21	7/19/2016 10:46	10354587125	Lead	10	15	ppb
026 64A Locker Room Shower #18	7/3/2016 04:23	7/19/2016 10:47	10354587127	Copper	1.0	1.3	ppm
026 64A Locker Room Shower #18	7/3/2016 04:23	7/19/2016 10:47	10354587127	Lead	12	15	ppb
026 65A Locker Room Drinking Fountain	7/3/2016 04:25	7/19/2016 10:48	10354587129	Copper	0.1	1.3	ppm
026 65A Locker Room Drinking Fountain	7/3/2016 04:25	7/19/2016 10:48	10354587129	Lead	47	15	ppb
026 66A Locker Room Water Spigot #3	7/3/2016 04:27	7/19/2016 10:50	10354587131	Copper	0.0	1.3	ppm
026 66A Locker Room Water Spigot #3	7/3/2016 04:27	7/19/2016 10:50	10354587131	Lead	103	15	ppb
026 67A Locker Office Sink Faucet	7/3/2016 04:28	7/19/2016 10:54	10354587133	Copper	0.0	1.3	ppm
026 67A Locker Office Sink Faucet	7/3/2016 04:28	7/19/2016 10:54	10354587133	Lead	69	15	ppb
026 68A Locker Office Shower	7/3/2016 04:30	7/19/2016 10:55	10354587135	Copper	0.0	1.3	ppm
026 68A Locker Office Shower	7/3/2016 04:30	7/19/2016 10:55	10354587135	Lead	11	15	ppb
026 69A G 27 Sink Faucet	7/3/2016 04:32	7/19/2016 10:57	10354587137	Copper	0.1	1.3	ppm
026 69A G 27 Sink Faucet	7/3/2016 04:32	7/19/2016 10:57	10354587137	Lead	18	15	ppb
026 70A Gym Locker Room Drinking Fountain	7/3/2016 04:34	7/19/2016 10:58	10354587139	Copper	0.1	1.3	ppm
026 70A Gym Locker Room Drinking Fountain	7/3/2016 04:34	7/19/2016 10:58	10354587139	Lead	2	15	ppb
026 71A Gym Locker Room Sink Faucet #1	7/3/2016 04:36	7/19/2016 10:59	10354587141	Copper	0.1	1.3	ppm
026 71A Gym Locker Room Sink Faucet #1	7/3/2016 04:36	7/19/2016 10:59	10354587141	Lead	6	15	ppb
026 72A Gym Locker Room Sink Faucet #2	7/3/2016 04:38	7/19/2016 11:01	10354587143	Copper	0.1	1.3	ppm
026 72A Gym Locker Room Sink Faucet #2	7/3/2016 04:38	7/19/2016 11:01	10354587143	Lead	7	15	ppb
026 73A Gym Locker Room Water Spigot #1	7/3/2016 04:40	7/19/2016 08:49	10354587145	Copper	0.1	1.3	ppm
026 73A Gym Locker Room Water Spigot #1	7/3/2016 04:40	7/19/2016 08:49	10354587145	Lead	6	15	ppb
026 74A Gym Locker Room Shower #1	7/3/2016 04:42	7/19/2016 11:04	10354587147	Copper	1.1	1.3	ppm
026 74A Gym Locker Room Shower #1	7/3/2016 04:42	7/19/2016 11:04	10354587147	Lead	12	15	ppb
026 75A Gym Locker Room Shower #2	7/3/2016 04:44	7/19/2016 09:13	10354587149	Copper	0.5	1.3	ppm
026 75A Gym Locker Room Shower #2	7/3/2016 04:44	7/19/2016 08:51	10354587149	Lead	52	15	ppb
026 76A Gym Locker Room Shower #3	7/3/2016 04:46	7/19/2016 08:52	10354587151	Copper	0.4	1.3	ppm
026 76A Gym Locker Room Shower #3	7/3/2016 04:46	7/19/2016 08:52	10354587151	Lead	92	15	ppb
026 77A Gym Locker Room Shower #4	7/3/2016 04:48	7/11/2016 22:29	10354587153	Copper	0.4	1.3	ppm
026 77A Gym Locker Room Shower #4	7/3/2016 04:48	7/11/2016 22:29	10354587153	Lead	88	15	ppb
026 78A Gym Locker Room Shower #5	7/3/2016 04:50	7/11/2016 22:30	10354587155	Copper	0.2	1.3	ppm
026 78A Gym Locker Room Shower #5	7/3/2016 04:50	7/11/2016 22:30	10354587155	Lead	72	15	ppb
026 79A Gym Locker Room Shower #6	7/3/2016 04:52	7/12/2016 07:59	10354587157	Copper	0.6	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Cleveland High School

026 79A Gym Locker Room Shower #6	7/3/2016 04:52	7/11/2016 22:31	10354587157	Lead	82	15	ppb
026 80A Gym Locker Room Shower #7	7/3/2016 04:54	7/12/2016 08:01	10354587159	Copper	0.7	1.3	ppm
026 80A Gym Locker Room Shower #7	7/3/2016 04:54	7/11/2016 22:35	10354587159	Lead	66	15	ppb
026 81A Gym Locker Room Shower #8	7/3/2016 04:56	7/12/2016 08:02	10354587161	Copper	0.5	1.3	ppm
026 81A Gym Locker Room Shower #8	7/3/2016 04:56	7/11/2016 22:37	10354587161	Lead	104	15	ppb
026 82A Gym Locker Room Shower #9	7/3/2016 04:58	7/12/2016 08:03	10354587163	Copper	0.7	1.3	ppm
026 82A Gym Locker Room Shower #9	7/3/2016 04:58	7/11/2016 22:38	10354587163	Lead	83	15	ppb
026 83A Gym Room G12 Sink Faucet	7/3/2016 05:00	7/19/2016 12:25	10354587165	Copper	0.0	1.3	ppm
026 83A Gym Room G12 Sink Faucet	7/3/2016 05:00	7/19/2016 12:25	10354587165	Lead	98	15	ppb
026 84A Gym Room G11 Sink Faucet	7/3/2016 05:02	7/19/2016 12:23	10354587167	Copper	0.0	1.3	ppm
026 84A Gym Room G11 Sink Faucet	7/3/2016 05:02	7/19/2016 12:23	10354587167	Lead	10	15	ppb
026 85A Gym Room G11 Shower	7/3/2016 05:04	7/19/2016 12:33	10354587169	Copper	0.0	1.3	ppm
026 85A Gym Room G11 Shower	7/3/2016 05:04	7/19/2016 12:33	10354587169	Lead	6	15	ppb
026 86A Gym Room G11 Shower	7/3/2016 05:06	7/19/2016 12:35	10354587171	Copper	0.0	1.3	ppm
026 86A Gym Room G11 Shower	7/3/2016 05:06	7/19/2016 12:35	10354587171	Lead	28	15	ppb
026 87A Gym Janitor Closet Sink Faucet	7/3/2016 05:08	7/19/2016 12:36	10354587173	Copper	0.0	1.3	ppm
026 87A Gym Janitor Closet Sink Faucet	7/3/2016 05:08	7/19/2016 12:36	10354587173	Lead	8	15	ppb
026 88A Lockers Room Drinking Fountain	7/3/2016 05:10	7/19/2016 12:37	10354587175	Copper	0.0	1.3	ppm
026 88A Lockers Room Drinking Fountain	7/3/2016 05:10	7/19/2016 12:37	10354587175	Lead	14	15	ppb
026 89A Gym Locker Room Water Spigot #2	7/3/2016 05:12	7/19/2016 12:39	10354587177	Copper	0.1	1.3	ppm
026 89A Gym Locker Room Water Spigot #2	7/3/2016 05:12	7/19/2016 12:39	10354587177	Lead	4	15	ppb
026 90A Gym Locker Room Sink Faucet #3	7/3/2016 05:14	7/19/2016 12:40	10354587179	Copper	0.3	1.3	ppm
026 90A Gym Locker Room Sink Faucet #3	7/3/2016 05:14	7/19/2016 12:40	10354587179	Lead	23	15	ppb
026 91A Gym Locker Room Sink Faucet #4	7/3/2016 05:16	7/19/2016 12:41	10354587181	Copper	0.1	1.3	ppm
026 91A Gym Locker Room Sink Faucet #4	7/3/2016 05:16	7/19/2016 12:41	10354587181	Lead	11	15	ppb
026 92A Gym Locker Room Shower #10	7/3/2016 05:18	7/19/2016 12:43	10354587183	Copper	1.2	1.3	ppm
026 92A Gym Locker Room Shower #10	7/3/2016 05:18	7/19/2016 12:43	10354587183	Lead	32	15	ppb
026 93A Gym Locker Room Shower #11	7/3/2016 05:20	7/12/2016 08:05	10354587185	Copper	0.7	1.3	ppm
026 93A Gym Locker Room Shower #11	7/3/2016 05:20	7/11/2016 22:40	10354587185	Lead	196	15	ppb
026 94A Gym Locker Room Shower #12	7/3/2016 05:22	7/19/2016 12:44	10354587187	Copper	0.5	1.3	ppm
026 94A Gym Locker Room Shower #12	7/3/2016 05:22	7/19/2016 12:44	10354587187	Lead	134	15	ppb
026 95A Gym Locker Room Shower #13	7/3/2016 05:24	7/12/2016 08:06	10354587189	Copper	0.6	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Cleveland High School

026 95A Gym Locker Room Shower #13	7/3/2016 05:24	7/11/2016 22:41	10354587189	Lead	171	15	ppb
026 96A Gym Locker Room Shower #14	7/3/2016 05:26	7/19/2016 12:50	10354587191	Copper	0.5	1.3	ppm
026 96A Gym Locker Room Shower #14	7/3/2016 05:26	7/19/2016 12:50	10354587191	Lead	176	15	ppb
026 97A Gym Locker Room Shower #15	7/3/2016 05:28	7/11/2016 22:42	10354587193	Copper	0.3	1.3	ppm
026 97A Gym Locker Room Shower #15	7/3/2016 05:28	7/11/2016 22:42	10354587193	Lead	229	15	ppb
026 98A Gym Locker Room Shower #16	7/3/2016 05:30	7/12/2016 08:07	10354587195	Copper	0.6	1.3	ppm
026 98A Gym Locker Room Shower #16	7/3/2016 05:30	7/11/2016 22:45	10354587195	Lead	145	15	ppb
026 99A Gym Locker Room Shower #17	7/3/2016 05:32	7/12/2016 08:09	10354587197	Copper	1.0	1.3	ppm
026 99A Gym Locker Room Shower #17	7/3/2016 05:32	7/11/2016 22:47	10354587197	Lead	182	15	ppb
026 100A Gym Locker Room Shower #18	7/3/2016 05:34	7/19/2016 12:51	10354587199	Copper	0.6	1.3	ppm
026 100A Gym Locker Room Shower #18	7/3/2016 05:34	7/19/2016 12:51	10354587199	Lead	156	15	ppb
026 101A Gym Locker Room Shower #19	7/3/2016 05:36	7/19/2016 11:36	10354587201	Copper	0.6	1.3	ppm
026 101A Gym Locker Room Shower #19	7/3/2016 05:36	7/19/2016 11:36	10354587201	Lead	175	15	ppb
026 102A Gym Locker Room Shower #20	7/3/2016 05:38	7/18/2016 14:35	10354587203	Copper	0.1	1.3	ppm
026 102A Gym Locker Room Shower #20	7/3/2016 05:38	7/18/2016 14:35	10354587203	Lead	17	15	ppb
026 103A Gym Locker Room Office Sink Faucet	7/3/2016 05:40	7/18/2016 14:46	10354587205	Copper	0.1	1.3	ppm
026 103A Gym Locker Room Office Sink Faucet	7/3/2016 05:40	7/18/2016 14:46	10354587205	Lead	35	15	ppb
026 104A Gym Locker Room Office Shower	7/3/2016 05:42	7/19/2016 10:34	10354587207	Copper	0.0	1.3	ppm
026 104A Gym Locker Room Office Shower	7/3/2016 05:42	7/19/2016 10:34	10354587207	Lead	53	15	ppb
026 105A Hallway Drinking Fountain	7/3/2016 05:44	7/18/2016 14:47	10354587209	Copper	0.0	1.3	ppm
026 105A Hallway Drinking Fountain	7/3/2016 05:44	7/18/2016 14:47	10354587209	Lead	11	15	ppb
026 106A Women's G31 Sink Faucet	7/3/2016 05:46	7/18/2016 14:49	10354587211	Copper	0.1	1.3	ppm
026 106A Women's G31 Sink Faucet	7/3/2016 05:46	7/18/2016 14:49	10354587211	Lead	25	15	ppb
026 107A Women's G31 Sink Faucet	7/3/2016 05:48	7/18/2016 14:50	10354587213	Copper	0.1	1.3	ppm
026 107A Women's G31 Sink Faucet	7/3/2016 05:48	7/18/2016 14:50	10354587213	Lead	20	15	ppb
026 108A Apparatus Drinking Fountain	7/3/2016 05:50	7/18/2016 14:51	10354587215	Copper	0.0	1.3	ppm
026 108A Apparatus Drinking Fountain	7/3/2016 05:50	7/18/2016 14:51	10354587215	Lead	19	15	ppb
026 109A 1st Floor Drinking Fountain #1	7/3/2016 05:52	7/18/2016 14:53	10354587217	Copper	0.0	1.3	ppm
026 109A 1st Floor Drinking Fountain #1	7/3/2016 05:52	7/18/2016 14:53	10354587217	Lead	5	15	ppb
026 110A 1st Floor Drinking Fountain #2	7/3/2016 05:54	7/18/2016 14:55	10354587219	Copper	0.0	1.3	ppm
026 110A 1st Floor Drinking Fountain #2	7/3/2016 05:54	7/18/2016 14:55	10354587219	Lead	15.4	15	ppb
026 111A Sack Sink Faucet #1	7/3/2016 05:56	7/18/2016 16:48	10354587221	Copper	0.5	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Cleveland High School

026 111A Sack Sink Faucet #1	7/3/2016 05:56	7/18/2016 14:56	10354587221	Lead	60	15	ppb
026 112A Sack Sink Faucet #2	7/3/2016 05:58	7/18/2016 15:04	10354587223	Copper	0.3	1.3	ppm
026 112A Sack Sink Faucet #2	7/3/2016 05:58	7/18/2016 15:04	10354587223	Lead	30	15	ppb
026 113A Sack Sink Faucet #3	7/3/2016 06:00	7/18/2016 15:06	10354587225	Copper	0.2	1.3	ppm
026 113A Sack Sink Faucet #3	7/3/2016 06:00	7/18/2016 15:06	10354587225	Lead	23	15	ppb
026 114A Janitor's Closet Sink Faucet	7/3/2016 06:02	7/18/2016 15:08	10354587227	Copper	0.1	1.3	ppm
026 114A Janitor's Closet Sink Faucet	7/3/2016 06:02	7/18/2016 15:08	10354587227	Lead	7	15	ppb
026 115A Gym Drinking Fountain #1	7/3/2016 06:04	7/18/2016 15:09	10354587229	Copper	0.0	1.3	ppm
026 115A Gym Drinking Fountain #1	7/3/2016 06:04	7/18/2016 15:09	10354587229	Lead	3	15	ppb
026 116A Gym Drinking Fountain #2	7/3/2016 06:06	7/18/2016 15:11	10354587231	Copper	0.0	1.3	ppm
026 116A Gym Drinking Fountain #2	7/3/2016 06:06	7/18/2016 15:11	10354587231	Lead	1	15	ppb
026 117A Girls Restroom Sink Faucet #1	7/3/2016 06:08	7/18/2016 15:12	10354587233	Copper	0.2	1.3	ppm
026 117A Girls Restroom Sink Faucet #1	7/3/2016 06:08	7/18/2016 15:12	10354587233	Lead	21	15	ppb
026 118A Girls Restroom Sink Faucet #2	7/3/2016 06:10	7/18/2016 15:13	10354587235	Copper	0.1	1.3	ppm
026 118A Girls Restroom Sink Faucet #2	7/3/2016 06:10	7/18/2016 15:13	10354587235	Lead	21	15	ppb
026 119A Girls Restroom Sink Faucet #3	7/3/2016 06:12	7/18/2016 15:15	10354587237	Copper	0.3	1.3	ppm
026 119A Girls Restroom Sink Faucet #3	7/3/2016 06:12	7/18/2016 15:15	10354587237	Lead	22	15	ppb
026 120A Girls Restroom Water Spigot	7/3/2016 06:14	7/19/2016 10:37	10354587239	Copper	0.2	1.3	ppm
026 120A Girls Restroom Water Spigot	7/3/2016 06:14	7/19/2016 10:37	10354587239	Lead	761	15	ppb
026 121A Hallway Drinking Fountain	7/3/2016 06:16	7/19/2016 13:00	10354587241	Copper	0.1	1.3	ppm
026 121A Hallway Drinking Fountain	7/3/2016 06:16	7/19/2016 13:00	10354587241	Lead	10	15	ppb
026 122A Girls Restroom Sink Faucet #4	7/3/2016 06:18	7/19/2016 13:05	10354587243	Copper	0.2	1.3	ppm
026 122A Girls Restroom Sink Faucet #4	7/3/2016 06:18	7/19/2016 13:05	10354587243	Lead	70	15	ppb
026 123A Room 225 Sink Faucet	7/3/2016 06:20	7/19/2016 13:07	10354587245	Copper	0.0	1.3	ppm
026 123A Room 225 Sink Faucet	7/3/2016 06:20	7/19/2016 13:07	10354587245	Lead	38	15	ppb
026 124A Room 213 Sink Faucet	7/3/2016 06:22	7/19/2016 13:08	10354587247	Copper	0.1	1.3	ppm
026 124A Room 213 Sink Faucet	7/3/2016 06:22	7/19/2016 13:08	10354587247	Lead	28	15	ppb
026 125A Office Restroom Sink Faucet	7/3/2016 06:24	7/19/2016 13:09	10354587249	Copper	0.2	1.3	ppm
026 125A Office Restroom Sink Faucet	7/3/2016 06:24	7/19/2016 13:09	10354587249	Lead	49	15	ppb
026 126A Makeup Room Sink Faucet	7/3/2016 06:26	7/19/2016 13:14	10354587251	Copper	0.0	1.3	ppm
026 126A Makeup Room Sink Faucet	7/3/2016 06:26	7/19/2016 13:14	10354587251	Lead	23	15	ppb
026 127A Room 200 Sink Faucet	7/3/2016 06:28	7/19/2016 13:15	10354587253	Copper	0.0	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Cleveland High School

026 127A Room 200 Sink Faucet	7/3/2016 06:28	7/19/2016 13:15	10354587253	Lead	11	15	ppb
026 128A Room 206 Sink Faucet	7/3/2016 06:30	7/19/2016 13:16	10354587255	Copper	0.3	1.3	ppm
026 128A Room 206 Sink Faucet	7/3/2016 06:30	7/19/2016 13:16	10354587255	Lead	16	15	ppb
026 129A Room 206 Office Sink Faucet	7/3/2016 06:32	7/19/2016 13:18	10354587257	Copper	0.0	1.3	ppm
026 129A Room 206 Office Sink Faucet	7/3/2016 06:32	7/19/2016 13:18	10354587257	Lead	49	15	ppb
026 130A Teachers Lounge Sink Faucet	7/3/2016 06:34	7/19/2016 13:19	10354587259	Copper	0.1	1.3	ppm
026 130A Teachers Lounge Sink Faucet	7/3/2016 06:34	7/19/2016 13:19	10354587259	Lead	61	15	ppb
026 131A Girls Restroom Sink Faucet #5	7/3/2016 06:36	7/19/2016 13:20	10354587261	Copper	0.0	1.3	ppm
026 131A Girls Restroom Sink Faucet #5	7/3/2016 06:36	7/19/2016 13:20	10354587261	Lead	48	15	ppb
026 132A Girls Restroom Sink Faucet #6	7/3/2016 06:38	7/19/2016 13:23	10354587263	Copper	0.0	1.3	ppm
026 132A Girls Restroom Sink Faucet #6	7/3/2016 06:38	7/19/2016 13:23	10354587263	Lead	30	15	ppb
026 133A Girls Restroom Sink Faucet #7	7/3/2016 06:39	7/18/2016 16:43	10354587265	Copper	0.2	1.3	ppm
026 133A Girls Restroom Sink Faucet #7	7/3/2016 06:39	7/18/2016 16:43	10354587265	Lead	32	15	ppb
026 134A Girls Restroom Water Spigot	7/3/2016 06:41	7/19/2016 10:40	10354587267	Copper	0.1	1.3	ppm
026 134A Girls Restroom Water Spigot	7/3/2016 06:41	7/19/2016 10:40	10354587267	Lead	377	15	ppb
026 135A Student Services Sink Faucet	7/3/2016 06:43	7/19/2016 13:25	10354587269	Copper	0.2	1.3	ppm
026 135A Student Services Sink Faucet	7/3/2016 06:43	7/19/2016 13:25	10354587269	Lead	32	15	ppb
026 136A Wood Shop Sink Faucet	7/3/2016 06:45	7/19/2016 13:26	10354587271	Copper	0.4	1.3	ppm
026 136A Wood Shop Sink Faucet	7/3/2016 06:45	7/19/2016 13:26	10354587271	Lead	53	15	ppb
026 137A Wood Shop Drinking Fountain	7/3/2016 06:47	7/19/2016 13:33	10354587273	Copper	0.0	1.3	ppm
026 137A Wood Shop Drinking Fountain	7/3/2016 06:47	7/19/2016 13:33	10354587273	Lead	0	15	ppb
026 138A Planning Room Sink Faucet	7/3/2016 06:49	7/19/2016 13:34	10354587275	Copper	0.5	1.3	ppm
026 138A Planning Room Sink Faucet	7/3/2016 06:49	7/19/2016 13:34	10354587275	Lead	3	15	ppb
026 139A Mens Restroom Sink Faucet #1	7/3/2016 06:51	7/19/2016 13:36	10354587277	Copper	0.4	1.3	ppm
026 139A Mens Restroom Sink Faucet #1	7/3/2016 06:51	7/19/2016 13:36	10354587277	Lead	30	15	ppb
026 140A Mens Restroom Sink Faucet #2	7/3/2016 06:53	7/19/2016 13:37	10354587279	Copper	0.1	1.3	ppm
026 140A Mens Restroom Sink Faucet #2	7/3/2016 06:53	7/19/2016 13:37	10354587279	Lead	19	15	ppb
026 141A Mens Restroom Water Spigot	7/3/2016 06:55	7/19/2016 10:44	10354587281	Copper	0.2	1.3	ppm
026 141A Mens Restroom Water Spigot	7/3/2016 06:55	7/19/2016 10:44	10354587281	Lead	13	15	ppb
026 142A Janitor's Closet Sink Faucet	7/3/2016 06:57	7/19/2016 14:12	10354587283	Copper	0.1	1.3	ppm
026 142A Janitor's Closet Sink Faucet	7/3/2016 06:57	7/19/2016 14:12	10354587283	Lead	5	15	ppb
026 143A Hallway Drinking Fountain	7/3/2016 06:59	7/19/2016 14:20	10354587285	Copper	0.1	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Cleveland High School

026 143A Hallway Drinking Fountain	7/3/2016 06:59	7/19/2016 14:20	10354587285	Lead	10	15	ppb
026 144A Girls Restroom Sink Faucet #8	7/3/2016 07:01	7/19/2016 14:22	10354587287	Copper	0.1	1.3	ppm
026 144A Girls Restroom Sink Faucet #8	7/3/2016 07:01	7/19/2016 14:22	10354587287	Lead	116	15	ppb
026 145A Girls Restroom Sink Faucet #9	7/3/2016 07:03	7/19/2016 14:23	10354587289	Copper	0.1	1.3	ppm
026 145A Girls Restroom Sink Faucet #9	7/3/2016 07:03	7/19/2016 14:23	10354587289	Lead	26	15	ppb
026 146A Girls Restroom Water Spigot	7/3/2016 07:05	7/19/2016 14:24	10354587291	Copper	0.3	1.3	ppm
026 146A Girls Restroom Water Spigot	7/3/2016 07:05	7/19/2016 14:24	10354587291	Lead	42	15	ppb
026 147A Janitor's Closet Sink Faucet	7/3/2016 07:07	7/19/2016 10:47	10354587293	Copper	0.0	1.3	ppm
026 147A Janitor's Closet Sink Faucet	7/3/2016 07:07	7/19/2016 10:47	10354587293	Lead	274	15	ppb
026 148A Boys Restroom Sink Faucet	7/3/2016 07:09	7/19/2016 14:26	10354587295	Copper	0.0	1.3	ppm
026 148A Boys Restroom Sink Faucet	7/3/2016 07:09	7/19/2016 14:26	10354587295	Lead	61	15	ppb
026 149A Boys Restroom Water Spigot	7/3/2016 07:11	7/19/2016 14:27	10354587297	Copper	1.30	1.3	ppm
026 149A Boys Restroom Water Spigot	7/3/2016 07:11	7/19/2016 14:27	10354587297	Lead	67	15	ppb
026 150A Library Book Room Sink Faucet	7/3/2016 07:13	7/19/2016 14:29	10354587299	Copper	0.2	1.3	ppm
026 150A Library Book Room Sink Faucet	7/3/2016 07:13	7/19/2016 14:29	10354587299	Lead	28	15	ppb
026 151A Room 263 Sink Faucet #1	7/3/2016 07:15	7/19/2016 14:30	10354587301	Copper	0.2	1.3	ppm
026 151A Room 263 Sink Faucet #1	7/3/2016 07:15	7/19/2016 14:30	10354587301	Lead	20	15	ppb
026 152A Room 263 Sink Faucet #2	7/3/2016 07:17	7/19/2016 14:34	10354587303	Copper	0.1	1.3	ppm
026 152A Room 263 Sink Faucet #2	7/3/2016 07:17	7/19/2016 14:34	10354587303	Lead	84	15	ppb
026 153A Janitor's Closet Sink Faucet	7/3/2016 07:19	7/19/2016 14:37	10354587305	Copper	0.1	1.3	ppm
026 153A Janitor's Closet Sink Faucet	7/3/2016 07:19	7/19/2016 14:37	10354587305	Lead	10	15	ppb
026 154A Boys Restroom Sink Faucet	7/3/2016 07:21	7/19/2016 14:38	10354587307	Copper	0.1	1.3	ppm
026 154A Boys Restroom Sink Faucet	7/3/2016 07:21	7/19/2016 14:38	10354587307	Lead	13	15	ppb
026 155A Boys Restroom Water Spigot	7/3/2016 07:21	7/19/2016 14:40	10354587309	Copper	0.3	1.3	ppm
026 155A Boys Restroom Water Spigot	7/3/2016 07:21	7/19/2016 14:40	10354587309	Lead	42	15	ppb
026 156A Janitor's Closet Sink Faucet	7/3/2016 07:22	7/19/2016 14:41	10354587311	Copper	0.1	1.3	ppm
026 156A Janitor's Closet Sink Faucet	7/3/2016 07:22	7/19/2016 14:41	10354587311	Lead	42	15	ppb
026 157A Room 233 Sink Faucet	7/3/2016 07:24	7/19/2016 14:43	10354587313	Copper	0.4	1.3	ppm
026 157A Room 233 Sink Faucet	7/3/2016 07:24	7/19/2016 14:43	10354587313	Lead	28	15	ppb
026 158A Hallway Drinking Fountain #1	7/3/2016 07:26	7/19/2016 14:44	10354587315	Copper	0.0	1.3	ppm
026 158A Hallway Drinking Fountain #1	7/3/2016 07:26	7/19/2016 14:44	10354587315	Lead	2	15	ppb
026 159A Hallway Drinking Fountain #2	7/3/2016 07:26	7/19/2016 14:45	10354587317	Copper	0.0	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Cleveland High School

026 159A Hallway Drinking Fountain #2	7/3/2016 07:26	7/19/2016 14:45	10354587317	Lead	2	15	ppb
026 160A Room 229	7/3/2016 07:28	7/19/2016 14:47	10354587319	Copper	0.2	1.3	ppm
026 160A Room 229	7/3/2016 07:28	7/19/2016 14:47	10354587319	Lead	107	15	ppb
026 161A Girls Restroom Sink Faucet 3rd #1	7/3/2016 07:32	7/19/2016 15:32	10354587321	Copper	0.2	1.3	ppm
026 161A Girls Restroom Sink Faucet 3rd #1	7/3/2016 07:32	7/19/2016 15:32	10354587321	Lead	41	15	ppb
026 162A Girls Restroom Sink Faucet 3rd #2	7/3/2016 07:32	7/19/2016 15:30	10354587323	Copper	0.1	1.3	ppm
026 162A Girls Restroom Sink Faucet 3rd #2	7/3/2016 07:32	7/19/2016 15:30	10354587323	Lead	27	15	ppb
026 163A Girls Restroom Sink Faucet 3rd #3	7/3/2016 07:33	7/19/2016 15:31	10354587325	Copper	0.1	1.3	ppm
026 163A Girls Restroom Sink Faucet 3rd #3	7/3/2016 07:33	7/19/2016 15:31	10354587325	Lead	21	15	ppb
026 164A Girls Restroom Sink Faucet 3rd #4	7/3/2016 07:33	7/19/2016 15:41	10354587327	Copper	0.0	1.3	ppm
026 164A Girls Restroom Sink Faucet 3rd #4	7/3/2016 07:33	7/19/2016 15:41	10354587327	Lead	40	15	ppb
026 165A Girls Restroom Water Spigot	7/3/2016 07:35	7/19/2016 15:42	10354587329	Copper	0.1	1.3	ppm
026 165A Girls Restroom Water Spigot	7/3/2016 07:35	7/19/2016 15:42	10354587329	Lead	69	15	ppb
026 166A Hallway Drinking Fountain	7/3/2016 07:37	7/19/2016 15:44	10354587331	Copper	0.1	1.3	ppm
026 166A Hallway Drinking Fountain	7/3/2016 07:37	7/19/2016 15:44	10354587331	Lead	67	15	ppb
026 167A Room 300 Sink Faucet	7/3/2016 07:39	7/19/2016 10:50	10354587333	Copper	0.2	1.3	ppm
026 167A Room 300 Sink Faucet	7/3/2016 07:39	7/19/2016 11:58	10354587333	Lead	1540	15	ppb
026 168A Room 312 Sink Faucet #1	7/3/2016 07:41	7/19/2016 15:45	10354587335	Copper	0.1	1.3	ppm
026 168A Room 312 Sink Faucet #1	7/3/2016 07:41	7/19/2016 15:45	10354587335	Lead	20	15	ppb
026 169A Room 312 Sink Faucet #2	7/3/2016 07:41	7/19/2016 15:46	10354587337	Copper	0.1	1.3	ppm
026 169A Room 312 Sink Faucet #2	7/3/2016 07:41	7/19/2016 15:46	10354587337	Lead	19	15	ppb
026 170A Room 314 Sink Faucet #1	7/3/2016 07:43	7/19/2016 15:48	10354587339	Copper	0.1	1.3	ppm
026 170A Room 314 Sink Faucet #1	7/3/2016 07:43	7/19/2016 15:48	10354587339	Lead	140	15	ppb
026 171A Room 314 Sink Faucet #2	7/3/2016 07:43	7/19/2016 15:49	10354587341	Copper	0.1	1.3	ppm
026 171A Room 314 Sink Faucet #2	7/3/2016 07:43	7/19/2016 15:49	10354587341	Lead	87	15	ppb
026 172A Room 308+310 Sink Faucet North #1	7/3/2016 07:45	7/19/2016 15:52	10354587343	Copper	0.1	1.3	ppm
026 172A Room 308+310 Sink Faucet North #1	7/3/2016 07:45	7/19/2016 15:52	10354587343	Lead	92	15	ppb
026 173A Room 308+310 Sink Faucet North #2	7/3/2016 07:45	7/19/2016 10:53	10354587345	Copper	0.1	1.3	ppm
026 173A Room 308+310 Sink Faucet North #2	7/3/2016 07:45	7/19/2016 10:53	10354587345	Lead	74	15	ppb
026 174A Room 308+310 Sink Faucet North #3	7/3/2016 07:45	7/19/2016 15:53	10354587347	Copper	0.1	1.3	ppm
026 174A Room 308+310 Sink Faucet North #3	7/3/2016 07:45	7/19/2016 15:53	10354587347	Lead	34	15	ppb
026 175A Room 308+310 Sink Faucet South #4	7/3/2016 07:45	7/19/2016 15:57	10354587349	Copper	0.1	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Cleveland High School

026 175A Room 308+310 Sink Faucet South #4	7/3/2016 07:45	7/19/2016 15:57	10354587349	Lead	26	15	ppb
026 176A Hallway Drinking Fountain	7/3/2016 07:47	7/19/2016 15:59	10354587351	Copper	0.0	1.3	ppm
026 176A Hallway Drinking Fountain	7/3/2016 07:47	7/19/2016 15:59	10354587351	Lead	7	15	ppb
026 177A Room 326 Bathroom Sink Faucet	7/3/2016 07:49	7/19/2016 16:00	10354587353	Copper	0.0	1.3	ppm
026 177A Room 326 Bathroom Sink Faucet	7/3/2016 07:49	7/19/2016 16:00	10354587353	Lead	5	15	ppb
026 178A Room 320 Sink Faucet	7/3/2016 07:51	7/19/2016 16:01	10354587355	Copper	0.1	1.3	ppm
026 178A Room 320 Sink Faucet	7/3/2016 07:51	7/19/2016 16:01	10354587355	Lead	36	15	ppb
026 179A Janitor's Closet Sink Faucet	7/3/2016 07:51	7/19/2016 16:03	10354587357	Copper	0.0	1.3	ppm
026 179A Janitor's Closet Sink Faucet	7/3/2016 07:51	7/19/2016 16:03	10354587357	Lead	1	15	ppb
026 180A Room 330 Sink Faucet #1	7/3/2016 07:53	7/19/2016 10:57	10354587359	Copper	0.3	1.3	ppm
026 180A Room 330 Sink Faucet #1	7/3/2016 07:53	7/19/2016 10:57	10354587359	Lead	62	15	ppb
026 181A Room 330 Sink Faucet #2	7/3/2016 07:53	7/19/2016 06:47	10354587361	Copper	0.1	1.3	ppm
026 181A Room 330 Sink Faucet #2	7/3/2016 07:53	7/19/2016 06:47	10354587361	Lead	56	15	ppb
026 182A Room 330 Sink Faucet #3	7/3/2016 07:55	7/19/2016 11:00	10354587363	Copper	0.0	1.3	ppm
026 182A Room 330 Sink Faucet #3	7/3/2016 07:55	7/19/2016 11:00	10354587363	Lead	112	15	ppb
026 183A Room 330 Sink Faucet #4	7/3/2016 07:55	7/19/2016 10:21	10354587365	Copper	0.0	1.3	ppm
026 183A Room 330 Sink Faucet #4	7/3/2016 07:55	7/19/2016 10:21	10354587365	Lead	273	15	ppb
026 184A Room 330 Sink Faucet #5	7/3/2016 07:55	7/19/2016 11:03	10354587367	Copper	0.0	1.3	ppm
026 184A Room 330 Sink Faucet #5	7/3/2016 07:55	7/19/2016 11:03	10354587367	Lead	63	15	ppb
026 185A Room 330 Sink Faucet #6	7/3/2016 07:57	7/19/2016 11:13	10354587369	Copper	0.0	1.3	ppm
026 185A Room 330 Sink Faucet #6	7/3/2016 07:57	7/19/2016 11:13	10354587369	Lead	66	15	ppb
026 186A Room 330 Sink Faucet #7	7/3/2016 07:57	7/19/2016 11:16	10354587371	Copper	0.0	1.3	ppm
026 186A Room 330 Sink Faucet #7	7/3/2016 07:57	7/19/2016 11:16	10354587371	Lead	78	15	ppb
026 187A Room 330 Sink Faucet #8	7/3/2016 07:57	7/19/2016 11:19	10354587373	Copper	0.0	1.3	ppm
026 187A Room 330 Sink Faucet #8	7/3/2016 07:57	7/19/2016 11:19	10354587373	Lead	115	15	ppb
026 188A Room 330 Sink Faucet #9	7/3/2016 07:59	7/18/2016 16:41	10354587375	Copper	0.0	1.3	ppm
026 188A Room 330 Sink Faucet #9	7/3/2016 07:59	7/18/2016 16:41	10354587375	Lead	13	15	ppb
026 189A Room 330 Sink Faucet #10	7/3/2016 07:59	7/19/2016 07:00	10354587377	Copper	0.1	1.3	ppm
026 189A Room 330 Sink Faucet #10	7/3/2016 07:59	7/19/2016 07:00	10354587377	Lead	12	15	ppb
026 190A Room 330 Sink Faucet #11	7/3/2016 07:59	7/19/2016 07:03	10354587379	Copper	0.0	1.3	ppm
026 190A Room 330 Sink Faucet #11	7/3/2016 07:59	7/19/2016 07:03	10354587379	Lead	75	15	ppb
026 191A Room 330 Sink Faucet #12	7/3/2016 08:01	7/19/2016 11:23	10354587381	Copper	0.0	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Cleveland High School

026 191A Room 330 Sink Faucet #12	7/3/2016 08:01	7/19/2016 11:23	10354587381	Lead	103	15	ppb
026 192A Room 330 Sink Faucet #13	7/3/2016 08:01	7/19/2016 07:07	10354587383	Copper	0.1	1.3	ppm
026 192A Room 330 Sink Faucet #13	7/3/2016 08:01	7/19/2016 07:07	10354587383	Lead	32	15	ppb
026 193A Room 330 Sink Faucet #14	7/3/2016 08:01	7/19/2016 11:26	10354587385	Copper	0.0	1.3	ppm
026 193A Room 330 Sink Faucet #14	7/3/2016 08:01	7/19/2016 11:26	10354587385	Lead	72	15	ppb
026 194A Room 330 Sink Faucet #15	7/3/2016 08:01	7/19/2016 11:29	10354587387	Copper	0.3	1.3	ppm
026 194A Room 330 Sink Faucet #15	7/3/2016 08:01	7/19/2016 11:29	10354587387	Lead	111	15	ppb
026 195A Room 330 Sink Faucet #16	7/3/2016 08:03	7/19/2016 07:10	10354587389	Copper	0.0	1.3	ppm
026 195A Room 330 Sink Faucet #16	7/3/2016 08:03	7/19/2016 07:10	10354587389	Lead	10	15	ppb
026 196A Room 330 Sink Faucet #17	7/3/2016 08:03	7/19/2016 07:20	10354587391	Copper	0.0	1.3	ppm
026 196A Room 330 Sink Faucet #17	7/3/2016 08:03	7/19/2016 07:20	10354587391	Lead	52	15	ppb
026 197A Room 330 Sink Faucet #18	7/3/2016 08:03	7/19/2016 07:23	10354587393	Copper	0.0	1.3	ppm
026 197A Room 330 Sink Faucet #18	7/3/2016 08:03	7/19/2016 07:23	10354587393	Lead	54	15	ppb
026 198A Room 330 Sink Faucet #19	7/3/2016 08:03	7/19/2016 07:26	10354587395	Copper	0.0	1.3	ppm
026 198A Room 330 Sink Faucet #19	7/3/2016 08:03	7/19/2016 07:26	10354587395	Lead	50	15	ppb
026 199A Room 330 Island Sink Faucet #1	7/3/2016 08:05	7/19/2016 11:32	10354587397	Copper	0.3	1.3	ppm
026 199A Room 330 Island Sink Faucet #1	7/3/2016 08:05	7/19/2016 11:32	10354587397	Lead	182	15	ppb
026 200A Room 330 Island Sink Faucet #2	7/3/2016 08:05	7/18/2016 13:54	10354587399	Copper	0.1	1.3	ppm
026 200A Room 330 Island Sink Faucet #2	7/3/2016 08:05	7/18/2016 13:54	10354587399	Lead	111	15	ppb
026 201A Room 330 Island Sink Faucet #3	7/3/2016 08:05	7/18/2016 13:59	10354587401	Copper	0.0	1.3	ppm
026 201A Room 330 Island Sink Faucet #3	7/3/2016 08:05	7/18/2016 13:59	10354587401	Lead	104	15	ppb
026 202A Room 330 Island Sink Faucet #4	7/3/2016 08:05	7/18/2016 14:01	10354587403	Copper	0.0	1.3	ppm
026 202A Room 330 Island Sink Faucet #4	7/3/2016 08:05	7/18/2016 14:01	10354587403	Lead	87	15	ppb
026 203A Room 330 Island Sink Faucet #5	7/3/2016 08:07	7/19/2016 12:15	10354587405	Copper	0.0	1.3	ppm
026 203A Room 330 Island Sink Faucet #5	7/3/2016 08:07	7/19/2016 12:15	10354587405	Lead	99	15	ppb
026 204A Room 330 Island Sink Faucet #6	7/3/2016 08:07	7/19/2016 12:28	10354587407	Copper	0.3	1.3	ppm
026 204A Room 330 Island Sink Faucet #6	7/3/2016 08:07	7/19/2016 12:28	10354587407	Lead	95	15	ppb
026 205A Room 330 Island Sink Faucet #7	7/3/2016 08:07	7/19/2016 12:31	10354587409	Copper	0.0	1.3	ppm
026 205A Room 330 Island Sink Faucet #7	7/3/2016 08:07	7/19/2016 12:31	10354587409	Lead	47	15	ppb
026 206A Room 330 Island Sink Faucet #8	7/3/2016 08:07	7/19/2016 12:34	10354587411	Copper	0.1	1.3	ppm
026 206A Room 330 Island Sink Faucet #8	7/3/2016 08:07	7/19/2016 12:34	10354587411	Lead	60	15	ppb
026 207A Room 330 Island Sink Faucet #9	7/3/2016 08:07	7/19/2016 12:37	10354587413	Copper	0.0	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Cleveland High School

026 207A Room 330 Island Sink Faucet #9	7/3/2016 08:07	7/19/2016 12:37	10354587413	Lead	22	15	ppb
026 208A Room 330 Island Sink Faucet #10	7/3/2016 08:07	7/19/2016 12:47	10354587415	Copper	0.0	1.3	ppm
026 208A Room 330 Island Sink Faucet #10	7/3/2016 08:07	7/19/2016 12:47	10354587415	Lead	64	15	ppb
026 209A Room 330 328A Sink Faucet	7/3/2016 08:09	7/19/2016 12:50	10354587417	Copper	0.2	1.3	ppm
026 209A Room 330 328A Sink Faucet	7/3/2016 08:09	7/19/2016 12:50	10354587417	Lead	9	15	ppb
026 210A Room 328A Eye Wash	7/3/2016 08:13	7/18/2016 14:02	10354587419	Copper	0.1	1.3	ppm
026 210A Room 328A Eye Wash	7/3/2016 08:13	7/18/2016 14:02	10354587419	Lead	57	15	ppb
026 211A Room 328A Hood Left Side	7/3/2016 08:15	7/18/2016 15:16	10354587421	Copper	0.3	1.3	ppm
026 211A Room 328A Hood Left Side	7/3/2016 08:15	7/18/2016 14:03	10354587421	Lead	32	15	ppb
026 212A Room 328A Hood Right side	7/3/2016 08:15	7/19/2016 12:53	10354587423	Copper	0.4	1.3	ppm
026 212A Room 328A Hood Right side	7/3/2016 08:15	7/19/2016 12:53	10354587423	Lead	57	15	ppb
026 213A Room330/328A Hood Right side	7/3/2016 08:17	7/19/2016 12:57	10354587425	Copper	0.1	1.3	ppm
026 213A Room330/328A Hood Right side	7/3/2016 08:17	7/19/2016 12:57	10354587425	Lead	27	15	ppb
026 214A Room330/328A Hood Right Side	7/3/2016 08:17	7/19/2016 13:00	10354587427	Copper	0.3	1.3	ppm
026 214A Room330/328A Hood Right Side	7/3/2016 08:17	7/19/2016 13:00	10354587427	Lead	55	15	ppb
026 215A Room West Side Hood Left	7/3/2016 08:19	7/19/2016 13:07	10354587429	Copper	0.2	1.3	ppm
026 215A Room West Side Hood Left	7/3/2016 08:19	7/19/2016 13:07	10354587429	Lead	51	15	ppb
026 216A Room West Side Of Hood Right Side	7/3/2016 08:19	7/19/2016 13:10	10354587431	Copper	0.1	1.3	ppm
026 216A Room West Side Of Hood Right Side	7/3/2016 08:19	7/19/2016 13:10	10354587431	Lead	93	15	ppb
026 217A Room 328A Eyewash	7/3/2016 08:19	7/19/2016 13:13	10354587433	Copper	0.0	1.3	ppm
026 217A Room 328A Eyewash	7/3/2016 08:19	7/19/2016 13:13	10354587433	Lead	5	15	ppb
026 218A Room West 328A Side Of Hood Left	7/3/2016 08:19	7/19/2016 13:16	10354587435	Copper	0.1	1.3	ppm
026 218A Room West 328A Side Of Hood Left	7/3/2016 08:19	7/19/2016 13:16	10354587435	Lead	40	15	ppb
026 219A Room West 328A Side Of Hood Right	7/3/2016 08:19	7/19/2016 13:34	10354587437	Copper	1.7	1.3	ppm
026 219A Room West 328A Side Of Hood Right	7/3/2016 08:19	7/19/2016 13:26	10354587437	Lead	81	15	ppb
026 220A Room 328A East Side Of Hood Left	7/3/2016 08:21	7/19/2016 13:29	10354587439	Copper	0.6	1.3	ppm
026 220A Room 328A East Side Of Hood Left	7/3/2016 08:21	7/19/2016 13:29	10354587439	Lead	95	15	ppb
026 221A Room 330 East Side of Hoods Left #1	7/3/2016 08:21	7/19/2016 07:36	10354587441	Copper	0.1	1.3	ppm
026 221A Room 330 East Side of Hoods Left #1	7/3/2016 08:21	7/19/2016 07:36	10354587441	Lead	45	15	ppb
026 222A Room 330 East Side of Hoods Left #2	7/3/2016 08:23	7/19/2016 07:48	10354587443	Copper	0.8	1.3	ppm
026 222A Room 330 East Side of Hoods Left #2	7/3/2016 08:23	7/19/2016 07:48	10354587443	Lead	253	15	ppb
026 223A Room 330 East Side of Hoods Left #3	7/3/2016 08:23	7/19/2016 07:58	10354587445	Copper	0.2	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Cleveland High School

026 223A Room 330 East Side of Hoods Left #3	7/3/2016 08:23	7/19/2016 07:58	10354587445	Lead	101	15	ppb
026 224A Room 332 Biology Sink Faucet	7/3/2016 08:27	7/18/2016 15:50	10354587447	Copper	1.1	1.3	ppm
026 224A Room 332 Biology Sink Faucet	7/3/2016 08:27	7/18/2016 14:07	10354587447	Lead	353	15	ppb
026 225A Room 366/332A Sink Faucet #1	7/3/2016 08:29	7/19/2016 08:01	10354587449	Copper	0.1	1.3	ppm
026 225A Room 366/332A Sink Faucet #1	7/3/2016 08:29	7/19/2016 08:01	10354587449	Lead	65	15	ppb
026 226A Room 366/332A Sink Faucet #2	7/3/2016 08:31	7/19/2016 08:05	10354587451	Copper	0.1	1.3	ppm
026 226A Room 366/332A Sink Faucet #2	7/3/2016 08:31	7/19/2016 08:05	10354587451	Lead	35	15	ppb
026 227A Room 366/332A Sprayer	7/3/2016 08:31	7/19/2016 08:08	10354587453	Copper	0.1	1.3	ppm
026 227A Room 366/332A Sprayer	7/3/2016 08:31	7/19/2016 08:08	10354587453	Lead	28	15	ppb
026 228A Room 366/332A Sink Faucet #3	7/3/2016 08:33	7/19/2016 08:11	10354587455	Copper	0.1	1.3	ppm
026 228A Room 366/332A Sink Faucet #3	7/3/2016 08:33	7/19/2016 08:11	10354587455	Lead	18	15	ppb
026 229A Room 344 Southwest Sink Faucet #1	7/3/2016 08:35	7/19/2016 08:14	10354587457	Copper	0.2	1.3	ppm
026 229A Room 344 Southwest Sink Faucet #1	7/3/2016 08:35	7/19/2016 08:14	10354587457	Lead	64	15	ppb
026 230A Room 344 Northwest Sink Faucet #2	7/3/2016 08:35	7/19/2016 08:17	10354587459	Copper	0.1	1.3	ppm
026 230A Room 344 Northwest Sink Faucet #2	7/3/2016 08:35	7/19/2016 08:17	10354587459	Lead	14	15	ppb
026 231A Room 366/332A Sink Faucet North	7/3/2016 08:37	7/19/2016 08:21	10354587461	Copper	0.1	1.3	ppm
026 231A Room 366/332A Sink Faucet North	7/3/2016 08:37	7/19/2016 08:21	10354587461	Lead	35	15	ppb
026 232A Room 366/344 Sink Faucet South C	7/3/2016 08:37	7/19/2016 08:27	10354587463	Copper	0.1	1.3	ppm
026 232A Room 366/344 Sink Faucet South C	7/3/2016 08:37	7/19/2016 08:27	10354587463	Lead	31	15	ppb
026 233A Room 366/344 Sink Faucet Southeast	7/3/2016 08:39	7/19/2016 08:37	10354587465	Copper	0.1	1.3	ppm
026 233A Room 366/344 Sink Faucet Southeast	7/3/2016 08:39	7/19/2016 08:37	10354587465	Lead	8	15	ppb
026 234A Room 366/344 Sink Faucet Northeast	7/3/2016 08:39	7/19/2016 08:40	10354587467	Copper	0.1	1.3	ppm
026 234A Room 366/344 Sink Faucet Northeast	7/3/2016 08:39	7/19/2016 08:40	10354587467	Lead	20	15	ppb
026 235A Room Biology 366 Side Sink Faucet 344B	7/3/2016 08:41	7/18/2016 14:09	10354587469	Copper	0.0	1.3	ppm
026 235A Room Biology 366 Side Sink Faucet 344B	7/3/2016 08:41	7/18/2016 14:09	10354587469	Lead	136	15	ppb
026 236A Room 336 Beaker Sink Faucet	7/3/2016 08:43	7/19/2016 08:43	10354587471	Copper	0.1	1.3	ppm
026 236A Room 336 Beaker Sink Faucet	7/3/2016 08:43	7/19/2016 08:43	10354587471	Lead	28	15	ppb
026 237A Room 336 Northwest Sink Faucet	7/3/2016 08:43	7/19/2016 08:47	10354587473	Copper	0.1	1.3	ppm
026 237A Room 336 Northwest Sink Faucet	7/3/2016 08:43	7/19/2016 08:47	10354587473	Lead	19	15	ppb
026 238A Room 336 Southwest Sink Faucet	7/3/2016 08:45	7/19/2016 08:50	10354587475	Copper	0.1	1.3	ppm
026 238A Room 336 Southwest Sink Faucet	7/3/2016 08:45	7/19/2016 08:50	10354587475	Lead	66	15	ppb
026 239A Room 336 South Counter Sink Faucet	7/3/2016 08:45	7/19/2016 08:53	10354587477	Copper	0.0	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Cleveland High School

026 239A Room 336 South Counter Sink Faucet	7/3/2016 08:45	7/19/2016 08:53	10354587477	Lead	10	15	ppb
026 240A Room 336 North Counter Sink Faucet	7/3/2016 08:47	7/19/2016 08:56	10354587479	Copper	0.1	1.3	ppm
026 240A Room 336 North Counter Sink Faucet	7/3/2016 08:47	7/19/2016 08:56	10354587479	Lead	20	15	ppb
026 241A Room 336 Southeast Sink Faucet	7/3/2016 08:47	7/19/2016 13:38	10354587481	Copper	0.1	1.3	ppm
026 241A Room 336 Southeast Sink Faucet	7/3/2016 08:47	7/19/2016 13:38	10354587481	Lead	64	15	ppb
026 242A Room 336 Northeast Sink Faucet	7/3/2016 08:49	7/18/2016 14:10	10354587483	Copper	0.0	1.3	ppm
026 242A Room 336 Northeast Sink Faucet	7/3/2016 08:49	7/18/2016 14:10	10354587483	Lead	71	15	ppb
026 243A Room 336 Side Sink Faucet West	7/3/2016 08:49	7/18/2016 14:12	10354587485	Copper	0.0	1.3	ppm
026 243A Room 336 Side Sink Faucet West	7/3/2016 08:49	7/18/2016 14:12	10354587485	Lead	11	15	ppb
026 244A Room 336 Side Sink Faucet East	7/3/2016 08:50	7/19/2016 13:47	10354587487	Copper	0.0	1.3	ppm
026 244A Room 336 Side Sink Faucet East	7/3/2016 08:50	7/19/2016 13:47	10354587487	Lead	57	15	ppb
026 245A Basement Janitor's Office	7/3/2016 08:58	7/19/2016 13:48	10354587489	Copper	0.0	1.3	ppm
026 245A Basement Janitor's Office	7/3/2016 08:58	7/19/2016 13:48	10354587489	Lead	4	15	ppb
026 246A Room 366 Sink Faucet at door	7/3/2016 08:52	7/18/2016 14:13	10354587491	Copper	0.4	1.3	ppm
026 246A Room 366 Sink Faucet at door	7/3/2016 08:52	7/18/2016 14:13	10354587491	Lead	20	15	ppb
026 247A Room 366 Eye Wash	7/3/2016 08:52	7/19/2016 13:50	10354587493	Copper	0.0	1.3	ppm
026 247A Room 366 Eye Wash	7/3/2016 08:52	7/19/2016 13:50	10354587493	Lead	49	15	ppb
026 248A Room 366 Next to Eye Wash	7/3/2016 08:52	7/19/2016 13:51	10354587495	Copper	0.1	1.3	ppm
026 248A Room 366 Next to Eye Wash	7/3/2016 08:52	7/19/2016 13:51	10354587495	Lead	16	15	ppb
026 249A Room 366 Southwest Sink Faucet	7/3/2016 08:54	7/19/2016 13:52	10354587497	Copper	0.1	1.3	ppm
026 249A Room 366 Southwest Sink Faucet	7/3/2016 08:54	7/19/2016 13:52	10354587497	Lead	46	15	ppb
026 250A Room 366 Southeast Sink Faucet	7/3/2016 08:54	7/19/2016 13:54	10354587499	Copper	0.1	1.3	ppm
026 250A Room 366 Southeast Sink Faucet	7/3/2016 08:54	7/19/2016 13:54	10354587499	Lead	8	15	ppb
026 251A Room 366 Counter West Sink Faucet	7/3/2016 08:54	7/19/2016 13:55	10354587501	Copper	0.0	1.3	ppm
026 251A Room 366 Counter West Sink Faucet	7/3/2016 08:54	7/19/2016 13:55	10354587501	Lead	7	15	ppb
026 252A Room 366 Counter East Sink Faucet	7/3/2016 08:56	7/19/2016 14:03	10354587503	Copper	0.1	1.3	ppm
026 252A Room 366 Counter East Sink Faucet	7/3/2016 08:56	7/19/2016 14:03	10354587503	Lead	7	15	ppb
026 253A Room 366 Northwest Sink Faucet	7/3/2016 08:56	7/19/2016 14:05	10354587505	Copper	0.2	1.3	ppm
026 253A Room 366 Northwest Sink Faucet	7/3/2016 08:56	7/19/2016 14:05	10354587505	Lead	37	15	ppb
026 254A Room 366 Northeast Sink Faucet	7/3/2016 08:58	7/19/2016 14:06	10354587507	Copper	0.0	1.3	ppm
026 254A Room 366 Northeast Sink Faucet	7/3/2016 08:58	7/19/2016 14:06	10354587507	Lead	11	15	ppb
026 255A Hallway Drinking Fountain	7/3/2016 09:01	7/19/2016 14:08	10354587509	Copper	0.0	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Cleveland High School

026 255A Hallway Drinking Fountain	7/3/2016 09:01	7/19/2016 14:08	10354587509	Lead	7	15	ppb
026 256A Woman Restroom Sink Faucet	7/3/2016 09:04	7/19/2016 14:09	10354587511	Copper	0.0	1.3	ppm
026 256A Woman Restroom Sink Faucet	7/3/2016 09:04	7/19/2016 14:09	10354587511	Lead	94	15	ppb
026 257A Dark Room 367B Sink Faucet #1	7/3/2016 09:07	7/19/2016 14:10	10354587513	Copper	0.0	1.3	ppm
026 257A Dark Room 367B Sink Faucet #1	7/3/2016 09:07	7/19/2016 14:10	10354587513	Lead	10	15	ppb
026 258A Dark Room 367B Sink Faucet #2	7/3/2016 09:07	7/18/2016 14:14	10354587515	Copper	0.2	1.3	ppm
026 258A Dark Room 367B Sink Faucet #2	7/3/2016 09:07	7/18/2016 14:14	10354587515	Lead	44	15	ppb
026 259A Dark Room 367B Sink Faucet #3	7/3/2016 09:09	7/18/2016 15:51	10354587517	Copper	1.7	1.3	ppm
026 259A Dark Room 367B Sink Faucet #3	7/3/2016 09:09	7/18/2016 14:17	10354587517	Lead	79	15	ppb
026 260A 2 Dark Room 367 Sink Faucet	7/3/2016 09:10	7/18/2016 14:19	10354587519	Copper	0.2	1.3	ppm
026 260A 2 Dark Room 367 Sink Faucet	7/3/2016 09:10	7/18/2016 14:19	10354587519	Lead	98	15	ppb
026 261A Art Room 361 Back Sink Faucet	7/3/2016 09:12	7/18/2016 14:20	10354587521	Copper	0.3	1.3	ppm
026 261A Art Room 361 Back Sink Faucet	7/3/2016 09:12	7/18/2016 14:20	10354587521	Lead	392	15	ppb
026 262A Art Room Sink Faucet #1	7/3/2016 09:13	7/18/2016 14:27	10354587523	Copper	0.2	1.3	ppm
026 262A Art Room Sink Faucet #1	7/3/2016 09:13	7/18/2016 14:27	10354587523	Lead	15.4	15	ppb
026 263A Art Room Sink Faucet #2	7/3/2016 09:13	7/19/2016 09:06	10354587525	Copper	0.1	1.3	ppm
026 263A Art Room Sink Faucet #2	7/3/2016 09:13	7/19/2016 09:06	10354587525	Lead	5	15	ppb
026 264A Janitor's Closet Sink Faucet	7/3/2016 09:15	7/19/2016 09:26	10354587527	Copper	0.0	1.3	ppm
026 264A Janitor's Closet Sink Faucet	7/3/2016 09:15	7/19/2016 09:26	10354587527	Lead	2	15	ppb
026 265A Room 357 Sink Faucet #1	7/3/2016 09:17	7/19/2016 09:29	10354587529	Copper	0.1	1.3	ppm
026 265A Room 357 Sink Faucet #1	7/3/2016 09:17	7/19/2016 09:29	10354587529	Lead	3	15	ppb
026 266A Room 357 Sink Faucet #2	7/3/2016 09:17	7/19/2016 09:32	10354587531	Copper	0.2	1.3	ppm
026 266A Room 357 Sink Faucet #2	7/3/2016 09:17	7/19/2016 09:32	10354587531	Lead	35	15	ppb
026 267A Room 357c Sink Faucet	7/3/2016 09:20	7/18/2016 14:28	10354587533	Copper	0.1	1.3	ppm
026 267A Room 357c Sink Faucet	7/3/2016 09:20	7/18/2016 14:28	10354587533	Lead	11	15	ppb
026 268A Room 355 Sink Faucet #1	7/3/2016 09:23	7/18/2016 14:30	10354587535	Copper	0.1	1.3	ppm
026 268A Room 355 Sink Faucet #1	7/3/2016 09:23	7/18/2016 14:30	10354587535	Lead	23	15	ppb
026 269A Room 355 Sink Faucet #2	7/3/2016 09:23	7/18/2016 14:31	10354587537	Copper	0.1	1.3	ppm
026 269A Room 355 Sink Faucet #2	7/3/2016 09:23	7/18/2016 14:31	10354587537	Lead	18	15	ppb
026 270A Room 355 Sink Faucet #3	7/3/2016 09:25	7/18/2016 14:33	10354587539	Copper	0.1	1.3	ppm
026 270A Room 355 Sink Faucet #3	7/3/2016 09:25	7/18/2016 14:33	10354587539	Lead	82	15	ppb
026 271A Room 355 Sink Faucet #4	7/3/2016 09:25	7/19/2016 09:36	10354587541	Copper	0.1	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Cleveland High School

026 271A Room 355 Sink Faucet #4	7/3/2016 09:25	7/19/2016 09:36	10354587541	Lead	33	15	ppb
026 272A Room 363 Fumehood Sink Faucet	7/3/2016 09:30	7/19/2016 09:39	10354587543	Copper	0.5	1.3	ppm
026 272A Room 363 Fumehood Sink Faucet	7/3/2016 09:30	7/19/2016 09:39	10354587543	Lead	173	15	ppb
026 273A Room 363 Left-Clockwise #1	7/3/2016 09:33	7/19/2016 09:42	10354587545	Copper	0.7	1.3	ppm
026 273A Room 363 Left-Clockwise #1	7/3/2016 09:33	7/19/2016 09:42	10354587545	Lead	47	15	ppb
026 274A Room 363 Left-Clockwise #2	7/3/2016 09:33	7/19/2016 09:45	10354587547	Copper	0.6	1.3	ppm
026 274A Room 363 Left-Clockwise #2	7/3/2016 09:33	7/19/2016 09:45	10354587547	Lead	14.8	15	ppb
026 275A Room 363 Left-Clockwise #3	7/3/2016 09:33	7/19/2016 09:55	10354587549	Copper	0.2	1.3	ppm
026 275A Room 363 Left-Clockwise #3	7/3/2016 09:33	7/19/2016 09:55	10354587549	Lead	11	15	ppb
026 276A Room 363 Left-Clockwise #4	7/3/2016 09:35	7/19/2016 09:58	10354587551	Copper	0.6	1.3	ppm
026 276A Room 363 Left-Clockwise #4	7/3/2016 09:35	7/19/2016 09:58	10354587551	Lead	6	15	ppb
026 277A Room 363 Left-Clockwise #5	7/3/2016 09:35	7/19/2016 10:02	10354587553	Copper	0.4	1.3	ppm
026 277A Room 363 Left-Clockwise #5	7/3/2016 09:35	7/19/2016 10:02	10354587553	Lead	18	15	ppb
026 278A Room 363 Left-Clockwise #6	7/3/2016 09:35	7/19/2016 10:08	10354587555	Copper	0.5	1.3	ppm
026 278A Room 363 Left-Clockwise #6	7/3/2016 09:35	7/19/2016 10:08	10354587555	Lead	43	15	ppb
026 279A Room 363 Left-Clockwise #7	7/3/2016 09:37	7/19/2016 10:11	10354587557	Copper	0.2	1.3	ppm
026 279A Room 363 Left-Clockwise #7	7/3/2016 09:37	7/19/2016 10:11	10354587557	Lead	20	15	ppb
026 280A Boys Restroom Sink Faucet #1	7/3/2016 09:39	7/19/2016 10:14	10354587559	Copper	0.1	1.3	ppm
026 280A Boys Restroom Sink Faucet #1	7/3/2016 09:39	7/19/2016 10:14	10354587559	Lead	21	15	ppb
026 281A Boys Restroom Sink Faucet #2	7/3/2016 09:39	7/18/2016 16:01	10354587561	Copper	0.1	1.3	ppm
026 281A Boys Restroom Sink Faucet #2	7/3/2016 09:39	7/18/2016 16:01	10354587561	Lead	14.5	15	ppb
026 282A Boys Restroom Water Spigot	7/3/2016 09:41	7/18/2016 16:07	10354587563	Copper	0.2	1.3	ppm
026 282A Boys Restroom Water Spigot	7/3/2016 09:41	7/18/2016 16:07	10354587563	Lead	48	15	ppb
026 283A Room 335 Sink Faucet	7/3/2016 09:43	7/18/2016 16:08	10354587565	Copper	0.1	1.3	ppm
026 283A Room 335 Sink Faucet	7/3/2016 09:43	7/18/2016 16:08	10354587565	Lead	98	15	ppb
026 284A Hallway Drinking Fountain	7/3/2016 09:45	7/18/2016 16:10	10354587567	Copper	0.2	1.3	ppm
026 284A Hallway Drinking Fountain	7/3/2016 09:45	7/18/2016 16:10	10354587567	Lead	10	15	ppb
026 285A Hallway Drinking Fountain Bottle Refill	7/3/2016 09:45	7/18/2016 16:11	10354587569	Copper	0.2	1.3	ppm
026 285A Hallway Drinking Fountain Bottle Refill	7/3/2016 09:45	7/18/2016 16:11	10354587569	Lead	6	15	ppb
026 286A Boys Restroom Sink Faucet #1	7/3/2016 09:49	7/18/2016 16:15	10354587571	Copper	0.1	1.3	ppm
026 286A Boys Restroom Sink Faucet #1	7/3/2016 09:49	7/18/2016 16:15	10354587571	Lead	8	15	ppb
026 287A Boys Restroom Sink Faucet #2	7/3/2016 09:49	7/18/2016 16:17	10354587573	Copper	0.1	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Cleveland High School

026 287A Boys Restroom Sink Faucet #2	7/3/2016 09:49	7/18/2016 16:17	10354587573	Lead	19	15	ppb
026 288A Boys Restroom Water Spigot	7/3/2016 09:51	7/18/2016 14:34	10354587575	Copper	0.1	1.3	ppm
026 288A Boys Restroom Water Spigot	7/3/2016 09:51	7/18/2016 14:34	10354587575	Lead	25	15	ppb
026 289A Janitor's Closet Sink Faucet	7/3/2016 09:53	7/19/2016 16:17	10354587577	Copper	0.1	1.3	ppm
026 289A Janitor's Closet Sink Faucet	7/3/2016 09:53	7/19/2016 16:17	10354587577	Lead	117	15	ppb
026 290A Girls Restroom Sink Faucet #1	7/3/2016 09:53	7/18/2016 16:18	10354587579	Copper	0.0	1.3	ppm
026 290A Girls Restroom Sink Faucet #1	7/3/2016 09:53	7/18/2016 16:18	10354587579	Lead	10	15	ppb
026 291A Girls Restroom Sink Faucet #2	7/3/2016 09:53	7/18/2016 16:19	10354587581	Copper	0.1	1.3	ppm
026 291A Girls Restroom Sink Faucet #2	7/3/2016 09:53	7/18/2016 16:19	10354587581	Lead	21	15	ppb
026 292A Girls Restroom Water Spigot	7/3/2016 09:55	7/19/2016 16:23	10354587583	Copper	0.1	1.3	ppm
026 292A Girls Restroom Water Spigot	7/3/2016 09:55	7/19/2016 16:23	10354587583	Lead	44	15	ppb
026 293A Room 381 Sink Faucet	7/3/2016 09:59	7/18/2016 16:22	10354587585	Copper	0.0	1.3	ppm
026 293A Room 381 Sink Faucet	7/3/2016 09:59	7/18/2016 16:22	10354587585	Lead	10	15	ppb
026 294A Room 383 Sink Faucet	7/3/2016 10:00	7/18/2016 16:24	10354587587	Copper	0.0	1.3	ppm
026 294A Room 383 Sink Faucet	7/3/2016 10:00	7/18/2016 16:24	10354587587	Lead	13	15	ppb
026 295A Room 385 Sink Faucet	7/3/2016 10:02	7/18/2016 16:25	10354587589	Copper	0.0	1.3	ppm
026 295A Room 385 Sink Faucet	7/3/2016 10:02	7/18/2016 16:25	10354587589	Lead	10	15	ppb
026 296A Room 386 Sink Faucet #1	7/3/2016 10:16	7/18/2016 16:26	10354587591	Copper	0.0	1.3	ppm
026 296A Room 386 Sink Faucet #1	7/3/2016 10:16	7/18/2016 16:26	10354587591	Lead	14	15	ppb
026 297A Room 386 Sink Faucet #2	7/3/2016 10:16	7/18/2016 16:28	10354587593	Copper	0.0	1.3	ppm
026 297A Room 386 Sink Faucet #2	7/3/2016 10:16	7/18/2016 16:28	10354587593	Lead	28	15	ppb
026 298A Room 287 Sink Faucet #1	7/3/2016 10:16	7/18/2016 16:39	10354587595	Copper	0.0	1.3	ppm
026 298A Room 287 Sink Faucet #1	7/3/2016 10:16	7/18/2016 16:39	10354587595	Lead	17	15	ppb
026 299A Room 287 Sink Faucet #2	7/3/2016 10:18	7/19/2016 16:24	10354587597	Copper	0.0	1.3	ppm
026 299A Room 287 Sink Faucet #2	7/3/2016 10:18	7/19/2016 16:24	10354587597	Lead	78	15	ppb
026 300A Room 285 Sink Faucet #1	7/3/2016 10:19	7/18/2016 16:40	10354587599	Copper	0.0	1.3	ppm
026 300A Room 285 Sink Faucet #1	7/3/2016 10:19	7/18/2016 16:40	10354587599	Lead	50	15	ppb
026 301A Room 285 Sink Faucet #2	7/3/2016 10:19	7/19/2016 16:08	10354587601	Copper	0.1	1.3	ppm
026 301A Room 285 Sink Faucet #2	7/3/2016 10:19	7/19/2016 16:08	10354587601	Lead	52	15	ppb
026 302A Room 285 Sink Faucet #3	7/3/2016 10:20	7/19/2016 16:10	10354587603	Copper	0.1	1.3	ppm
026 302A Room 285 Sink Faucet #3	7/3/2016 10:20	7/19/2016 16:10	10354587603	Lead	69	15	ppb
026 303A Room 283 Sink Faucet	7/3/2016 10:22	7/19/2016 14:54	10354587605	Copper	0.1	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Cleveland High School

026 303A Room 283 Sink Faucet	7/3/2016 10:22	7/19/2016 14:54	10354587605	Lead	14	15	ppb
026 304A Room 281 Sink Faucet Right to Left #1	7/3/2016 10:24	7/19/2016 16:04	10354587607	Copper	0.2	1.3	ppm
026 304A Room 281 Sink Faucet Right to Left #1	7/3/2016 10:24	7/19/2016 16:04	10354587607	Lead	51	15	ppb
026 305A Room 281 Sink Faucet Right to Left #2	7/3/2016 10:24	7/19/2016 16:06	10354587609	Copper	0.1	1.3	ppm
026 305A Room 281 Sink Faucet Right to Left #2	7/3/2016 10:24	7/19/2016 16:06	10354587609	Lead	23	15	ppb
026 306A Room 281 Sink Faucet Right to Left #3	7/3/2016 10:24	7/19/2016 14:59	10354587611	Copper	0.0	1.3	ppm
026 306A Room 281 Sink Faucet Right to Left #3	7/3/2016 10:24	7/19/2016 14:59	10354587611	Lead	34	15	ppb
026 307A Room 281 Sink Faucet Right to Left #4	7/3/2016 10:26	7/19/2016 15:01	10354587613	Copper	0.0	1.3	ppm
026 307A Room 281 Sink Faucet Right to Left #4	7/3/2016 10:26	7/19/2016 15:01	10354587613	Lead	20	15	ppb
026 308A Room 281 Sink Faucet Right to Left #5	7/3/2016 10:26	7/19/2016 15:02	10354587615	Copper	0.0	1.3	ppm
026 308A Room 281 Sink Faucet Right to Left #5	7/3/2016 10:26	7/19/2016 15:02	10354587615	Lead	18	15	ppb
026 309A Room 281 Sink Faucet Right to Left #6	7/3/2016 10:26	7/19/2016 15:03	10354587617	Copper	0.0	1.3	ppm
026 309A Room 281 Sink Faucet Right to Left #6	7/3/2016 10:26	7/19/2016 15:03	10354587617	Lead	7	15	ppb
026 310A C Sink Faucet	7/3/2016 10:28	7/19/2016 15:08	10354587619	Copper	0.0	1.3	ppm
026 310A C Sink Faucet	7/3/2016 10:28	7/19/2016 15:08	10354587619	Lead	4	15	ppb
026 311A Hallway Drinking Fountain	7/3/2016 10:29	7/19/2016 15:09	10354587621	Copper	0.0	1.3	ppm
026 311A Hallway Drinking Fountain	7/3/2016 10:29	7/19/2016 15:09	10354587621	Lead	3	15	ppb
026 312A Girls Restroom Sink Faucet	7/3/2016 10:31	7/19/2016 15:10	10354587623	Copper	0.1	1.3	ppm
026 312A Girls Restroom Sink Faucet	7/3/2016 10:31	7/19/2016 15:10	10354587623	Lead	9	15	ppb
026 313A Boys Restroom Sink Faucet #1	7/3/2016 10:33	7/19/2016 15:12	10354587625	Copper	0.1	1.3	ppm
026 313A Boys Restroom Sink Faucet #1	7/3/2016 10:33	7/19/2016 15:12	10354587625	Lead	8	15	ppb
026 314A Boys Restroom Sink Faucet #2	7/3/2016 10:33	7/19/2016 15:13	10354587627	Copper	0.0	1.3	ppm
026 314A Boys Restroom Sink Faucet #2	7/3/2016 10:33	7/19/2016 15:13	10354587627	Lead	16	15	ppb
026 315A Boys Restroom Sink Faucet #3	7/3/2016 10:35	7/19/2016 15:14	10354587629	Copper	0.1	1.3	ppm
026 315A Boys Restroom Sink Faucet #3	7/3/2016 10:35	7/19/2016 15:14	10354587629	Lead	8	15	ppb
026 316A Boys Restroom Water Spigot	7/3/2016 10:36	7/19/2016 15:17	10354587631	Copper	0.1	1.3	ppm
026 316A Boys Restroom Water Spigot	7/3/2016 10:36	7/19/2016 15:17	10354587631	Lead	22	15	ppb
026 317A Room P6 Sink Faucet	7/3/2016 10:40	7/19/2016 15:19	10354587633	Copper	0.3	1.3	ppm
026 317A Room P6 Sink Faucet	7/3/2016 10:40	7/19/2016 15:19	10354587633	Lead	4	15	ppb
026 318A Outside Water Spigot #1	7/3/2016 10:45	7/19/2016 15:20	10354587635	Copper	0.0	1.3	ppm
026 318A Outside Water Spigot #1	7/3/2016 10:45	7/19/2016 15:20	10354587635	Lead	17	15	ppb
026 319A Outside Water Spigot #2	7/3/2016 10:49	7/19/2016 15:27	10354587637	Copper	0.0	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Cleveland High School

026 319A Outside Water Spigot #2	7/3/2016 10:49	7/19/2016 15:27	10354587637	Lead	12	15	ppb
026 320A Outside Water Spigot #3	7/3/2016 10:54	7/19/2016 15:28	10354587639	Copper	0.1	1.3	ppm
026 320A Outside Water Spigot #3	7/3/2016 10:54	7/19/2016 15:28	10354587639	Lead	62	15	ppb
026 321A Outside Water Spigot #4	7/3/2016 10:56	7/13/2016 01:27	10354587641	Copper	0.0	1.3	ppm
026 321A Outside Water Spigot #4	7/3/2016 10:56	7/13/2016 01:27	10354587641	Lead	11	15	ppb
026 322A Hall Drinking Fountain next to Room 380	7/3/2016 09:56	7/19/2016 16:07	10354587643	Copper	0.2	1.3	ppm
026 322A Hall Drinking Fountain next to Room 380	7/3/2016 09:56	7/19/2016 16:07	10354587643	Lead	10	15	ppb
026 323A Custodial Closet 341	7/3/2016 10:05	7/13/2016 01:35	10354587645	Copper	0.0	1.3	ppm
026 323A Custodial Closet 341	7/3/2016 10:05	7/13/2016 01:35	10354587645	Lead	1	15	ppb
026-324A Men's Bathroom Left Sink Faucet	8/20/2016	9/1/2016 11:54	10360188001	Copper	0.3	1.3	ppm
026-324A Men's Bathroom Left Sink Faucet	8/20/2016	9/1/2016 11:09	10360188001	Lead	6	15	ppb
026-325A Mens Bathroom Center Sink Faucet	8/20/2016	9/1/2016 11:57	10360188003	Copper	0.3	1.3	ppm
026-325A Mens Bathroom Center Sink Faucet	8/20/2016	9/1/2016 11:15	10360188003	Lead	8	15	ppb
026-326A Men's Bathroom Right Sink Faucet	8/20/2016	9/1/2016 11:59	10360188005	Copper	0.3	1.3	ppm
026-326A Men's Bathroom Right Sink Faucet	8/20/2016	9/1/2016 11:17	10360188005	Lead	9	15	ppb
026-327A Concession Stand Sink Faucet	8/20/2016	9/1/2016 12:00	10360188007	Copper	0.3	1.3	ppm
026-327A Concession Stand Sink Faucet	8/20/2016	9/1/2016 11:18	10360188007	Lead	37	15	ppb
026-328A Women's Bathroom Left Sink Faucet	8/20/2016	9/1/2016 12:38	10360188009	Copper	0.3	1.3	ppm
026-328A Women's Bathroom Left Sink Faucet	8/20/2016	9/1/2016 11:20	10360188009	Lead	8	15	ppb
026-329A Women's Bathroom Center Sink Faucet	8/20/2016	9/1/2016 12:57	10360188011	Copper	0.4	1.3	ppm
026-329A Women's Bathroom Center Sink Faucet	8/20/2016	9/1/2016 11:26	10360188011	Lead	6	15	ppb
026-330A Women's Bathroom Right Sink Faucet	8/20/2016	9/1/2016 13:02	10360188013	Copper	0.3	1.3	ppm
026-330A Womens Right Sink Faucet	8/20/2016	9/1/2016 11:28	10360188013	Lead	15	15	ppb
026-331A Outside Concession Stand South Spigot	8/20/2016	9/1/2016 13:03	10360188015	Copper	0.2	1.3	ppm
026-331A Outside Concession Stand South Spigot	8/20/2016	9/1/2016 11:29	10360188015	Lead	3	15	ppb
026-332A Outside Concession Stand North Spigot	8/20/2016	9/1/2016 13:05	10360188017	Copper	0.6	1.3	ppm
026-332A Outside Concession Stand North Spigot	8/20/2016	9/1/2016 11:31	10360188017	Lead	12	15	ppb
026-333A Fieldhouse Locker Room Drinking	8/20/2016	9/1/2016 11:32	10360188019	Copper	0.0	1.3	ppm
026-333A Fieldhouse Locker Room Drinking	8/20/2016	9/1/2016 11:32	10360188019	Lead	8	15	ppb
026-334A Fieldhouse Men's Restroom Left Sink	8/20/2016	9/1/2016 11:34	10360188021	Copper	0.0	1.3	ppm
026-334A Fieldhouse Men's Restroom Left Sink	8/20/2016	9/1/2016 11:34	10360188021	Lead	7	15	ppb
026-335A Fieldhouse Men's Restroom Right Sink	8/20/2016	9/1/2016 11:37	10360188023	Copper	0.1	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Cleveland High School

026-335A Fieldhouse Men's Restroom Right Sink	8/20/2016	9/1/2016 11:37	10360188023	Lead	5	15	ppb
026-336A Fieldhouse Men's Restroom Spigot	8/20/2016	9/1/2016 11:39	10360188025	Copper	0.0	1.3	ppm
026-336A Fieldhouse Men's Restroom Spigot	8/20/2016	9/1/2016 11:39	10360188025	Lead	2	15	ppb
026-337A Fieldhouse Left Drinking Fountain	8/20/2016	9/1/2016 11:40	10360188027	Copper	0.0	1.3	ppm
026-337A Fieldhouse Left Drinking Fountain	8/20/2016	9/1/2016 11:40	10360188027	Lead	3	15	ppb
026-338A Fieldhouse Right Drinking Fountain	8/20/2016	9/1/2016 11:46	10360188029	Copper	0.0	1.3	ppm
026-338A Fieldhouse Right Drinking Fountain	8/20/2016	9/1/2016 11:46	10360188029	Lead	4	15	ppb
026-339A Fieldhouse Team Room Spigot	8/20/2016	9/1/2016 12:46	10360188031	Copper	0.2	1.3	ppm
026-339A Fieldhouse Team Room Spigot	8/20/2016	9/1/2016 12:46	10360188031	Lead	64	15	ppb
026-340A Custodial Room Utility Sink Faucet	8/20/2016	9/1/2016 11:48	10360188033	Copper	0.1	1.3	ppm
026-340A Custodial Room Utility Sink Faucet	8/20/2016	9/1/2016 11:48	10360188033	Lead	4	15	ppb
026-341A Fieldhouse East Side Exterior Drinking	8/20/2016	9/1/2016 11:49	10360188035	Copper	0.0	1.3	ppm
026-341A Fieldhouse East Side Exterior Drinking	8/20/2016	9/1/2016 11:49	10360188035	Lead	25	15	ppb
026-342A Team Room SE Corner Left Sink Faucet	8/20/2016	9/1/2016 11:51	10360188037	Copper	0.0	1.3	ppm
026-342A Team Room SE Corner Left Sink Faucet	8/20/2016	9/1/2016 11:51	10360188037	Lead	6	15	ppb
026-343A Team Room SE Corner Right Sink Faucet	8/20/2016	9/1/2016 11:53	10360188039	Copper	0.1	1.3	ppm
026-343A Team Room SE Corner Right Sink Faucet	8/20/2016	9/1/2016 11:53	10360188039	Lead	16	15	ppb
026-344A Team Room SE Corner Left Spigot	8/20/2016	9/1/2016 12:08	10360188041	Copper	0.0	1.3	ppm
026-344A Team Room SE Corner Left Spigot	8/20/2016	9/1/2016 12:08	10360188041	Lead	2	15	ppb
026-345A Team Room SE Corner Right Spigot	8/20/2016	9/1/2016 12:52	10360188043	Copper	0.1	1.3	ppm
026-345A Team Room SE Corner Right Spigot	8/20/2016	9/1/2016 12:52	10360188043	Lead	35	15	ppb
026-346A Fieldhouse Concession Sink Faucet	8/20/2016	9/1/2016 12:14	10360188045	Copper	0.1	1.3	ppm
026-346A Fieldhouse Concession Sink Faucet	8/20/2016	9/1/2016 12:14	10360188045	Lead	18	15	ppb
026-347A Fieldhouse Locker Room Spigot Upper	8/20/2016	9/1/2016 12:54	10360188047	Copper	0.2	1.3	ppm
026-347A Fieldhouse Locker Room Spigot Upper	8/20/2016	9/1/2016 12:54	10360188047	Lead	124	15	ppb
026-348A Fieldhouse Locker Room Spigot Lower	8/20/2016	9/1/2016 12:56	10360188049	Copper	0.1	1.3	ppm
026-348A Fieldhouse Locker Room Spigot Lower	8/20/2016	9/1/2016 13:12	10360188049	Lead	464	15	ppb
026-349A Concession Stand Ice Maker	8/20/2016	9/1/2016 12:15	10360188051	Copper	0.1	1.3	ppm
026-349A Concession Stand Ice Maker	8/20/2016	9/1/2016 12:15	10360188051	Lead	1	15	ppb
EPA Action Level for Lead of 15 ppb							
EPA Action Level for Copper of 1.3 ppm							
Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.							