

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Columbia Site

| Sample Identification # and Location | Date/Time Collected                             | Date/Time Analyzed   | Container ID          | Analyte | Results | EPA    |         |
|--------------------------------------|-------------------------------------------------|----------------------|-----------------------|---------|---------|--------|---------|
|                                      |                                                 |                      |                       |         |         | Action | Units   |
|                                      |                                                 |                      |                       |         |         | Level  |         |
| 027-01A                              | Custodial #3 Sink Faucet                        | 6/19/2016 2:30:00 AM | 6/24/2016 10:21:00 AM | BB65688 | Copper  | 0.0    | 15 PPM  |
| 027-01A                              | Custodial #3 Sink Faucet                        | 6/19/2016 2:30:00 AM | 6/24/2016 10:21:00 AM | BB65688 | Lead    | 12     | 15 PPB  |
| 027-02A                              | Drinking Fountain Btwn Custodial 3 & BB (left)  | 6/19/2016 2:33:00 AM | 6/24/2016 10:24:00 AM | BB65689 | Copper  | 0.0    | 1.3 PPM |
| 027-02A                              | Drinking Fountain Btwn Custodial 3 & BB (left)  | 6/19/2016 2:33:00 AM | 6/24/2016 10:24:00 AM | BB65689 | Lead    | 4      | 1.3 PPB |
| 027-03A                              | Drinking Fountain Btwn Custodial 3 & BB (right) | 6/19/2016 2:36:00 AM | 6/24/2016 10:27:00 AM | BB65690 | Copper  | 0.0    | 1.3 PPM |
| 027-03A                              | Drinking Fountain Btwn Custodial 3 & BB (right) | 6/19/2016 2:36:00 AM | 6/24/2016 10:27:00 AM | BB65690 | Lead    | 4      | 1.3 PPB |
| 027-04A                              | Kitchen White Handwash Sink Faucet              | 6/19/2016 2:39:00 AM | 6/24/2016 10:30:00 AM | BB65691 | Copper  | 0.2    | 1.3 PPM |
| 027-04A                              | Kitchen White Handwash Sink Faucet              | 6/19/2016 2:39:00 AM | 6/24/2016 10:30:00 AM | BB65691 | Lead    | 11     | 15 PPB  |
| 027-05A                              | Kitchen Dishwash Sink Faucet                    | 6/19/2016 2:41:00 AM | 6/24/2016 10:33:00 AM | BB65692 | Copper  | 0.1    | 1.3 PPM |
| 027-05A                              | Kitchen Dishwash Sink Faucet                    | 6/19/2016 2:41:00 AM | 6/24/2016 10:33:00 AM | BB65692 | Lead    | 5      | 15 PPB  |
| 027-06A                              | Custodial #7 Sink Faucet                        | 6/19/2016 2:44:00 AM | 6/24/2016 10:36:00 AM | BB65693 | Copper  | 0.0    | 15 PPM  |
| 027-06A                              | Custodial #7 Sink Faucet                        | 6/19/2016 2:44:00 AM | 6/24/2016 10:36:00 AM | BB65693 | Lead    | 6      | 15 PPB  |
| 027-07A                              | Kitchen Restroom Sink Faucet                    | 6/19/2016 2:47:00 AM | 6/24/2016 10:39:00 AM | BB65694 | Copper  | 0.0    | 1.3 PPM |
| 027-07A                              | Kitchen Restroom Sink Faucet                    | 6/19/2016 2:47:00 AM | 6/24/2016 10:39:00 AM | BB65694 | Lead    | 3      | 1.3 PPB |
| 027-08A                              | Art Room/Classroom 2 Sink Faucet                | 6/19/2016 2:50:00 AM | 6/24/2016 10:42:00 AM | BB65695 | Copper  | 0.4    | 15 PPM  |
| 027-08A                              | Art Room/Classroom 2 Sink Faucet                | 6/19/2016 2:50:00 AM | 6/24/2016 10:42:00 AM | BB65695 | Lead    | 10     | 1.3 PPB |
| 027-09A                              | Room 3 1/2 (Secret Room) Sink Faucet            | 6/19/2016 2:53:00 AM | 6/24/2016 11:03:00 AM | BB65696 | Copper  | 0.1    | 1.3 PPM |
| 027-09A                              | Room 3 1/2 (Secret Room) Sink Faucet            | 6/19/2016 2:53:00 AM | 6/24/2016 11:03:00 AM | BB65696 | Lead    | 14.5   | 15 PPB  |
| 027-10A                              | Room 3 1/2 Sink Faucet                          | 6/19/2016 2:55:00 AM | 6/24/2016 11:06:00 AM | BB65697 | Copper  | 0.1    | 15 PPM  |
| 027-10A                              | Room 3 1/2 Sink Faucet                          | 6/19/2016 2:55:00 AM | 6/24/2016 11:06:00 AM | BB65697 | Lead    | 13     | 1.3 PPB |
| 027-11A                              | MDF 1 Workroom/Lounge Bath Sink Faucet          | 6/19/2016 2:58:00 AM | 6/24/2016 11:09:00 AM | BB65698 | Copper  | 0.1    | 15 PPM  |
| 027-11A                              | MDF 1 Workroom/Lounge Bath Sink Faucet          | 6/19/2016 2:58:00 AM | 6/24/2016 11:09:00 AM | BB65698 | Lead    | 5      | 1.3 PPB |
| 027-12A                              | Classroom 5 Sink Faucet                         | 6/19/2016 3:02:00 AM | 6/24/2016 11:12:00 AM | BB65699 | Copper  | 0.0    | 15 PPM  |
| 027-12A                              | Classroom 5 Sink Faucet                         | 6/19/2016 3:02:00 AM | 6/24/2016 11:12:00 AM | BB65699 | Lead    | 3      | 15 PPB  |
| 027-13A                              | Office Sink Faucet                              | 6/19/2016 3:05:00 AM | 6/24/2016 11:15:00 AM | BB65700 | Copper  | 0.0    | 15 PPM  |
| 027-13A                              | Office Sink Faucet                              | 6/19/2016 3:05:00 AM | 6/24/2016 11:15:00 AM | BB65700 | Lead    | 8      | 1.3 PPB |
| 027-14A                              | Room 9 (Staff Room) Sink Faucet                 | 6/19/2016 3:08:00 AM | 6/24/2016 11:18:00 AM | BB65701 | Copper  | 0.1    | 1.3 PPM |
| 027-14A                              | Room 9 (Staff Room) Sink Faucet                 | 6/19/2016 3:08:00 AM | 6/24/2016 11:18:00 AM | BB65701 | Lead    | 8      | 15 PPB  |
| 027-15A                              | Room 10 Sink Faucet                             | 6/19/2016 3:11:00 AM | 6/24/2016 11:22:00 AM | BB65702 | Copper  | 0.0    | 1.3 PPM |
| 027-15A                              | Room 10 Sink Faucet                             | 6/19/2016 3:11:00 AM | 6/24/2016 11:22:00 AM | BB65702 | Lead    | 6      | 15 PPB  |
| 027-16A                              | Drinking Fountain Btwn 9 & 11                   | 6/19/2016 3:14:00 AM | 6/24/2016 11:24:00 AM | BB65703 | Copper  | 0.1    | 15 PPM  |
| 027-16A                              | Drinking Fountain Btwn 9 & 11                   | 6/19/2016 3:14:00 AM | 6/24/2016 11:24:00 AM | BB65703 | Lead    | 4      | 1.3 PPB |
| 027-17A                              | Room 11 Sink Faucet                             | 6/19/2016 3:16:00 AM | 6/24/2016 11:28:00 AM | BB65704 | Copper  | 0.1    | 1.3 PPM |
| 027-17A                              | Room 11 Sink Faucet                             | 6/19/2016 3:16:00 AM | 6/24/2016 11:28:00 AM | BB65704 | Lead    | 3      | 15 PPB  |
| 027-18A                              | Training/Safety Center Bathroom Sink Faucet 1   | 6/19/2016 3:20:00 AM | 6/24/2016 11:31:00 AM | BB65705 | Copper  | 0.0    | 15 PPM  |
| 027-18A                              | Training/Safety Center Bathroom Sink Faucet 1   | 6/19/2016 3:20:00 AM | 6/24/2016 11:31:00 AM | BB65705 | Lead    | 4      | 15 PPB  |
| 027-19A                              | Training/Safety Center Bathroom Spigot (left)   | 6/19/2016 3:23:00 AM | 6/24/2016 11:46:00 AM | BB65706 | Copper  | 0.0    | 15 PPM  |
| 027-19A                              | Training/Safety Center Bathroom Spigot (left)   | 6/19/2016 3:23:00 AM | 6/24/2016 11:46:00 AM | BB65706 | Lead    | 32     | 1.3 PPB |
| 027-20A                              | Training/Safety Center Bathroom Spigot (right)  | 6/19/2016 3:25:00 AM | 6/24/2016 11:49:00 AM | BB65707 | Copper  | 0.0    | 15 PPM  |
| 027-20A                              | Training/Safety Center Bathroom Spigot (right)  | 6/19/2016 3:25:00 AM | 6/24/2016 11:49:00 AM | BB65707 | Lead    | 2      | 15 PPB  |
| 027-21A                              | Training/Safety Center Bathroom Sink Faucet 2   | 6/19/2016 3:27:00 AM | 6/24/2016 11:52:00 AM | BB65708 | Copper  | 0.0    | 1.3 PPM |
| 027-21A                              | Training/Safety Center Bathroom Sink Faucet 2   | 6/19/2016 3:27:00 AM | 6/24/2016 11:52:00 AM | BB65708 | Lead    | 7      | 1.3 PPB |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Columbia Site

| Sample Identification # and Location |                                               | Date/Time Collected  | Date/Time Analyzed    | Container ID | Analyte | Results | EPA    |       |
|--------------------------------------|-----------------------------------------------|----------------------|-----------------------|--------------|---------|---------|--------|-------|
|                                      |                                               |                      |                       |              |         |         | Action | Units |
|                                      |                                               |                      |                       |              |         |         | Level  |       |
| 027-22A                              | Drinking Fountain next to Girls Bathroom 36   | 6/19/2016 3:30:00 AM | 6/24/2016 11:55:00 AM | BB65709      | Copper  | 0.0     | 15     | PPM   |
| 027-22A                              | Drinking Fountain next to Girls Bathroom 36   | 6/19/2016 3:30:00 AM | 6/24/2016 11:55:00 AM | BB65709      | Lead    | 12      | 15     | PPB   |
| 027-23A                              | 36 Girls Bathroom Sink Faucet                 | 6/19/2016 3:33:00 AM | 6/24/2016 11:58:00 AM | BB65710      | Copper  | 0.0     | 15     | PPM   |
| 027-23A                              | 36 Girls Bathroom Sink Faucet                 | 6/19/2016 3:33:00 AM | 6/24/2016 11:58:00 AM | BB65710      | Lead    | 13      | 15     | PPB   |
| 027-24A                              | Custodial Sink Faucet Btwn 36/37              | 6/19/2016 3:36:00 AM | 6/24/2016 12:01:00 PM | BB65711      | Copper  | 0.0     | 1.3    | PPM   |
| 027-24A                              | Custodial Sink Faucet Btwn 36/37              | 6/19/2016 3:36:00 AM | 6/24/2016 12:01:00 PM | BB65711      | Lead    | 1       | 15     | PPB   |
| 027-25A                              | 37 Boys Bathroom Sink Faucet                  | 6/19/2016 3:39:00 AM | 7/3/2016 6:37:00 PM   | BB65712      | Copper  | 1.7     | 1.3    | PPM   |
| 027-25A                              | 37 Boys Bathroom Sink Faucet                  | 6/19/2016 3:39:00 AM | 7/3/2016 6:37:00 PM   | BB65712      | Lead    | 11      | 1.3    | PPB   |
| 027-26A                              | Kitchen Storage Room Sink Faucet (downstairs) | 6/19/2016 3:43:00 AM | 7/3/2016 6:41:00 PM   | BB65713      | Copper  | 0.0     | 1.3    | PPM   |
| 027-26A                              | Kitchen Storage Room Sink Faucet (downstairs) | 6/19/2016 3:43:00 AM | 7/3/2016 6:41:00 PM   | BB65713      | Lead    | 10      | 15     | PPB   |
| 027-28A                              | Kitchen Sink Faucet (right)                   | 6/19/2016 3:47:00 AM | 6/24/2016 12:07:00 PM | BB65715      | Copper  | 0.0     | 1.3    | PPM   |
| 027-28A                              | Kitchen Sink Faucet (right)                   | 6/19/2016 3:47:00 AM | 6/24/2016 12:07:00 PM | BB65715      | Lead    | 6       | 1.3    | PPB   |
| 027-29A                              | Room 16 Sink Faucet                           | 6/19/2016 3:50:00 AM | 7/3/2016 6:44:00 PM   | BB65716      | Copper  | 0.2     | 15     | PPM   |
| 027-29A                              | Room 16 Sink Faucet                           | 6/19/2016 3:50:00 AM | 7/3/2016 6:44:00 PM   | BB65716      | Lead    | 20      | 1.3    | PPB   |
| 027-30A                              | Gymnasium Drinking Fountain (left)            | 6/19/2016 3:54:00 AM | 6/24/2016 12:10:00 PM | BB65717      | Copper  | 0.0     | 15     | PPM   |
| 027-30A                              | Gymnasium Drinking Fountain (left)            | 6/19/2016 3:54:00 AM | 6/24/2016 12:10:00 PM | BB65717      | Lead    | 4       | 15     | PPB   |
| 027-31A                              | Gymnasium Drinking Fountain (right)           | 6/19/2016 3:56:00 AM | 6/24/2016 12:13:00 PM | BB65718      | Copper  | 0.0     | 1.3    | PPM   |
| 027-31A                              | Gymnasium Drinking Fountain (right)           | 6/19/2016 3:56:00 AM | 6/24/2016 12:13:00 PM | BB65718      | Lead    | 0       | 1.3    | PPB   |
| 027-32A                              | Garage Womens Bathroom Sink Faucet            | 6/19/2016 4:00:00 AM | 6/24/2016 12:35:00 PM | BB65719      | Copper  | 0.6     | 15     | PPM   |
| 027-32A                              | Garage Womens Bathroom Sink Faucet            | 6/19/2016 4:00:00 AM | 6/24/2016 12:35:00 PM | BB65719      | Lead    | 2       | 1.3    | PPB   |
| 027-33A                              | Garage Mens Bathroom Sink Faucet              | 6/19/2016 4:04:00 AM | 7/3/2016 7:06:00 PM   | BB65720      | Copper  | 2       | 15     | PPM   |
| 027-33A                              | Garage Mens Bathroom Sink Faucet              | 6/19/2016 4:04:00 AM | 7/3/2016 6:48:00 PM   | BB65720      | Lead    | 12      | 1.3    | PPB   |
| 027-34A                              | Garage Shop Sink Faucet                       | 6/19/2016 4:06:00 AM | 6/24/2016 12:37:00 PM | BB65721      | Copper  | 0.3     | 1.3    | PPM   |
| 027-34A                              | Garage Shop Sink Faucet                       | 6/19/2016 4:06:00 AM | 6/24/2016 12:37:00 PM | BB65721      | Lead    | 1       | 1.3    | PPB   |
| 027-35A                              | Water Spigot outside Operations               | 6/19/2016 4:13:00 AM | 6/24/2016 12:41:00 PM | BB65722      | Copper  | 0.1     | 15     | PPM   |
| 027-35A                              | Water Spigot outside Operations               | 6/19/2016 4:13:00 AM | 6/24/2016 12:41:00 PM | BB65722      | Lead    | 12      | 1.3    | PPB   |
| 027-36A                              | Exterior Water Spigot oustide Gymnasium       | 6/19/2016 4:16:00 AM | 6/24/2016 12:44:00 PM | BB65723      | Copper  | 0.4     | 1.3    | PPM   |
| 027-36A                              | Exterior Water Spigot oustide Gymnasium       | 6/19/2016 4:16:00 AM | 6/24/2016 12:44:00 PM | BB65723      | Lead    | 20      | 15     | PPB   |
| 027-37A                              | Exterior Water Spigot near Front Door         | 6/19/2016 4:19:00 AM | 6/24/2016 12:47:00 PM | BB65724      | Copper  | 0.0     | 15     | PPM   |
| 027-37A                              | Exterior Water Spigot near Front Door         | 6/19/2016 4:19:00 AM | 6/24/2016 12:47:00 PM | BB65724      | Lead    | 24      | 1.3    | PPB   |
| 027-38A                              | Exterior Water Spigot off Art Room            | 6/19/2016 4:22:00 AM | 6/24/2016 12:50:00 PM | BB65725      | Copper  | 0.0     | 1.3    | PPM   |
| 027-38A                              | Exterior Water Spigot off Art Room            | 6/19/2016 4:22:00 AM | 6/24/2016 12:50:00 PM | BB65725      | Lead    | 24      | 15     | PPB   |
| 027-39A                              | Exterior Water Spigot off Room 16 area        | 6/19/2016 4:28:00 AM | 6/24/2016 12:53:00 PM | BB65726      | Copper  | 0.1     | 15     | PPM   |
| 027-39A                              | Exterior Water Spigot off Room 16 area        | 6/19/2016 4:28:00 AM | 6/24/2016 12:53:00 PM | BB65726      | Lead    | 57      | 15     | PPB   |
| 027-40A                              | Room 116 Drinking Fountain                    | 6/19/2016 4:32:00 AM | 6/24/2016 12:04:00 PM | BB65714      | Copper  | 0.0     | 1.3    | PPM   |
| 027-40A                              | Room 116 Drinking Fountain                    | 6/19/2016 4:32:00 AM | 6/24/2016 12:04:00 PM | BB65714      | Lead    | 1       | 15     | PPB   |

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.