

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Green Thumb School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA	
						Action Level	Units
041-01A Storage Main Water Spigot	6/22/16 10:58	7/4/2016	1606C59-01A	Copper	0.9	1.3	ppm
041-01A Storage Main Water Spigot	6/22/16 10:58	7/4/2016	1606C59-01A	Lead	83	15	ppb
041-02A Garage Water Spigot Door	6/22/16 10:55	7/4/2016	1606C59-02A	Copper	ND	1.3	ppm
041-02A Garage Water Spigot Door	6/22/16 10:55	7/4/2016	1606C59-02A	Lead	4	15	ppb
041-03A Drinking Fountain Between Bathrooms	6/22/16 11:00	7/4/2016	1606C59-03A	Copper	0.6	1.3	ppm
041-03A Drinking Fountain Between Bathrooms	6/22/16 11:00	7/4/2016	1606C59-03A	Lead	ND	15	ppb
041-04A Mens Sink Faucet	6/22/16 11:03	7/4/2016	1606C59-04A	Copper	ND	1.3	ppm
041-04A Mens Sink Faucet	6/22/16 11:03	7/4/2016	1606C59-04A	Lead	8	15	ppb
041-05A Womens Sink Faucet	6/22/16 11:05	7/4/2016	1606C59-05A	Copper	ND	1.3	ppm
041-05A Womens Sink Faucet	6/22/16 11:05	7/4/2016	1606C59-05A	Lead	16	15	ppb
041-06A Water Spigot	6/22/16 11:08	7/4/2016	1606C59-06A	Copper	ND	1.3	ppm
041-06A Water Spigot	6/22/16 11:08	7/4/2016	1606C59-06A	Lead	140	15	ppb
041-07A Modular B Sink Faucet	6/22/16 10:50	7/4/2016	1606C59-07A	Copper	0.1	1.3	ppm
041-07A Modular B Sink Faucet	6/22/16 10:50	7/4/2016	1606C59-07A	Lead	25	15	ppb
041-08A Classroom 3 Sink Faucet	6/22/16 10:53	7/4/2016	1606C59-08A	Copper	0.4	1.3	ppm
041-08A Classroom 3 Sink Faucet	6/22/16 10:53	7/4/2016	1606C59-08A	Lead	3	15	ppb
041-09A Unisex Bathroom Sink Faucet 1	6/22/16 10:47	7/4/2016	1606C59-09A	Copper	0.4	1.3	ppm
041-09A Unisex Bathroom Sink Faucet 1	6/22/16 10:47	7/4/2016	1606C59-09A	Lead	4	15	ppb
041-10A Unisex Bathroom Sink Faucet 2	6/22/16 10:49	7/4/2016	1606C59-10A	Copper	1.2	1.3	ppm
041-10A Unisex Bathroom Sink Faucet 2	6/22/16 10:49	7/4/2016	1606C59-10A	Lead	30	15	ppb
041-11A Drinking Fountain #2	6/22/16 10:51	7/4/2016	1606C59-11A	Copper	0.6	1.3	ppm
041-11A Drinking Fountain #2	6/22/16 10:51	7/4/2016	1606C59-11A	Lead	3	15	ppb
041-12A Unisex Bathroom Sink Faucet	6/22/16 10:53	7/4/2016	1606C59-12A	Copper	0.3	1.3	ppm
041-12A Unisex Bathroom Sink Faucet	6/22/16 10:53	7/4/2016	1606C59-12A	Lead	2	15	ppb
041-13A Unisex Bathroom Sink Faucet	6/22/16 10:55	7/4/2016	1606C59-13A	Copper	0.3	1.3	ppm
041-13A Unisex Bathroom Sink Faucet	6/22/16 10:55	7/4/2016	1606C59-13A	Lead	ND	15	ppb
041-14A Classroom 4 Sink Faucet	6/22/16 11:05	7/4/2016	1606C59-14A	Copper	0.4	1.3	ppm
041-14A Classroom 4 Sink Faucet	6/22/16 11:05	7/4/2016	1606C59-14A	Lead	9	15	ppb
041-15A Sink Faucet between Rooms 4 & 5	6/22/16 11:06	7/4/2016	1606C59-15A	Copper	0.2	1.3	ppm
041-15A Sink Faucet between Rooms 4 & 5	6/22/16 11:06	7/4/2016	1606C59-15A	Lead	12	15	ppb
041-16A Classroom 5 Sink Faucet	6/22/16 11:08	7/4/2016	1606C59-16A	Copper	0.3	1.3	ppm
041-16A Classroom 5 Sink Faucet	6/22/16 11:08	7/4/2016	1606C59-16A	Lead	10	15	ppb
041-17A Classroom 6 Sink Faucet	6/22/16 11:13	7/4/2016	1606C59-17A	Copper	0.2	1.3	ppm
041-17A Classroom 6 Sink Faucet	6/22/16 11:13	7/4/2016	1606C59-17A	Lead	ND	15	ppb
041-18A Classroom 6 Sink Faucet Bathroom	6/22/16 11:10	7/4/2016	1606C59-18A	Copper	0.2	1.3	ppm
041-18A Classroom 6 Sink Faucet Bathroom	6/22/16 11:10	7/4/2016	1606C59-18A	Lead	2	15	ppb
041-19A Classroom 7 Sink Faucet	6/22/16 11:14	7/4/2016	1606C59-19A	Copper	0.2	1.3	ppm
041-19A Classroom 7 Sink Faucet	6/22/16 11:14	7/4/2016	1606C59-19A	Lead	1	15	ppb
041-20A Classroom 7 Sink Faucet Bathroom	6/22/16 11:19	7/4/2016	1606C59-20A	Copper	0.3	1.3	ppm
041-20A Classroom 7 Sink Faucet Bathroom	6/22/16 11:19	7/4/2016	1606C59-20A	Lead	4	15	ppb
041-21A Caretaker Sink Faucet	6/22/16 10:44	7/4/2016	1606C59-21A	Copper	0.2	1.3	ppm
041-21A Caretaker Sink Faucet	6/22/16 10:44	7/4/2016	1606C59-21A	Lead	40	15	ppb
041-22A Caretaker Bathroom Sink Faucet	6/22/16 10:46	7/4/2016	1606C59-22A	Copper	ND	1.3	ppm
041-22A Caretaker Bathroom Sink Faucet	6/22/16 10:46	7/4/2016	1606C59-22A	Lead	1	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Green Thumb School

041-23A	Caretaker Water Spigot	6/22/16 10:39	7/4/2016	1606C59-23A	Copper	ND	1.3	ppm
041-23A	Caretaker Water Spigot	6/22/16 10:39	7/4/2016	1606C59-23A	Lead	ND	15	ppb
041-24A	Kitchen Sink Faucet Office	6/22/16 11:45	7/4/2016	1606C59-24A	Copper	0.3	1.3	ppm
041-24A	Kitchen Sink Faucet Office	6/22/16 11:45	7/4/2016	1606C59-24A	Lead	8	15	ppb
041-25A	Bathroom Sink Faucet Office	6/22/16 11:47	7/4/2016	1606C59-25A	Copper	0.2	1.3	ppm
041-25A	Bathroom Sink Faucet Office	6/22/16 11:47	7/4/2016	1606C59-25A	Lead	13	15	ppb
041-26A	Bathroom Shower Faucet	6/22/16 11:49	7/4/2016	1606C59-26A	Copper	0.6	1.3	ppm
041-26A	Bathroom Shower Faucet	6/22/16 11:49	7/4/2016	1606C59-26A	Lead	30	15	ppb
041-27A	Greenhouse 1 Sink Faucet	6/22/16 11:13	7/4/2016	1606C59-27A	Copper	ND	1.3	ppm
041-27A	Greenhouse 1 Sink Faucet	6/22/16 11:13	7/4/2016	1606C59-27A	Lead	2	15	ppb
041-28A	Greenhouse 1 Water Spigot	6/22/16 11:15	7/4/2016	1606C59-28A	Copper	ND	1.3	ppm
041-28A	Greenhouse 1 Water Spigot	6/22/16 11:15	7/4/2016	1606C59-28A	Lead	ND	15	ppb
041-29A	Greenhouse 1 Water Spigot	6/22/16 11:10	7/4/2016	1606C59-29A	Copper	ND	1.3	ppm
041-29A	Greenhouse 1 Water Spigot	6/22/16 11:10	7/4/2016	1606C59-29A	Lead	13	15	ppb
041-30A	Greenhouse 2 Sink Faucet	6/22/16 11:20	7/4/2016	1606C59-30A	Copper	ND	1.3	ppm
041-30A	Greenhouse 2 Sink Faucet	6/22/16 11:20	7/4/2016	1606C59-30A	Lead	3	15	ppb
041-31A	Greenhouse 2 Water Spigot	6/22/16 11:25	7/4/2016	1606C59-31A	Copper	ND	1.3	ppm
041-31A	Greenhouse 2 Water Spigot	6/22/16 11:25	7/4/2016	1606C59-31A	Lead	10	15	ppb
041-32A	Greenhouse 3 Water Spigot	6/22/16 11:49	7/4/2016	1606C59-32A	Copper	ND	1.3	ppm
041-32A	Greenhouse 3 Water Spigot	6/22/16 11:49	7/4/2016	1606C59-32A	Lead	17	15	ppb
041-33A	Greenhouse 3 Sink Faucet	6/22/16 11:52	7/4/2016	1606C59-33A	Copper	ND	1.3	ppm
041-33A	Greenhouse 3 Sink Faucet	6/22/16 11:52	7/4/2016	1606C59-33A	Lead	13	15	ppb
041-34A	Greenhouse 3 HW Station	6/22/16 11:56	7/4/2016	1606C59-34A	Copper	ND	1.3	ppm
041-34A	Greenhouse 3 HW Station	6/22/16 11:56	7/4/2016	1606C59-34A	Lead	8	15	ppb
041-35A	Greenhouse 3 Water Spigot	6/22/16 12:00	7/4/2016	1606C59-35A	Copper	ND	1.3	ppm
041-35A	Greenhouse 3 Water Spigot	6/22/16 12:00	7/4/2016	1606C59-35A	Lead	68	15	ppb
041-36A	Greenhouse 3 Water Spigot	6/22/16 12:10	7/3/2016	1606C59-36A	Copper	0.1	1.3	ppm
041-36A	Greenhouse 3 Water Spigot	6/22/16 12:10	7/3/2016	1606C59-36A	Lead	590	15	ppb
041-37A	Greenhouse 4 Water Spigot	6/22/16 12:04	7/5/2016	1606C59-37A	Copper	ND	1.3	ppm
041-37A	Greenhouse 4 Water Spigot	6/22/16 12:04	7/5/2016	1606C59-37A	Lead	110	15	ppb
041-38A	Greenhouse 4 Water Spigot	6/22/16 12:01	7/5/2016	1606C59-38A	Copper	ND	1.3	ppm
041-38A	Greenhouse 4 Water Spigot	6/22/16 12:01	7/5/2016	1606C59-38A	Lead	10	15	ppb
041-39A	Greenhouse 5 Water Spigot	6/22/16 12:12	7/5/2016	1606C59-39A	Copper	ND	1.3	ppm
041-39A	Greenhouse 5 Water Spigot	6/22/16 12:12	7/5/2016	1606C59-39A	Lead	5	15	ppb
041-40A	Greenhouse 5 Water Spigot	6/22/16 12:16	7/5/2016	1606C59-40A	Copper	ND	1.3	ppm
041-40A	Greenhouse 5 Water Spigot	6/22/16 12:16	7/5/2016	1606C59-40A	Lead	6	15	ppb
041-41A	Greenhouse 5 Water Spigot	6/22/16 12:20	7/5/2016	1606C59-41A	Copper	ND	1.3	ppm
041-41A	Greenhouse 5 Water Spigot	6/22/16 12:20	7/5/2016	1606C59-41A	Lead	6	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

ND = Non detect

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.