

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Creative Science School

| Sample Identification # and Location   | Date & Time Collected | Date & Time Analyzed | Container ID | Analyte | Results | EPA Action Limit | Units |
|----------------------------------------|-----------------------|----------------------|--------------|---------|---------|------------------|-------|
| 028-01A Custodial Office Bathroom Sink | 6/21/16 8:22          | 7/1/16 7:45          | 606221701    | Copper  | 0.1     | 1.3              | ppm   |
| 028-01A Custodial Office Bathroom Sink | 6/21/16 8:22          | 7/1/16 7:45          | 606221701    | Lead    | 27      | 15               | ppb   |
| 028-02A Boiler Room Sink               | 6/21/16 8:20          | 7/1/16 7:45          | 606221702    | Copper  | 0.1     | 1.3              | ppm   |
| 028-02A Boiler Room Sink               | 6/21/16 8:20          | 7/1/16 7:45          | 606221702    | Lead    | 14      | 15               | ppb   |
| 028-03A Room 27 Sink                   | 6/21/16 8:26          | 7/1/16 7:45          | 606221703    | Copper  | 0.1     | 1.3              | ppm   |
| 028-03A Room 27 Sink                   | 6/21/16 8:26          | 7/1/16 7:45          | 606221703    | Lead    | 31      | 15               | ppb   |
| 028-04A Girls Restroom Sink (left)     | 6/21/16 8:28          | 7/1/16 7:45          | 606221704    | Copper  | 0.1     | 1.3              | ppm   |
| 028-04A Girls Restroom Sink (left)     | 6/21/16 8:28          | 7/1/16 7:45          | 606221704    | Lead    | 15      | 15               | ppb   |
| 028-05A Girls Restroom Sink (right)    | 6/21/16 8:28          | 7/1/16 7:45          | 606221705    | Copper  | 0.1     | 1.3              | ppm   |
| 028-05A Girls Restroom Sink (right)    | 6/21/16 8:28          | 7/1/16 7:45          | 606221705    | Lead    | 7       | 15               | ppb   |
| 028-06A Boy Restroom Sink (left)       | 6/21/16 8:30          | 7/1/16 7:45          | 606221706    | Copper  | 0.1     | 1.3              | ppm   |
| 028-06A Boy Restroom Sink (left)       | 6/21/16 8:30          | 7/1/16 7:45          | 606221706    | Lead    | 8       | 15               | ppb   |
| 028-07A Boy Restroom Sink (right)      | 6/21/16 8:30          | 7/1/16 7:45          | 606221707    | Copper  | 0.1     | 1.3              | ppm   |
| 028-07A Boy Restroom Sink (right)      | 6/21/16 8:30          | 7/1/16 7:45          | 606221707    | Lead    | 5       | 15               | ppb   |
| 028-08A Drinking Fountain              | 6/21/16 8:31          | 7/1/16 7:45          | 606221708    | Copper  | 0.0     | 1.3              | ppm   |
| 028-08A Drinking Fountain              | 6/21/16 8:31          | 7/1/16 7:45          | 606221708    | Lead    | 7       | 15               | ppb   |
| 028-09A Room 26 Teachers Sink (right)  | 6/21/16 8:34          | 7/1/16 7:45          | 606221709    | Copper  | 0.2     | 1.3              | ppm   |
| 028-09A Room 26 Teachers Sink (right)  | 6/21/16 8:34          | 7/1/16 7:45          | 606221709    | Lead    | 21      | 15               | ppb   |
| 028-100A Janitors Closet Sink          | 6/21/16 11:20         | 7/1/16 8:10          | 606221799    | Copper  | 0.0     | 1.3              | ppm   |
| 028-100A Janitors Closet Sink          | 6/21/16 11:20         | 7/1/16 8:10          | 606221799    | Lead    | 11      | 15               | ppb   |
| 028-10A Room 26 Teachers Sink (middle) | 6/21/16 8:34          | 7/1/16 7:45          | 606221710    | Copper  | 0.1     | 1.3              | ppm   |
| 028-10A Room 26 Teachers Sink (middle) | 6/21/16 8:34          | 7/1/16 7:45          | 606221710    | Lead    | 11      | 15               | ppb   |
| 028-11A Room 26 Teachers Sink (left)   | 6/21/16 8:34          | 7/1/16 7:46          | 606221711    | Copper  | 0.2     | 1.3              | ppm   |
| 028-11A Room 26 Teachers Sink (left)   | 6/21/16 8:34          | 7/1/16 7:46          | 606221711    | Lead    | 25      | 15               | ppb   |
| 028-12A Room 25 Sink                   | 6/21/16 8:37          | 7/1/16 7:46          | 606221712    | Copper  | 0.1     | 1.3              | ppm   |
| 028-12A Room 25 Sink                   | 6/21/16 8:37          | 7/1/16 7:46          | 606221712    | Lead    | 25      | 15               | ppb   |
| 028-13A Room 25 Drinking Fountain      | 6/21/16 8:37          | 7/1/16 7:46          | 606221713    | Copper  | 0.0     | 1.3              | ppm   |
| 028-13A Room 25 Drinking Fountain      | 6/21/16 8:37          | 7/1/16 7:46          | 606221713    | Lead    | 1       | 15               | ppb   |
| 028-14A Drinking Fountain              | 6/21/16 8:39          | 7/1/16 7:46          | 606221714    | Copper  | 0.0     | 1.3              | ppm   |
| 028-14A Drinking Fountain              | 6/21/16 8:39          | 7/1/16 7:46          | 606221714    | Lead    | 18      | 15               | ppb   |
| 028-15A Room 24 Sink                   | 6/21/16 8:43          | 7/1/16 7:46          | 606221715    | Copper  | 0.1     | 1.3              | ppm   |
| 028-15A Room 24 Sink                   | 6/21/16 8:43          | 7/1/16 7:46          | 606221715    | Lead    | 5       | 15               | ppb   |
| 028-16A Room 24 Drinking Fountain      | 6/21/16 8:43          | 7/1/16 7:46          | 606221716    | Copper  | 0.0     | 1.3              | ppm   |
| 028-16A Room 24 Drinking Fountain      | 6/21/16 8:43          | 7/1/16 7:46          | 606221716    | Lead    | 3       | 15               | ppb   |
| 028-17A Room 23 Sink                   | 6/21/16 8:45          | 7/1/16 7:46          | 606221717    | Copper  | 0.1     | 1.3              | ppm   |
| 028-17A Room 23 Sink                   | 6/21/16 8:45          | 7/1/16 7:46          | 606221717    | Lead    | 9       | 15               | ppb   |
| 028-18A Room 23 Drinking Fountain      | 6/21/16 8:45          | 7/1/16 7:46          | 606221718    | Copper  | 0.0     | 1.3              | ppm   |
| 028-18A Room 23 Drinking Fountain      | 6/21/16 8:45          | 7/1/16 7:46          | 606221718    | Lead    | 2       | 15               | ppb   |
| 028-19A Room 13 Sink                   | 6/21/16 8:51          | 7/1/16 7:46          | 606221719    | Copper  | 0.1     | 1.3              | ppm   |
| 028-19A Room 13 Sink                   | 6/21/16 8:51          | 7/1/16 7:46          | 606221719    | Lead    | 11      | 15               | ppb   |
| 028-20A Room 13 Drinking Fountain      | 6/21/16 8:51          | 7/1/16 7:46          | 606221720    | Copper  | 0.1     | 1.3              | ppm   |
| 028-20A Room 13 Drinking Fountain      | 6/21/16 8:51          | 7/1/16 7:46          | 606221720    | Lead    | 32      | 15               | ppb   |
| 028-21A Room 21 Sink                   | 6/21/16 8:51          | 7/1/16 7:47          | 606221721    | Copper  | 0.1     | 1.3              | ppm   |
| 028-21A Room 21 Sink                   | 6/21/16 8:51          | 7/1/16 7:47          | 606221721    | Lead    | 3       | 15               | ppb   |
| 028-22A Room 21 Drinking Fountain      | 6/21/16 8:51          | 7/1/16 7:47          | 606221722    | Copper  | 0.0     | 1.3              | ppm   |
| 028-22A Room 21 Drinking Fountain      | 6/21/16 8:51          | 7/1/16 7:47          | 606221722    | Lead    | 3       | 15               | ppb   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Creative Science School

| Sample Identification # and Location | Date & Time Collected | Date & Time Analyzed | Container ID | Analyte | Results | EPA Action Limit | Units |
|--------------------------------------|-----------------------|----------------------|--------------|---------|---------|------------------|-------|
| 028-23A Boys Restroom Sink           | 6/21/16 8:58          | 7/1/16 7:47          | 606221723    | Copper  | 0.5     | 1.3              | ppm   |
| 028-23A Boys Restroom Sink           | 6/21/16 8:58          | 7/1/16 7:47          | 606221723    | Lead    | 35      | 15               | ppb   |
| 028-24A Boys Restroom Sink           | 6/21/16 8:58          | 7/1/16 7:47          | 606221724    | Copper  | 0.4     | 1.3              | ppm   |
| 028-24A Boys Restroom Sink           | 6/21/16 8:58          | 7/1/16 7:47          | 606221724    | Lead    | 40      | 15               | ppb   |
| 028-25A Boys Restroom Sink           | 6/21/16 9:02          | 7/1/16 7:47          | 606221725    | Copper  | 0.3     | 1.3              | ppm   |
| 028-25A Boys Restroom Sink           | 6/21/16 9:02          | 7/1/16 7:47          | 606221725    | Lead    | 30      | 15               | ppb   |
| 028-26A Boys Restroom Spigot         | 6/21/16 9:05          | 7/1/16 7:47          | 606221726    | Copper  | 0.3     | 1.3              | ppm   |
| 028-26A Boys Restroom Spigot         | 6/21/16 9:05          | 7/1/16 7:47          | 606221726    | Lead    | 18      | 15               | ppb   |
| 028-27A Janitors Closet Sink         | 6/21/16 8:56          | 7/1/16 7:47          | 606221727    | Copper  | 0.1     | 1.3              | ppm   |
| 028-27A Janitors Closet Sink         | 6/21/16 8:56          | 7/1/16 7:47          | 606221727    | Lead    | 41      | 15               | ppb   |
| 028-28A Girls Restroom Sink (left)   | 6/21/16 9:01          | 7/1/16 7:47          | 606221728    | Copper  | 0.2     | 1.3              | ppm   |
| 028-28A Girls Restroom Sink (left)   | 6/21/16 9:01          | 7/1/16 7:47          | 606221728    | Lead    | 32      | 15               | ppb   |
| 028-29A Girls Restroom Sink (mid)    | 6/21/16 9:01          | 7/1/16 7:47          | 606221729    | Copper  | 0.4     | 1.3              | ppm   |
| 028-29A Girls Restroom Sink (mid)    | 6/21/16 9:01          | 7/1/16 7:47          | 606221729    | Lead    | 41      | 15               | ppb   |
| 028-30A Girls Restroom Sink (right)  | 6/21/16 9:05          | 7/1/16 7:47          | 606221730    | Copper  | 0.5     | 1.3              | ppm   |
| 028-30A Girls Restroom Sink (right)  | 6/21/16 9:05          | 7/1/16 7:47          | 606221730    | Lead    | 50      | 15               | ppb   |
| 028-31A Girls Restroom Spigot        | 6/21/16 9:08          | 7/1/16 8:00          | 606221731    | Copper  | 0.2     | 1.3              | ppm   |
| 028-31A Girls Restroom Spigot        | 6/21/16 9:08          | 7/1/16 8:00          | 606221731    | Lead    | 10      | 15               | ppb   |
| 028-32A Room 20 Sink                 | 6/21/16 9:09          | 7/1/16 8:00          | 606221732    | Copper  | 0.2     | 1.3              | ppm   |
| 028-32A Room 20 Sink                 | 6/21/16 9:09          | 7/1/16 8:00          | 606221732    | Lead    | 21      | 15               | ppb   |
| 028-33A Room 14 Sink                 | 6/21/16 9:14          | 7/1/16 8:00          | 606221733    | Copper  | 0.2     | 1.3              | ppm   |
| 028-33A Room 14 Sink                 | 6/21/16 9:14          | 7/1/16 8:00          | 606221733    | Lead    | 51      | 15               | ppb   |
| 028-34A Room 14 Drinking Fountain    | 6/21/16 9:14          | 7/1/16 8:00          | 606221734    | Copper  | 0.0     | 1.3              | ppm   |
| 028-34A Room 14 Drinking Fountain    | 6/21/16 9:14          | 7/1/16 8:00          | 606221734    | Lead    | 3       | 15               | ppb   |
| 028-35A Hallway Drinking Fountain    | 6/21/16 9:13          | 7/1/16 8:00          | 606221735    | Copper  | 0.0     | 1.3              | ppm   |
| 028-35A Hallway Drinking Fountain    | 6/21/16 9:13          | 7/1/16 8:00          | 606221735    | Lead    | 11      | 15               | ppb   |
| 028-36A Room 19 Sink                 | 6/21/16 9:17          | 7/1/16 8:01          | 606221736    | Copper  | 0.1     | 1.3              | ppm   |
| 028-36A Room 19 Sink                 | 6/21/16 9:17          | 7/1/16 8:01          | 606221736    | Lead    | 6       | 15               | ppb   |
| 028-37A Room 19 Drinking Fountain    | 6/21/16 9:17          | 7/1/16 8:01          | 606221737    | Copper  | 0.1     | 1.3              | ppm   |
| 028-37A Room 19 Drinking Fountain    | 6/21/16 9:17          | 7/1/16 8:01          | 606221737    | Lead    | 1       | 15               | ppb   |
| 028-38A Room 15 Sink                 | 6/21/16 9:21          | 7/1/16 8:01          | 606221738    | Copper  | 0.4     | 1.3              | ppm   |
| 028-38A Room 15 Sink                 | 6/21/16 9:21          | 7/1/16 8:01          | 606221738    | Lead    | 17      | 15               | ppb   |
| 028-40A Room 15 Sink                 | 6/21/16 9:21          | 7/1/16 8:01          | 606221739    | Copper  | 0.1     | 1.3              | ppm   |
| 028-40A Room 15 Sink                 | 6/21/16 9:21          | 7/1/16 8:01          | 606221739    | Lead    | 17      | 15               | ppb   |
| 028-41A Room 18 Sink                 | 6/21/16 9:25          | 7/1/16 8:01          | 606221740    | Copper  | 0.1     | 1.3              | ppm   |
| 028-41A Room 18 Sink                 | 6/21/16 9:25          | 7/1/16 8:01          | 606221740    | Lead    | 18      | 15               | ppb   |
| 028-42A Room 18 Drinking Fountain    | 6/21/16 9:25          | 7/1/16 8:01          | 606221741    | Copper  | 0.0     | 1.3              | ppm   |
| 028-42A Room 18 Drinking Fountain    | 6/21/16 9:25          | 7/1/16 8:01          | 606221741    | Lead    | 2       | 15               | ppb   |
| 028-43A Room 16 Sink                 | 6/21/16 9:26          | 7/1/16 8:01          | 606221742    | Copper  | 0.2     | 1.3              | ppm   |
| 028-43A Room 16 Sink                 | 6/21/16 9:26          | 7/1/16 8:01          | 606221742    | Lead    | 53      | 15               | ppb   |
| 028-44A Room 16 Drinking Fountain    | 6/21/16 9:26          | 7/1/16 8:01          | 606221743    | Copper  | 0.1     | 1.3              | ppm   |
| 028-44A Room 16 Drinking Fountain    | 6/21/16 9:26          | 7/1/16 8:01          | 606221743    | Lead    | 14      | 15               | ppb   |
| 028-45A Room 17 Sink                 | 6/21/16 9:31          | 7/1/16 8:02          | 606221744    | Copper  | 0.0     | 1.3              | ppm   |
| 028-45A Room 17 Sink                 | 6/21/16 9:31          | 7/1/16 8:02          | 606221744    | Lead    | 8       | 15               | ppb   |
| 028-46A Room 17 Drinking Fountain    | 6/21/16 9:31          | 7/1/16 8:02          | 606221745    | Copper  | 0.1     | 1.3              | ppm   |
| 028-46A Room 17 Drinking Fountain    | 6/21/16 9:31          | 7/1/16 8:02          | 606221745    | Lead    | 9       | 15               | ppb   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Creative Science School

| Sample Identification # and Location | Date & Time Collected | Date & Time Analyzed | Container ID | Analyte | Results | EPA Action Limit | Units |
|--------------------------------------|-----------------------|----------------------|--------------|---------|---------|------------------|-------|
| 028-47A Boy/Girl Bathroom Sink       | 6/21/16 9:35          | 7/1/16 8:02          | 606221746    | Copper  | 0.2     | 1.3              | ppm   |
| 028-47A Boy/Girl Bathroom Sink       | 6/21/16 9:35          | 7/1/16 8:02          | 606221746    | Lead    | 13      | 15               | ppb   |
| 028-48A Drinking Fountain            | 6/21/16 9:34          | 7/1/16 8:02          | 606221747    | Copper  | 0.0     | 1.3              | ppm   |
| 028-48A Drinking Fountain            | 6/21/16 9:34          | 7/1/16 8:02          | 606221747    | Lead    | 2       | 15               | ppb   |
| 028-49A Boy/Girl Bathroom Sink       | 6/21/16 9:38          | 7/1/16 8:02          | 606221748    | Copper  | 0.1     | 1.3              | ppm   |
| 028-49A Boy/Girl Bathroom Sink       | 6/21/16 9:38          | 7/1/16 8:02          | 606221748    | Lead    | 14      | 15               | ppb   |
| 028-50A Room 11 Sink                 | 6/21/16 9:42          | 7/1/16 8:02          | 606221749    | Copper  | 0.1     | 1.3              | ppm   |
| 028-50A Room 11 Sink                 | 6/21/16 9:42          | 7/1/16 8:02          | 606221749    | Lead    | 11      | 15               | ppb   |
| 028-51A Room 11 Drinking Fountain    | 6/21/16 9:42          | 7/1/16 8:02          | 606221750    | Copper  | 0.0     | 1.3              | ppm   |
| 028-51A Room 11 Drinking Fountain    | 6/21/16 9:42          | 7/1/16 8:02          | 606221750    | Lead    | 7       | 15               | ppb   |
| 028-52A Room 10 Sink                 | 6/21/16 9:52          | 7/1/16 8:02          | 606221751    | Copper  | 0.1     | 1.3              | ppm   |
| 028-52A Room 10 Sink                 | 6/21/16 9:52          | 7/1/16 8:02          | 606221751    | Lead    | 22      | 15               | ppb   |
| 028-53A Room 10 Drinking Fountain    | 6/21/16 9:52          | 7/1/16 8:02          | 606221752    | Copper  | 0.0     | 1.3              | ppm   |
| 028-53A Room 10 Drinking Fountain    | 6/21/16 9:52          | 7/1/16 8:02          | 606221752    | Lead    | 4       | 15               | ppb   |
| 028-54A Boys Restroom Sink (left)    | 6/21/16 9:57          | 7/1/16 8:02          | 606221753    | Copper  | 0.1     | 1.3              | ppm   |
| 028-54A Boys Restroom Sink (left)    | 6/21/16 9:57          | 7/1/16 8:02          | 606221753    | Lead    | 7       | 15               | ppb   |
| 028-55A Boys Restroom Sink (mid)     | 6/21/16 9:57          | 7/1/16 8:02          | 606221754    | Copper  | 0.1     | 1.3              | ppm   |
| 028-55A Boys Restroom Sink (mid)     | 6/21/16 9:57          | 7/1/16 8:02          | 606221754    | Lead    | 2       | 15               | ppb   |
| 028-56A Boys Restroom Sink (right)   | 6/21/16 12:03         | 7/1/16 8:02          | 606221755    | Copper  | 0.1     | 1.3              | ppm   |
| 028-56A Boys Restroom Sink (right)   | 6/21/16 12:03         | 7/1/16 8:02          | 606221755    | Lead    | 10      | 15               | ppb   |
| 028-57A Boys Restroom Spigot         | 6/21/16 12:03         | 7/1/16 8:02          | 606221756    | Copper  | 0.1     | 1.3              | ppm   |
| 028-57A Boys Restroom Spigot         | 6/21/16 12:03         | 7/1/16 8:02          | 606221756    | Lead    | 3       | 15               | ppb   |
| 028-58A Janitors Closet Sink         | 6/21/16 10:03         | 7/1/16 8:02          | 606221757    | Copper  | 0.0     | 1.3              | ppm   |
| 028-58A Janitors Closet Sink         | 6/21/16 10:03         | 7/1/16 8:02          | 606221757    | Lead    | 2       | 15               | ppb   |
| 028-59A Girls Restroom Sink (left)   | 6/21/16 10:07         | 7/1/16 8:02          | 606221758    | Copper  | 0.2     | 1.3              | ppm   |
| 028-59A Girls Restroom Sink (left)   | 6/21/16 10:07         | 7/1/16 8:02          | 606221758    | Lead    | 10      | 15               | ppb   |
| 028-60A Girls Restroom Sink (middle) | 6/21/16 10:07         | 7/1/16 8:02          | 606221759    | Copper  | 0.1     | 1.3              | ppm   |
| 028-60A Girls Restroom Sink (middle) | 6/21/16 10:07         | 7/1/16 8:02          | 606221759    | Lead    | 2       | 15               | ppb   |
| 028-61A Girls Restroom Sink (right)  | 6/21/16 10:11         | 7/1/16 8:02          | 606221760    | Copper  | 0.1     | 1.3              | ppm   |
| 028-61A Girls Restroom Sink (right)  | 6/21/16 10:11         | 7/1/16 8:02          | 606221760    | Lead    | 2       | 15               | ppb   |
| 028-62A Girls Restroom Spigot        | 6/21/16 10:11         | 7/1/16 8:03          | 606221761    | Copper  | 0.2     | 1.3              | ppm   |
| 028-62A Girls Restroom Spigot        | 6/21/16 10:11         | 7/1/16 8:03          | 606221761    | Lead    | 6       | 15               | ppb   |
| 028-63A Room 9 Sink                  | 6/21/16 10:08         | 7/1/16 8:03          | 606221762    | Copper  | 0.1     | 1.3              | ppm   |
| 028-63A Room 9 Sink                  | 6/21/16 10:08         | 7/1/16 8:03          | 606221762    | Lead    | 14      | 15               | ppb   |
| 028-64A Room 9 Drinking Fountain     | 6/21/16 10:08         | 7/1/16 8:03          | 606221763    | Copper  | 0.0     | 1.3              | ppm   |
| 028-64A Room 9 Drinking Fountain     | 6/21/16 10:08         | 7/1/16 8:03          | 606221763    | Lead    | 2       | 15               | ppb   |
| 028-65A Room 8 Sink                  | 6/21/16 10:16         | 7/1/16 8:03          | 606221764    | Copper  | 0.1     | 1.3              | ppm   |
| 028-65A Room 8 Sink                  | 6/21/16 10:16         | 7/1/16 8:03          | 606221764    | Lead    | 10      | 15               | ppb   |
| 028-66A Room 8 Drinking Fountain     | 6/21/16 10:16         | 7/1/16 8:03          | 606221765    | Copper  | 0.0     | 1.3              | ppm   |
| 028-66A Room 8 Drinking Fountain     | 6/21/16 10:16         | 7/1/16 8:03          | 606221765    | Lead    | 3       | 15               | ppb   |
| 028-67A Room 7 Sink (left)           | 6/21/16 10:21         | 7/1/16 8:03          | 606221766    | Copper  | 0.1     | 1.3              | ppm   |
| 028-67A Room 7 Sink (left)           | 6/21/16 10:21         | 7/1/16 8:03          | 606221766    | Lead    | 7       | 15               | ppb   |
| 028-68A Room 7 Drinking Fountain     | 6/21/16 10:21         | 7/1/16 8:04          | 606221767    | Copper  | 0.0     | 1.3              | ppm   |
| 028-68A Room 7 Drinking Fountain     | 6/21/16 10:21         | 7/1/16 8:04          | 606221767    | Lead    | 3       | 15               | ppb   |
| 028-69A Room 7 Sink (right)          | 6/21/16 10:29         | 7/1/16 8:04          | 606221768    | Copper  | 0.1     | 1.3              | ppm   |
| 028-69A Room 7 Sink (right)          | 6/21/16 10:29         | 7/1/16 8:04          | 606221768    | Lead    | 11      | 15               | ppb   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Creative Science School

| Sample Identification # and Location | Date & Time Collected | Date & Time Analyzed | Container ID | Analyte | Results | EPA Action Limit | Units |
|--------------------------------------|-----------------------|----------------------|--------------|---------|---------|------------------|-------|
| 028-70A Room 6 Sink (right)          | 6/21/16 10:30         | 7/1/16 8:04          | 606221769    | Copper  | 0.1     | 1.3              | ppm   |
| 028-70A Room 6 Sink (right)          | 6/21/16 10:30         | 7/1/16 8:04          | 606221769    | Lead    | 5       | 15               | ppb   |
| 028-71A Room 6 Drinking Fountain     | 6/21/16 10:30         | 7/1/16 8:04          | 606221770    | Copper  | 0.0     | 1.3              | ppm   |
| 028-71A Room 6 Drinking Fountain     | 6/21/16 10:30         | 7/1/16 8:04          | 606221770    | Lead    | 5       | 15               | ppb   |
| 028-72A Room 6 Sink (left)           | 6/21/16 10:39         | 7/1/16 8:04          | 606221771    | Copper  | 0.1     | 1.3              | ppm   |
| 028-72A Room 6 Sink (left)           | 6/21/16 10:39         | 7/1/16 8:04          | 606221771    | Lead    | 12      | 15               | ppb   |
| 028-73A Room 5 Sink                  | 6/21/16 10:43         | 7/1/16 8:04          | 606221772    | Copper  | 0.1     | 1.3              | ppm   |
| 028-73A Room 5 Sink                  | 6/21/16 10:43         | 7/1/16 8:04          | 606221772    | Lead    | 25      | 15               | ppb   |
| 028-74A Room 5 Drinking Fountain     | 6/21/16 10:43         | 7/1/16 8:04          | 606221773    | Copper  | 0.0     | 1.3              | ppm   |
| 028-74A Room 5 Drinking Fountain     | 6/21/16 10:43         | 7/1/16 8:04          | 606221773    | Lead    | 13      | 15               | ppb   |
| 028-75A Room 4 Sink                  | 6/21/16 10:50         | 7/1/16 8:04          | 606221774    | Copper  | 0.3     | 1.3              | ppm   |
| 028-75A Room 4 Sink                  | 6/21/16 10:50         | 7/1/16 8:04          | 606221774    | Lead    | 65      | 15               | ppb   |
| 028-76A Room 4 Drinking Fountain     | 6/21/16 10:50         | 7/1/16 8:04          | 606221775    | Copper  | 0.0     | 1.3              | ppm   |
| 028-76A Room 4 Drinking Fountain     | 6/21/16 10:50         | 7/1/16 8:04          | 606221775    | Lead    | 17      | 15               | ppb   |
| 028-77A Drinking Fountain            | 6/21/16 10:57         | 7/1/16 8:04          | 606221776    | Copper  | 0.1     | 1.3              | ppm   |
| 028-77A Drinking Fountain            | 6/21/16 10:57         | 7/1/16 8:04          | 606221776    | Lead    | 8       | 15               | ppb   |
| 028-78A Room 3 Sink                  | 6/21/16 10:58         | 7/1/16 8:04          | 606221777    | Copper  | 0.2     | 1.3              | ppm   |
| 028-78A Room 3 Sink                  | 6/21/16 10:58         | 7/1/16 8:04          | 606221777    | Lead    | 36      | 15               | ppb   |
| 028-79A Room 3 Drinking Fountain     | 6/21/16 10:58         | 7/1/16 8:04          | 606221778    | Copper  | 0.1     | 1.3              | ppm   |
| 028-79A Room 3 Drinking Fountain     | 6/21/16 10:58         | 7/1/16 8:04          | 606221778    | Lead    | 7       | 15               | ppb   |
| 028-80A Room 2 Sink                  | 6/21/16 11:02         | 7/1/16 8:04          | 606221779    | Copper  | 0.2     | 1.3              | ppm   |
| 028-80A Room 2 Sink                  | 6/21/16 11:02         | 7/1/16 8:04          | 606221779    | Lead    | 53      | 15               | ppb   |
| 028-81A Room 2 Drinking Fountain     | 6/21/16 11:02         | 7/1/16 8:04          | 606221780    | Copper  | 0.0     | 1.3              | ppm   |
| 028-81A Room 2 Drinking Fountain     | 6/21/16 11:02         | 7/1/16 8:04          | 606221780    | Lead    | 20      | 15               | ppb   |
| 028-82A Room 113 Sink                | 6/21/16 11:05         | 7/1/16 8:05          | 606221781    | Copper  | 0.1     | 1.3              | ppm   |
| 028-82A Room 113 Sink                | 6/21/16 11:05         | 7/1/16 8:05          | 606221781    | Lead    | 17      | 15               | ppb   |
| 028-83A Nurse Room Sink              | 6/21/16 11:06         | 7/1/16 8:05          | 606221782    | Copper  | 0.2     | 1.3              | ppm   |
| 028-83A Nurse Room Sink              | 6/21/16 11:06         | 7/1/16 8:05          | 606221782    | Lead    | 14      | 15               | ppb   |
| 028-84A Kitchen Sink                 | 6/21/16 11:09         | 7/1/16 8:05          | 606221783    | Copper  | 0.1     | 1.3              | ppm   |
| 028-84A Kitchen Sink                 | 6/21/16 11:09         | 7/1/16 8:05          | 606221783    | Lead    | 21      | 15               | ppb   |
| 028-85A Kitchen Sink                 | 6/21/16 11:09         | 7/1/16 8:05          | 606221784    | Copper  | 0.2     | 1.3              | ppm   |
| 028-85A Kitchen Sink                 | 6/21/16 11:09         | 7/1/16 8:05          | 606221784    | Lead    | 12      | 15               | ppb   |
| 028-86A Janitors Closet Sink         | 6/21/16 11:12         | 7/1/16 8:05          | 606221785    | Copper  | 0.0     | 1.3              | ppm   |
| 028-86A Janitors Closet Sink         | 6/21/16 11:12         | 7/1/16 8:05          | 606221785    | Lead    | 52      | 15               | ppb   |
| 028-87A Restroom Sink                | 6/21/16 11:12         | 7/1/16 8:05          | 606221786    | Copper  | 0.1     | 1.3              | ppm   |
| 028-87A Restroom Sink                | 6/21/16 11:12         | 7/1/16 8:05          | 606221786    | Lead    | 19      | 15               | ppb   |
| 028-88A Kitchen Spray                | 6/21/16 11:14         | 7/1/16 8:05          | 606221787    | Copper  | 0.1     | 1.3              | ppm   |
| 028-88A Kitchen Spray                | 6/21/16 11:14         | 7/1/16 8:05          | 606221787    | Lead    | 12      | 15               | ppb   |
| 028-89A Cafeteria Drinking Fountain  | 6/21/16 10:14         | 7/1/16 8:05          | 606221788    | Copper  | 0.0     | 1.3              | ppm   |
| 028-89A Cafeteria Drinking Fountain  | 6/21/16 10:14         | 7/1/16 8:05          | 606221788    | Lead    | 5       | 15               | ppb   |
| 028-90A Outside Spigot               | 6/21/16 10:17         | 7/1/16 8:05          | 606221789    | Copper  | 0.0     | 1.3              | ppm   |
| 028-90A Outside Spigot               | 6/21/16 10:17         | 7/1/16 8:05          | 606221789    | Lead    | 3       | 15               | ppb   |
| 028-91A Outside Spigot               | 6/21/16 10:18         | 7/1/16 8:05          | 606221790    | Copper  | 0.0     | 1.3              | ppm   |
| 028-91A Outside Spigot               | 6/21/16 10:18         | 7/1/16 8:05          | 606221790    | Lead    | 4       | 15               | ppb   |
| 028-92A Outside Spigot               | 6/21/16 10:28         | 7/1/16 8:10          | 606221791    | Copper  | 0.0     | 1.3              | ppm   |
| 028-92A Outside Spigot               | 6/21/16 10:28         | 7/1/16 8:10          | 606221791    | Lead    | 9       | 15               | ppb   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Creative Science School

| Sample Identification # and Location | Date & Time Collected | Date & Time Analyzed | Container ID | Analyte | Results | EPA Action Limit | Units |
|--------------------------------------|-----------------------|----------------------|--------------|---------|---------|------------------|-------|
| 028-93A Outside Spigot               | 6/21/16 10:30         | 7/1/16 8:10          | 606221792    | Copper  | 0.0     | 1.3              | ppm   |
| 028-93A Outside Spigot               | 6/21/16 10:30         | 7/1/16 8:10          | 606221792    | Lead    | 23      | 15               | ppb   |
| 028-94A Outside Spigot               | 6/21/16 10:39         | 7/1/16 8:10          | 606221793    | Copper  | 0.0     | 1.3              | ppm   |
| 028-94A Outside Spigot               | 6/21/16 10:39         | 7/1/16 8:10          | 606221793    | Lead    | 12      | 15               | ppb   |
| 028-95A Outside Spigot               | 6/21/16 10:37         | 7/1/16 8:10          | 606221794    | Copper  | 0.0     | 1.3              | ppm   |
| 028-95A Outside Spigot               | 6/21/16 10:37         | 7/1/16 8:10          | 606221794    | Lead    | 8       | 15               | ppb   |
| 028-96A Outside Spigot               | 6/21/16 9:53          | 7/1/16 8:10          | 606221795    | Copper  | 0.0     | 1.3              | ppm   |
| 028-96A Outside Spigot               | 6/21/16 9:53          | 7/1/16 8:10          | 606221795    | Lead    | 1       | 15               | ppb   |
| 028-97A Outside Spigot               | 6/21/16 9:57          | 7/1/16 8:10          | 606221796    | Copper  | 0.0     | 1.3              | ppm   |
| 028-97A Outside Spigot               | 6/21/16 9:57          | 7/1/16 8:10          | 606221796    | Lead    | 5       | 15               | ppb   |
| 028-98A Outside Spigot               | 6/21/16 10:50         | 7/1/16 8:10          | 606221797    | Copper  | 0.1     | 1.3              | ppm   |
| 028-98A Outside Spigot               | 6/21/16 10:50         | 7/1/16 8:10          | 606221797    | Lead    | 13      | 15               | ppb   |
| 028-99A Outside Spigot               | 6/21/16 10:48         | 7/1/16 8:10          | 606221798    | Copper  | 0.0     | 1.3              | ppm   |
| 028-99A Outside Spigot               | 6/21/16 10:48         | 7/1/16 8:10          | 606221798    | Lead    | 5       | 15               | ppb   |

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.