

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Da Vinci Arts Middle School

| Sample Identification # and Location                   | Date/Time Collected | Date/Time Analyzed | Container ID | Analyte | Results | EPA Action Level | Units |
|--------------------------------------------------------|---------------------|--------------------|--------------|---------|---------|------------------|-------|
| 031-01A Boiler Room - Sink Faucet (1)                  | 6/27/2016 22:59     | 7/7/2016 18:38     | 10354095001  | Copper  | 0.0     | 1.3              | ppm   |
| 031-01A Boiler Room - Sink Faucet (1)                  | 6/27/2016 22:59     | 7/7/2016 18:38     | 10354095001  | Lead    | 2       | 15               | ppb   |
| 031-02A Boiler Room - Sink Faucet (2)                  | 6/27/2016 23:01     | 7/7/2016 18:47     | 10354095003  | Copper  | 0.1     | 1.3              | ppm   |
| 031-02A Boiler Room - Sink Faucet (2)                  | 6/27/2016 23:01     | 7/7/2016 18:47     | 10354095003  | Lead    | 5       | 15               | ppb   |
| 031-03A Hall Drinking Fountain Outside Boiler Room (1) | 6/27/2016 23:06     | 7/7/2016 18:48     | 10354095005  | Copper  | 0.0     | 1.3              | ppm   |
| 031-03A Hall Drinking Fountain Outside Boiler Room (1) | 6/27/2016 23:06     | 7/7/2016 18:48     | 10354095005  | Lead    | 2       | 15               | ppb   |
| 031-04A Hall Drinking Fountain Outside Boiler Room (2) | 6/27/2016 23:08     | 7/7/2016 18:49     | 10354095007  | Copper  | 0.0     | 1.3              | ppm   |
| 031-04A Hall Drinking Fountain Outside Boiler Room (2) | 6/27/2016 23:08     | 7/7/2016 18:49     | 10354095007  | Lead    | 2       | 15               | ppb   |
| 031-05A Classroom 109 - Sink Faucet                    | 6/27/2016 23:10     | 7/7/2016 18:50     | 10354095009  | Copper  | 0.1     | 1.3              | ppm   |
| 031-05A Classroom 109 - Sink Faucet                    | 6/27/2016 23:10     | 7/7/2016 18:50     | 10354095009  | Lead    | 44      | 15               | ppb   |
| 031-06A Kitchen - Sink Faucet (1)                      | 6/27/2016 23:13     | 7/7/2016 18:52     | 10354095011  | Copper  | 0.2     | 1.3              | ppm   |
| 031-06A Kitchen - Sink Faucet (1)                      | 6/27/2016 23:13     | 7/7/2016 18:52     | 10354095011  | Lead    | 12      | 15               | ppb   |
| 031-07A Kitchen - Sink Faucet (2)                      | 6/27/2016 23:15     | 7/7/2016 18:53     | 10354095013  | Copper  | 0.2     | 1.3              | ppm   |
| 031-07A Kitchen - Sink Faucet (2)                      | 6/27/2016 23:15     | 7/7/2016 18:53     | 10354095013  | Lead    | 10      | 15               | ppb   |
| 031-08A Kitchen - Water Spigot (1)                     | 6/27/2016 23:17     | 7/7/2016 18:55     | 10354095015  | Copper  | 0.1     | 1.3              | ppm   |
| 031-08A Kitchen - Water Spigot (1)                     | 6/27/2016 23:17     | 7/7/2016 18:55     | 10354095015  | Lead    | 54      | 15               | ppb   |
| 031-09A Kitchen - Water Spigot (2)                     | 6/27/2016 23:19     | 7/7/2016 18:19     | 10354095017  | Copper  | 0.0     | 1.3              | ppm   |
| 031-09A Kitchen - Water Spigot (2)                     | 6/27/2016 23:19     | 7/7/2016 18:19     | 10354095017  | Lead    | 30      | 15               | ppb   |
| 031-10A Classroom 107 - Sink Faucet (1)                | 6/27/2016 23:21     | 7/7/2016 18:57     | 10354095019  | Copper  | 0.1     | 1.3              | ppm   |
| 031-10A Classroom 107 - Sink Faucet (1)                | 6/27/2016 23:21     | 7/7/2016 18:57     | 10354095019  | Lead    | 123     | 15               | ppb   |
| 031-11A Classroom 107 - Sink Faucet (2)                | 6/27/2016 23:23     | 7/7/2016 18:58     | 10354095021  | Copper  | 0.2     | 1.3              | ppm   |
| 031-11A Classroom 107 - Sink Faucet (2)                | 6/27/2016 23:23     | 7/7/2016 18:58     | 10354095021  | Lead    | 129     | 15               | ppb   |
| 031-12A Classroom 107 - Sink Faucet (3)                | 6/27/2016 23:25     | 7/7/2016 18:27     | 10354095023  | Copper  | 0.0     | 1.3              | ppm   |
| 031-12A Classroom 107 - Sink Faucet (3)                | 6/27/2016 23:25     | 7/7/2016 18:27     | 10354095023  | Lead    | 90      | 15               | ppb   |
| 031-13A Classroom 107 - Sink Faucet (4)                | 6/27/2016 23:27     | 7/7/2016 19:01     | 10354095025  | Copper  | 0.0     | 1.3              | ppm   |
| 031-13A Classroom 107 - Sink Faucet (4)                | 6/27/2016 23:27     | 7/7/2016 19:01     | 10354095025  | Lead    | 5       | 15               | ppb   |
| 031-14A Girls Bathroom - Sink Faucet (1)               | 6/27/2016 23:30     | 7/7/2016 18:28     | 10354095027  | Copper  | 0.1     | 1.3              | ppm   |
| 031-14A Girls Bathroom - Sink Faucet (1)               | 6/27/2016 23:30     | 7/7/2016 18:28     | 10354095027  | Lead    | 6       | 15               | ppb   |
| 031-15A Girls Bathroom - Sink Faucet (2)               | 6/27/2016 23:32     | 7/7/2016 18:30     | 10354095029  | Copper  | 0.1     | 1.3              | ppm   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Da Vinci Arts Middle School

| Sample Identification # and Location     | Date/Time Collected | Date/Time Analyzed | Container ID | Analyte | Results | EPA Action Level | Units |
|------------------------------------------|---------------------|--------------------|--------------|---------|---------|------------------|-------|
| 031-15A Girls Bathroom - Sink Faucet (2) | 6/27/2016 23:32     | 7/7/2016 18:30     | 10354095029  | Lead    | 12      | 15               | ppb   |
| 031-16A Hall - Drinking Fountain         | 6/27/2016 23:35     | 7/7/2016 18:31     | 10354095031  | Copper  | 0.2     | 1.3              | ppm   |
| 031-16A Hall - Drinking Fountain         | 6/27/2016 23:35     | 7/7/2016 18:31     | 10354095031  | Lead    | 10      | 15               | ppb   |
| 031-17A Boys Bathroom - Sink Faucet (1)  | 6/27/2016 23:37     | 7/7/2016 19:03     | 10354095033  | Copper  | 0.3     | 1.3              | ppm   |
| 031-17A Boys Bathroom - Sink Faucet (1)  | 6/27/2016 23:37     | 7/7/2016 19:03     | 10354095033  | Lead    | 13      | 15               | ppb   |
| 031-18A Boys Bathroom - Sink Faucet (2)  | 6/27/2016 23:39     | 7/7/2016 22:24     | 10354095035  | Copper  | 0.8     | 1.3              | ppm   |
| 031-18A Boys Bathroom - Sink Faucet (2)  | 6/27/2016 23:39     | 7/7/2016 22:24     | 10354095035  | Lead    | 5       | 15               | ppb   |
| 031-19A Classroom 105 - Sink Faucet (1)  | 6/27/2016 23:42     | 7/7/2016 18:32     | 10354095037  | Copper  | 0.1     | 1.3              | ppm   |
| 031-19A Classroom 105 - Sink Faucet (1)  | 6/27/2016 23:42     | 7/7/2016 18:32     | 10354095037  | Lead    | 24      | 15               | ppb   |
| 031-20A Classroom 105 - Sink Faucet (2)  | 6/27/2016 23:44     | 7/7/2016 18:34     | 10354095039  | Copper  | 0.1     | 1.3              | ppm   |
| 031-20A Classroom 105 - Sink Faucet (2)  | 6/27/2016 23:44     | 7/7/2016 18:34     | 10354095039  | Lead    | 17      | 15               | ppb   |
| 031-21A Classroom 105 - Sink Faucet (3)  | 6/27/2016 23:46     | 7/7/2016 18:35     | 10354095041  | Copper  | 0.1     | 1.3              | ppm   |
| 031-21A Classroom 105 - Sink Faucet (3)  | 6/27/2016 23:46     | 7/7/2016 18:35     | 10354095041  | Lead    | 58      | 15               | ppb   |
| 031-22A Classroom 105 - Eyewash          | 6/27/2016 23:48     | 7/7/2016 15:30     | 10354095043  | Copper  | 0.2     | 1.3              | ppm   |
| 031-22A Classroom 105 - Eyewash          | 6/27/2016 23:48     | 7/7/2016 15:30     | 10354095043  | Lead    | 20      | 15               | ppb   |
| 031-23A Classroom 105 - Sink Faucet (4)  | 6/27/2016 23:50     | 7/7/2016 15:35     | 10354095045  | Copper  | 0.3     | 1.3              | ppm   |
| 031-23A Classroom 105 - Sink Faucet (4)  | 6/27/2016 23:50     | 7/7/2016 15:35     | 10354095045  | Lead    | 16      | 15               | ppb   |
| 031-24A Classroom 105 - Sink Faucet (5)  | 6/27/2016 23:52     | 7/7/2016 15:36     | 10354095047  | Copper  | 0.2     | 1.3              | ppm   |
| 031-24A Classroom 105 - Sink Faucet (5)  | 6/27/2016 23:52     | 7/7/2016 15:36     | 10354095047  | Lead    | 63      | 15               | ppb   |
| 031-25A Classroom 105 - Sink Faucet (6)  | 6/27/2016 23:54     | 7/7/2016 15:37     | 10354095049  | Copper  | 0.0     | 1.3              | ppm   |
| 031-25A Classroom 105 - Sink Faucet (6)  | 6/27/2016 23:54     | 7/7/2016 15:37     | 10354095049  | Lead    | 55      | 15               | ppb   |
| 031-26A Classroom 105 - Sink Faucet (7)  | 6/27/2016 23:56     | 7/7/2016 15:38     | 10354095051  | Copper  | 0.1     | 1.3              | ppm   |
| 031-26A Classroom 105 - Sink Faucet (7)  | 6/27/2016 23:56     | 7/7/2016 15:38     | 10354095051  | Lead    | 50      | 15               | ppb   |
| 031-27A Hall - Drinking Fountain (1)     | 6/27/2016 23:59     | 7/7/2016 18:37     | 10354095053  | Copper  | 0.0     | 1.3              | ppm   |
| 031-27A Hall - Drinking Fountain (1)     | 6/27/2016 23:59     | 7/7/2016 18:37     | 10354095053  | Lead    | 8       | 15               | ppb   |
| 031-28A Hall - Drinking Fountain (2)     | 6/28/2016 00:01     | 7/7/2016 15:42     | 10354095055  | Copper  | 0.0     | 1.3              | ppm   |
| 031-28A Hall - Drinking Fountain (2)     | 6/28/2016 00:01     | 7/7/2016 15:42     | 10354095055  | Lead    | 4       | 15               | ppb   |
| 031-29A Bathroom - Sink Faucet           | 6/28/2016 00:04     | 7/7/2016 15:43     | 10354095057  | Copper  | 0.1     | 1.3              | ppm   |
| 031-29A Bathroom - Sink Faucet           | 6/28/2016 00:04     | 7/7/2016 15:43     | 10354095057  | Lead    | 7       | 15               | ppb   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Da Vinci Arts Middle School

| Sample Identification # and Location             | Date/Time Collected | Date/Time Analyzed | Container ID | Analyte | Results | EPA Action Level | Units |
|--------------------------------------------------|---------------------|--------------------|--------------|---------|---------|------------------|-------|
| 031-30A Hall - Drinking Fountain (1)             | 6/28/2016 00:05     | 7/7/2016 15:44     | 10354095059  | Copper  | 0.0     | 1.3              | ppm   |
| 031-30A Hall - Drinking Fountain (1)             | 6/28/2016 00:05     | 7/7/2016 15:44     | 10354095059  | Lead    | 7       | 15               | ppb   |
| 031-31A Hall - Drinking Fountain (2)             | 6/28/2016 00:07     | 7/7/2016 15:45     | 10354095061  | Copper  | 0.0     | 1.3              | ppm   |
| 031-31A Hall - Drinking Fountain (2)             | 6/28/2016 00:07     | 7/7/2016 15:45     | 10354095061  | Lead    | 3       | 15               | ppb   |
| 031-32A Locker Room Bathroom - Sink Faucet       | 6/28/2016 00:09     | 7/8/2016 08:03     | 10354095063  | Copper  | 1.0     | 1.3              | ppm   |
| 031-32A Locker Room Bathroom - Sink Faucet       | 6/28/2016 00:09     | 7/8/2016 08:03     | 10354095063  | Lead    | 1730    | 15               | ppb   |
| 031-33A Classroom 112A - Sink Faucet             | 6/28/2016 00:11     | 7/7/2016 15:47     | 10354095065  | Copper  | 0.0     | 1.3              | ppm   |
| 031-33A Classroom 112A - Sink Faucet             | 6/28/2016 00:11     | 7/7/2016 15:47     | 10354095065  | Lead    | 2       | 15               | ppb   |
| 031-34A Classroom 102 - Sink Faucet              | 6/28/2016 00:13     | 7/7/2016 15:48     | 10354095067  | Copper  | 0.0     | 1.3              | ppm   |
| 031-34A Classroom 102 - Sink Faucet              | 6/28/2016 00:13     | 7/7/2016 15:48     | 10354095067  | Lead    | 5       | 15               | ppb   |
| 031-35A Hall - Drinking Fountain next to 102 (1) | 6/28/2016 00:14     | 7/7/2016 15:50     | 10354095069  | Copper  | 0.0     | 1.3              | ppm   |
| 031-35A Hall - Drinking Fountain next to 102 (1) | 6/28/2016 00:14     | 7/7/2016 15:50     | 10354095069  | Lead    | 11      | 15               | ppb   |
| 031-36A Hall - Drinking Fountain next to 102 (2) | 6/28/2016 00:16     | 7/7/2016 15:51     | 10354095071  | Copper  | 0.0     | 1.3              | ppm   |
| 031-36A Hall - Drinking Fountain next to 102 (2) | 6/28/2016 00:16     | 7/7/2016 15:51     | 10354095071  | Lead    | 6       | 15               | ppb   |
| 031-37A Classroom 101 - Sink Faucet (1)          | 6/28/2016 00:19     | 7/7/2016 18:42     | 10354095073  | Copper  | 0.4     | 1.3              | ppm   |
| 031-37A Classroom 101 - Sink Faucet (1)          | 6/28/2016 00:19     | 7/7/2016 18:42     | 10354095073  | Lead    | 129     | 15               | ppb   |
| 031-38A Classroom 101 - Eyewash                  | 6/28/2016 00:21     | 7/7/2016 18:45     | 10354095075  | Copper  | 0.2     | 1.3              | ppm   |
| 031-38A Classroom 101 - Eyewash                  | 6/28/2016 00:21     | 7/7/2016 18:45     | 10354095075  | Lead    | 25      | 15               | ppb   |
| 031-39A Classroom 101 - Sink Faucet (2)          | 6/28/2016 00:23     | 7/7/2016 18:46     | 10354095077  | Copper  | 0.1     | 1.3              | ppm   |
| 031-39A Classroom 101 - Sink Faucet (2)          | 6/28/2016 00:23     | 7/7/2016 18:46     | 10354095077  | Lead    | 89      | 15               | ppb   |
| 031-40A Classroom 101 - Sink Faucet (3)          | 6/28/2016 00:25     | 7/7/2016 18:48     | 10354095079  | Copper  | 0.1     | 1.3              | ppm   |
| 031-40A Classroom 101 - Sink Faucet (3)          | 6/28/2016 00:25     | 7/7/2016 18:48     | 10354095079  | Lead    | 160     | 15               | ppb   |
| 031-41A Classroom 101 - Sink Faucet (4)          | 6/28/2016 00:27     | 7/7/2016 18:49     | 10354095081  | Copper  | 0.2     | 1.3              | ppm   |
| 031-41A Classroom 101 - Sink Faucet (4)          | 6/28/2016 00:27     | 7/7/2016 18:49     | 10354095081  | Lead    | 177     | 15               | ppb   |
| 031-42A Classroom 101 - Sink Faucet (5)          | 6/28/2016 00:29     | 7/7/2016 18:51     | 10354095083  | Copper  | 0.1     | 1.3              | ppm   |
| 031-42A Classroom 101 - Sink Faucet (5)          | 6/28/2016 00:29     | 7/7/2016 18:51     | 10354095083  | Lead    | 63      | 15               | ppb   |
| 031-43A Classroom 101 - Sink Faucet (6)          | 6/28/2016 00:31     | 7/7/2016 18:52     | 10354095085  | Copper  | 0.3     | 1.3              | ppm   |
| 031-43A Classroom 101 - Sink Faucet (6)          | 6/28/2016 00:31     | 7/8/2016 08:07     | 10354095085  | Lead    | 936     | 15               | ppb   |
| 031-44A Classroom 101 - Sink Faucet (7)          | 6/28/2016 00:33     | 7/7/2016 18:53     | 10354095087  | Copper  | 0.4     | 1.3              | ppm   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Da Vinci Arts Middle School

| Sample Identification # and Location    | Date/Time Collected | Date/Time Analyzed | Container ID | Analyte | Results | EPA Action Level | Units |
|-----------------------------------------|---------------------|--------------------|--------------|---------|---------|------------------|-------|
| 031-44A Classroom 101 - Sink Faucet (7) | 6/28/2016 00:33     | 7/8/2016 08:09     | 10354095087  | Lead    | 1730    | 15               | ppb   |
| 031-45A Classroom 101 - Sink Faucet (8) | 6/28/2016 00:36     | 7/7/2016 19:00     | 10354095089  | Copper  | 0.2     | 1.3              | ppm   |
| 031-45A Classroom 101 - Sink Faucet (8) | 6/28/2016 00:36     | 7/7/2016 19:00     | 10354095089  | Lead    | 124     | 15               | ppb   |
| 031-46A Custodial - Sink Faucet         | 6/28/2016 00:38     | 7/7/2016 16:02     | 10354095091  | Copper  | 0.0     | 1.3              | ppm   |
| 031-46A Custodial - Sink Faucet         | 6/28/2016 00:38     | 7/7/2016 16:02     | 10354095091  | Lead    | 1       | 15               | ppb   |
| 031-47A Classroom 100 - Sink Faucet (1) | 6/28/2016 00:40     | 7/7/2016 16:09     | 10354095093  | Copper  | 0.3     | 1.3              | ppm   |
| 031-47A Classroom 100 - Sink Faucet (1) | 6/28/2016 00:40     | 7/7/2016 16:09     | 10354095093  | Lead    | 4       | 15               | ppb   |
| 031-48A Classroom 100 - Sink Faucet (2) | 6/28/2016 00:42     | 7/7/2016 16:10     | 10354095095  | Copper  | 0.2     | 1.3              | ppm   |
| 031-48A Classroom 100 - Sink Faucet (2) | 6/28/2016 00:42     | 7/7/2016 16:10     | 10354095095  | Lead    | 25      | 15               | ppb   |
| 031-49A Green Annex - Sink Faucet       | 6/28/2016 00:58     | 7/7/2016 19:02     | 10354095097  | Copper  | 0.0     | 1.3              | ppm   |
| 031-49A Green Annex - Sink Faucet       | 6/28/2016 00:58     | 7/7/2016 19:02     | 10354095097  | Lead    | 4       | 15               | ppb   |
| 031-50A Green Annex - Drinking Fountain | 6/28/2016 01:00     | 7/7/2016 09:38     | 10354095099  | Copper  | 0.1     | 1.3              | ppm   |
| 031-50A Green Annex - Drinking Fountain | 6/28/2016 01:00     | 7/7/2016 09:38     | 10354095099  | Lead    | 34      | 15               | ppb   |
| 031-51A Classroom 208 - Sink Faucet (1) | 6/28/2016 01:03     | 7/7/2016 16:11     | 10354095101  | Copper  | 0.0     | 1.3              | ppm   |
| 031-51A Classroom 208 - Sink Faucet (1) | 6/28/2016 01:03     | 7/7/2016 16:11     | 10354095101  | Lead    | 18      | 15               | ppb   |
| 031-52A Classroom 208 - Sink Faucet (2) | 6/28/2016 01:05     | 7/7/2016 16:12     | 10354095103  | Copper  | 0.0     | 1.3              | ppm   |
| 031-52A Classroom 208 - Sink Faucet (2) | 6/28/2016 01:05     | 7/7/2016 16:12     | 10354095103  | Lead    | 14.8    | 15               | ppb   |
| 031-53A Room 209 Bathroom - Sink Faucet | 6/28/2016 01:07     | 7/7/2016 16:16     | 10354095105  | Copper  | 0.1     | 1.3              | ppm   |
| 031-53A Room 209 Bathroom - Sink Faucet | 6/28/2016 01:07     | 7/7/2016 16:16     | 10354095105  | Lead    | 10      | 15               | ppb   |
| 031-54A Custodial - Sink Faucet         | 6/28/2016 01:09     | 7/7/2016 16:17     | 10354095107  | Copper  | 0.1     | 1.3              | ppm   |
| 031-54A Custodial - Sink Faucet         | 6/28/2016 01:09     | 7/7/2016 16:17     | 10354095107  | Lead    | 6       | 15               | ppb   |
| 031-55A Classroom 207 - Sink Faucet     | 6/28/2016 01:10     | 7/7/2016 16:18     | 10354095109  | Copper  | 0.1     | 1.3              | ppm   |
| 031-55A Classroom 207 - Sink Faucet     | 6/28/2016 01:10     | 7/7/2016 16:18     | 10354095109  | Lead    | 21      | 15               | ppb   |
| 031-56A Classroom 207 - Water Filter    | 6/28/2016 01:12     | 7/7/2016 16:19     | 10354095111  | Copper  | 0.0     | 1.3              | ppm   |
| 031-56A Classroom 207 - Water Filter    | 6/28/2016 01:12     | 7/7/2016 16:19     | 10354095111  | Lead    | 1       | 15               | ppb   |
| 031-57A Boys Bathroom - Sink Faucet     | 6/28/2016 01:15     | 7/7/2016 16:21     | 10354095113  | Copper  | 0.1     | 1.3              | ppm   |
| 031-57A Boys Bathroom - Sink Faucet     | 6/28/2016 01:15     | 7/7/2016 16:21     | 10354095113  | Lead    | 7       | 15               | ppb   |
| 031-58A Boys Bathroom - Sink Faucet     | 6/28/2016 01:17     | 7/7/2016 14:38     | 10354095115  | Copper  | 0.9     | 1.3              | ppm   |
| 031-58A Boys Bathroom - Sink Faucet     | 6/28/2016 01:17     | 7/7/2016 09:39     | 10354095115  | Lead    | 85      | 15               | ppb   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Da Vinci Arts Middle School

| Sample Identification # and Location  | Date/Time Collected | Date/Time Analyzed | Container ID | Analyte | Results | EPA Action Level | Units |
|---------------------------------------|---------------------|--------------------|--------------|---------|---------|------------------|-------|
| 031-59A Boys Bathroom - Sink Faucet   | 6/28/2016 01:19     | 7/7/2016 16:22     | 10354095117  | Copper  | 0.1     | 1.3              | ppm   |
| 031-59A Boys Bathroom - Sink Faucet   | 6/28/2016 01:19     | 7/7/2016 16:22     | 10354095117  | Lead    | 4       | 15               | ppb   |
| 031-60A Boys Bathroom - Water Spigot  | 6/28/2016 01:21     | 7/7/2016 16:25     | 10354095119  | Copper  | 0.1     | 1.3              | ppm   |
| 031-60A Boys Bathroom - Water Spigot  | 6/28/2016 01:21     | 7/7/2016 16:25     | 10354095119  | Lead    | 84      | 15               | ppb   |
| 031-61A Hall - Drinking Fountain      | 6/28/2016 01:23     | 7/7/2016 16:56     | 10354095121  | Copper  | 0.1     | 1.3              | ppm   |
| 031-61A Hall - Drinking Fountain      | 6/28/2016 01:23     | 7/7/2016 16:56     | 10354095121  | Lead    | 5       | 15               | ppb   |
| 031-62A Room 205 Office - Sink Faucet | 6/28/2016 01:25     | 7/7/2016 17:01     | 10354095123  | Copper  | 0.1     | 1.3              | ppm   |
| 031-62A Room 205 Office - Sink Faucet | 6/28/2016 01:25     | 7/7/2016 17:01     | 10354095123  | Lead    | 3       | 15               | ppb   |
| 031-63A Girls Bathroom - Sink Faucet  | 6/28/2016 01:28     | 7/7/2016 17:02     | 10354095125  | Copper  | 0.1     | 1.3              | ppm   |
| 031-63A Girls Bathroom - Sink Faucet  | 6/28/2016 01:28     | 7/7/2016 17:02     | 10354095125  | Lead    | 3       | 15               | ppb   |
| 031-64A Girls Bathroom - Water Spigot | 6/28/2016 01:30     | 7/7/2016 17:03     | 10354095127  | Copper  | 0.1     | 1.3              | ppm   |
| 031-64A Girls Bathroom - Water Spigot | 6/28/2016 01:30     | 7/7/2016 17:03     | 10354095127  | Lead    | 14      | 15               | ppb   |
| 031-65A Nurses - Sink Faucet          | 6/28/2016 01:32     | 7/7/2016 17:04     | 10354095129  | Copper  | 0.0     | 1.3              | ppm   |
| 031-65A Nurses - Sink Faucet          | 6/28/2016 01:32     | 7/7/2016 17:04     | 10354095129  | Lead    | 2       | 15               | ppb   |
| 031-66A Classroom 204 - Sink Faucet   | 6/28/2016 01:35     | 7/7/2016 09:40     | 10354095131  | Copper  | 0.1     | 1.3              | ppm   |
| 031-66A Classroom 204 - Sink Faucet   | 6/28/2016 01:35     | 7/7/2016 09:40     | 10354095131  | Lead    | 213     | 15               | ppb   |
| 031-67A Hall - Drinking Fountain (1)  | 6/28/2016 01:37     | 7/7/2016 09:41     | 10354095133  | Copper  | 0.0     | 1.3              | ppm   |
| 031-67A Hall - Drinking Fountain (1)  | 6/28/2016 01:37     | 7/7/2016 09:41     | 10354095133  | Lead    | 5       | 15               | ppb   |
| 031-68A Hall - Drinking Fountain (2)  | 6/28/2016 01:39     | 7/7/2016 17:08     | 10354095135  | Copper  | 0.0     | 1.3              | ppm   |
| 031-68A Hall - Drinking Fountain (2)  | 6/28/2016 01:39     | 7/7/2016 17:08     | 10354095135  | Lead    | 5       | 15               | ppb   |
| 031-69A Hall - Drinking Fountain (3)  | 6/28/2016 01:42     | 7/7/2016 17:09     | 10354095137  | Copper  | 0.0     | 1.3              | ppm   |
| 031-69A Hall - Drinking Fountain (3)  | 6/28/2016 01:42     | 7/7/2016 17:09     | 10354095137  | Lead    | 2       | 15               | ppb   |
| 031-70A Hall - Drinking Fountain (4)  | 6/28/2016 01:44     | 7/7/2016 17:10     | 10354095139  | Copper  | 0.0     | 1.3              | ppm   |
| 031-70A Hall - Drinking Fountain (4)  | 6/28/2016 01:44     | 7/7/2016 17:10     | 10354095139  | Lead    | 2       | 15               | ppb   |
| 031-71A Classroom 203 - Sink Faucet   | 6/28/2016 01:46     | 7/7/2016 17:11     | 10354095141  | Copper  | 0.1     | 1.3              | ppm   |
| 031-71A Classroom 203 - Sink Faucet   | 6/28/2016 01:46     | 7/7/2016 17:11     | 10354095141  | Lead    | 21      | 15               | ppb   |
| 031-72A Classroom 213A - Sink Faucet  | 6/28/2016 01:47     | 7/7/2016 17:13     | 10354095143  | Copper  | 0.0     | 1.3              | ppm   |
| 031-72A Classroom 213A - Sink Faucet  | 6/28/2016 01:47     | 7/7/2016 17:13     | 10354095143  | Lead    | 13      | 15               | ppb   |
| 031-73A Hall - Drinking Fountain (1)  | 6/28/2016 01:49     | 7/7/2016 17:14     | 10354095145  | Copper  | 0.0     | 1.3              | ppm   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Da Vinci Arts Middle School

| Sample Identification # and Location | Date/Time Collected | Date/Time Analyzed | Container ID | Analyte | Results | EPA Action Level | Units |
|--------------------------------------|---------------------|--------------------|--------------|---------|---------|------------------|-------|
| 031-73A Hall - Drinking Fountain (1) | 6/28/2016 01:49     | 7/7/2016 17:14     | 10354095145  | Lead    | 6       | 15               | ppb   |
| 031-74A Hall - Drinking Fountain (2) | 6/28/2016 01:51     | 7/7/2016 17:17     | 10354095147  | Copper  | 0.0     | 1.3              | ppm   |
| 031-74A Hall - Drinking Fountain (2) | 6/28/2016 01:51     | 7/7/2016 17:17     | 10354095147  | Lead    | 4       | 15               | ppb   |
| 031-75A Classroom 200 - Sink Faucet  | 6/28/2016 01:54     | 7/7/2016 17:18     | 10354095149  | Copper  | 0.0     | 1.3              | ppm   |
| 031-75A Classroom 200 - Sink Faucet  | 6/28/2016 01:54     | 7/7/2016 17:18     | 10354095149  | Lead    | 11      | 15               | ppb   |
| 031-76A Classroom 201 - Sink Faucet  | 6/28/2016 01:56     | 7/7/2016 17:20     | 10354095151  | Copper  | 0.0     | 1.3              | ppm   |
| 031-76A Classroom 201 - Sink Faucet  | 6/28/2016 01:56     | 7/7/2016 17:20     | 10354095151  | Lead    | 17      | 15               | ppb   |
| 031-77A Classroom 300 - Sink Faucet  | 6/28/2016 01:59     | 7/7/2016 09:55     | 10354095153  | Copper  | 0.1     | 1.3              | ppm   |
| 031-77A Classroom 300 - Sink Faucet  | 6/28/2016 01:59     | 7/7/2016 09:55     | 10354095153  | Lead    | 152     | 15               | ppb   |
| 031-78A Classroom 301 - Sink Faucet  | 6/28/2016 02:01     | 7/7/2016 17:25     | 10354095155  | Copper  | 0.0     | 1.3              | ppm   |
| 031-78A Classroom 301 - Sink Faucet  | 6/28/2016 02:01     | 7/7/2016 17:25     | 10354095155  | Lead    | 5       | 15               | ppb   |
| 031-79A Custodian - Sink Faucet      | 6/28/2016 02:04     | 7/7/2016 17:26     | 10354095157  | Copper  | 0.0     | 1.3              | ppm   |
| 031-79A Custodian - Sink Faucet      | 6/28/2016 02:04     | 7/7/2016 17:26     | 10354095157  | Lead    | 3       | 15               | ppb   |
| 031-80A Hall - Drinking Fountain (1) | 6/28/2016 02:06     | 7/7/2016 09:56     | 10354095159  | Copper  | 0.0     | 1.3              | ppm   |
| 031-80A Hall - Drinking Fountain (1) | 6/28/2016 02:06     | 7/7/2016 09:56     | 10354095159  | Lead    | 24      | 15               | ppb   |
| 031-81A Hall - Drinking Fountain (2) | 6/28/2016 02:08     | 7/7/2016 09:57     | 10354095161  | Copper  | 0.1     | 1.3              | ppm   |
| 031-81A Hall - Drinking Fountain (2) | 6/28/2016 02:08     | 7/7/2016 09:57     | 10354095161  | Lead    | 4       | 15               | ppb   |
| 031-82A Staff Restroom - Sink Faucet | 6/28/2016 02:11     | 7/7/2016 17:29     | 10354095163  | Copper  | 0.1     | 1.3              | ppm   |
| 031-82A Staff Restroom - Sink Faucet | 6/28/2016 02:11     | 7/7/2016 17:29     | 10354095163  | Lead    | 6       | 15               | ppb   |
| 031-83A Classroom 304 - Sink Faucet  | 6/28/2016 02:12     | 7/7/2016 17:35     | 10354095165  | Copper  | 0.1     | 1.3              | ppm   |
| 031-83A Classroom 304 - Sink Faucet  | 6/28/2016 02:12     | 7/7/2016 17:35     | 10354095165  | Lead    | 61      | 15               | ppb   |
| 031-84A Hall - Drinking Fountain (1) | 6/28/2016 02:15     | 7/7/2016 17:36     | 10354095167  | Copper  | 0.0     | 1.3              | ppm   |
| 031-84A Hall - Drinking Fountain (1) | 6/28/2016 02:15     | 7/7/2016 17:36     | 10354095167  | Lead    | 2       | 15               | ppb   |
| 031-85A Hall - Drinking Fountain (2) | 6/28/2016 02:16     | 7/7/2016 17:43     | 10354095169  | Copper  | 0.0     | 1.3              | ppm   |
| 031-85A Hall - Drinking Fountain (2) | 6/28/2016 02:16     | 7/8/2016 07:02     | 10354095169  | Lead    | 2       | 15               | ppb   |
| 031-86A Upper Auditorium (1)         | 6/28/2016 02:18     | 7/7/2016 17:44     | 10354095171  | Copper  | 0.1     | 1.3              | ppm   |
| 031-86A Upper Auditorium (1)         | 6/28/2016 02:18     | 7/8/2016 07:03     | 10354095171  | Lead    | 40      | 15               | ppb   |
| 031-87A Upper Auditorium (2)         | 6/28/2016 02:20     | 7/7/2016 17:45     | 10354095173  | Copper  | 0.0     | 1.3              | ppm   |
| 031-87A Upper Auditorium (2)         | 6/28/2016 02:20     | 7/8/2016 07:04     | 10354095173  | Lead    | 50      | 15               | ppb   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Da Vinci Arts Middle School

| Sample Identification # and Location     | Date/Time Collected | Date/Time Analyzed | Container ID | Analyte | Results | EPA Action Level | Units |
|------------------------------------------|---------------------|--------------------|--------------|---------|---------|------------------|-------|
| 031-88A Hall - Drinking Fountain         | 6/28/2016 02:23     | 7/7/2016 17:46     | 10354095175  | Copper  | 0.0     | 1.3              | ppm   |
| 031-88A Hall - Drinking Fountain         | 6/28/2016 02:23     | 7/8/2016 07:06     | 10354095175  | Lead    | 19      | 15               | ppb   |
| 031-89A Girls Bathroom - Sink Faucet (1) | 6/28/2016 02:26     | 7/7/2016 09:58     | 10354095177  | Copper  | 0.1     | 1.3              | ppm   |
| 031-89A Girls Bathroom - Sink Faucet (1) | 6/28/2016 02:26     | 7/7/2016 09:58     | 10354095177  | Lead    | 25      | 15               | ppb   |
| 031-90A Girls Bathroom - Sink Faucet (2) | 6/28/2016 02:28     | 7/7/2016 17:48     | 10354095179  | Copper  | 0.1     | 1.3              | ppm   |
| 031-90A Girls Bathroom - Sink Faucet (2) | 6/28/2016 02:28     | 7/8/2016 07:07     | 10354095179  | Lead    | 12      | 15               | ppb   |
| 031-91A Girls Bathroom - Sink Faucet (3) | 6/28/2016 02:30     | 7/7/2016 17:49     | 10354095181  | Copper  | 0.1     | 1.3              | ppm   |
| 031-91A Girls Bathroom - Sink Faucet (3) | 6/28/2016 02:30     | 7/8/2016 07:09     | 10354095181  | Lead    | 10      | 15               | ppb   |
| 031-92A Hall - Drinking Fountain         | 6/28/2016 02:33     | 7/7/2016 17:50     | 10354095183  | Copper  | 0.2     | 1.3              | ppm   |
| 031-92A Hall - Drinking Fountain         | 6/28/2016 02:33     | 7/8/2016 07:10     | 10354095183  | Lead    | 1       | 15               | ppb   |
| 031-93A Classroom 308 - Sink Faucet      | 6/28/2016 02:36     | 7/7/2016 17:51     | 10354095185  | Copper  | 0.1     | 1.3              | ppm   |
| 031-93A Classroom 308 - Sink Faucet      | 6/28/2016 02:36     | 7/8/2016 07:11     | 10354095185  | Lead    | 12      | 15               | ppb   |
| 031-94A Classroom 309 - Sink Faucet      | 6/28/2016 02:38     | 7/7/2016 17:55     | 10354095187  | Copper  | 0.1     | 1.3              | ppm   |
| 031-94A Classroom 309 - Sink Faucet      | 6/28/2016 02:38     | 7/8/2016 07:14     | 10354095187  | Lead    | 7       | 15               | ppb   |
| 031-95A Annex F - Sink Faucet            | 6/28/2016 02:59     | 7/7/2016 17:59     | 10354095189  | Copper  | 0.0     | 1.3              | ppm   |
| 031-95A Annex F - Sink Faucet            | 6/28/2016 02:59     | 7/8/2016 07:18     | 10354095189  | Lead    | 5       | 15               | ppb   |
| 031-96A Water Spigot on Boiler Room      | 6/28/2016 02:45     | 7/7/2016 18:00     | 10354095191  | Copper  | 0.0     | 1.3              | ppm   |
| 031-96A Water Spigot on Boiler Room      | 6/28/2016 02:45     | 7/8/2016 07:19     | 10354095191  | Lead    | 5       | 15               | ppb   |
| 031-97A Water Spigot in Fenced Courtyard | 6/28/2016 02:50     | 7/7/2016 18:01     | 10354095193  | Copper  | 0.0     | 1.3              | ppm   |
| 031-97A Water Spigot in Fenced Courtyard | 6/28/2016 02:50     | 7/8/2016 07:21     | 10354095193  | Lead    | 2       | 15               | ppb   |

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

**Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.**