

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Duniway Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
032 01A Boiler Room Sink Faucet	6/26/2016 20:32	7/7/2016 23:28	10354064001	Copper	0.1	1.3	ppm
032 01A Boiler Room Sink Faucet	6/26/2016 20:32	7/7/2016 23:28	10354064001	Lead	11	15	ppb
032 02A Gymnasium Office Bathroom Sink Faucet	6/26/2016 20:38	7/7/2016 23:34	10354064003	Copper	0.2	1.3	ppm
032 02A Gymnasium Office Bathroom Sink Faucet	6/26/2016 20:38	7/7/2016 23:34	10354064003	Lead	16	15	ppb
032 03A South Gymnasium Wall Water Spigot	6/26/2016 20:41	7/7/2016 23:38	10354064005	Copper	0.0	1.3	ppm
032 03A South Gymnasium Wall Water Spigot	6/26/2016 20:41	7/7/2016 23:38	10354064005	Lead	21	15	ppb
032 04A Drinking Fountain Outside Gymnasium (1)	6/26/2016 20:44	7/7/2016 23:39	10354064007	Copper	0.0	1.3	ppm
032 04A Drinking Fountain Outside Gymnasium (1)	6/26/2016 20:44	7/7/2016 23:39	10354064007	Lead	36	15	ppb
032 05A Drinking Fountain Outside Gymnasium (2)	6/26/2016 20:44	7/7/2016 23:41	10354064009	Copper	0.0	1.3	ppm
032 05A Drinking Fountain Outside Gymnasium (2)	6/26/2016 20:44	7/7/2016 23:41	10354064009	Lead	33	15	ppb
032 06A Electrical Closet Sink Faucet	6/26/2016 20:47	7/7/2016 23:42	10354064011	Copper	0.3	1.3	ppm
032 06A Electrical Closet Sink Faucet	6/26/2016 20:47	7/7/2016 23:42	10354064011	Lead	52	15	ppb
032 07A Girls Bathroom Sink Faucet (1)	6/26/2016 20:50	7/7/2016 23:43	10354064013	Copper	0.1	1.3	ppm
032 07A Girls Bathroom Sink Faucet (1)	6/26/2016 20:50	7/7/2016 23:43	10354064013	Lead	8	15	ppb
032 08A Girls Bathroom Sink Faucet (2)	6/26/2016 20:50	7/7/2016 23:45	10354064015	Copper	0.1	1.3	ppm
032 08A Girls Bathroom Sink Faucet (2)	6/26/2016 20:50	7/7/2016 23:45	10354064015	Lead	6	15	ppb
032 09A Girls Bathroom Water Spigot	6/26/2016 20:52	7/7/2016 15:06	10354064017	Copper	1.8	1.3	ppm
032 09A Girls Bathroom Water Spigot	6/26/2016 20:52	7/7/2016 12:26	10354064017	Lead	166	15	ppb
032 10A Room 18 Sink Faucet	6/26/2016 20:54	7/7/2016 23:46	10354064019	Copper	0.4	1.3	ppm
032 10A Room 18 Sink Faucet	6/26/2016 20:54	7/7/2016 23:46	10354064019	Lead	27	15	ppb
032 11A Room 18 Drinking Fountain	6/26/2016 20:54	7/7/2016 23:48	10354064021	Copper	0.2	1.3	ppm
032 11A Room 18 Drinking Fountain	6/26/2016 20:54	7/7/2016 23:48	10354064021	Lead	7	15	ppb
032 12A Room 17 Sink Faucet	6/26/2016 20:58	7/7/2016 23:49	10354064023	Copper	0.3	1.3	ppm
032 12A Room 17 Sink Faucet	6/26/2016 20:58	7/7/2016 23:49	10354064023	Lead	28	15	ppb
032 13A Room 17 Drinking Fountain	6/26/2016 20:58	7/7/2016 23:54	10354064025	Copper	0.0	1.3	ppm
032 13A Room 17 Drinking Fountain	6/26/2016 20:58	7/7/2016 23:54	10354064025	Lead	2	15	ppb
032 14A Boys Bathroom Sink Faucet	6/26/2016 21:01	7/7/2016 23:56	10354064027	Copper	0.2	1.3	ppm
032 14A Boys Bathroom Sink Faucet	6/26/2016 21:01	7/7/2016 23:56	10354064027	Lead	6	15	ppb
032 15A Drinking Fountain Hallway (1)	6/26/2016 21:03	7/7/2016 23:57	10354064029	Copper	0.0	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Duniway Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
032 15A Drinking Fountain Hallway (1)	6/26/2016 21:03	7/7/2016 23:57	10354064029	Lead	3	15	ppb
032 15A Drinking Fountain Hallway (2)	6/26/2016 21:03	7/7/2016 23:59	10354064031	Copper	0.0	1.3	ppm
032 15A Drinking Fountain Hallway (2)	6/26/2016 21:03	7/7/2016 23:59	10354064031	Lead	4	15	ppb
032 17A Room 16 Sink Faucet	6/26/2016 21:06	7/8/2016 00:00	10354064033	Copper	0.1	1.3	ppm
032 17A Room 16 Sink Faucet	6/26/2016 21:06	7/8/2016 00:00	10354064033	Lead	10	15	ppb
032 18A Room 16 Drinking Fountain	6/26/2016 21:06	7/8/2016 00:01	10354064035	Copper	0.2	1.3	ppm
032 18A Room 16 Drinking Fountain	6/26/2016 21:06	7/8/2016 00:01	10354064035	Lead	24	15	ppb
032 19A Room 14 Library Sink Faucet	6/26/2016 21:09	7/8/2016 00:03	10354064037	Copper	0.0	1.3	ppm
032 19A Room 14 Library Sink Faucet	6/26/2016 21:09	7/8/2016 00:03	10354064037	Lead	14.6	15	ppb
032 20A Office Bathroom Sink Faucet	6/26/2016 21:12	7/8/2016 00:04	10354064039	Copper	0.1	1.3	ppm
032 20A Office Bathroom Sink Faucet	6/26/2016 21:12	7/8/2016 00:04	10354064039	Lead	29	15	ppb
032 21A Nurses Staff Bathroom Sink Faucet	6/26/2016 21:14	7/7/2016 20:00	10354064041	Copper	0.2	1.3	ppm
032 21A Nurses Staff Bathroom Sink Faucet	6/26/2016 21:14	7/7/2016 20:00	10354064041	Lead	18	15	ppb
032 22A Girls Bathroom Sink Faucet (1)	6/26/2016 21:22	7/7/2016 12:28	10354064043	Copper	0.1	1.3	ppm
032 22A Girls Bathroom Sink Faucet (1)	6/26/2016 21:22	7/7/2016 12:28	10354064043	Lead	44	15	ppb
032 23A Girls Bathroom Sink Faucet (2)	6/26/2016 21:22	7/7/2016 20:06	10354064045	Copper	0.2	1.3	ppm
032 23A Girls Bathroom Sink Faucet (2)	6/26/2016 21:22	7/7/2016 20:06	10354064045	Lead	15.1	15	ppb
032 24A Girls Bathroom Water Spigot	6/26/2016 21:24	7/7/2016 15:07	10354064047	Copper	0.6	1.3	ppm
032 24A Girls Bathroom Water Spigot	6/26/2016 21:24	7/7/2016 15:07	10354064047	Lead	671	15	ppb
032 25A Custodial Closet Sink Faucet	6/26/2016 21:27	7/7/2016 20:07	10354064049	Copper	0.1	1.3	ppm
032 25A Custodial Closet Sink Faucet	6/26/2016 21:27	7/7/2016 20:07	10354064049	Lead	6	15	ppb
032 26A Drinking Fountain Bottle Fill	6/26/2016 21:30	7/7/2016 22:34	10354064051	Copper	0.8	1.3	ppm
032 26A Drinking Fountain Bottle Fill	6/26/2016 21:30	7/7/2016 20:08	10354064051	Lead	0	15	ppb
032 27A Drinking Fountain	6/26/2016 21:32	7/7/2016 22:35	10354064053	Copper	0.8	1.3	ppm
032 27A Drinking Fountain	6/26/2016 21:32	7/7/2016 20:10	10354064053	Lead	0	15	ppb
032 28A Drinking Fountain	6/26/2016 21:34	7/7/2016 20:13	10354064055	Copper	0.4	1.3	ppm
032 28A Drinking Fountain	6/26/2016 21:34	7/7/2016 20:13	10354064055	Lead	0	15	ppb
032 29A Drinking Fountain Left	6/26/2016 21:17	7/7/2016 20:14	10354064057	Copper	0.0	1.3	ppm
032 29A Drinking Fountain Left	6/26/2016 21:17	7/7/2016 20:14	10354064057	Lead	57	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Duniway Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
032 30A Drinking Fountain Right	6/26/2016 21:17	7/7/2016 20:16	10354064059	Copper	0.0	1.3	ppm
032 30A Drinking Fountain Right	6/26/2016 21:17	7/7/2016 20:16	10354064059	Lead	44	15	ppb
032 31A Room 11 Sink Faucet	6/26/2016 21:36	7/7/2016 20:17	10354064061	Copper	0.0	1.3	ppm
032 31A Room 11 Sink Faucet	6/26/2016 21:36	7/7/2016 20:17	10354064061	Lead	7	15	ppb
032 32A Boys Bathroom Sink Faucet Left	6/26/2016 21:39	7/7/2016 20:18	10354064063	Copper	0.2	1.3	ppm
032 32A Boys Bathroom Sink Faucet Left	6/26/2016 21:39	7/7/2016 20:18	10354064063	Lead	30	15	ppb
032 33A Boys Bathroom Sink Faucet Right	6/26/2016 21:39	7/7/2016 20:19	10354064065	Copper	0.1	1.3	ppm
032 33A Boys Bathroom Sink Faucet Right	6/26/2016 21:39	7/7/2016 20:19	10354064065	Lead	12	15	ppb
032 34A Boys Bathroom Water Spigot	6/26/2016 21:41	7/7/2016 15:09	10354064067	Copper	0.5	1.3	ppm
032 34A Boys Bathroom Water Spigot	6/26/2016 21:41	7/7/2016 15:09	10354064067	Lead	803	15	ppb
032 35A Room 9 Sink Faucet Left	6/26/2016 21:44	7/7/2016 20:21	10354064069	Copper	0.1	1.3	ppm
032 35A Room 9 Sink Faucet Left	6/26/2016 21:44	7/7/2016 20:21	10354064069	Lead	59	15	ppb
032 36A Room 9 Drinking Fountain Left	6/26/2016 21:44	7/7/2016 20:22	10354064071	Copper	0.1	1.3	ppm
032 36A Room 9 Drinking Fountain Left	6/26/2016 21:44	7/7/2016 20:22	10354064071	Lead	65	15	ppb
032 37A Room 9 Sink Faucet Right	6/26/2016 21:45	7/7/2016 20:24	10354064073	Copper	0.2	1.3	ppm
032 37A Room 9 Sink Faucet Right	6/26/2016 21:45	7/7/2016 20:24	10354064073	Lead	10	15	ppb
032 38A Room 9 Drinking Fountain Right	6/26/2016 21:45	7/7/2016 20:27	10354064075	Copper	0.0	1.3	ppm
032 38A Room 9 Drinking Fountain Right	6/26/2016 21:45	7/7/2016 20:27	10354064075	Lead	18	15	ppb
032 39A Cafeteria Drinking Fountain Left	6/26/2016 21:49	7/7/2016 20:28	10354064077	Copper	0.0	1.3	ppm
032 39A Cafeteria Drinking Fountain Left	6/26/2016 21:49	7/7/2016 20:28	10354064077	Lead	4	15	ppb
032 40A Cafeteria Drinking Fountain Right	6/26/2016 21:49	7/7/2016 20:30	10354064079	Copper	0.1	1.3	ppm
032 40A Cafeteria Drinking Fountain Right	6/26/2016 21:49	7/7/2016 20:30	10354064079	Lead	4	15	ppb
032 41A Kitchen Sprayer	6/26/2016 21:56	7/7/2016 21:12	10354064081	Copper	0.2	1.3	ppm
032 41A Kitchen Sprayer	6/26/2016 21:56	7/7/2016 21:12	10354064081	Lead	4	15	ppb
032 42A Kitchen Bathroom Sink Faucet	6/26/2016 21:58	7/7/2016 21:18	10354064083	Copper	0.1	1.3	ppm
032 42A Kitchen Bathroom Sink Faucet	6/26/2016 21:58	7/7/2016 21:18	10354064083	Lead	17	15	ppb
032 43A Kitchen Dishwash Sink Faucet	6/26/2016 21:56	7/7/2016 21:19	10354064085	Copper	0.1	1.3	ppm
032 43A Kitchen Dishwash Sink Faucet	6/26/2016 21:56	7/7/2016 21:19	10354064085	Lead	8	15	ppb
032 44A Kitchen Handwash Sink Faucet	6/26/2016 21:57	7/8/2016 08:28	10354064087	Copper	0.6	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Duniway Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
032 44A Kitchen Handwash Sink Faucet	6/26/2016 21:57	7/7/2016 21:21	10354064087	Lead	14	15	ppb
032 45A Room 7 Drinking Fountain	6/26/2016 22:01	7/7/2016 21:25	10354064089	Copper	0.0	1.3	ppm
032 45A Room 7 Drinking Fountain	6/26/2016 22:01	7/7/2016 21:25	10354064089	Lead	13	15	ppb
032 46A Custodial Closet Sink Faucet	6/26/2016 22:03	7/7/2016 21:26	10354064091	Copper	0.1	1.3	ppm
032 46A Custodial Closet Sink Faucet	6/26/2016 22:03	7/7/2016 21:26	10354064091	Lead	15.0	15	ppb
032 47A Room 6 Sink Faucet	6/26/2016 22:05	7/7/2016 21:27	10354064093	Copper	0.1	1.3	ppm
032 47A Room 6 Sink Faucet	6/26/2016 22:05	7/7/2016 21:27	10354064093	Lead	15.1	15	ppb
032 48A Room 5 Sink Faucet	6/26/2016 22:08	7/7/2016 21:29	10354064095	Copper	0.2	1.3	ppm
032 48A Room 5 Sink Faucet	6/26/2016 22:08	7/7/2016 21:29	10354064095	Lead	41	15	ppb
032 49A Room 5 Drinking Fountain	6/26/2016 22:08	7/7/2016 21:30	10354064097	Copper	0.0	1.3	ppm
032 49A Room 5 Drinking Fountain	6/26/2016 22:08	7/7/2016 21:30	10354064097	Lead	2	15	ppb
032 50A Girls Bathroom Sink Faucet	6/26/2016 22:13	7/7/2016 21:31	10354064099	Copper	0.2	1.3	ppm
032 50A Girls Bathroom Sink Faucet	6/26/2016 22:13	7/7/2016 21:31	10354064099	Lead	5	15	ppb
032 51A Girls Bathroom Water Spigot	6/26/2016 22:13	7/7/2016 12:37	10354064101	Copper	0.3	1.3	ppm
032 51A Girls Bathroom Water Spigot	6/26/2016 22:13	7/7/2016 15:10	10354064101	Lead	585	15	ppb
032 52A Room 4 Sink Faucet	6/26/2016 22:16	7/7/2016 21:33	10354064103	Copper	0.1	1.3	ppm
032 52A Room 4 Sink Faucet	6/26/2016 22:16	7/7/2016 21:33	10354064103	Lead	16	15	ppb
032 53A Room 4 Drinking Fountain	6/26/2016 22:16	7/7/2016 21:34	10354064105	Copper	0.1	1.3	ppm
032 53A Room 4 Drinking Fountain	6/26/2016 22:16	7/7/2016 21:34	10354064105	Lead	6	15	ppb
032 54A Boys Bathroom Sink Faucet Left	6/26/2016 22:25	7/7/2016 21:37	10354064107	Copper	0.1	1.3	ppm
032 54A Boys Bathroom Sink Faucet Left	6/26/2016 22:25	7/7/2016 21:37	10354064107	Lead	9	15	ppb
032 55A Boys Bathroom Sink Faucet Right	6/26/2016 22:25	7/7/2016 12:38	10354064109	Copper	0.1	1.3	ppm
032 55A Boys Bathroom Sink Faucet Right	6/26/2016 22:25	7/7/2016 12:38	10354064109	Lead	10	15	ppb
032 56A Boys Bathroom Water Spigot	6/26/2016 22:27	7/7/2016 15:12	10354064111	Copper	1.1	1.3	ppm
032 56A Boys Bathroom Water Spigot	6/26/2016 22:27	7/7/2016 15:12	10354064111	Lead	874	15	ppb
032 57A Room 2 Sink Faucet	6/26/2016 22:30	7/7/2016 21:41	10354064113	Copper	0.1	1.3	ppm
032 57A Room 2 Sink Faucet	6/26/2016 22:30	7/7/2016 21:41	10354064113	Lead	15.4	15	ppb
032 58A Room 2 Drinking Fountain	6/26/2016 22:31	7/7/2016 21:42	10354064115	Copper	0.0	1.3	ppm
032 58A Room 2 Drinking Fountain	6/26/2016 22:31	7/7/2016 21:42	10354064115	Lead	6	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Duniway Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
032 59A Room 1 Sink Faucet	6/26/2016 22:39	7/7/2016 21:44	10354064117	Copper	0.0	1.3	ppm
032 59A Room 1 Sink Faucet	6/26/2016 22:39	7/7/2016 21:44	10354064117	Lead	4	15	ppb
032 60A Room 1 Drinking Fountain	6/26/2016 22:39	7/7/2016 21:45	10354064119	Copper	0.0	1.3	ppm
032 60A Room 1 Drinking Fountain	6/26/2016 22:39	7/7/2016 21:45	10354064119	Lead	3	15	ppb
032 61A Hallway Drinking Fountain	6/26/2016 22:44	7/8/2016 09:31	10354064121	Copper	0.0	1.3	ppm
032 61A Hallway Drinking Fountain	6/26/2016 22:44	7/8/2016 09:31	10354064121	Lead	2	15	ppb
032 62A Upstairs Boys Bathroom Sink Faucet Left	6/26/2016 22:56	7/7/2016 21:49	10354064123	Copper	0.1	1.3	ppm
032 62A Upstairs Boys Bathroom Sink Faucet Left	6/26/2016 22:56	7/7/2016 21:49	10354064123	Lead	51	15	ppb
032 63A Upstairs Boys Bathroom Sink Faucet Right	6/26/2016 22:56	7/7/2016 21:57	10354064125	Copper	0.2	1.3	ppm
032 63A Upstairs Boys Bathroom Sink Faucet Right	6/26/2016 22:56	7/7/2016 21:57	10354064125	Lead	37	15	ppb
032 64A Upstairs Boys Bathroom Water Spigot	6/26/2016 22:57	7/7/2016 21:59	10354064127	Copper	0.2	1.3	ppm
032 64A Upstairs Boys Bathroom Water Spigot	6/26/2016 22:57	7/7/2016 21:59	10354064127	Lead	162	15	ppb
032 65A Upstairs Hall Drinking Fountain Bottle	6/26/2016 22:59	7/8/2016 08:42	10354064129	Copper	0.7	1.3	ppm
032 65A Upstairs Hall Drinking Fountain Bottle	6/26/2016 22:59	7/7/2016 22:00	10354064129	Lead	0	15	ppb
032 66A Upstairs Hall Drinking Fountain	6/26/2016 22:59	7/8/2016 08:44	10354064131	Copper	0.8	1.3	ppm
032 66A Upstairs Hall Drinking Fountain	6/26/2016 22:59	7/7/2016 22:01	10354064131	Lead	0	15	ppb
032 67A Upstairs Custodial Closet Sink Faucet	6/26/2016 23:03	7/7/2016 22:03	10354064133	Copper	0.0	1.3	ppm
032 67A Upstairs Custodial Closet Sink Faucet	6/26/2016 23:03	7/7/2016 22:03	10354064133	Lead	4	15	ppb
032 68A Upstairs Girls Bathroom Sink Faucet Left	6/26/2016 23:05	7/7/2016 22:04	10354064135	Copper	0.2	1.3	ppm
032 68A Upstairs Girls Bathroom Sink Faucet Left	6/26/2016 23:05	7/7/2016 22:04	10354064135	Lead	48	15	ppb
032 69A Upstairs Girls Bathroom Sink Faucet Right	6/26/2016 23:05	7/7/2016 22:06	10354064137	Copper	0.3	1.3	ppm
032 69A Upstairs Girls Bathroom Sink Faucet Right	6/26/2016 23:05	7/7/2016 22:06	10354064137	Lead	57	15	ppb
032 70A Upstairs Girls Bathroom Water Spigot	6/26/2016 23:07	7/7/2016 15:13	10354064139	Copper	5.8	1.3	ppm
032 70A Upstairs Girls Bathroom Water Spigot	6/26/2016 23:07	7/7/2016 15:13	10354064139	Lead	2800	15	ppb
032 71A Room 27-B Sink Faucet	6/26/2016 23:09	7/7/2016 22:07	10354064141	Copper	0.2	1.3	ppm
032 71A Room 27-B Sink Faucet	6/26/2016 23:09	7/7/2016 22:07	10354064141	Lead	103	15	ppb
032 72A Classroom 27 Sink Faucet	6/26/2016 23:11	7/8/2016 08:45	10354064143	Copper	0.5	1.3	ppm
032 72A Classroom 27 Sink Faucet	6/26/2016 23:11	7/7/2016 22:08	10354064143	Lead	4	15	ppb
032 73A Teacher Lounge Kitchen Sink Faucet	6/26/2016 23:14	7/7/2016 22:10	10354064145	Copper	0.0	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Duniway Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
032 73A Teacher Lounge Kitchen Sink Faucet	6/26/2016 23:14	7/7/2016 22:10	10354064145	Lead	13	15	ppb
032 74A Teacher Lounge Bathroom Sink Faucet	6/26/2016 23:14	7/7/2016 22:16	10354064147	Copper	0.1	1.3	ppm
032 74A Teacher Lounge Bathroom Sink Faucet	6/26/2016 23:14	7/7/2016 22:16	10354064147	Lead	8	15	ppb
032 75A Room 29 Sink Faucet	6/26/2016 23:17	7/7/2016 22:18	10354064149	Copper	0.1	1.3	ppm
032 75A Room 29 Sink Faucet	6/26/2016 23:17	7/7/2016 22:18	10354064149	Lead	4	15	ppb
032 76A Room 29 Drinking Fountain	6/26/2016 23:17	7/8/2016 08:46	10354064151	Copper	0.8	1.3	ppm
032 76A Room 29 Drinking Fountain	6/26/2016 23:17	7/7/2016 22:19	10354064151	Lead	9	15	ppb
032 77A Outdoor Water Spigot	6/26/2016 23:21	7/8/2016 08:48	10354064153	Copper	0.0	1.3	ppm
032 77A Outdoor Water Spigot	6/26/2016 23:21	7/8/2016 08:48	10354064153	Lead	0	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.