

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Edwards Elementary School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
34-01A	Room 6B Drinking Fountain	6/19/2016 12:51:00 AM	6/24/2016 12:59:00 PM	BB65881	Copper	0.2	1.3	PPM
34-01A	Room 6B Drinking Fountain	6/19/2016 12:51:00 AM	6/24/2016 12:59:00 PM	BB65881	Lead	12	15	PPB
34-02A	Kitchen Handwashing Sink Faucet	6/19/2016 12:54:00 AM	6/24/2016 1:02:00 PM	BB65882	Copper	0.4	1.3	PPM
34-02A	Kitchen Handwashing Sink Faucet	6/19/2016 12:54:00 AM	6/24/2016 1:02:00 PM	BB65882	Lead	10	15	PPB
34-03A	Kitchen Dishwashing Sink Faucet	6/19/2016 12:54:00 AM	6/24/2016 1:17:00 PM	BB65883	Copper	0.3	1.3	PPM
34-03A	Kitchen Dishwashing Sink Faucet	6/19/2016 12:54:00 AM	6/24/2016 1:17:00 PM	BB65883	Lead	3	15	PPB
34-04A	Kitchen Sanitizing Sink Faucet	6/19/2016 12:56:00 AM	6/24/2016 1:20:00 PM	BB65884	Copper	0.2	1.3	PPM
34-04A	Kitchen Sanitizing Sink Faucet	6/19/2016 12:56:00 AM	6/24/2016 1:20:00 PM	BB65884	Lead	5	15	PPB
34-05A	Bathroom 15 Sink Faucet	6/19/2016 1:00:00 AM	6/24/2016 1:23:00 PM	BB65885	Copper	0.2	1.3	PPM
34-05A	Bathroom 15 Sink Faucet	6/19/2016 1:00:00 AM	6/24/2016 1:23:00 PM	BB65885	Lead	1	15	PPB
34-06A	Hall Drinking Fountain 1	6/19/2016 1:01:00 AM	6/24/2016 1:26:00 PM	BB65886	Copper	0.0	1.3	PPM
34-06A	Hall Drinking Fountain 1	6/19/2016 1:01:00 AM	6/24/2016 1:26:00 PM	BB65886	Lead	3	15	PPB
34-07A	Room 20 Sink Faucet	6/19/2016 1:04:00 AM	6/24/2016 1:29:00 PM	BB65887	Copper	0.0	1.3	PPM
34-07A	Room 20 Sink Faucet	6/19/2016 1:04:00 AM	6/24/2016 1:29:00 PM	BB65887	Lead	2	15	PPB
34-08A	Office Work Room Sink Faucet	6/19/2016 1:06:00 AM	6/24/2016 1:32:00 PM	BB65888	Copper	0.1	1.3	PPM
34-08A	Office Work Room Sink Faucet	6/19/2016 1:06:00 AM	6/24/2016 1:32:00 PM	BB65888	Lead	9	15	PPB
34-09A	Office Work Room Drinking Fountain	6/19/2016 1:08:00 AM	6/24/2016 1:35:00 PM	BB65889	Copper	0.0	1.3	PPM
34-09A	Office Work Room Drinking Fountain	6/19/2016 1:08:00 AM	6/24/2016 1:35:00 PM	BB65889	Lead	1	15	PPB
34-10A	Office Bathroom Sink Faucet	6/19/2016 1:10:00 AM	6/24/2016 1:38:00 PM	BB65890	Copper	0.0	1.3	PPM
34-10A	Office Bathroom Sink Faucet	6/19/2016 1:10:00 AM	6/24/2016 1:38:00 PM	BB65890	Lead	3	15	PPB
34-11A	Room 2 Sink Faucet	6/19/2016 1:12:00 AM	7/3/2016 1:45:00 PM	BB65891	Copper	0.1	1.3	PPM
34-11A	Room 2 Sink Faucet	6/19/2016 1:12:00 AM	7/3/2016 1:45:00 PM	BB65891	Lead	10	15	PPB
34-12A	Room 2 Drinking Fountain	6/19/2016 1:15:00 AM	7/3/2016 1:39:00 PM	BB65892	Copper	0.8	1.3	PPM
34-12A	Room 2 Drinking Fountain	6/19/2016 1:15:00 AM	7/3/2016 1:39:00 PM	BB65892	Lead	56	15	PPB
34-13A	Room 13 Custodian Sink Faucet	6/19/2016 1:18:00 AM	7/3/2016 1:52:00 PM	BB65893	Copper	0.1	1.3	PPM
34-13A	Room 13 Custodian Sink Faucet	6/19/2016 1:18:00 AM	7/3/2016 1:52:00 PM	BB65893	Lead	5	15	PPB
34-14A	Room 12 Boys Bathroom Sink Faucet 1	6/19/2016 1:21:00 AM	6/24/2016 1:41:00 PM	BB65894	Copper	0.1	1.3	PPM
34-14A	Room 12 Boys Bathroom Sink Faucet 1	6/19/2016 1:21:00 AM	6/24/2016 1:41:00 PM	BB65894	Lead	1	15	PPB
34-15A	Room 12 Boys Bathroom Sink Faucet 2	6/19/2016 1:23:00 AM	6/24/2016 1:44:00 PM	BB65895	Copper	0.1	1.3	PPM
34-15A	Room 12 Boys Bathroom Sink Faucet 2	6/19/2016 1:23:00 AM	6/24/2016 1:44:00 PM	BB65895	Lead	2	15	PPB
34-16A	Room 12 Boys Bathroom Sink Faucet 3	6/19/2016 1:25:00 AM	6/24/2016 2:05:00 PM	BB65896	Copper	0.1	1.3	PPM
34-16A	Room 12 Boys Bathroom Sink Faucet 3	6/19/2016 1:25:00 AM	6/24/2016 2:05:00 PM	BB65896	Lead	7	15	PPB
34-17A	Room 11 Girls Bathroom Sink Faucet 1	6/19/2016 1:28:00 AM	7/3/2016 1:56:00 PM	BB65897	Copper	0.2	1.3	PPM
34-17A	Room 11 Girls Bathroom Sink Faucet 1	6/19/2016 1:28:00 AM	7/3/2016 1:56:00 PM	BB65897	Lead	11	15	PPB
34-18A	Room 11 Girls Bathroom Sink Faucet 2	6/19/2016 1:30:00 AM	7/3/2016 1:59:00 PM	BB65898	Copper	0.2	1.3	PPM
34-18A	Room 11 Girls Bathroom Sink Faucet 2	6/19/2016 1:30:00 AM	7/3/2016 1:59:00 PM	BB65898	Lead	3	15	PPB
34-19A	Room 11 Girls Bathroom Sink Faucet 3	6/19/2016 1:32:00 AM	6/24/2016 2:08:00 PM	BB65899	Copper	0.2	1.3	PPM
34-19A	Room 11 Girls Bathroom Sink Faucet 3	6/19/2016 1:32:00 AM	6/24/2016 2:08:00 PM	BB65899	Lead	21	15	PPB
34-20A	Room 3 Sink Faucet	6/19/2016 1:35:00 AM	7/3/2016 2:03:00 PM	BB65900	Copper	0.3	1.3	PPM
34-20A	Room 3 Sink Faucet	6/19/2016 1:35:00 AM	7/3/2016 2:03:00 PM	BB65900	Lead	23	15	PPB
34-21A	Room 3 Drinking Fountain	6/19/2016 1:37:00 AM	7/3/2016 2:08:00 PM	BB65901	Copper	0.3	1.3	PPM
34-21A	Room 3 Drinking Fountain	6/19/2016 1:37:00 AM	7/3/2016 2:08:00 PM	BB65901	Lead	14.7	15	PPB
34-22A (1)	Room 10 Sink Faucet	6/19/2016 1:40:00 AM	6/24/2016 2:11:00 PM	BB65902	Copper	0.1	1.3	PPM
34-22A (1)	Room 10 Sink Faucet	6/19/2016 1:40:00 AM	6/24/2016 2:11:00 PM	BB65902	Lead	6	15	PPB
34-22A (2)	Room 10 Drinking Fountain	6/19/2016 1:40:00 AM	6/24/2016 2:14:00 PM	BB65903	Copper	0.1	1.3	PPM
34-22A (2)	Room 10 Drinking Fountain	6/19/2016 1:40:00 AM	6/24/2016 2:14:00 PM	BB65903	Lead	7	15	PPB
34-24A	Room 9 Sink Faucet	6/19/2016 1:45:00 AM	7/3/2016 2:12:00 PM	BB65904	Copper	0.7	1.3	PPM
34-24A	Room 9 Sink Faucet	6/19/2016 1:45:00 AM	7/3/2016 2:12:00 PM	BB65904	Lead	40	15	PPB
34-25A	Room 8 Drinking Fountain	6/19/2016 1:48:00 AM	7/3/2016 2:15:00 PM	BB65905	Copper	1.7	1.3	PPM
34-25A	Room 8 Drinking Fountain	6/19/2016 1:48:00 AM	7/3/2016 2:15:00 PM	BB65905	Lead	154	15	PPB
34-26A	Room 7 Sink Faucet	6/19/2016 1:51:00 AM	7/3/2016 2:46:00 PM	BB65906	Copper	0.3	1.3	PPM
34-26A	Room 7 Sink Faucet	6/19/2016 1:51:00 AM	7/3/2016 2:46:00 PM	BB65906	Lead	5	15	PPB

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Edwards Elementary School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
34-27A	Room 7 Drinking Fountain	6/19/2016 1:53:00 AM	7/3/2016 2:50:00 PM	BB65907	Copper	0.4	1.3	PPM
34-27A	Room 7 Drinking Fountain	6/19/2016 1:53:00 AM	7/3/2016 2:50:00 PM	BB65907	Lead	8	15	PPB
34-28A	Room 6D Library Sink Faucet	6/19/2016 1:57:00 AM	6/24/2016 2:18:00 PM	BB65908	Copper	0.2	1.3	PPM
34-28A	Room 6D Library Sink Faucet	6/19/2016 1:57:00 AM	6/24/2016 2:18:00 PM	BB65908	Lead	30	15	PPB
34-29A	Room 6D Library Drinking Fountain	6/19/2016 2:00:00 AM	6/24/2016 2:21:00 PM	BB65909	Copper	0.6	1.3	PPM
34-29A	Room 6D Library Drinking Fountain	6/19/2016 2:00:00 AM	6/24/2016 2:21:00 PM	BB65909	Lead	7	15	PPB
34-30A	Room 6A Sink Faucet	6/19/2016 2:02:00 AM	6/24/2016 2:24:00 PM	BB65910	Copper	0.9	1.3	PPM
34-30A	Room 6A Sink Faucet	6/19/2016 2:02:00 AM	6/24/2016 2:24:00 PM	BB65910	Lead	71	15	PPB
34-31A	Exterior Water Spigot 1	6/19/2016 2:06:00 AM	6/24/2016 2:27:00 PM	BB65911	Copper	0.5	1.3	PPM
34-31A	Exterior Water Spigot 1	6/19/2016 2:06:00 AM	6/24/2016 2:27:00 PM	BB65911	Lead	5	15	PPB
34-32A	Exterior Water Spigot 4	6/19/2016 2:09:00 AM	7/3/2016 2:53:00 PM	BB65912	Copper	0.5	1.3	PPM
34-32A	Exterior Water Spigot 4	6/19/2016 2:09:00 AM	7/3/2016 2:53:00 PM	BB65912	Lead	24	15	PPB
34-33A	Exterior Water Spigot 5	6/19/2016 2:12:00 AM	6/24/2016 2:30:00 PM	BB65913	Copper	0.0	1.3	PPM
34-33A	Exterior Water Spigot 5	6/19/2016 2:12:00 AM	6/24/2016 2:30:00 PM	BB65913	Lead	79	15	PPB

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.