

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Faubion School at Harriet Tubman Middle School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
035-01A Room off Room 132 Sink Faucet	6/29/16 23:00	7/12/16 8:16	606303401	Copper	0.0	1.3	ppm
035-01A Room off Room 132 Sink Faucet	6/29/16 23:00	7/12/16 8:16	606303401	Lead	237	15	ppb
035-02A Room 132 Sink Faucet #1	6/29/16 23:01	7/12/16 8:16	606303402	Copper	0.0	1.3	ppm
035-02A Room 132 Sink Faucet #1	6/29/16 23:01	7/12/16 8:16	606303402	Lead	90	15	ppb
035-03A Room 132 Sink Faucet #2	6/29/16 23:02	7/12/16 8:16	606303403	Copper	0.2	1.3	ppm
035-03A Room 132 Sink Faucet #2	6/29/16 23:02	7/12/16 8:16	606303403	Lead	150	15	ppb
035-04A Room 132 Sink Faucet #3	6/29/16 23:03	7/12/16 8:16	606303404	Copper	0.1	1.3	ppm
035-04A Room 132 Sink Faucet #3	6/29/16 23:03	7/12/16 8:16	606303404	Lead	227	15	ppb
035-05A Staff Mens Restroom Sink Faucet	6/29/16 23:05	7/12/16 8:16	606303405	Copper	0.7	1.3	ppm
035-05A Staff Mens Restroom Sink Faucet	6/29/16 23:05	7/12/16 8:16	606303405	Lead	3	15	ppb
035-06A Staff Womens Restroom Sink Faucet	6/29/16 23:07	7/12/16 8:16	606303406	Copper	0.5	1.3	ppm
035-06A Staff Womens Restroom Sink Faucet	6/29/16 23:07	7/12/16 8:16	606303406	Lead	25	15	ppb
035-07A Janitors Closet Sink Faucet #1	6/29/16 23:09	7/12/16 8:16	606303407	Copper	0.5	1.3	ppm
035-07A Janitors Closet Sink Faucet #1	6/29/16 23:09	7/12/16 8:16	606303407	Lead	49	15	ppb
035-08A Janitors Closet Sink Faucet #2	6/29/16 23:11	7/12/16 8:16	606303408	Copper	0.0	1.3	ppm
035-08A Janitors Closet Sink Faucet #2	6/29/16 23:11	7/12/16 8:16	606303408	Lead	24	15	ppb
035-09A Girls Restroom Sink Faucet #1	6/29/16 23:14	7/12/16 8:16	606303409	Copper	0.0	1.3	ppm
035-09A Girls Restroom Sink Faucet #1	6/29/16 23:14	7/12/16 8:16	606303409	Lead	42	15	ppb
035-10A Girls Restroom Sink Faucet #2	6/29/16 23:14	7/13/16 8:54	606303410	Copper	0.1	1.3	ppm
035-10A Girls Restroom Sink Faucet #2	6/29/16 23:14	7/13/16 8:54	606303410	Lead	57	15	ppb
035-11A Boys Restroom Sink Faucet #1	6/29/16 23:16	7/13/16 8:54	606303411	Copper	0.1	1.3	ppm
035-11A Boys Restroom Sink Faucet #1	6/29/16 23:16	7/13/16 8:54	606303411	Lead	41	15	ppb
035-12A Boys Restroom Sink Faucet #2	6/29/16 23:17	7/13/16 8:54	606303412	Copper	0.1	1.3	ppm
035-12A Boys Restroom Sink Faucet #2	6/29/16 23:17	7/13/16 8:54	606303412	Lead	35	15	ppb
035-13A Boys Restroom Water Spigot	6/29/16 23:18	7/13/16 8:54	606303413	Copper	0.1	1.3	ppm
035-13A Boys Restroom Water Spigot	6/29/16 23:18	7/13/16 8:54	606303413	Lead	16	15	ppb
035-14A Boiler Room 100 Sink Faucet	6/29/16 23:20	7/13/16 8:54	606303414	Copper	0.1	1.3	ppm
035-14A Boiler Room 100 Sink Faucet	6/29/16 23:20	7/13/16 8:54	606303414	Lead	5	15	ppb
035-15A Girls Locker Room Sink Faucet #1	6/29/16 23:22	7/13/16 8:54	606303415	Copper	0.5	1.3	ppm
035-15A Girls Locker Room Sink Faucet #1	6/29/16 23:22	7/13/16 8:54	606303415	Lead	23	15	ppb
035-16A Girls Locker Room Sink Faucet #2	6/29/16 23:22	7/13/16 8:54	606303416	Copper	0.3	1.3	ppm
035-16A Girls Locker Room Sink Faucet #2	6/29/16 23:22	7/13/16 8:54	606303416	Lead	42	15	ppb
035-17A Girls Locker Room Sink Faucet #3	6/29/16 23:23	7/13/16 8:54	606303417	Copper	0.3	1.3	ppm
035-17A Girls Locker Room Sink Faucet #3	6/29/16 23:23	7/13/16 8:54	606303417	Lead	25	15	ppb
035-18A Girls Locker Room Sink Faucet #4	6/29/16 23:23	7/13/16 8:54	606303418	Copper	0.5	1.3	ppm
035-18A Girls Locker Room Sink Faucet #4	6/29/16 23:23	7/13/16 8:54	606303418	Lead	24	15	ppb
035-19A Girls Locker Room Sink Faucet #5	6/29/16 23:25	7/13/16 8:54	606303419	Copper	0.5	1.3	ppm
035-19A Girls Locker Room Sink Faucet #5	6/29/16 23:25	7/13/16 8:54	606303419	Lead	23	15	ppb
035-20A Girls Locker Room Water Spigot	6/29/16 23:27	7/13/16 8:54	606303420	Copper	0.7	1.3	ppm
035-20A Girls Locker Room Water Spigot	6/29/16 23:27	7/13/16 8:54	606303420	Lead	50	15	ppb
035-21A Gymnasium Drinking Fountain	6/29/16 23:29	7/13/16 8:54	606303421	Copper	0.4	1.3	ppm
035-21A Gymnasium Drinking Fountain	6/29/16 23:29	7/13/16 8:54	606303421	Lead	12	15	ppb
035-22A Gymnasium Office Shower	6/29/16 23:31	7/13/16 8:54	606303422	Copper	0.2	1.3	ppm
035-22A Gymnasium Office Shower	6/29/16 23:31	7/13/16 8:54	606303422	Lead	48	15	ppb
035-23A Gymnasium Office Sink Faucet	6/29/16 23:32	7/13/16 8:54	606303423	Copper	0.1	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Faubion School at Harriet Tubman Middle School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
035-23A Gymnasium Office Sink Faucet	6/29/16 23:32	7/13/16 8:54	606303423	Lead	18	15	ppb
035-24A Gymnasium Office Water Spigot	6/29/16 23:33	7/14/16 11:04	606303424	Copper	2.5	1.3	ppm
035-24A Gymnasium Office Water Spigot	6/29/16 23:33	7/14/16 11:04	606303424	Lead	952	15	ppb
035-25A Boys Locker Room Sink Faucet #1	6/29/16 23:35	7/13/16 8:54	606303425	Copper	0.7	1.3	ppm
035-25A Boys Locker Room Sink Faucet #1	6/29/16 23:35	7/13/16 8:54	606303425	Lead	65	15	ppb
035-26A Boys Locker Room Sink Faucet #2	6/29/16 23:35	7/13/16 8:54	606303426	Copper	0.8	1.3	ppm
035-26A Boys Locker Room Sink Faucet #2	6/29/16 23:35	7/13/16 8:54	606303426	Lead	42	15	ppb
035-27A Boys Locker Room Sink Faucet #3	6/29/16 23:37	7/13/16 8:54	606303427	Copper	0.5	1.3	ppm
035-27A Boys Locker Room Sink Faucet #3	6/29/16 23:37	7/13/16 8:54	606303427	Lead	61	15	ppb
035-28A Boys Locker Room Water Spigot	6/29/16 23:37	7/13/16 8:54	606303428	Copper	0.3	1.3	ppm
035-28A Boys Locker Room Water Spigot	6/29/16 23:37	7/13/16 8:54	606303428	Lead	12	15	ppb
035-29A Office Sink Faucet	6/29/16 23:40	7/13/16 8:54	606303429	Copper	0.4	1.3	ppm
035-29A Office Sink Faucet	6/29/16 23:40	7/13/16 8:54	606303429	Lead	21	15	ppb
035-30A Hallway Drinking Fountain #1	6/29/16 23:42	7/13/16 8:54	606303430	Copper	0.6	1.3	ppm
035-30A Hallway Drinking Fountain #1	6/29/16 23:42	7/13/16 8:54	606303430	Lead	5	15	ppb
035-31A Hallway Drinking Fountain #2	6/29/16 23:42	7/13/16 8:55	606303431	Copper	0.3	1.3	ppm
035-31A Hallway Drinking Fountain #2	6/29/16 23:42	7/13/16 8:55	606303431	Lead	2	15	ppb
035-32A Janitors Closet Sink Faucet	6/29/16 23:44	7/13/16 8:55	606303432	Copper	0.4	1.3	ppm
035-32A Janitors Closet Sink Faucet	6/29/16 23:44	7/13/16 8:55	606303432	Lead	13	15	ppb
035-33A Boys Restroom Sink Faucet #1	6/29/16 23:46	7/13/16 8:55	606303433	Copper	0.3	1.3	ppm
035-33A Boys Restroom Sink Faucet #1	6/29/16 23:46	7/13/16 8:55	606303433	Lead	6	15	ppb
035-34A Boys Restroom Sink Faucet #2	6/29/16 23:46	7/13/16 8:55	606303434	Copper	0.3	1.3	ppm
035-34A Boys Restroom Sink Faucet #2	6/29/16 23:46	7/13/16 8:55	606303434	Lead	11	15	ppb
035-35A Boys Restroom Sink Faucet #3	6/29/16 23:48	7/13/16 8:55	606303435	Copper	0.7	1.3	ppm
035-35A Boys Restroom Sink Faucet #3	6/29/16 23:48	7/13/16 8:55	606303435	Lead	63	15	ppb
035-36A Boys Restroom Water Spigot	6/29/16 23:50	7/13/16 8:55	606303436	Copper	0.4	1.3	ppm
035-36A Boys Restroom Water Spigot	6/29/16 23:50	7/13/16 8:55	606303436	Lead	29	15	ppb
035-37A Girls Restroom Sink Faucet #1	6/29/16 23:53	7/13/16 8:55	606303437	Copper	0.9	1.3	ppm
035-37A Girls Restroom Sink Faucet #1	6/29/16 23:53	7/13/16 8:55	606303437	Lead	68	15	ppb
035-38A Girls Restroom Sink Faucet #2	6/29/16 23:53	7/13/16 8:55	606303438	Copper	0.4	1.3	ppm
035-38A Girls Restroom Sink Faucet #2	6/29/16 23:53	7/13/16 8:55	606303438	Lead	16	15	ppb
035-39A Girls Restroom Sink Faucet #3	6/29/16 23:55	7/13/16 8:55	606303439	Copper	0.2	1.3	ppm
035-39A Girls Restroom Sink Faucet #3	6/29/16 23:55	7/13/16 8:55	606303439	Lead	15.4	15	ppb
035-40A Girls Restroom Sink Faucet #4	6/29/16 23:55	7/13/16 8:55	606303440	Copper	0.2	1.3	ppm
035-40A Girls Restroom Sink Faucet #4	6/29/16 23:55	7/13/16 8:55	606303440	Lead	3	15	ppb
035-41A Girls Restroom Water Spigot	6/29/16 23:56	7/13/16 8:55	606303441	Copper	0.6	1.3	ppm
035-41A Girls Restroom Water Spigot	6/29/16 23:56	7/13/16 8:55	606303441	Lead	46	15	ppb
035-42A R165 Sink Faucet	6/29/16 23:58	7/13/16 8:55	606303442	Copper	0.5	1.3	ppm
035-42A R165 Sink Faucet	6/29/16 23:58	7/13/16 8:55	606303442	Lead	16	15	ppb
035-43A R165 Drinking Fountain	6/29/16 23:58	7/13/16 8:55	606303443	Copper	0.7	1.3	ppm
035-43A R165 Drinking Fountain	6/29/16 23:58	7/13/16 8:55	606303443	Lead	6	15	ppb
035-44A Cafeteria Sink Faucet	6/30/16 0:01	7/13/16 8:55	606303444	Copper	0.3	1.3	ppm
035-44A Cafeteria Sink Faucet	6/30/16 0:01	7/13/16 8:55	606303444	Lead	42	15	ppb
035-45A Cafeteria Drinking Fountain	6/30/16 0:05	7/13/16 8:55	606303445	Copper	0.9	1.3	ppm
035-45A Cafeteria Drinking Fountain	6/30/16 0:05	7/13/16 8:55	606303445	Lead	12	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Faubion School at Harriet Tubman Middle School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
035-46A Womens Sink Faucet	6/30/16 0:07	7/13/16 8:55	606303446	Copper	0.6	1.3	ppm
035-46A Womens Sink Faucet	6/30/16 0:07	7/13/16 8:55	606303446	Lead	33	15	ppb
035-47A Mens Sink Faucet	6/30/16 0:09	7/13/16 8:55	606303447	Copper	0.6	1.3	ppm
035-47A Mens Sink Faucet	6/30/16 0:09	7/13/16 8:55	606303447	Lead	20	15	ppb
035-48A Staff Restroom Sink Faucet	6/30/16 0:11	7/13/16 8:55	606303448	Copper	0.4	1.3	ppm
035-48A Staff Restroom Sink Faucet	6/30/16 0:11	7/13/16 8:55	606303448	Lead	51	15	ppb
035-49A Janitors Closet Sink Faucet	6/30/16 0:13	7/13/16 8:55	606303449	Copper	0.2	1.3	ppm
035-49A Janitors Closet Sink Faucet	6/30/16 0:13	7/13/16 8:55	606303449	Lead	0	15	ppb
035-50A Kitchen Spray #1	6/30/16 0:15	7/13/16 8:55	606303450	Copper	0.3	1.3	ppm
035-50A Kitchen Spray #1	6/30/16 0:15	7/13/16 8:55	606303450	Lead	6	15	ppb
035-51A Kitchen Sink Faucet #1	6/30/16 0:17	7/13/16 8:56	606303451	Copper	0.5	1.3	ppm
035-51A Kitchen Sink Faucet #1	6/30/16 0:17	7/13/16 8:56	606303451	Lead	1	15	ppb
035-52A Kitchen Spray #2	6/30/16 0:17	7/13/16 8:56	606303452	Copper	0.4	1.3	ppm
035-52A Kitchen Spray #2	6/30/16 0:17	7/13/16 8:56	606303452	Lead	2	15	ppb
035-53A Kitchen Sink Faucet #2	6/30/16 0:19	7/13/16 8:56	606303453	Copper	0.4	1.3	ppm
035-53A Kitchen Sink Faucet #2	6/30/16 0:19	7/13/16 8:56	606303453	Lead	2	15	ppb
035-54A Kitchen Sink Faucet #3	6/30/16 0:21	7/13/16 8:56	606303454	Copper	0.5	1.3	ppm
035-54A Kitchen Sink Faucet #3	6/30/16 0:21	7/13/16 8:56	606303454	Lead	5	15	ppb
035-55A Kitchen Sink Faucet #4	6/30/16 0:23	7/13/16 8:56	606303455	Copper	0.5	1.3	ppm
035-55A Kitchen Sink Faucet #4	6/30/16 0:23	7/13/16 8:56	606303455	Lead	17	15	ppb
035-56A Next to CR 156 Sink Faucet #1	6/30/16 0:25	7/13/16 8:56	606303456	Copper	0.4	1.3	ppm
035-56A Next to CR 156 Sink Faucet #1	6/30/16 0:25	7/13/16 8:56	606303456	Lead	38	15	ppb
035-57A Next to CR 156 Sink Faucet #2	6/30/16 0:26	7/13/16 8:56	606303457	Copper	0.7	1.3	ppm
035-57A Next to CR 156 Sink Faucet #2	6/30/16 0:26	7/13/16 8:56	606303457	Lead	18	15	ppb
035-58A Next to CR 156 Sink Faucet #3	6/30/16 0:27	7/13/16 8:56	606303458	Copper	0.4	1.3	ppm
035-58A Next to CR 156 Sink Faucet #3	6/30/16 0:27	7/13/16 8:56	606303458	Lead	29	15	ppb
035-59A Next to CR 156 Sink Faucet #4	6/30/16 0:30	7/13/16 8:56	606303459	Copper	0.3	1.3	ppm
035-59A Next to CR 156 Sink Faucet #4	6/30/16 0:30	7/13/16 8:56	606303459	Lead	79	15	ppb
035-60A Drinking Fountain Next to CR 156	6/30/16 0:30	7/13/16 8:56	606303460	Copper	0.4	1.3	ppm
035-60A Drinking Fountain Next to CR 156	6/30/16 0:30	7/13/16 8:56	606303460	Lead	17	15	ppb
035-61A Room 155 Sink Faucet #1	6/30/16 0:32	7/13/16 8:56	606303461	Copper	1.1	1.3	ppm
035-61A Room 155 Sink Faucet #1	6/30/16 0:32	7/13/16 8:56	606303461	Lead	14	15	ppb
035-62A Room 155 Sink Faucet #2	6/30/16 0:32	7/13/16 8:56	606303462	Copper	0.6	1.3	ppm
035-62A Room 155 Sink Faucet #2	6/30/16 0:32	7/13/16 8:56	606303462	Lead	114	15	ppb
035-63A Room 155 Sink Faucet #3	6/30/16 0:34	7/13/16 8:56	606303463	Copper	0.9	1.3	ppm
035-63A Room 155 Sink Faucet #3	6/30/16 0:34	7/13/16 8:56	606303463	Lead	191	15	ppb
035-64A Room 155 Sink Faucet #4	6/30/16 0:34	7/13/16 8:56	606303464	Copper	1.0	1.3	ppm
035-64A Room 155 Sink Faucet #4	6/30/16 0:34	7/13/16 8:56	606303464	Lead	258	15	ppb
035-65A Room 155 Sink Faucet #5	6/30/16 0:36	7/13/16 8:56	606303465	Copper	0.8	1.3	ppm
035-65A Room 155 Sink Faucet #5	6/30/16 0:36	7/13/16 8:56	606303465	Lead	330	15	ppb
035-66A Drinking Fountain in Commons	6/30/16 0:38	7/13/16 8:56	606303466	Copper	0.0	1.3	ppm
035-66A Drinking Fountain in Commons	6/30/16 0:38	7/13/16 8:56	606303466	Lead	5	15	ppb
035-67A Boys Restroom Sink Faucet #1	6/30/16 0:40	7/13/16 8:56	606303467	Copper	0.2	1.3	ppm
035-67A Boys Restroom Sink Faucet #1	6/30/16 0:40	7/13/16 8:56	606303467	Lead	49	15	ppb
035-68A Boys Restroom Sink Faucet #2	6/30/16 0:40	7/13/16 8:56	606303468	Copper	0.1	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Faubion School at Harriet Tubman Middle School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
035-68A Boys Restroom Sink Faucet #2	6/30/16 0:40	7/13/16 8:56	606303468	Lead	69	15	ppb
035-69A Boys Restroom Water Spigot	6/30/16 0:42	7/13/16 8:56	606303469	Copper	0.4	1.3	ppm
035-69A Boys Restroom Water Spigot	6/30/16 0:42	7/13/16 8:56	606303469	Lead	120	15	ppb
035-70A Janitors Closet Sink Faucet	6/30/16 0:44	7/13/16 8:56	606303470	Copper	0.1	1.3	ppm
035-70A Janitors Closet Sink Faucet	6/30/16 0:44	7/13/16 8:56	606303470	Lead	66	15	ppb
035-71A Girls Restroom Sink Faucet #1	6/30/16 0:46	7/13/16 8:57	606303471	Copper	0.2	1.3	ppm
035-71A Girls Restroom Sink Faucet #1	6/30/16 0:46	7/13/16 8:57	606303471	Lead	29	15	ppb
035-72A Girls Restroom Sink Faucet #2	6/30/16 0:46	7/13/16 8:57	606303472	Copper	0.1	1.3	ppm
035-72A Girls Restroom Sink Faucet #2	6/30/16 0:46	7/13/16 8:57	606303472	Lead	33	15	ppb
035-73A Room 119 Sink Faucet	6/30/16 0:48	7/13/16 8:57	606303473	Copper	0.4	1.3	ppm
035-73A Room 119 Sink Faucet	6/30/16 0:48	7/13/16 8:57	606303473	Lead	31	15	ppb
035-74A Room 119 Drinking Fountain	6/30/16 0:48	7/13/16 8:57	606303474	Copper	0.1	1.3	ppm
035-74A Room 119 Drinking Fountain	6/30/16 0:48	7/13/16 8:57	606303474	Lead	2	15	ppb
035-75A Room 117 Sink Faucet	6/30/16 0:50	7/13/16 8:57	606303475	Copper	0.3	1.3	ppm
035-75A Room 117 Sink Faucet	6/30/16 0:50	7/13/16 8:57	606303475	Lead	26	15	ppb
035-76A Room 117 Drinking Fountain	6/30/16 0:50	7/13/16 8:57	606303476	Copper	0.2	1.3	ppm
035-76A Room 117 Drinking Fountain	6/30/16 0:50	7/13/16 8:57	606303476	Lead	3	15	ppb
035-77A Room 118 Sink Faucet	6/30/16 0:52	7/13/16 8:57	606303477	Copper	0.5	1.3	ppm
035-77A Room 118 Sink Faucet	6/30/16 0:52	7/13/16 8:57	606303477	Lead	101	15	ppb
035-78A Room 118 Drinking Fountain	6/30/16 0:52	7/13/16 8:57	606303478	Copper	0.1	1.3	ppm
035-78A Room 118 Drinking Fountain	6/30/16 0:52	7/13/16 8:57	606303478	Lead	32	15	ppb
035-79A Room 116 Sink Faucet	6/30/16 0:54	7/13/16 8:57	606303479	Copper	0.1	1.3	ppm
035-79A Room 116 Sink Faucet	6/30/16 0:54	7/13/16 8:57	606303479	Lead	30	15	ppb
035-80A Room 116 Drinking Fountain	6/30/16 0:54	7/13/16 8:57	606303480	Copper	0.1	1.3	ppm
035-80A Room 116 Drinking Fountain	6/30/16 0:54	7/13/16 8:57	606303480	Lead	2	15	ppb
035-81A Room 115 Sink Faucet	6/30/16 0:56	7/13/16 8:58	606303481	Copper	0.5	1.3	ppm
035-81A Room 115 Sink Faucet	6/30/16 0:56	7/13/16 8:58	606303481	Lead	59	15	ppb
035-82A Room 115 Drinking Fountain	6/30/16 0:56	7/13/16 8:58	606303482	Copper	0.2	1.3	ppm
035-82A Room 115 Drinking Fountain	6/30/16 0:56	7/13/16 8:58	606303482	Lead	2	15	ppb
035-83A Room 113 Sink Faucet	6/30/16 0:58	7/13/16 8:58	606303483	Copper	0.3	1.3	ppm
035-83A Room 113 Sink Faucet	6/30/16 0:58	7/13/16 8:58	606303483	Lead	38	15	ppb
035-84A Room 113 Drinking Fountain	6/30/16 0:58	7/13/16 8:58	606303484	Copper	0.1	1.3	ppm
035-84A Room 113 Drinking Fountain	6/30/16 0:58	7/13/16 8:58	606303484	Lead	4	15	ppb
035-85A Room 114 Sink Faucet	6/30/16 1:01	7/13/16 8:58	606303485	Copper	0.3	1.3	ppm
035-85A Room 114 Sink Faucet	6/30/16 1:01	7/13/16 8:58	606303485	Lead	51	15	ppb
035-86A Room 114 Drinking Fountain	6/30/16 1:01	7/13/16 8:58	606303486	Copper	0.1	1.3	ppm
035-86A Room 114 Drinking Fountain	6/30/16 1:01	7/13/16 8:58	606303486	Lead	10	15	ppb
035-87A Room 112 Sink Faucet	6/30/16 1:03	7/13/16 9:01	606303487	Copper	0.2	1.3	ppm
035-87A Room 112 Sink Faucet	6/30/16 1:03	7/13/16 9:01	606303487	Lead	44	15	ppb
035-88A Room 112 Drinking Fountain	6/30/16 1:03	7/13/16 8:58	606303488	Copper	0.1	1.3	ppm
035-88A Room 112 Drinking Fountain	6/30/16 1:03	7/13/16 8:58	606303488	Lead	14.9	15	ppb
035-89A Adult Restroom Sink Faucet #1	6/30/16 1:05	7/13/16 8:58	606303489	Copper	0.0	1.3	ppm
035-89A Adult Restroom Sink Faucet #1	6/30/16 1:05	7/13/16 8:58	606303489	Lead	10	15	ppb
035-90A Adult Restroom Sink Faucet #2	6/30/16 1:05	7/13/16 8:58	606303490	Copper	0.1	1.3	ppm
035-90A Adult Restroom Sink Faucet #2	6/30/16 1:05	7/13/16 8:58	606303490	Lead	38	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Faubion School at Harriet Tubman Middle School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
035-91A Adult Restroom Water Spigot	6/30/16 1:06	7/13/16 9:00	606303491	Copper	0.3	1.3	ppm
035-91A Adult Restroom Water Spigot	6/30/16 1:06	7/13/16 9:00	606303491	Lead	53	15	ppb
035-92A Room 105C Sink Faucet	6/30/16 1:08	7/13/16 9:00	606303492	Copper	0.1	1.3	ppm
035-92A Room 105C Sink Faucet	6/30/16 1:08	7/13/16 9:00	606303492	Lead	6	15	ppb
035-93A Room 103 Sink Faucet	6/30/16 1:08	7/13/16 9:00	606303493	Copper	0.3	1.3	ppm
035-93A Room 103 Sink Faucet	6/30/16 1:08	7/13/16 9:00	606303493	Lead	24	15	ppb
035-94A Room 112 Sink Faucet	6/30/16 1:10	7/13/16 9:00	606303494	Copper	0.1	1.3	ppm
035-94A Room 112 Sink Faucet	6/30/16 1:10	7/13/16 9:00	606303494	Lead	25	15	ppb
035-95A Room 111 Sink Faucet	6/30/16 1:12	7/13/16 9:00	606303495	Copper	0.1	1.3	ppm
035-95A Room 111 Sink Faucet	6/30/16 1:12	7/13/16 9:00	606303495	Lead	16	15	ppb
035-96A Janitors Closet Sink Faucet	6/30/16 1:14	7/13/16 9:00	606303496	Copper	0.1	1.3	ppm
035-96A Janitors Closet Sink Faucet	6/30/16 1:14	7/13/16 9:00	606303496	Lead	5	15	ppb
035-97A Hallway Drinking Fountain	6/30/16 1:16	7/13/16 9:00	606303497	Copper	1.0	1.3	ppm
035-97A Hallway Drinking Fountain	6/30/16 1:16	7/13/16 9:00	606303497	Lead	1	15	ppb
035-98A Hallway Drinking Fountain Bottle Refill	6/30/16 1:16	7/13/16 9:00	606303498	Copper	0.9	1.3	ppm
035-98A Hallway Drinking Fountain Bottle Refill	6/30/16 1:16	7/13/16 9:00	606303498	Lead	1	15	ppb
035-99A Mens Restroom Sink Faucet #1	6/30/16 1:16	7/13/16 9:00	606303499	Copper	0.0	1.3	ppm
035-99A Mens Restroom Sink Faucet #1	6/30/16 1:16	7/13/16 9:00	606303499	Lead	16	15	ppb
035-100A Mens Restroom Sink Faucet #2	6/30/16 1:18	7/13/16 9:00	6063034100	Copper	0.0	1.3	ppm
035-100A Mens Restroom Sink Faucet #2	6/30/16 1:18	7/13/16 9:00	6063034100	Lead	29	15	ppb
035-101A Mens Restroom Water Spigot	6/30/16 1:18	7/13/16 9:00	6063034101	Copper	0.6	1.3	ppm
035-101A Mens Restroom Water Spigot	6/30/16 1:18	7/13/16 9:00	6063034101	Lead	62	15	ppb
035-102A Drinking Fountain Hallway	6/30/16 1:20	7/13/16 9:00	6063034102	Copper	0.7	1.3	ppm
035-102A Drinking Fountain Hallway	6/30/16 1:20	7/13/16 9:00	6063034102	Lead	1	15	ppb
035-103A Boys Restroom Sink Faucet #1	6/30/16 1:21	7/13/16 9:00	6063034103	Copper	0.5	1.3	ppm
035-103A Boys Restroom Sink Faucet #1	6/30/16 1:21	7/13/16 9:00	6063034103	Lead	25	15	ppb
035-104A Boys Restroom Sink Faucet #2	6/30/16 1:22	7/13/16 9:00	6063034104	Copper	0.6	1.3	ppm
035-104A Boys Restroom Sink Faucet #2	6/30/16 1:22	7/13/16 9:00	6063034104	Lead	2	15	ppb
035-105A Boys Restroom Sink Faucet #3	6/30/16 1:22	7/13/16 9:00	6063034105	Copper	0.5	1.3	ppm
035-105A Boys Restroom Sink Faucet #3	6/30/16 1:22	7/13/16 9:00	6063034105	Lead	4	15	ppb
035-106A Boys Restroom Water Spigot	6/30/16 1:22	7/14/16 9:35	6063034106	Copper	2.5	1.3	ppm
035-106A Boys Restroom Water Spigot	6/30/16 1:22	7/13/16 9:01	6063034106	Lead	80	15	ppb
035-107A Room 229 Sink Faucet	6/30/16 1:29	7/13/16 9:01	6063034107	Copper	0.5	1.3	ppm
035-107A Room 229 Sink Faucet	6/30/16 1:29	7/13/16 9:01	6063034107	Lead	1	15	ppb
035-108A Room 227 Sink Faucet	6/30/16 1:24	7/13/16 9:01	6063034108	Copper	0.2	1.3	ppm
035-108A Room 227 Sink Faucet	6/30/16 1:24	7/13/16 9:01	6063034108	Lead	1	15	ppb
035-109A Girls Restroom Sink Faucet #1	6/30/16 1:26	7/13/16 9:01	6063034109	Copper	0.4	1.3	ppm
035-109A Girls Restroom Sink Faucet #1	6/30/16 1:26	7/13/16 9:01	6063034109	Lead	9	15	ppb
035-110A Girls Restroom Sink Faucet #2	6/30/16 1:26	7/13/16 9:01	6063034110	Copper	0.5	1.3	ppm
035-110A Girls Restroom Sink Faucet #2	6/30/16 1:26	7/13/16 9:01	6063034110	Lead	13	15	ppb
035-111A Girls Restroom Sink Faucet #3	6/30/16 1:28	7/13/16 9:01	6063034111	Copper	0.3	1.3	ppm
035-111A Girls Restroom Sink Faucet #3	6/30/16 1:28	7/13/16 9:01	6063034111	Lead	13	15	ppb
035-112A Girls Restroom Sink Faucet #4	6/30/16 1:28	7/13/16 9:01	6063034112	Copper	0.7	1.3	ppm
035-112A Girls Restroom Sink Faucet #4	6/30/16 1:28	7/13/16 9:01	6063034112	Lead	22	15	ppb
035-113A Girls Restroom Sink Faucet #5	6/30/16 1:30	7/13/16 9:01	6063034113	Copper	0.6	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Faubion School at Harriet Tubman Middle School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
035-113A Girls Restroom Sink Faucet #5	6/30/16 1:30	7/13/16 9:01	6063034113	Lead	20	15	ppb
035-114A Girls Restroom Water Spigot	6/30/16 1:30	7/13/16 9:01	6063034114	Copper	0.7	1.3	ppm
035-114A Girls Restroom Water Spigot	6/30/16 1:30	7/13/16 9:01	6063034114	Lead	42	15	ppb
035-115A Janitors Sink Faucet	6/30/16 1:32	7/13/16 9:01	6063034115	Copper	0.2	1.3	ppm
035-115A Janitors Sink Faucet	6/30/16 1:32	7/13/16 9:01	6063034115	Lead	5	15	ppb
035-116A Room 228 Sink Faucet	6/30/16 1:32	7/13/16 9:01	6063034116	Copper	0.6	1.3	ppm
035-116A Room 228 Sink Faucet	6/30/16 1:32	7/13/16 9:01	6063034116	Lead	29	15	ppb
035-117A Room 228 Drinking Fountain	6/30/16 1:33	7/13/16 9:01	6063034117	Copper	0.5	1.3	ppm
035-117A Room 228 Drinking Fountain	6/30/16 1:33	7/13/16 9:01	6063034117	Lead	9	15	ppb
035-118A Room 221 Sink Faucet	6/30/16 1:35	7/13/16 9:01	6063034118	Copper	0.5	1.3	ppm
035-118A Room 221 Sink Faucet	6/30/16 1:35	7/13/16 9:01	6063034118	Lead	26	15	ppb
035-119A Room 221 Drinking Fountain	6/30/16 1:35	7/13/16 9:01	6063034119	Copper	0.2	1.3	ppm
035-119A Room 221 Drinking Fountain	6/30/16 1:35	7/13/16 9:01	6063034119	Lead	3	15	ppb
035-120A Room 219 Sink Faucet	6/30/16 1:37	7/13/16 9:01	6063034120	Copper	0.7	1.3	ppm
035-120A Room 219 Sink Faucet	6/30/16 1:37	7/13/16 9:01	6063034120	Lead	33	15	ppb
035-121A Room 219 Drinking Fountain	6/30/16 1:37	7/13/16 11:54	6063034121	Copper	0.2	1.3	ppm
035-121A Room 219 Drinking Fountain	6/30/16 1:37	7/13/16 11:54	6063034121	Lead	5	15	ppb
035-122A Room 226 Sink Faucet	6/30/16 1:39	7/13/16 11:54	6063034122	Copper	0.5	1.3	ppm
035-122A Room 226 Sink Faucet	6/30/16 1:39	7/13/16 11:54	6063034122	Lead	22	15	ppb
035-123A Room 226 Drinking Fountain	6/30/16 1:39	7/13/16 11:54	6063034123	Copper	0.2	1.3	ppm
035-123A Room 226 Drinking Fountain	6/30/16 1:39	7/13/16 11:54	6063034123	Lead	2	15	ppb
035-124A Room 224 Sink Faucet	6/30/16 1:39	7/13/16 11:54	6063034124	Copper	0.7	1.3	ppm
035-124A Room 224 Sink Faucet	6/30/16 1:39	7/13/16 11:54	6063034124	Lead	18	15	ppb
035-125A Room 224 Drinking Fountain	6/30/16 1:39	7/13/16 11:54	6063034125	Copper	0.7	1.3	ppm
035-125A Room 224 Drinking Fountain	6/30/16 1:39	7/13/16 11:54	6063034125	Lead	6	15	ppb
035-126A Room 217 Sink Faucet	6/30/16 1:47	7/13/16 11:54	6063034126	Copper	0.6	1.3	ppm
035-126A Room 217 Sink Faucet	6/30/16 1:47	7/13/16 11:54	6063034126	Lead	15.0	15	ppb
035-127A Room 217 Drinking Fountain	6/30/16 1:41	7/13/16 11:54	6063034127	Copper	0.4	1.3	ppm
035-127A Room 217 Drinking Fountain	6/30/16 1:41	7/13/16 11:54	6063034127	Lead	3	15	ppb
035-128A Room 222 Sink Faucet #1	6/30/16 1:43	7/13/16 11:54	6063034128	Copper	0.7	1.3	ppm
035-128A Room 222 Sink Faucet #1	6/30/16 1:43	7/13/16 11:54	6063034128	Lead	14	15	ppb
035-129A Room 222 Sink Faucet #2	6/30/16 1:43	7/13/16 11:54	6063034129	Copper	0.1	1.3	ppm
035-129A Room 222 Sink Faucet #2	6/30/16 1:43	7/13/16 11:54	6063034129	Lead	2	15	ppb
035-130A Room 218 Sink Faucet #1	6/30/16 1:45	7/13/16 11:54	6063034130	Copper	0.2	1.3	ppm
035-130A Room 218 Sink Faucet #1	6/30/16 1:45	7/13/16 11:54	6063034130	Lead	42	15	ppb
035-131A Room 218 Sink Faucet #2	6/30/16 1:45	7/13/16 11:54	6063034131	Copper	0.2	1.3	ppm
035-131A Room 218 Sink Faucet #2	6/30/16 1:45	7/13/16 11:54	6063034131	Lead	173	15	ppb
035-132A Room 218 Sink Faucet #3	6/30/16 1:46	7/13/16 11:54	6063034132	Copper	0.3	1.3	ppm
035-132A Room 218 Sink Faucet #3	6/30/16 1:46	7/13/16 11:54	6063034132	Lead	190	15	ppb
035-133A Room 218 Sink Faucet #4	6/30/16 1:47	7/13/16 11:54	6063034133	Copper	0.3	1.3	ppm
035-133A Room 218 Sink Faucet #4	6/30/16 1:47	7/13/16 11:54	6063034133	Lead	96	15	ppb
035-134A Room 218 Sink Faucet #5	6/30/16 1:48	7/13/16 11:54	6063034134	Copper	0.2	1.3	ppm
035-134A Room 218 Sink Faucet #5	6/30/16 1:48	7/13/16 11:54	6063034134	Lead	58	15	ppb
035-135A Room 212 Sink Faucet #1	6/30/16 1:50	7/13/16 11:54	6063034135	Copper	0.3	1.3	ppm
035-135A Room 212 Sink Faucet #1	6/30/16 1:50	7/13/16 11:54	6063034135	Lead	84	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Faubion School at Harriet Tubman Middle School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
035-136A Room 212 Sink Faucet #2	6/30/16 1:50	7/13/16 11:54	6063034136	Copper	0.1	1.3	ppm
035-136A Room 212 Sink Faucet #2	6/30/16 1:50	7/13/16 11:54	6063034136	Lead	108	15	ppb
035-137A Room 212 Sink Faucet #3	6/30/16 1:51	7/13/16 11:54	6063034137	Copper	0.4	1.3	ppm
035-137A Room 212 Sink Faucet #3	6/30/16 1:51	7/13/16 11:54	6063034137	Lead	19	15	ppb
035-138A Room 212 Sink Faucet #4	6/30/16 1:52	7/13/16 11:54	6063034138	Copper	0.5	1.3	ppm
035-138A Room 212 Sink Faucet #4	6/30/16 1:52	7/13/16 11:54	6063034138	Lead	79	15	ppb
035-139A Hallway Sink Faucet #1	6/30/16 1:54	7/13/16 11:54	6063034139	Copper	0.4	1.3	ppm
035-139A Hallway Sink Faucet #1	6/30/16 1:54	7/13/16 11:54	6063034139	Lead	95	15	ppb
035-140A Hallway Sink Faucet #2	6/30/16 1:54	7/13/16 11:55	6063034140	Copper	0.5	1.3	ppm
035-140A Hallway Sink Faucet #2	6/30/16 1:54	7/13/16 11:55	6063034140	Lead	59	15	ppb
035-141A Room 215 Sink Faucet #1	6/30/16 1:56	7/13/16 11:55	6063034141	Copper	0.9	1.3	ppm
035-141A Room 215 Sink Faucet #1	6/30/16 1:56	7/13/16 11:55	6063034141	Lead	81	15	ppb
035-142A Room 215 Sink Faucet #2	6/30/16 1:56	7/13/16 11:55	6063034142	Copper	1.0	1.3	ppm
035-142A Room 215 Sink Faucet #2	6/30/16 1:56	7/13/16 11:55	6063034142	Lead	58	15	ppb
035-143A Room 215 Sink Faucet #3	6/30/16 1:58	7/13/16 11:55	6063034143	Copper	0.7	1.3	ppm
035-143A Room 215 Sink Faucet #3	6/30/16 1:58	7/13/16 11:55	6063034143	Lead	112	15	ppb
035-144A Room 215 Sink Faucet #4	6/30/16 1:58	7/13/16 11:55	6063034144	Copper	0.9	1.3	ppm
035-144A Room 215 Sink Faucet #4	6/30/16 1:58	7/13/16 11:55	6063034144	Lead	49	15	ppb
035-145A Room 215 Sink Faucet #5	6/30/16 2:01	7/13/16 11:55	6063034145	Copper	0.7	1.3	ppm
035-145A Room 215 Sink Faucet #5	6/30/16 2:01	7/13/16 11:55	6063034145	Lead	29	15	ppb
035-146A Room 215 Sink Faucet #6	6/30/16 2:01	7/13/16 11:55	6063034146	Copper	1.0	1.3	ppm
035-146A Room 215 Sink Faucet #6	6/30/16 2:01	7/13/16 11:55	6063034146	Lead	61	15	ppb
035-147A Room 215 Sink Faucet #7	6/30/16 2:03	7/13/16 11:55	6063034147	Copper	0.5	1.3	ppm
035-147A Room 215 Sink Faucet #7	6/30/16 2:03	7/13/16 11:55	6063034147	Lead	241	15	ppb
035-148A Room 215 Eye Wash	6/30/16 2:04	7/13/16 11:55	6063034148	Copper	0.4	1.3	ppm
035-148A Room 215 Eye Wash	6/30/16 2:04	7/13/16 11:55	6063034148	Lead	9	15	ppb
035-149A Hallway Drinking Fountain	6/30/16 2:06	7/13/16 11:55	6063034149	Copper	0.0	1.3	ppm
035-149A Hallway Drinking Fountain	6/30/16 2:06	7/13/16 11:55	6063034149	Lead	6	15	ppb
035-150A Girls Restroom Sink Faucet #1	6/30/16 2:08	7/13/16 11:55	6063034150	Copper	0.6	1.3	ppm
035-150A Girls Restroom Sink Faucet #1	6/30/16 2:08	7/13/16 11:55	6063034150	Lead	22	15	ppb
035-151A Girls Restroom Sink Faucet #2	6/30/16 2:08	7/13/16 11:55	6063034151	Copper	1.1	1.3	ppm
035-151A Girls Restroom Sink Faucet #2	6/30/16 2:08	7/13/16 11:55	6063034151	Lead	48	15	ppb
035-152A Boys Restroom Sink Faucet #1	6/30/16 2:10	7/13/16 11:55	6063034152	Copper	0.4	1.3	ppm
035-152A Boys Restroom Sink Faucet #1	6/30/16 2:10	7/13/16 11:55	6063034152	Lead	16	15	ppb
035-153A Boys Restroom Sink Faucet #2	6/30/16 2:10	7/13/16 11:55	6063034153	Copper	1.0	1.3	ppm
035-153A Boys Restroom Sink Faucet #2	6/30/16 2:10	7/13/16 11:55	6063034153	Lead	41	15	ppb
035-154A Boys Restroom Water Spigot	6/30/16 2:11	7/13/16 11:55	6063034154	Copper	1.1	1.3	ppm
035-154A Boys Restroom Water Spigot	6/30/16 2:11	7/13/16 11:55	6063034154	Lead	29	15	ppb
035-155A Janitors Closet Sink Faucet	6/30/16 2:13	7/13/16 11:55	6063034155	Copper	0.2	1.3	ppm
035-155A Janitors Closet Sink Faucet	6/30/16 2:13	7/13/16 11:55	6063034155	Lead	8	15	ppb
035-156A Staff Restroom Sink Faucet	6/30/16 2:15	7/13/16 11:55	6063034156	Copper	0.9	1.3	ppm
035-156A Staff Restroom Sink Faucet	6/30/16 2:15	7/13/16 11:55	6063034156	Lead	7	15	ppb
035-157A Room 211 Drinking Fountain	6/30/16 2:17	7/13/16 11:55	6063034157	Copper	0.1	1.3	ppm
035-157A Room 211 Drinking Fountain	6/30/16 2:17	7/13/16 11:55	6063034157	Lead	1	15	ppb
035-158A Room 209 Sink Faucet	6/30/16 2:19	7/13/16 11:55	6063034158	Copper	0.4	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Faubion School at Harriet Tubman Middle School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
035-158A Room 209 Sink Faucet	6/30/16 2:19	7/13/16 11:55	6063034158	Lead	30	15	ppb
035-159A Room 209 Drinking Fountain	6/30/16 2:19	7/13/16 11:55	6063034159	Copper	0.1	1.3	ppm
035-159A Room 209 Drinking Fountain	6/30/16 2:19	7/13/16 11:55	6063034159	Lead	11	15	ppb
035-160A Room 206 Sink Faucet	6/30/16 2:21	7/13/16 11:55	6063034160	Copper	0.2	1.3	ppm
035-160A Room 206 Sink Faucet	6/30/16 2:21	7/13/16 11:55	6063034160	Lead	91	15	ppb
035-161A Room 206 Drinking Fountain	6/30/16 2:22	7/13/16 11:56	6063034161	Copper	0.1	1.3	ppm
035-161A Room 206 Drinking Fountain	6/30/16 2:22	7/13/16 11:56	6063034161	Lead	23	15	ppb
035-162A Room 204 Sink Faucet	6/30/16 2:22	7/13/16 11:56	6063034162	Copper	0.2	1.3	ppm
035-162A Room 204 Sink Faucet	6/30/16 2:22	7/13/16 11:56	6063034162	Lead	24	15	ppb
035-163A Room 204 Drinking Fountain	6/30/16 2:23	7/13/16 11:56	6063034163	Copper	0.0	1.3	ppm
035-163A Room 204 Drinking Fountain	6/30/16 2:23	7/13/16 11:56	6063034163	Lead	28	15	ppb
035-164A Room 207 Sink Faucet	6/30/16 2:25	7/13/16 11:56	6063034164	Copper	0.4	1.3	ppm
035-164A Room 207 Sink Faucet	6/30/16 2:25	7/13/16 11:56	6063034164	Lead	33	15	ppb
035-165A Room 207 Drinking Fountain	6/30/16 2:26	7/13/16 11:56	6063034165	Copper	0.2	1.3	ppm
035-165A Room 207 Drinking Fountain	6/30/16 2:26	7/13/16 11:56	6063034165	Lead	3	15	ppb
035-166A Room 205 Sink Faucet	6/30/16 2:28	7/13/16 11:56	6063034166	Copper	0.2	1.3	ppm
035-166A Room 205 Sink Faucet	6/30/16 2:28	7/13/16 11:56	6063034166	Lead	29	15	ppb
035-167A Room 205 Drinking Fountain	6/30/16 2:29	7/13/16 11:56	6063034167	Copper	0.1	1.3	ppm
035-167A Room 205 Drinking Fountain	6/30/16 2:29	7/13/16 11:56	6063034167	Lead	8	15	ppb
035-168A Room 202 Sink Faucet	6/30/16 2:28	7/13/16 11:56	6063034168	Copper	0.2	1.3	ppm
035-168A Room 202 Sink Faucet	6/30/16 2:28	7/13/16 11:56	6063034168	Lead	14.8	15	ppb
035-169A Room 202 Drinking Fountain	6/30/16 2:29	7/13/16 11:56	6063034169	Copper	0.1	1.3	ppm
035-169A Room 202 Drinking Fountain	6/30/16 2:29	7/13/16 11:56	6063034169	Lead	19	15	ppb
035-170A Room 200 Sink Faucet	6/30/16 2:31	7/13/16 11:56	6063034170	Copper	0.2	1.3	ppm
035-170A Room 200 Sink Faucet	6/30/16 2:31	7/13/16 11:56	6063034170	Lead	15.0	15	ppb
035-171A Room 200 Drinking Fountain	6/30/16 2:31	7/13/16 11:56	6063034171	Copper	0.0	1.3	ppm
035-171A Room 200 Drinking Fountain	6/30/16 2:31	7/13/16 11:56	6063034171	Lead	9	15	ppb
035-172A Hallway Drinking Fountain	6/30/16 2:31	7/13/16 11:56	6063034172	Copper	0.0	1.3	ppm
035-172A Hallway Drinking Fountain	6/30/16 2:31	7/13/16 11:56	6063034172	Lead	4	15	ppb
035-173A Room 203 Sink Faucet	6/30/16 2:34	7/13/16 11:56	6063034173	Copper	0.2	1.3	ppm
035-173A Room 203 Sink Faucet	6/30/16 2:34	7/13/16 11:56	6063034173	Lead	32	15	ppb
035-174A Room 203 Drinking Fountain	6/30/16 2:35	7/13/16 11:56	6063034174	Copper	0.1	1.3	ppm
035-174A Room 203 Drinking Fountain	6/30/16 2:35	7/13/16 11:56	6063034174	Lead	6	15	ppb
035-175A Girls Restroom Sink Faucet #1	6/30/16 2:37	7/13/16 11:56	6063034175	Copper	0.0	1.3	ppm
035-175A Girls Restroom Sink Faucet #1	6/30/16 2:37	7/13/16 11:56	6063034175	Lead	6	15	ppb
035-176A Girls Restroom Sink Faucet #2	6/30/16 2:37	7/13/16 11:56	6063034176	Copper	0.1	1.3	ppm
035-176A Girls Restroom Sink Faucet #2	6/30/16 2:37	7/13/16 11:56	6063034176	Lead	9	15	ppb
035-177A Girls Restroom Water Spigot	6/30/16 2:38	7/13/16 11:56	6063034177	Copper	0.4	1.3	ppm
035-177A Girls Restroom Water Spigot	6/30/16 2:38	7/13/16 11:56	6063034177	Lead	74	15	ppb
035-178A Room 201 Sink Faucet	6/30/16 2:40	7/13/16 11:56	6063034178	Copper	0.2	1.3	ppm
035-178A Room 201 Sink Faucet	6/30/16 2:40	7/13/16 11:56	6063034178	Lead	23	15	ppb
035-179A Room 201 Drinking Fountain	6/30/16 2:40	7/13/16 11:56	6063034179	Copper	0.1	1.3	ppm
035-179A Room 201 Drinking Fountain	6/30/16 2:40	7/13/16 11:56	6063034179	Lead	2	15	ppb
035-180A Janitors Closet Sink Faucet	6/30/16 2:43	7/13/16 11:56	6063034180	Copper	0.1	1.3	ppm
035-180A Janitors Closet Sink Faucet	6/30/16 2:43	7/13/16 11:56	6063034180	Lead	3	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Faubion School at Harriet Tubman Middle School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
035-181A Boys Restroom Sink Faucet #1	6/30/16 2:45	7/13/16 11:56	6063034181	Copper	0.1	1.3	ppm
035-181A Boys Restroom Sink Faucet #1	6/30/16 2:45	7/13/16 11:56	6063034181	Lead	20	15	ppb
035-182A Boys Restroom Sink Faucet #2	6/30/16 2:45	7/13/16 11:56	6063034182	Copper	0.0	1.3	ppm
035-182A Boys Restroom Sink Faucet #2	6/30/16 2:45	7/13/16 11:56	6063034182	Lead	14	15	ppb
035-183A Boys Restroom Water Spigot	6/30/16 2:46	7/13/16 11:56	6063034183	Copper	0.3	1.3	ppm
035-183A Boys Restroom Water Spigot	6/30/16 2:46	7/13/16 11:56	6063034183	Lead	42	15	ppb
035-184A Janitors Closet Sink Faucet	6/30/16 2:55	7/13/16 11:57	6063034184	Copper	0.3	1.3	ppm
035-184A Janitors Closet Sink Faucet	6/30/16 2:55	7/13/16 11:57	6063034184	Lead	21	15	ppb
035-185A Staff Restroom Sink Faucet	6/30/16 2:57	7/13/16 11:57	6063034185	Copper	0.3	1.3	ppm
035-185A Staff Restroom Sink Faucet	6/30/16 2:57	7/13/16 11:57	6063034185	Lead	14.6	15	ppb
035-186A Arts Sink Faucet #1	6/30/16 2:57	7/13/16 11:57	6063034186	Copper	0.4	1.3	ppm
035-186A Arts Sink Faucet #1	6/30/16 2:57	7/13/16 11:57	6063034186	Lead	64	15	ppb
035-187A Arts Drinking Fountain #1	6/30/16 2:58	7/13/16 11:57	6063034187	Copper	0.3	1.3	ppm
035-187A Arts Drinking Fountain #1	6/30/16 2:58	7/13/16 11:57	6063034187	Lead	9	15	ppb
035-188A Arts Sink Faucet #2	6/30/16 3:01	7/13/16 11:57	6063034188	Copper	0.4	1.3	ppm
035-188A Arts Sink Faucet #2	6/30/16 3:01	7/13/16 11:57	6063034188	Lead	30	15	ppb
035-189A Arts Drinking Fountain #2	6/30/16 3:03	7/13/16 11:57	6063034189	Copper	0.0	1.3	ppm
035-189A Arts Drinking Fountain #2	6/30/16 3:03	7/13/16 11:57	6063034189	Lead	1	15	ppb
035-190A Outside Arts Water Spigot	6/30/16 3:08	7/13/16 11:57	6063034190	Copper	0.5	1.3	ppm
035-190A Outside Arts Water Spigot	6/30/16 3:08	7/13/16 11:57	6063034190	Lead	21	15	ppb
035-191A Arts Sink Faucet #3	6/30/16 3:10	7/13/16 11:57	6063034191	Copper	0.4	1.3	ppm
035-191A Arts Sink Faucet #3	6/30/16 3:10	7/13/16 11:57	6063034191	Lead	26	15	ppb
035-192A Outside Main Water Spigot #1	6/30/16 3:18	7/13/16 11:57	6063034192	Copper	0.5	1.3	ppm
035-192A Outside Main Water Spigot #1	6/30/16 3:18	7/13/16 11:57	6063034192	Lead	7	15	ppb
035-193A Outside Main Water Spigot #2	6/30/16 3:22	7/13/16 11:57	6063034193	Copper	0.2	1.3	ppm
035-193A Outside Main Water Spigot #2	6/30/16 3:22	7/13/16 11:57	6063034193	Lead	42	15	ppb
035-194A Outside Main Water Spigot #3	6/30/16 3:25	7/13/16 11:57	6063034194	Copper	0.1	1.3	ppm
035-194A Outside Main Water Spigot #3	6/30/16 3:25	7/13/16 11:57	6063034194	Lead	20	15	ppb
035-195A Room 211 Sink Faucet	6/30/16 3:40	7/13/16 11:57	6063034195	Copper	0.2	1.3	ppm
035-195A Room 211 Sink Faucet	6/30/16 3:40	7/13/16 11:57	6063034195	Lead	21	15	ppb
035-196A Room 212 Sink Faucet	6/30/16 3:44	7/13/16 11:57	6063034196	Copper	0.2	1.3	ppm
035-196A Room 212 Sink Faucet	6/30/16 3:44	7/13/16 11:57	6063034196	Lead	50	15	ppb

EPA Action Level for Lead of 15 ppb
EPA Action Level for Copper of 1.3 ppm

ND = Non detect

Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.