

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Forest Park Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
036-01A Boiler Room 104 Water Spigot	6/28/16 16:39	7/13/16 13:14	606300901	Copper	0.6	1.3	ppm
036-01A Boiler Room 104 Water Spigot	6/28/16 16:39	7/13/16 13:14	606300901	Lead	43	15	ppb
036-02A Bathroom 103 Sink Faucet	6/28/16 16:40	7/13/16 13:14	606300902	Copper	0.3	1.3	ppm
036-02A Bathroom 103 Sink Faucet	6/28/16 16:40	7/13/16 13:14	606300902	Lead	3	15	ppb
036-03A Hallway Sink Faucet near Kitchen	6/28/16 16:45	7/14/16 11:33	606300903	Copper	0.2	1.3	ppm
036-03A Hallway Sink Faucet near Kitchen	6/28/16 16:45	7/14/16 11:33	606300903	Lead	1	15	ppb
036-04A Kitchen Dishwash Sink Faucet #1	6/28/16 16:49	7/13/16 13:14	606300904	Copper	0.6	1.3	ppm
036-04A Kitchen Dishwash Sink Faucet #1	6/28/16 16:49	7/13/16 13:14	606300904	Lead	4	15	ppb
036-05A Kitchen Dishwash Sink Faucet #2	6/28/16 16:48	7/13/16 13:14	606300905	Copper	0.3	1.3	ppm
036-05A Kitchen Dishwash Sink Faucet #2	6/28/16 16:48	7/13/16 13:14	606300905	Lead	2	15	ppb
036-06A Kitchen Food Prep Sink Faucet	6/28/16 16:51	7/13/16 13:14	606300906	Copper	0.2	1.3	ppm
036-06A Kitchen Food Prep Sink Faucet	6/28/16 16:51	7/13/16 13:14	606300906	Lead	3	15	ppb
036-07A Kitchen Handwash Sink Faucet	6/28/16 16:48	7/13/16 13:14	606300907	Copper	0.3	1.3	ppm
036-07A Kitchen Handwash Sink Faucet	6/28/16 16:48	7/13/16 13:14	606300907	Lead	1	15	ppb
036-08A Cafeteria Drinking Fountain #1	6/28/16 16:53	7/13/16 13:14	606300908	Copper	0.4	1.3	ppm
036-08A Cafeteria Drinking Fountain #1	6/28/16 16:53	7/13/16 13:14	606300908	Lead	1	15	ppb
036-09A Cafeteria Drinking Fountain #2	6/28/16 16:54	7/13/16 13:14	606300909	Copper	0.1	1.3	ppm
036-09A Cafeteria Drinking Fountain #2	6/28/16 16:54	7/13/16 13:14	606300909	Lead	0	15	ppb
036-10A Drinking Fountain outside 116 #1	6/28/16 16:57	7/13/16 13:15	606300910	Copper	0.3	1.3	ppm
036-10A Drinking Fountain outside 116 #1	6/28/16 16:57	7/13/16 13:15	606300910	Lead	2	15	ppb
036-11A Drinking Fountain outside 116 #2	6/28/16 16:58	7/13/16 13:15	606300911	Copper	0.3	1.3	ppm
036-11A Drinking Fountain outside 116 #2	6/28/16 16:58	7/13/16 13:15	606300911	Lead	1	15	ppb
036-12A Girls Bathroom Sink Faucet	6/28/16 17:02	7/13/16 13:15	606300912	Copper	0.6	1.3	ppm
036-12A Girls Bathroom Sink Faucet	6/28/16 17:02	7/13/16 13:15	606300912	Lead	48	15	ppb
036-13A Girls Bathroom Water Spigot	6/28/16 17:03	7/13/16 13:15	606300913	Copper	0.2	1.3	ppm
036-13A Girls Bathroom Water Spigot	6/28/16 17:03	7/13/16 13:15	606300913	Lead	2	15	ppb
036-14A Custodian 116 Sink Faucet	6/28/16 17:05	7/13/16 13:15	606300914	Copper	0.2	1.3	ppm
036-14A Custodian 116 Sink Faucet	6/28/16 17:05	7/13/16 13:15	606300914	Lead	7	15	ppb
036-15A Sprinkler Valve Room 111A Sink Faucet	6/28/16 17:10	7/13/16 13:15	606300915	Copper	0.3	1.3	ppm
036-15A Sprinkler Valve Room 111A Sink Faucet	6/28/16 17:10	7/13/16 13:15	606300915	Lead	2	15	ppb
036-16A Room 120 Sink Faucet	6/28/16 17:15	7/13/16 13:15	606300916	Copper	0.4	1.3	ppm
036-16A Room 120 Sink Faucet	6/28/16 17:15	7/13/16 13:15	606300916	Lead	3	15	ppb
036-17A Classroom 124 Sink Faucet	6/28/16 17:17	7/13/16 13:15	606300917	Copper	0.6	1.3	ppm
036-17A Classroom 124 Sink Faucet	6/28/16 17:17	7/13/16 13:15	606300917	Lead	2	15	ppb
036-18A Classroom 125 Sink Faucet	6/28/16 17:16	7/13/16 13:15	606300918	Copper	0.4	1.3	ppm
036-18A Classroom 125 Sink Faucet	6/28/16 17:16	7/13/16 13:15	606300918	Lead	2	15	ppb
036-19A Act. 129 Sink Faucet	6/28/16 17:20	7/13/16 13:15	606300919	Copper	0.4	1.3	ppm
036-19A Act. 129 Sink Faucet	6/28/16 17:20	7/13/16 13:15	606300919	Lead	1	15	ppb
036-20A Classroom 126 Sink Faucet	6/28/16 17:20	7/13/16 13:15	606300920	Copper	0.5	1.3	ppm
036-20A Classroom 126 Sink Faucet	6/28/16 17:20	7/13/16 13:15	606300920	Lead	2	15	ppb
036-21A Classroom 127 Sink Faucet #1	6/28/16 17:22	7/14/16 9:36	606300921	Copper	0.5	1.3	ppm
036-21A Classroom 127 Sink Faucet #1	6/28/16 17:22	7/14/16 9:36	606300921	Lead	2	15	ppb
036-22A Classroom 127 Sink Faucet #2	6/28/16 17:25	7/14/16 9:36	606300922	Copper	0.3	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Forest Park Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
036-22A Classroom 127 Sink Faucet #2	6/28/16 17:25	7/14/16 9:36	606300922	Lead	1	15	ppb
036-23A Drinking Fountain outside 130 #1	6/28/16 17:27	7/14/16 9:36	606300923	Copper	0.6	1.3	ppm
036-23A Drinking Fountain outside 130 #1	6/28/16 17:27	7/14/16 9:36	606300923	Lead	1	15	ppb
036-24A Drinking Fountain outside 130 #2	6/28/16 17:29	7/14/16 9:36	606300924	Copper	0.3	1.3	ppm
036-24A Drinking Fountain outside 130 #2	6/28/16 17:29	7/14/16 9:36	606300924	Lead	1	15	ppb
036-25A Girls Bathroom Sink Faucet	6/28/16 17:32	7/14/16 9:36	606300925	Copper	0.3	1.3	ppm
036-25A Girls Bathroom Sink Faucet	6/28/16 17:32	7/14/16 9:36	606300925	Lead	1	15	ppb
036-26A Health 123A Sink Faucet	6/28/16 17:36	7/14/16 9:36	606300926	Copper	0.3	1.3	ppm
036-26A Health 123A Sink Faucet	6/28/16 17:36	7/14/16 9:36	606300926	Lead	2	15	ppb
036-27A Staff Bathroom 123C Sink Faucet	6/28/16 17:38	7/14/16 9:36	606300927	Copper	0.3	1.3	ppm
036-27A Staff Bathroom 123C Sink Faucet	6/28/16 17:38	7/14/16 9:36	606300927	Lead	5	15	ppb
036-28A Faculty Lounge 123K Sink Faucet	6/28/16 17:40	7/14/16 9:37	606300928	Copper	0.3	1.3	ppm
036-28A Faculty Lounge 123K Sink Faucet	6/28/16 17:40	7/14/16 9:37	606300928	Lead	1	15	ppb
036-29A Staff Bathroom 139 Sink Faucet	6/28/16 17:43	7/14/16 10:42	606300929	Copper	1.2	1.3	ppm
036-29A Staff Bathroom 139 Sink Faucet	6/28/16 17:43	7/14/16 9:37	606300929	Lead	10	15	ppb
036-30A Staff Bathroom 140 Sink Faucet	6/28/16 17:45	7/14/16 9:37	606300930	Copper	0.5	1.3	ppm
036-30A Staff Bathroom 140 Sink Faucet	6/28/16 17:45	7/14/16 9:37	606300930	Lead	4	15	ppb
036-31A Counselor/Room 141 Sink Faucet	6/28/16 17:42	7/14/16 9:37	606300931	Copper	0.5	1.3	ppm
036-31A Counselor/Room 141 Sink Faucet	6/28/16 17:42	7/14/16 9:37	606300931	Lead	1	15	ppb
036-32A Workroom 143 Sink Faucet	6/28/16 17:50	7/14/16 9:37	606300932	Copper	0.5	1.3	ppm
036-32A Workroom 143 Sink Faucet	6/28/16 17:50	7/14/16 9:37	606300932	Lead	1	15	ppb
036-33A Custodian 144 Sink Faucet	6/28/16 17:49	7/14/16 9:37	606300933	Copper	0.4	1.3	ppm
036-33A Custodian 144 Sink Faucet	6/28/16 17:49	7/14/16 9:37	606300933	Lead	2	15	ppb
036-34A Custodian 216 Sink Faucet	6/28/16 17:56	7/14/16 9:37	606300934	Copper	0.4	1.3	ppm
036-34A Custodian 216 Sink Faucet	6/28/16 17:56	7/14/16 9:37	606300934	Lead	1	15	ppb
036-35A Workroom 214 Sink Faucet	6/28/16 17:58	7/14/16 9:37	606300935	Copper	0.4	1.3	ppm
036-35A Workroom 214 Sink Faucet	6/28/16 17:58	7/14/16 9:37	606300935	Lead	2	15	ppb
036-36A Drinking Fountain outside 201 #1	6/28/16 18:01	7/14/16 9:39	606300936	Copper	0.5	1.3	ppm
036-36A Drinking Fountain outside 201 #1	6/28/16 18:01	7/14/16 9:39	606300936	Lead	1	15	ppb
036-37A Drinking Fountain outside 201 #2	6/28/16 18:03	7/14/16 9:39	606300937	Copper	0.4	1.3	ppm
036-37A Drinking Fountain outside 201 #2	6/28/16 18:03	7/14/16 9:39	606300937	Lead	0	15	ppb
036-38A Classroom 202 Sink Faucet	6/28/16 18:02	7/14/16 9:55	606300938	Copper	0.4	1.3	ppm
036-38A Classroom 202 Sink Faucet	6/28/16 18:02	7/14/16 9:55	606300938	Lead	2	15	ppb
036-39A Classroom 203 Sink Faucet	6/28/16 18:05	7/14/16 9:55	606300939	Copper	0.3	1.3	ppm
036-39A Classroom 203 Sink Faucet	6/28/16 18:05	7/14/16 9:55	606300939	Lead	2	15	ppb
036-40A Classroom 204 Sink Faucet	6/28/16 18:07	7/14/16 9:55	606300940	Copper	0.5	1.3	ppm
036-40A Classroom 204 Sink Faucet	6/28/16 18:07	7/14/16 9:55	606300940	Lead	2	15	ppb
036-41A Act. 206 Sink Faucet	6/28/16 18:07	7/14/16 9:55	606300941	Copper	0.4	1.3	ppm
036-41A Act. 206 Sink Faucet	6/28/16 18:07	7/14/16 9:55	606300941	Lead	2	15	ppb
036-42A Classroom 205 Sink Faucet	6/28/16 18:10	7/14/16 9:55	606300942	Copper	0.5	1.3	ppm
036-42A Classroom 205 Sink Faucet	6/28/16 18:10	7/14/16 9:55	606300942	Lead	2	15	ppb
036-43A Classroom 207 Sink Faucet	6/28/16 18:12	7/14/16 9:55	606300943	Copper	0.4	1.3	ppm
036-43A Classroom 207 Sink Faucet	6/28/16 18:12	7/14/16 9:55	606300943	Lead	1	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Forest Park Elementary School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
036-44A Girls Bathroom Sink Faucet	6/28/16 18:14	7/14/16 9:55	606300944	Copper	0.4	1.3	ppm
036-44A Girls Bathroom Sink Faucet	6/28/16 18:14	7/14/16 9:55	606300944	Lead	4	15	ppb
036-45A Outside Drinking Fountain	6/28/16 18:33	7/14/16 9:55	606300945	Copper	0.1	1.3	ppm
036-45A Outside Drinking Fountain	6/28/16 18:33	7/14/16 9:55	606300945	Lead	0	15	ppb
036-46A Outside Water Spigot 3	6/28/16 18:30	7/14/16 9:56	606300946	Copper	0.8	1.3	ppm
036-46A Outside Water Spigot 3	6/28/16 18:30	7/14/16 9:56	606300946	Lead	93	15	ppb
036-47A Outside Water Spigot 4	6/28/16 18:26	7/14/16 9:56	606300947	Copper	0.3	1.3	ppm
036-47A Outside Water Spigot 4	6/28/16 18:26	7/14/16 9:56	606300947	Lead	6	15	ppb
036-48A Outside Water Spigot 5	6/28/16 18:22	7/14/16 10:42	606300948	Copper	1.9	1.3	ppm
036-48A Outside Water Spigot 5	6/28/16 18:22	7/14/16 9:56	606300948	Lead	285	15	ppb
036-49A Outside Water Spigot 6	6/28/16 18:37	7/14/16 9:56	606300949	Copper	0.4	1.3	ppm
036-49A Outside Water Spigot 6	6/28/16 18:37	7/14/16 9:56	606300949	Lead	12	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.