

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
George Middle School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
038-134-001A	Girls Locker Room Shower 1	6/15/2016 8:12:00 PM	6/21/2016 9:54:00 AM	BB65343	Copper	0.3	1.3	ppm
038-134-001A	Girls Locker Room Shower 1	6/15/2016 8:12:00 PM	6/21/2016 9:54:00 AM	BB65343	Lead	27	15	ppb
038-134-02A	Girls Locker Room Shower 2	6/15/2016 8:15:00 PM	6/21/2016 9:57:00 AM	BB65344	Copper	0.2	1.3	ppm
038-134-02A	Girls Locker Room Shower 2	6/15/2016 8:15:00 PM	6/21/2016 9:57:00 AM	BB65344	Lead	30	15	ppb
038-134-03A	Girls Locker Room Shower 3	6/15/2016 8:17:00 PM	7/3/2016 11:36:00 AM	BB65345	Copper	0.2	1.3	ppm
038-134-03A	Girls Locker Room Shower 3	6/15/2016 8:17:00 PM	7/3/2016 11:36:00 AM	BB65345	Lead	80	15	ppb
038-134-04A	Girls Locker Room Shower 4	6/15/2016 8:19:00 PM	6/21/2016 10:00:00 AM	BB65346	Copper	0.1	1.3	ppm
038-134-04A	Girls Locker Room Shower 4	6/15/2016 8:19:00 PM	6/21/2016 10:00:00 AM	BB65346	Lead	16	15	ppb
038-134-05A	Girls Locker Room Shower 4	6/15/2016 8:21:00 PM	6/21/2016 10:03:00 AM	BB65347	Copper	0.1	1.3	ppm
038-134-05A	Girls Locker Room Shower 4	6/15/2016 8:21:00 PM	6/21/2016 10:03:00 AM	BB65347	Lead	29	15	ppb
038-04B-06A	Girls Locker Room Sink Faucet	6/15/2016 8:25:00 PM	6/21/2016 10:06:00 AM	BB65348	Copper	0.2	1.3	ppm
038-04B-06A	Girls Locker Room Sink Faucet	6/15/2016 8:25:00 PM	6/21/2016 10:06:00 AM	BB65348	Lead	8	15	ppb
038-129-07A	Gymnasium Drinking Fountain	6/15/2016 8:32:00 PM	6/21/2016 10:09:00 AM	BB65349	Copper	0.2	1.3	ppm
038-129-07A	Gymnasium Drinking Fountain	6/15/2016 8:32:00 PM	6/21/2016 10:09:00 AM	BB65349	Lead	5	15	ppb
038-133-08A	Boys Locker Room Shower 1	6/15/2016 8:36:00 PM	6/21/2016 10:12:00 AM	BB65350	Copper	0.3	1.3	ppm
038-133-08A	Boys Locker Room Shower 1	6/15/2016 8:36:00 PM	6/21/2016 10:12:00 AM	BB65350	Lead	18	15	ppb
038-133-09A	Boys Locker Room Shower 2	6/15/2016 8:40:00 PM	7/3/2016 11:43:00 AM	BB65351	Copper	0.9	1.3	ppm
038-133-09A	Boys Locker Room Shower 2	6/15/2016 8:40:00 PM	7/3/2016 11:43:00 AM	BB65351	Lead	84	15	ppb
038-133-10A	Boys Locker Room Shower 3	6/15/2016 8:44:00 PM	6/21/2016 10:15:00 AM	BB65352	Copper	0.3	1.3	ppm
038-133-10A	Boys Locker Room Shower 3	6/15/2016 8:44:00 PM	6/21/2016 10:15:00 AM	BB65352	Lead	61	15	ppb
038-133-11A	Boys Locker Room Shower 4	6/15/2016 8:46:00 PM	6/21/2016 10:18:00 AM	BB65353	Copper	0.0	1.3	ppm
038-133-11A	Boys Locker Room Shower 4	6/15/2016 8:46:00 PM	6/21/2016 10:18:00 AM	BB65353	Lead	16	15	ppb
038-133-12A	Boys Locker Room Shower 5	6/15/2016 8:49:00 PM	6/21/2016 10:21:00 AM	BB65354	Copper	0.3	1.3	ppm
038-133-12A	Boys Locker Room Shower 5	6/15/2016 8:49:00 PM	6/21/2016 10:21:00 AM	BB65354	Lead	86	15	ppb
038-133-13A	Boys Locker Room Shower 6	6/15/2016 8:53:00 PM	6/21/2016 10:42:00 AM	BB65355	Copper	0.1	1.3	ppm
038-133-13A	Boys Locker Room Shower 6	6/15/2016 8:53:00 PM	6/21/2016 10:42:00 AM	BB65355	Lead	16	15	ppb
038-133-14A	Boys Locker Room Sink Faucet	6/15/2016 8:54:00 PM	6/21/2016 10:45:00 AM	BB65356	Copper	0.2	1.3	ppm
038-133-14A	Boys Locker Room Sink Faucet	6/15/2016 8:54:00 PM	6/21/2016 10:45:00 AM	BB65356	Lead	5	15	ppb
038-132-15A	Gymnasium Office Shower	6/15/2016 9:00:00 PM	6/21/2016 10:48:00 AM	BB65357	Copper	0.3	1.3	ppm
038-132-15A	Gymnasium Office Shower	6/15/2016 9:00:00 PM	6/21/2016 10:48:00 AM	BB65357	Lead	10	15	ppb
038-132-16A	Gymnasium Office Sink Faucet	6/15/2016 9:03:00 PM	7/3/2016 6:52:00 PM	BB65358	Copper	4.3	1.3	ppm
038-132-16A	Gymnasium Office Sink Faucet	6/15/2016 9:03:00 PM	7/3/2016 6:52:00 PM	BB65358	Lead	1950	15	ppb
038-27-17A	Boiler Room Shower	6/15/2016 9:11:00 PM	7/3/2016 11:49:00 AM	BB65359	Copper	0.2	1.3	ppm
038-27-17A	Boiler Room Shower	6/15/2016 9:11:00 PM	7/3/2016 11:49:00 AM	BB65359	Lead	144	15	ppb
038-127-18A	Boiler Room Sink Faucet	6/15/2016 9:14:00 PM	6/21/2016 10:52:00 AM	BB65360	Copper	0.3	1.3	ppm
038-127-18A	Boiler Room Sink Faucet	6/15/2016 9:14:00 PM	6/21/2016 10:52:00 AM	BB65360	Lead	4	15	ppb
038-127-19A	Boiler Room Lavatory B Sink Faucet	6/15/2016 9:16:00 PM	6/21/2016 10:54:00 AM	BB65361	Copper	0.1	1.3	ppm
038-127-19A	Boiler Room Lavatory B Sink Faucet	6/15/2016 9:16:00 PM	6/21/2016 10:54:00 AM	BB65361	Lead	6	15	ppb
038-DF1-20A	Drinking Fountain #1 (Hall G outside Gym)	6/15/2016 9:19:00 PM	6/21/2016 5:38:00 PM	BB65362	Copper	1.34	1.3	ppm
038-DF1-20A	Drinking Fountain #1 (Hall G outside Gym)	6/15/2016 9:19:00 PM	6/21/2016 10:58:00 AM	BB65362	Lead	1	15	ppb
038-125-21A	Industrial Arts Sink Faucet	6/15/2016 9:27:00 PM	6/21/2016 11:01:00 AM	BB65363	Copper	0.3	1.3	ppm
038-125-21A	Industrial Arts Sink Faucet	6/15/2016 9:27:00 PM	6/21/2016 11:01:00 AM	BB65363	Lead	8	15	ppb
038-126-22A	Staff Unisex Bathroom Sink Faucet	6/15/2016 9:32:00 PM	6/21/2016 11:04:00 AM	BB65364	Copper	0.4	1.3	ppm
038-126-22A	Staff Unisex Bathroom Sink Faucet	6/15/2016 9:32:00 PM	6/21/2016 11:04:00 AM	BB65364	Lead	1	15	ppb
038-124-23A	Staff Lunch Room Sink Faucet	6/15/2016 9:37:00 PM	6/21/2016 11:07:00 AM	BB65365	Copper	0.3	1.3	ppm
038-124-23A	Staff Lunch Room Sink Faucet	6/15/2016 9:37:00 PM	6/21/2016 11:07:00 AM	BB65365	Lead	5	15	ppb
038-122-24A	Kitchen Food Prep Sink	6/15/2016 9:49:00 PM	6/21/2016 11:10:00 AM	BB65366	Copper	0.3	1.3	ppm
038-122-24A	Kitchen Food Prep Sink	6/15/2016 9:49:00 PM	6/21/2016 11:10:00 AM	BB65366	Lead	3	15	ppb
038-122A-25A	Kitchen Dishwashing Sink	6/15/2016 9:55:00 PM	7/3/2016 11:53:00 AM	BB65367	Copper	0.3	1.3	ppm
038-122A-25A	Kitchen Dishwashing Sink	6/15/2016 9:55:00 PM	7/3/2016 11:53:00 AM	BB65367	Lead	5	15	ppb
038-122A-26A	Kitchen Sink Faucet (Dishwash Room)	6/15/2016 10:00:00 PM	7/3/2016 11:56:00 AM	BB65368	Copper	0.1	1.3	ppm
038-122A-26A	Kitchen Sink Faucet (Dishwash Room)	6/15/2016 10:00:00 PM	7/3/2016 11:56:00 AM	BB65368	Lead	2	15	ppb
038-122B-27A	Kitchen Sink Faucet (Custodian Office)	6/15/2016 10:08:00 PM	7/3/2016 11:59:00 AM	BB65369	Copper	0.2	1.3	ppm
038-122B-27A	Kitchen Sink Faucet (Custodian Office)	6/15/2016 10:08:00 PM	7/3/2016 11:59:00 AM	BB65369	Lead	8	15	ppb
038-122C-28A	Kitchen Restroom 149C Sink Faucet	6/15/2016 10:16:00 PM	7/3/2016 12:03:00 PM	BB65370	Copper	0.2	1.3	ppm
038-122C-28A	Kitchen Restroom 149C Sink Faucet	6/15/2016 10:16:00 PM	7/3/2016 12:03:00 PM	BB65370	Lead	4	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
George Middle School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
038-DF2-29A	Drinking Fountain #2 (Btwn Rms 201 & 203)	6/15/2016 10:21:00 PM	6/21/2016 11:25:00 AM	BB65371	Copper	0.8	1.3	ppm
038-DF2-29A	Drinking Fountain #2 (Btwn Rms 201 & 203)	6/15/2016 10:21:00 PM	6/21/2016 11:25:00 AM	BB65371	Lead	1	15	ppb
038-BB1-30A	Boys Restroom Sink Faucet 1 (Btwn Rms 203 & 206)	6/15/2016 10:27:00 PM	6/21/2016 11:28:00 AM	BB65372	Copper	0.4	1.3	ppm
038-BB1-30A	Boys Restroom Sink Faucet 1 (Btwn Rms 203 & 206)	6/15/2016 10:27:00 PM	6/21/2016 11:28:00 AM	BB65372	Lead	14.9	15	ppb
038-BB1-31A	Boys Restroom Sink Faucet 2 (Btwn Rms 203 & 206)	6/15/2016 10:29:00 PM	6/21/2016 11:31:00 AM	BB65373	Copper	0.2	1.3	ppm
038-BB1-31A	Boys Restroom Sink Faucet 2 (Btwn Rms 203 & 206)	6/15/2016 10:29:00 PM	6/21/2016 11:31:00 AM	BB65373	Lead	10	15	ppb
038-BB1-32A	Boys Restroom Water Spigot	6/15/2016 10:32:00 PM	7/3/2016 12:06:00 PM	BB65374	Copper	0.7	1.3	ppm
038-BB1-32A	Boys Restroom Water Spigot	6/15/2016 10:32:00 PM	7/3/2016 12:06:00 PM	BB65374	Lead	72	15	ppb
038-GB1-33A	Girls Restroom GB1 Sink Faucet 1	6/15/2016 10:36:00 PM	6/21/2016 11:34:00 AM	BB65375	Copper	0.2	1.3	ppm
038-GB1-33A	Girls Restroom GB1 Sink Faucet 1	6/15/2016 10:36:00 PM	6/21/2016 11:34:00 AM	BB65375	Lead	6	15	ppb
038-GB1-34A	Girls Restroom GB1 Sink Faucet 2	6/15/2016 10:38:00 PM	6/21/2016 11:37:00 AM	BB65376	Copper	0.2	1.3	ppm
038-GB1-34A	Girls Restroom GB1 Sink Faucet 2	6/15/2016 10:38:00 PM	6/21/2016 11:37:00 AM	BB65376	Lead	9	15	ppb
038-GB1-35A	Girls Restroom Water Spigot	6/15/2016 10:40:00 PM	7/3/2016 12:41:00 PM	BB65377	Copper	0.8	1.3	ppm
038-GB1-35A	Girls Restroom Water Spigot	6/15/2016 10:40:00 PM	7/3/2016 12:41:00 PM	BB65377	Lead	60	15	ppb
038-205-36A	Spanish Classroom 205 Sink	6/15/2016 11:00:00 PM	6/21/2016 11:40:00 AM	BB65378	Copper	0.1	1.3	ppm
038-205-36A	Spanish Classroom 205 Sink	6/15/2016 11:00:00 PM	6/21/2016 11:40:00 AM	BB65378	Lead	12	15	ppb
038-205-37A	Spanish Classroom 205 Drinking Fountain	6/15/2016 11:02:00 PM	6/21/2016 11:43:00 AM	BB65379	Copper	0.1	1.3	ppm
038-205-37A	Spanish Classroom 205 Drinking Fountain	6/15/2016 11:02:00 PM	6/21/2016 11:43:00 AM	BB65379	Lead	0	15	ppb
038-207-38A	Classroom 207 Sink Faucet	6/15/2016 11:04:00 PM	6/21/2016 11:46:00 AM	BB65380	Copper	0.2	1.3	ppm
038-207-38A	Classroom 207 Sink Facuet	6/15/2016 11:04:00 PM	6/21/2016 11:46:00 AM	BB65380	Lead	11	15	ppb
038-207-39A	Classroom 207 Drinking Fountain	6/15/2016 11:06:00 PM	6/21/2016 11:49:00 AM	BB65381	Copper	0.1	1.3	ppm
038-207-39A	Classroom 207 Drinking Fountain	6/15/2016 11:06:00 PM	6/21/2016 11:49:00 AM	BB65381	Lead	2	15	ppb
038-208-40A	Home Economics 208 Sink Faucet #1	6/15/2016 11:10:00 PM	6/21/2016 11:52:00 AM	BB65382	Copper	0.4	1.3	ppm
038-208-40A	Home Economics 208 Sink Faucet #1	6/15/2016 11:10:00 PM	6/21/2016 11:52:00 AM	BB65382	Lead	3	15	ppb
038-208-41A	Home Economics 208 Sink Faucet #2	6/15/2016 11:12:00 PM	6/21/2016 12:13:00 PM	BB65383	Copper	0.4	1.3	ppm
038-208-41A	Home Economics 208 Sink Faucet #2	6/15/2016 11:12:00 PM	6/21/2016 12:13:00 PM	BB65383	Lead	3	15	ppb
038-208-42A	Home Economics 208 Drinking Fountain	6/15/2016 11:15:00 PM	6/21/2016 12:16:00 PM	BB65384	Copper	0.5	1.3	ppm
038-208-42A	Home Economics 208 Drinking Fountain	6/15/2016 11:15:00 PM	6/21/2016 12:16:00 PM	BB65384	Lead	5	15	ppb
038-209-43A	Classroom 209 Sink Faucet	6/15/2016 11:19:00 PM	6/21/2016 12:19:00 PM	BB65385	Copper	0.2	1.3	ppm
038-209-43A	Classroom 209 Sink Faucet	6/15/2016 11:19:00 PM	6/21/2016 12:19:00 PM	BB65385	Lead	19	15	ppb
038-209-44A	Classroom 209 Drinking Fountain	6/15/2016 11:20:00 PM	6/21/2016 12:23:00 PM	BB65386	Copper	0.2	1.3	ppm
038-209-44A	Classroom 209 Drinking Fountain	6/15/2016 11:20:00 PM	6/21/2016 12:23:00 PM	BB65386	Lead	3	15	ppb
038-210-45A	Classroom 210 Sink Faucet	6/15/2016 11:24:00 PM	6/21/2016 12:25:00 PM	BB65387	Copper	0.5	1.3	ppm
038-210-45A	Classroom 210 Sink Faucet	6/15/2016 11:24:00 PM	6/21/2016 12:25:00 PM	BB65387	Lead	11	15	ppb
038-210-46A	Classroom 210 Drinking Fountain	6/15/2016 11:28:00 PM	6/21/2016 12:29:00 PM	BB65388	Copper	0.5	1.3	ppm
038-210-46A	Classroom 210 Drinking Fountain	6/15/2016 11:28:00 PM	6/21/2016 12:29:00 PM	BB65388	Lead	4	15	ppb
038-211-47A	Classroom 211 Sink Faucet	6/15/2016 11:31:00 PM	7/3/2016 12:44:00 PM	BB65389	Copper	0.3	1.3	ppm
038-211-47A	Classroom 211 Sink Faucet	6/15/2016 11:31:00 PM	7/3/2016 12:44:00 PM	BB65389	Lead	30	15	ppb
038-211-48A	Classroom 211 Drinking Fountain	6/15/2016 11:35:00 PM	6/21/2016 12:32:00 PM	BB65390	Copper	0.2	1.3	ppm
038-211-48A	Classroom 211 Drinking Fountain	6/15/2016 11:35:00 PM	6/21/2016 12:32:00 PM	BB65390	Lead	26	15	ppb
038-212-49A	Classroom 212 Sink Faucet	6/15/2016 11:43:00 PM	6/21/2016 12:35:00 PM	BB65391	Copper	0.5	1.3	ppm
038-212-49A	Classroom 212 Sink Faucet	6/15/2016 11:43:00 PM	6/21/2016 12:35:00 PM	BB65391	Lead	8	15	ppb
038-212-50A	Classroom 212 Drinking Fountain	6/15/2016 11:44:00 PM	6/21/2016 12:38:00 PM	BB65392	Copper	0.3	1.3	ppm
038-212-50A	Classroom 212 Drinking Fountain	6/15/2016 11:44:00 PM	6/21/2016 12:38:00 PM	BB65392	Lead	2	15	ppb
038-509-51A	Classroom 509 Sink Faucet 1	6/15/2016 11:50:00 PM	6/21/2016 12:41:00 PM	BB65393	Copper	0.5	1.3	ppm
038-509-51A	Classroom 509 Sink Faucet 1	6/15/2016 11:50:00 PM	6/21/2016 12:41:00 PM	BB65393	Lead	1	15	ppb
038-509-52A	Classroom 509 Sink Faucet 2	6/15/2016 11:51:00 PM	6/21/2016 12:56:00 PM	BB65394	Copper	0.5	1.3	ppm
038-509-52A	Classroom 509 Sink Faucet 2	6/15/2016 11:51:00 PM	6/21/2016 12:56:00 PM	BB65394	Lead	2	15	ppb
038-509-53A	Classroom 509 Sink Faucet 3	6/15/2016 11:54:00 PM	6/21/2016 12:59:00 PM	BB65395	Copper	0.3	1.3	ppm
038-509-53A	Classroom 509 Sink Faucet 3	6/15/2016 11:54:00 PM	6/21/2016 12:59:00 PM	BB65395	Lead	2	15	ppb
038-509-54A	Classroom 509 Sink Faucet 4	6/15/2016 11:55:00 PM	6/21/2016 1:02:00 PM	BB65396	Copper	0.4	1.3	ppm
038-509-54A	Classroom 509 Sink Faucet 4	6/15/2016 11:55:00 PM	6/21/2016 1:02:00 PM	BB65396	Lead	1	15	ppb
038-509A-55A	Classroom 509A Connector Sink Faucet 1	6/15/2016 11:57:00 PM	6/21/2016 1:05:00 PM	BB65397	Copper	0.7	1.3	ppm
038-509A-55A	Classroom 509A Connector Sink Faucet 1	6/15/2016 11:57:00 PM	6/21/2016 1:05:00 PM	BB65397	Lead	8	15	ppb
038-509A-56A	Classroom 509A Connector Sink Faucet 2	6/16/2016 12:01:00 AM	6/21/2016 1:08:00 PM	BB65398	Copper	0.6	1.3	ppm
038-509A-56A	Classroom 509A Connector Sink Faucet 2	6/16/2016 12:01:00 AM	6/21/2016 1:08:00 PM	BB65398	Lead	65	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
George Middle School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action	Units
							Level	
038-507-57A	Classroom 507 Sink Faucet 1	6/16/2016 12:03:00 AM	6/21/2016 1:11:00 PM	BB65399	Copper	0.3	1.3	ppm
038-507-57A	Classroom 507 Sink Faucet 1	6/16/2016 12:03:00 AM	6/21/2016 1:11:00 PM	BB65399	Lead	1	15	ppb
038-507-58A	Classroom 507 Sink Faucet 2	6/16/2016 12:05:00 AM	6/21/2016 1:14:00 PM	BB65400	Copper	0.3	1.3	ppm
038-507-58A	Classroom 507 Sink Faucet 2	6/16/2016 12:05:00 AM	6/21/2016 1:14:00 PM	BB65400	Lead	0	15	ppb
038-507-59A	Classroom 507 Drinking Fountain	6/16/2016 12:07:00 AM	6/21/2016 1:17:00 PM	BB65401	Copper	0.0	1.3	ppm
038-507-59A	Classroom 507 Drinking Fountain	6/16/2016 12:07:00 AM	6/21/2016 1:17:00 PM	BB65401	Lead	4	15	ppb
038-507-60A	Classroom 507 Sink Faucet 3	6/16/2016 12:08:00 AM	6/21/2016 1:20:00 PM	BB65402	Copper	0.3	1.3	ppm
038-507-60A	Classroom 507 Sink Faucet 3	6/16/2016 12:08:00 AM	6/21/2016 1:20:00 PM	BB65402	Lead	3	15	ppb
038-507-61A	Classroom 507 Sink Faucet 4	6/16/2016 12:09:00 AM	6/21/2016 1:23:00 PM	BB65403	Copper	0.3	1.3	ppm
038-507-61A	Classroom 507 Sink Faucet 4	6/16/2016 12:09:00 AM	6/21/2016 1:23:00 PM	BB65403	Lead	1	15	ppb
038-508-62A	Classroom 508 Sink Faucet	6/16/2016 12:13:00 AM	6/21/2016 1:44:00 PM	BB65404	Copper	0.7	1.3	ppm
038-508-62A	Classroom 508 Sink Faucet	6/16/2016 12:13:00 AM	6/21/2016 1:44:00 PM	BB65404	Lead	12	15	ppb
038-508-63A	Classroom 508 Drinking Fountain	6/16/2016 12:14:00 AM	6/21/2016 1:47:00 PM	BB65405	Copper	0.7	1.3	ppm
038-508-63A	Classroom 508 Drinking Fountain	6/16/2016 12:14:00 AM	6/21/2016 1:47:00 PM	BB65405	Lead	2	15	ppb
038-505-64A	Classroom 505 Sink Faucet	6/16/2016 12:18:00 AM	6/21/2016 1:50:00 PM	BB65406	Copper	0.7	1.3	ppm
038-505-64A	Classroom 505 Sink Faucet	6/16/2016 12:18:00 AM	6/21/2016 1:50:00 PM	BB65406	Lead	10	15	ppb
038-505-65A	Classroom 505 Drinking Fountain	6/16/2016 12:21:00 AM	6/21/2016 1:53:00 PM	BB65407	Copper	0.8	1.3	ppm
038-505-65A	Classroom 505 Drinking Fountain	6/16/2016 12:21:00 AM	6/21/2016 1:53:00 PM	BB65407	Lead	2	15	ppb
038-503-66A	Classroom 503 Sink Faucet	6/16/2016 12:23:00 AM	6/21/2016 1:56:00 PM	BB65408	Copper	0.5	1.3	ppm
038-503-66A	Classroom 503 Sink Faucet	6/16/2016 12:23:00 AM	6/21/2016 1:56:00 PM	BB65408	Lead	8	15	ppb
038-503-67A	Classroom 503 Drinking Fountain	6/16/2016 12:26:00 AM	6/21/2016 1:59:00 PM	BB65409	Copper	0.9	1.3	ppm
038-503-67A	Classroom 503 Drinking Fountain	6/16/2016 12:26:00 AM	6/21/2016 1:59:00 PM	BB65409	Lead	2	15	ppb
038-506-68A	Janitors Closet Sink Faucet	6/16/2016 12:30:00 AM	6/21/2016 2:02:00 PM	BB65410	Copper	0.3	1.3	ppm
038-506-68A	Janitors Closet Sink Faucet	6/16/2016 12:30:00 AM	6/21/2016 2:02:00 PM	BB65410	Lead	2	15	ppb
038-504-69A	Classroom 504 Sink Faucet	6/16/2016 12:32:00 AM	6/21/2016 2:06:00 PM	BB65411	Copper	0.5	1.3	ppm
038-504-69A	Classroom 504 Sink Faucet	6/16/2016 12:32:00 AM	6/21/2016 2:06:00 PM	BB65411	Lead	13	15	ppb
038-504-70A	Classroom 504 Drinking Fountain	6/16/2016 12:34:00 AM	6/21/2016 2:08:00 PM	BB65412	Copper	0.7	1.3	ppm
038-504-70A	Classroom 504 Drinking Fountain	6/16/2016 12:34:00 AM	6/21/2016 2:08:00 PM	BB65412	Lead	3	15	ppb
038-502-71A	Classroom 502 Sink Faucet	6/16/2016 12:36:00 AM	6/21/2016 2:12:00 PM	BB65413	Copper	0.7	1.3	ppm
038-502-71A	Classroom 502 Sink Faucet	6/16/2016 12:36:00 AM	6/21/2016 2:12:00 PM	BB65413	Lead	6	15	ppb
038-502-72A	Classroom 502 Drinking Fountain	6/16/2016 12:38:00 AM	6/21/2016 2:27:00 PM	BB65414	Copper	0.8	1.3	ppm
038-502-72A	Classroom 502 Drinking Fountain	6/16/2016 12:38:00 AM	6/21/2016 2:27:00 PM	BB65414	Lead	2	15	ppb
038-501-73A	Classroom 501 Sink Faucet	6/16/2016 12:48:00 AM	6/21/2016 2:30:00 PM	BB65415	Copper	0.6	1.3	ppm
038-501-73A	Classroom 501 Sink Faucet	6/16/2016 12:48:00 AM	6/21/2016 2:30:00 PM	BB65415	Lead	6	15	ppb
038-501-74A	Classroom 501 Drinking Fountain	6/16/2016 12:50:00 AM	6/21/2016 2:33:00 PM	BB65416	Copper	0.9	1.3	ppm
038-501-74A	Classroom 501 Drinking Fountain	6/16/2016 12:50:00 AM	6/21/2016 2:33:00 PM	BB65416	Lead	2	15	ppb
038-417-75A	Classroom 417 Sink Faucet	6/16/2016 12:51:00 AM	6/21/2016 2:36:00 PM	BB65417	Copper	0.3	1.3	ppm
038-417-75A	Classroom 417 Sink Faucet	6/16/2016 12:51:00 AM	6/21/2016 2:36:00 PM	BB65417	Lead	6	15	ppb
038-417-76A	Classroom 417 Drinking Fountain	6/16/2016 12:53:00 AM	6/21/2016 2:39:00 PM	BB65418	Copper	0.2	1.3	ppm
038-417-76A	Classroom 417 Drinking Fountain	6/16/2016 12:53:00 AM	6/21/2016 2:39:00 PM	BB65418	Lead	2	15	ppb
038-415-77A	Classroom 415 Sink Faucet	6/16/2016 1:06:00 AM	6/21/2016 2:42:00 PM	BB65419	Copper	0.5	1.3	ppm
038-415-77A	Classroom 415 Sink Faucet	6/16/2016 1:06:00 AM	6/21/2016 2:42:00 PM	BB65419	Lead	14	15	ppb
038-415-78A	Classroom 415 Drinking Fountain	6/16/2016 1:08:00 AM	6/21/2016 2:45:00 PM	BB65420	Copper	0.1	1.3	ppm
038-415-78A	Classroom 415 Drinking Fountain	6/16/2016 1:08:00 AM	6/21/2016 2:45:00 PM	BB65420	Lead	2	15	ppb
038-413-79A	Classroom 413 Sink Faucet 1	6/16/2016 1:10:00 AM	6/21/2016 2:48:00 PM	BB65421	Copper	0.3	1.3	ppm
038-413-79A	Classroom 413 Sink Faucet 1	6/16/2016 1:10:00 AM	6/21/2016 2:48:00 PM	BB65421	Lead	51	15	ppb
038-413-80A	Classroom 413 Sink Faucet 2	6/16/2016 1:12:00 AM	6/21/2016 2:51:00 PM	BB65422	Copper	0.4	1.3	ppm
038-413-80A	Classroom 413 Sink Faucet 2	6/16/2016 1:12:00 AM	6/21/2016 2:51:00 PM	BB65422	Lead	1	15	ppb
038-413-81A	Classroom 413 Drinking Fountain	6/16/2016 1:13:00 AM	6/21/2016 2:54:00 PM	BB65423	Copper	0.2	1.3	ppm
038-413-81A	Classroom 413 Drinking Fountain	6/16/2016 1:13:00 AM	6/21/2016 2:54:00 PM	BB65423	Lead	4	15	ppb
038-407-82A	Boys Bathroom Sink Faucet 1	6/16/2016 1:15:00 AM	6/21/2016 3:15:00 PM	BB65424	Copper	0.4	1.3	ppm
038-407-82A	Boys Bathroom Sink Faucet 1	6/16/2016 1:15:00 AM	6/21/2016 3:15:00 PM	BB65424	Lead	6	15	ppb
038-407-83A	Boys Bathroom Sink Faucet 2	6/16/2016 1:17:00 AM	6/21/2016 3:18:00 PM	BB65425	Copper	0.4	1.3	ppm
038-407-83A	Boys Bathroom Sink Faucet 2	6/16/2016 1:17:00 AM	6/21/2016 3:18:00 PM	BB65425	Lead	4	15	ppb
038-407-84A	Boys Bathroom Water Spigot	6/16/2016 1:21:00 AM	6/21/2016 3:21:00 PM	BB65426	Copper	0.3	1.3	ppm
038-407-84A	Boys Bathroom Water Spigot	6/16/2016 1:21:00 AM	6/21/2016 3:21:00 PM	BB65426	Lead	38	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
George Middle School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
038-409-85A	Custodian Sink Faucet	6/16/2016 1:23:00 AM	6/21/2016 3:24:00 PM	BB65427	Copper	0.2	1.3	ppm
038-409-85A	Custodian Sink Faucet	6/16/2016 1:23:00 AM	6/21/2016 3:24:00 PM	BB65427	Lead	4	15	ppb
038-411-86A	Girls Bathroom Sink Faucet 1	6/16/2016 1:25:00 AM	6/21/2016 3:27:00 PM	BB65428	Copper	0.2	1.3	ppm
038-411-86A	Girls Bathroom Sink Faucet 1	6/16/2016 1:25:00 AM	6/21/2016 3:27:00 PM	BB65428	Lead	2	15	ppb
038-411-87A	Girls Bathroom Sink Faucet 2	6/16/2016 1:27:00 AM	6/21/2016 3:30:00 PM	BB65429	Copper	0.2	1.3	ppm
038-411-87A	Girls Bathroom Sink Faucet 2	6/16/2016 1:27:00 AM	6/21/2016 3:30:00 PM	BB65429	Lead	3	15	ppb
038-411-88A	Girls Bathroom Water Spigot	6/16/2016 1:29:00 AM	6/21/2016 8:11:00 PM	BB65430	Copper	1.1	1.3	ppm
038-411-88A	Girls Bathroom Water Spigot	6/16/2016 1:29:00 AM	6/21/2016 3:33:00 PM	BB65430	Lead	30	15	ppb
038-405-89A	Classroom 405 Sink Faucet	6/16/2016 1:31:00 AM	6/21/2016 3:36:00 PM	BB65431	Copper	0.3	1.3	ppm
038-405-89A	Classroom 405 Sink Faucet	6/16/2016 1:31:00 AM	6/21/2016 3:36:00 PM	BB65431	Lead	24	15	ppb
038-405-90A	Classroom 405 Drinking Fountain	6/16/2016 1:33:00 AM	6/21/2016 3:39:00 PM	BB65432	Copper	0.2	1.3	ppm
038-405-90A	Classroom 405 Drinking Fountain	6/16/2016 1:33:00 AM	6/21/2016 3:39:00 PM	BB65432	Lead	5	15	ppb
038-403-91A	Classroom 403 Sink Faucet	6/16/2016 1:35:00 AM	6/21/2016 3:42:00 PM	BB65433	Copper	0.2	1.3	ppm
038-403-91A	Classroom 403 Sink Faucet	6/16/2016 1:35:00 AM	6/21/2016 3:42:00 PM	BB65433	Lead	17	15	ppb
038-403-92A	Classroom 403 Drinking Fountain	6/16/2016 1:37:00 AM	6/21/2016 3:58:00 PM	BB65434	Copper	0.0	1.3	ppm
038-403-92A	Classroom 403 Drinking Fountain	6/16/2016 1:37:00 AM	6/21/2016 3:58:00 PM	BB65434	Lead	2	15	ppb
038-404-93A	Office 404 Sink Faucet	6/16/2016 1:39:00 AM	6/21/2016 4:01:00 PM	BB65435	Copper	0.9	1.3	ppm
038-404-93A	Office 404 Sink Faucet	6/16/2016 1:39:00 AM	6/21/2016 4:01:00 PM	BB65435	Lead	8	15	ppb
038-404-94A	Office 404 Drinking Fountain	6/16/2016 1:41:00 AM	6/21/2016 4:04:00 PM	BB65436	Copper	0.0	1.3	ppm
038-404-94A	Office 404 Drinking Fountain	6/16/2016 1:41:00 AM	6/21/2016 4:04:00 PM	BB65436	Lead	5	15	ppb
038-105F-95A	Office Bathroom (404/105F) Sink Faucet	6/16/2016 1:43:00 AM	6/21/2016 4:07:00 PM	BB65437	Copper	0.8	1.3	ppm
038-105F-95A	Office Bathroom (404/105F) Sink Faucet	6/16/2016 1:43:00 AM	6/21/2016 4:07:00 PM	BB65437	Lead	2	15	ppb
038-401-96A	Special Education Room 401 Sink Faucet	6/16/2016 1:45:00 AM	6/21/2016 4:10:00 PM	BB65438	Copper	0.8	1.3	ppm
038-401-96A	Special Education Room 401 Sink Faucet	6/16/2016 1:45:00 AM	6/21/2016 4:10:00 PM	BB65438	Lead	10	15	ppb
038-100-97A	Art Room 100 Sink Faucet 1	6/16/2016 2:05:00 AM	6/21/2016 4:13:00 PM	BB65439	Copper	0.4	1.3	ppm
038-100-97A	Art Room 100 Sink Faucet 1	6/16/2016 2:05:00 AM	6/21/2016 4:13:00 PM	BB65439	Lead	7	15	ppb
038-100-98A	Art Room 100 Sink Faucet 2	6/16/2016 2:07:00 AM	6/21/2016 4:16:00 PM	BB65440	Copper	0.5	1.3	ppm
038-100-98A	Art Room 100 Sink Faucet 2	6/16/2016 2:07:00 AM	6/21/2016 4:16:00 PM	BB65440	Lead	9	15	ppb
038-100-99A	Art Room 100 Sink Faucet 3	6/16/2016 2:09:00 AM	6/21/2016 4:19:00 PM	BB65441	Copper	0.3	1.3	ppm
038-100-99A	Art Room 100 Sink Faucet 3	6/16/2016 2:09:00 AM	6/21/2016 4:19:00 PM	BB65441	Lead	4	15	ppb
038-102-100A	Classroom 102 Sink Faucet	6/16/2016 2:10:00 AM	6/21/2016 4:22:00 PM	BB65442	Copper	0.0	1.3	ppm
038-102-100A	Classroom 102 Sink Faucet	6/16/2016 2:10:00 AM	6/21/2016 4:22:00 PM	BB65442	Lead	0	15	ppb
038-102-101A	Classroom 102 Drinking Fountain	6/16/2016 2:11:00 AM	6/21/2016 4:25:00 PM	BB65443	Copper	0.0	1.3	ppm
038-102-101A	Classroom 102 Drinking Fountain	6/16/2016 2:11:00 AM	6/21/2016 4:25:00 PM	BB65443	Lead	10	15	ppb
038-DF3-102A	Hallway Drinking Fountain Bottle Refill	6/16/2016 2:14:00 AM	6/21/2016 4:46:00 PM	BB65444	Copper	0.4	1.3	ppm
038-DF3-102A	Hallway Drinking Fountain Bottle Refill	6/16/2016 2:14:00 AM	6/21/2016 4:46:00 PM	BB65444	Lead	0	15	ppb
038-DF3-103A	Hall Drinking Fountain	6/16/2016 2:16:00 AM	6/21/2016 4:49:00 PM	BB65445	Copper	0.2	1.3	ppm
038-DF3-103A	Hall Drinking Fountain	6/16/2016 2:16:00 AM	6/21/2016 4:49:00 PM	BB65445	Lead	0	15	ppb
038-107-104A	Women's Staff Bathroom Sink Faucet 1	6/16/2016 2:18:00 AM	6/21/2016 4:52:00 PM	BB65446	Copper	0.3	1.3	ppm
038-107-104A	Women's Staff Bathroom Sink Faucet 1	6/16/2016 2:18:00 AM	6/21/2016 4:52:00 PM	BB65446	Lead	2	15	ppb
038-107-105A	Women's Staff Bathroom Sink Faucet 2	6/16/2016 2:20:00 AM	6/21/2016 4:55:00 PM	BB65447	Copper	0.3	1.3	ppm
038-107-105A	Women's Staff Bathroom Sink Faucet 2	6/16/2016 2:20:00 AM	6/21/2016 4:55:00 PM	BB65447	Lead	3	15	ppb
038-107-106A	Women's Staff Bathroom Water Spigot	6/16/2016 2:22:00 AM	6/21/2016 4:58:00 PM	BB65448	Copper	0.9	1.3	ppm
038-107-106A	Women's Staff Bathroom Water Spigot	6/16/2016 2:22:00 AM	6/21/2016 4:58:00 PM	BB65448	Lead	30	15	ppb
038-109-107A	Men's Staff Bathroom Sink Faucet 1	6/16/2016 2:26:00 AM	6/21/2016 5:01:00 PM	BB65449	Copper	0.2	1.3	ppm
038-109-107A	Men's Staff Bathroom Sink Faucet 1	6/16/2016 2:26:00 AM	6/21/2016 5:01:00 PM	BB65449	Lead	1	15	ppb
038-109-108A	Men's Staff Bathroom Sink Faucet 2	6/16/2016 2:28:00 AM	6/21/2016 5:04:00 PM	BB65450	Copper	0.3	1.3	ppm
038-109-108A	Men's Staff Bathroom Sink Faucet 2	6/16/2016 2:28:00 AM	6/21/2016 5:04:00 PM	BB65450	Lead	3	15	ppb
038-109-109A	Men's Staff Bathroom Water Spigot	6/16/2016 2:30:00 AM	6/21/2016 5:07:00 PM	BB65451	Copper	0.5	1.3	ppm
038-109-109A	Men's Staff Bathroom Water Spigot	6/16/2016 2:30:00 AM	6/21/2016 5:07:00 PM	BB65451	Lead	19	15	ppb
038-112-110A	Health Exam Room 2	6/16/2016 2:33:00 AM	6/21/2016 5:10:00 PM	BB65452	Copper	0.2	1.3	ppm
038-112-110A	Health Exam Room 2	6/16/2016 2:33:00 AM	6/21/2016 5:10:00 PM	BB65452	Lead	4	15	ppb
038-112-111A	Health Room 112 Sink Faucet 1 (lab)	6/16/2016 2:35:00 AM	6/21/2016 5:13:00 PM	BB65453	Copper	0.5	1.3	ppm
038-112-111A	Health Room 112 Sink Faucet 1 (lab)	6/16/2016 2:35:00 AM	6/21/2016 5:13:00 PM	BB65453	Lead	1	15	ppb
038-112-112A	Health Room 112 Hand Press Sink Faucet	6/16/2016 2:37:00 AM	6/21/2016 5:28:00 PM	BB65454	Copper	0.1	1.3	ppm
038-112-112A	Health Room 112 Hand Press Sink Faucet	6/16/2016 2:37:00 AM	6/21/2016 5:28:00 PM	BB65454	Lead	0	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
George Middle School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
038-112-113A	Health Room 112 Sink Faucet 2 (lab)	6/16/2016 2:29:00 AM	6/21/2016 5:32:00 PM	BB65455	Copper	0.3	1.3	ppm
038-112-113A	Health Room 112 Sink Faucet 2 (lab)	6/16/2016 2:29:00 AM	6/21/2016 5:32:00 PM	BB65455	Lead	11	15	ppb
038-302B-114A	Library Sink Faucet (113 Media Center)	6/16/2016 2:42:00 AM	6/21/2016 5:35:00 PM	BB65456	Copper	0.7	1.3	ppm
038-302B-114A	Library Sink Faucet (113 Media Center)	6/16/2016 2:42:00 AM	6/21/2016 5:35:00 PM	BB65456	Lead	9	15	ppb
038-115-115A	Girls Bathroom 115 Sink Faucet 1	6/16/2016 2:44:00 AM	7/3/2016 12:37:00 PM	BB65457	Copper	0.4	1.3	ppm
038-115-115A	Girls Bathroom 115 Sink Faucet 1	6/16/2016 2:44:00 AM	7/3/2016 12:37:00 PM	BB65457	Lead	2	15	ppb
038-115-116A	Girls Bathroom 115 Sink Faucet 2	6/16/2016 2:46:00 AM	6/21/2016 5:41:00 PM	BB65458	Copper	0.3	1.3	ppm
038-115-116A	Girls Bathroom 115 Sink Faucet 2	6/16/2016 2:46:00 AM	6/21/2016 5:41:00 PM	BB65458	Lead	7	15	ppb
038-115-117A	Girls Bathroom 115 Water Spigot	6/16/2016 2:48:00 AM	7/3/2016 12:48:00 PM	BB65459	Copper	0.8	1.3	ppm
038-115-117A	Girls Bathroom 115 Water Spigot	6/16/2016 2:48:00 AM	7/3/2016 12:48:00 PM	BB65459	Lead	80	15	ppb
038-117-118A	Custodian Closet 117 Sink Faucet	6/16/2016 2:51:00 AM	6/21/2016 5:44:00 PM	BB65460	Copper	0.1	1.3	ppm
038-117-118A	Custodian Closet 117 Sink Faucet	6/16/2016 2:51:00 AM	6/21/2016 5:44:00 PM	BB65460	Lead	1	15	ppb
038-121-119A	Boys Bathroom 121 Sink Faucet 1	6/16/2016 2:53:00 AM	6/21/2016 5:47:00 PM	BB65461	Copper	0.1	1.3	ppm
038-121-119A	Boys Bathroom 121 Sink Faucet 1	6/16/2016 2:53:00 AM	6/21/2016 5:47:00 PM	BB65461	Lead	3	15	ppb
038-121-120A	Boys Bathroom 121 Sink Faucet 2	6/16/2016 2:55:00 AM	6/21/2016 5:50:00 PM	BB65462	Copper	0.2	1.3	ppm
038-121-120A	Boys Bathroom 121 Sink Faucet 2	6/16/2016 2:55:00 AM	6/21/2016 5:50:00 PM	BB65462	Lead	4	15	ppb
038-121-121A	Boys Bathroom 121 Water Spigot	6/16/2016 2:57:00 AM	6/21/2016 5:53:00 PM	BB65463	Copper	0.3	1.3	ppm
038-121-121A	Boys Bathroom 121 Water Spigot	6/16/2016 2:57:00 AM	6/21/2016 5:53:00 PM	BB65463	Lead	4	15	ppb
038-116-122A	Cafeteria 116 Water Spigot	6/16/2016 3:05:00 AM	6/21/2016 5:56:00 PM	BB65464	Copper	0.9	1.3	ppm
038-116-122A	Cafeteria 116 Water Spigot	6/16/2016 3:05:00 AM	6/21/2016 5:56:00 PM	BB65464	Lead	1	15	ppb
038-301-123A	Custodian Closet 301 Sink Faucet	6/16/2016 3:08:00 AM	6/21/2016 6:17:00 PM	BB65465	Copper	0.2	1.3	ppm
038-301-123A	Custodian Closet 301 Sink Faucet	6/16/2016 3:08:00 AM	6/21/2016 6:17:00 PM	BB65465	Lead	2	15	ppb
038-303-124A	Book Storage Room 303 Sink Faucet	6/16/2016 3:10:00 AM	6/21/2016 6:20:00 PM	BB65466	Copper	0.5	1.3	ppm
038-303-124A	Book Storage Room 303 Sink Faucet	6/16/2016 3:10:00 AM	6/21/2016 6:20:00 PM	BB65466	Lead	20	15	ppb
038-303-125A	Storage Room 303 Drinking Fountain	6/16/2016 3:12:00 AM	6/21/2016 6:23:00 PM	BB65467	Copper	0.2	1.3	ppm
038-303-125A	Storage Room 303 Drinking Fountain	6/16/2016 3:12:00 AM	6/21/2016 6:23:00 PM	BB65467	Lead	25	15	ppb
038-305-126A	Classroom 305 Sink Faucet	6/16/2016 3:14:00 AM	6/21/2016 6:26:00 PM	BB65468	Copper	0.7	1.3	ppm
038-305-126A	Classroom 305 Sink Faucet	6/16/2016 3:14:00 AM	6/21/2016 6:26:00 PM	BB65468	Lead	23	15	ppb
038-305-127A	Classroom 305 Drinking Fountain	6/16/2016 3:16:00 AM	6/21/2016 6:29:00 PM	BB65469	Copper	0.7	1.3	ppm
038-305-127A	Classroom 305 Drinking Fountain	6/16/2016 3:16:00 AM	6/21/2016 6:29:00 PM	BB65469	Lead	24	15	ppb
038-307-128A	Classroom 307 Drinking Fountain	6/16/2016 3:19:00 AM	6/21/2016 6:32:00 PM	BB65470	Copper	0.2	1.3	ppm
038-307-128A	Classroom 307 Drinking Fountain	6/16/2016 3:19:00 AM	6/21/2016 6:32:00 PM	BB65470	Lead	59	15	ppb
038-309-129A	Classroom 309 Sink Faucet	6/16/2016 3:20:00 AM	6/21/2016 6:35:00 PM	BB65471	Copper	0.5	1.3	ppm
038-309-129A	Classroom 309 Sink Faucet	6/16/2016 3:20:00 AM	6/21/2016 6:35:00 PM	BB65471	Lead	8	15	ppb
038-309-130A	Classroom 309 Drinking Fountain	6/16/2016 3:22:00 AM	6/21/2016 6:38:00 PM	BB65472	Copper	0.0	1.3	ppm
038-309-130A	Classroom 309 Drinking Fountain	6/16/2016 3:22:00 AM	6/21/2016 6:38:00 PM	BB65472	Lead	3	15	ppb
038-311-131A	Classroom 311 Sink Faucet	6/16/2016 3:24:00 AM	6/21/2016 6:41:00 PM	BB65473	Copper	0.2	1.3	ppm
038-311-131A	Classroom 311 Sink Faucet	6/16/2016 3:24:00 AM	6/21/2016 6:41:00 PM	BB65473	Lead	6	15	ppb
038-DF4-132A	Drinking Fountain 4 (outside Rm 313)	6/16/2016 3:26:00 AM	6/21/2016 6:44:00 PM	BB65474	Copper	1.0	1.3	ppm
038-DF4-132A	Drinking Fountain 4 (outside Rm 313)	6/16/2016 3:26:00 AM	6/21/2016 6:44:00 PM	BB65474	Lead	1	15	ppb
038-313-133A	Classroom 313 Drinking Fountain	6/16/2016 3:27:00 AM	6/21/2016 6:59:00 PM	BB65475	Copper	0.1	1.3	ppm
038-313-133A	Classroom 313 Drinking Fountain	6/16/2016 3:27:00 AM	6/21/2016 6:59:00 PM	BB65475	Lead	6	15	ppb
038-315-134A	Boys Bathroom 315 Sink Faucet 1	6/16/2016 3:29:00 AM	7/3/2016 6:55:00 PM	BB65476	Copper	3.3	1.3	ppm
038-315-134A	Boys Bathroom 315 Sink Faucet 1	6/16/2016 3:29:00 AM	7/3/2016 12:51:00 PM	BB65476	Lead	6	15	ppb
038-315-135A	Boys Bathroom 315 Sink Faucet 2	6/16/2016 3:31:00 AM	6/22/2016 2:35:00 PM	BB65477	Copper	1.2	1.3	ppm
038-315-135A	Boys Bathroom 315 Sink Faucet 2	6/16/2016 3:31:00 AM	6/21/2016 7:02:00 PM	BB65477	Lead	4	15	ppb
038-315-136A	Boys Bathroom 315 Water Spigot	6/16/2016 3:33:00 AM	7/3/2016 6:59:00 PM	BB65478	Copper	24.6	1.3	ppm
038-315-136A	Boys Bathroom 315 Water Spigot	6/16/2016 3:33:00 AM	7/3/2016 12:55:00 PM	BB65478	Lead	62	15	ppb
038-317-137A	Girls Bathroom 317 Sink Faucet 1	6/16/2016 3:35:00 AM	6/21/2016 7:05:00 PM	BB65479	Copper	0.5	1.3	ppm
038-317-137A	Girls Bathroom 317 Sink Faucet 1	6/16/2016 3:35:00 AM	6/21/2016 7:05:00 PM	BB65479	Lead	3	15	ppb
038-317-138A	Girls Bathroom 317 Sink Faucet 2	6/16/2016 3:37:00 AM	6/21/2016 7:09:00 PM	BB65480	Copper	0.4	1.3	ppm
038-317-138A	Girls Bathroom 317 Sink Faucet 2	6/16/2016 3:37:00 AM	6/21/2016 7:09:00 PM	BB65480	Lead	1	15	ppb
038-317-139A	Girls Bathroom 317 Water Spigot zz	6/16/2016 3:39	6/21/2016 19:12	BB65481	Copper	0.8	1.3	ppm
038-317-139A	Girls Bathroom 317 Water Spigot zz	6/16/2016 3:39	6/21/2016 19:12	BB65481	Lead	18	15	ppb
038-WS-140A	Courtyard Water Spigot	6/16/2016 3:44:00 AM	6/21/2016 7:15:00 PM	BB65482	Copper	0.1	1.3	ppm
038-WS-140A	Courtyard Water Spigot	6/16/2016 3:44:00 AM	6/21/2016 7:15:00 PM	BB65482	Lead	8	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
George Middle School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
038-WS-141A	Courtyard Water Spigot z	6/16/2016 3:46:00 AM	6/21/2016 7:18:00 PM	BB65483	Copper	0.3	1.3	ppm
038-WS-141A	Courtyard Water Spigot z	6/16/2016 3:46:00 AM	6/21/2016 7:18:00 PM	BB65483	Lead	57	15	ppb
038-WS-142A	Courtyard Water Spigot w	6/16/2016 3:48:00 AM	6/21/2016 7:21:00 PM	BB65484	Copper	0.4	1.3	ppm
038-WS-142A	Courtyard Water Spigot w	6/16/2016 3:48:00 AM	6/21/2016 7:21:00 PM	BB65484	Lead	10	15	ppb
038-WS-143A	Courtyard Water Spigot x	6/16/2016 3:50:00 AM	6/21/2016 7:24:00 PM	BB65485	Copper	0.1	1.3	ppm
038-WS-143A	Courtyard Water Spigot x	6/16/2016 3:50:00 AM	6/21/2016 7:24:00 PM	BB65485	Lead	10	15	ppb
038-WS1-144A	Outside Spigot (Btwn Boiler Rm & Trash)	6/16/2016 3:52:00 AM	6/21/2016 7:27:00 PM	BB65486	Copper	0.4	1.3	ppm
038-WS1-144A	Outside Spigot (Btwn Boiler Rm & Trash)	6/16/2016 3:52:00 AM	6/21/2016 7:27:00 PM	BB65486	Lead	42	15	ppb
038-WS8-145A	Outside Spigot (near Pedestrian Bridge)	6/16/2016 3:54:00 AM	6/22/2016 2:26:00 PM	BB65487	Copper	1.1	1.3	ppm
038-WS8-145A	Outside Spigot (near Pedestrian Bridge)	6/16/2016 3:54:00 AM	6/21/2016 7:48:00 PM	BB65487	Lead	80	15	ppb
038-WS9-146A	Outside Spigot (near Track & Pedestrian Bdrge)	6/16/2016 3:56:00 AM	6/21/2016 7:51:00 PM	BB65488	Copper	0.4	1.3	ppm
038-WS9-146A	Outside Spigot (near Track & Pedestrian Bdrge)	6/16/2016 3:56:00 AM	6/21/2016 7:51:00 PM	BB65488	Lead	10	15	ppb
038-WS11-147A	Outside Spigot (behind Home Plate)	6/16/2016 3:58:00 AM	6/21/2016 7:54:00 PM	BB65489	Copper	0.5	1.3	ppm
038-WS11-147A	Outside Spigot (behind Home Plate)	6/16/2016 3:58:00 AM	6/21/2016 7:54:00 PM	BB65489	Lead	104	15	ppb
038-WS12-148A	Outside Spigot (near Tree behind Home Plate)	6/16/2016 4:00:00 AM	6/21/2016 7:57:00 PM	BB65490	Copper	0.6	1.3	ppm
038-WS12-148A	Outside Spigot (near Tree behind Home Plate)	6/16/2016 4:00:00 AM	6/21/2016 7:57:00 PM	BB65490	Lead	4	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.