

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Glencoe Elementary School

Sample Identification # and Location		Collection Date	Analysis Date	Sample ID	Analyte	Results	EPA Action Level	Units
039-01A	Sink Faucet Faucet Boiler Room	6/24/16 21:33	7/15/2016	1606C90-01A	Copper	0.3	1.3	ppm
039-01A	Sink Faucet Faucet Boiler Room	6/24/16 21:33	7/15/2016	1606C90-01A	Lead	6	15	ppb
039-02A	Kitchen Spray	6/24/16 19:24	7/15/2016	1606C90-02A	Copper	0.5	1.3	ppm
039-02A	Kitchen Spray	6/24/16 19:24	7/15/2016	1606C90-02A	Lead	3	15	ppb
039-03A	Kitchen Toilet Sink Faucet	6/24/16 19:27	7/15/2016	1606C90-03A	Copper	0.8	1.3	ppm
039-03A	Kitchen Toilet Sink Faucet	6/24/16 19:27	7/15/2016	1606C90-03A	Lead	6	15	ppb
039-04A	Kitchen Sink Faucet #1	6/24/16 19:24	7/15/2016	1606C90-04A	Copper	0.5	1.3	ppm
039-04A	Kitchen Sink Faucet #1	6/24/16 19:24	7/15/2016	1606C90-04A	Lead	4	15	ppb
039-05A	Kitchen Sink Faucet #2	6/24/16 19:26	7/15/2016	1606C90-05A	Copper	0.2	1.3	ppm
039-05A	Kitchen Sink Faucet #2	6/24/16 19:26	7/15/2016	1606C90-05A	Lead	3	15	ppb
039-06A	Kitchen Sink Faucet #3	6/24/16 19:29	7/15/2016	1606C90-06A	Copper	0.3	1.3	ppm
039-06A	Kitchen Sink Faucet #3	6/24/16 19:29	7/15/2016	1606C90-06A	Lead	2	15	ppb
039-07A	Drinking Fountain Cafeteria Left	6/24/16 19:32	7/18/2016	1606C90-07A	Copper	0.6	1.3	ppm
039-07A	Drinking Fountain Cafeteria Left	6/24/16 19:32	7/18/2016	1606C90-07A	Lead	2	15	ppb
039-08A	Drinking Fountain Cafeteria Right	6/24/16 19:32	7/16/2016	1606C90-08A	Copper	0.2	1.3	ppm
039-08A	Drinking Fountain Cafeteria Right	6/24/16 19:32	7/16/2016	1606C90-08A	Lead	ND	15	ppb
039-09A	Boys Bathroom Sink Faucet #1	6/24/16 19:37	7/16/2016	1606C90-09A	Copper	0.5	1.3	ppm
039-09A	Boys Bathroom Sink Faucet #1	6/24/16 19:37	7/16/2016	1606C90-09A	Lead	7	15	ppb
039-10A	Boys Bathroom Sink Faucet #2	6/24/16 19:37	7/16/2016	1606C90-10A	Copper	0.5	1.3	ppm
039-10A	Boys Bathroom Sink Faucet #2	6/24/16 19:37	7/16/2016	1606C90-10A	Lead	4	15	ppb
039-11A	Boys Bathroom Sink Faucet #3	6/24/16 19:37	7/16/2016	1606C90-11A	Copper	0.6	1.3	ppm
039-11A	Boys Bathroom Sink Faucet #3	6/24/16 19:37	7/16/2016	1606C90-11A	Lead	2	15	ppb
039-12A	Boys Bathroom Sink Faucet #4	6/24/16 19:39	7/16/2016	1606C90-12A	Copper	0.6	1.3	ppm
039-12A	Boys Bathroom Sink Faucet #4	6/24/16 19:39	7/16/2016	1606C90-12A	Lead	3	15	ppb
039-13A	Boys Bathroom Water Spigot	6/24/16 19:42	7/17/2016	1606C90-13A	Copper	1.1	1.3	ppm
039-13A	Boys Bathroom Water Spigot	6/24/16 19:42	7/16/2016	1606C90-13A	Lead	49	15	ppb
039-14A	Boys Bathroom Janitor Slop Sink Faucet	6/24/16 19:42	7/16/2016	1606C90-14A	Copper	0.6	1.3	ppm
039-14A	Boys Bathroom Janitor Slop Sink Faucet	6/24/16 19:42	7/16/2016	1606C90-14A	Lead	8	15	ppb
039-15A	Drinking Fountain Playroom Left	6/24/16 19:44	7/16/2016	1606C90-15A	Copper	0.2	1.3	ppm
039-15A	Drinking Fountain Playroom Left	6/24/16 19:44	7/16/2016	1606C90-15A	Lead	1	15	ppb
039-16A	Drinking Fountain Playroom Right	6/24/16 19:46	7/16/2016	1606C90-16A	Copper	0.3	1.3	ppm
039-16A	Drinking Fountain Playroom Right	6/24/16 19:46	7/16/2016	1606C90-16A	Lead	ND	15	ppb
039-17A	Media Center Sink Faucet	6/24/16 19:49	7/16/2016	1606C90-17A	Copper	0.6	1.3	ppm
039-17A	Media Center Sink Faucet	6/24/16 19:49	7/16/2016	1606C90-17A	Lead	8	15	ppb
039-18A	Girls Locker Room Sink Faucet	6/24/16 19:51	7/16/2016	1606C90-18A	Copper	0.5	1.3	ppm
039-18A	Girls Locker Room Sink Faucet	6/24/16 19:51	7/16/2016	1606C90-18A	Lead	2	15	ppb
039-19A	Girls Locker Room Water Spigot	6/24/16 19:52	7/16/2016	1606C90-19A	Copper	0.7	1.3	ppm
039-19A	Girls Locker Room Water Spigot	6/24/16 19:52	7/16/2016	1606C90-19A	Lead	4	15	ppb
039-20A	Girls Locker Room Drinking Fountain	6/24/16 19:52	7/16/2016	1606C90-20A	Copper	ND	1.3	ppm
039-20A	Girls Locker Room Drinking Fountain	6/24/16 19:52	7/16/2016	1606C90-20A	Lead	ND	15	ppb
039-21A	Drinking Fountain Gymnasium	6/24/16 19:54	7/16/2016	1606C90-21A	Copper	0.2	1.3	ppm
039-21A	Drinking Fountain Gymnasium	6/24/16 19:54	7/16/2016	1606C90-21A	Lead	ND	15	ppb
039-22A	Boys Locker Room Sink Faucet	6/24/16 19:57	7/16/2016	1606C90-22A	Copper	0.4	1.3	ppm
039-22A	Boys Locker Room Sink Faucet	6/24/16 19:57	7/16/2016	1606C90-22A	Lead	ND	15	ppb
039-23A	Boys Locker Room Water Spigot	6/24/16 19:59	7/16/2016	1606C90-23A	Copper	0.5	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Glencoe Elementary School

Sample Identification # and Location		Collection Date	Analysis Date	Sample ID	Analyte	Results	EPA Action Level	Units
039-23A	Boys Locker Room Water Spigot	6/24/16 19:59	7/16/2016	1606C90-23A	Lead	3	15	ppb
039-24A	Boys Locker Room Janitors Slop Sink Faucet	6/24/16 19:59	7/16/2016	1606C90-24A	Copper	0.4	1.3	ppm
039-24A	Boys Locker Room Janitors Slop Sink Faucet	6/24/16 19:59	7/16/2016	1606C90-24A	Lead	5	15	ppb
039-25A	Boys Locker Room Drinking Fountain	6/24/16 19:59	7/16/2016	1606C90-25A	Copper	ND	1.3	ppm
039-25A	Boys Locker Room Drinking Fountain	6/24/16 19:59	7/16/2016	1606C90-25A	Lead	2	15	ppb
039-26A	Sink Faucet Room 102	6/24/16 20:06	7/16/2016	1606C90-26A	Copper	0.3	1.3	ppm
039-26A	Sink Faucet Room 102	6/24/16 20:06	7/16/2016	1606C90-26A	Lead	ND	15	ppb
039-27A	Drinking Fountain Room 102	6/24/16 20:06	7/16/2016	1606C90-27A	Copper	0.4	1.3	ppm
039-27A	Drinking Fountain Room 102	6/24/16 20:06	7/16/2016	1606C90-27A	Lead	2	15	ppb
039-28A	Workroom Sink Faucet #1	6/24/16 20:09	7/16/2016	1606C90-28A	Copper	0.4	1.3	ppm
039-28A	Workroom Sink Faucet #1	6/24/16 20:09	7/16/2016	1606C90-28A	Lead	3	15	ppb
039-29A	Workroom Sink Faucet #2	6/24/16 20:10	7/16/2016	1606C90-29A	Copper	0.3	1.3	ppm
039-29A	Workroom Sink Faucet #2	6/24/16 20:10	7/16/2016	1606C90-29A	Lead	ND	15	ppb
039-30A	Office Health Room Sink Faucet	6/24/16 20:13	7/16/2016	1606C90-30A	Copper	0.4	1.3	ppm
039-30A	Office Health Room Sink Faucet	6/24/16 20:13	7/16/2016	1606C90-30A	Lead	ND	15	ppb
039-31A	Girls Bathroom Sink Faucet #1	6/24/16 20:13	7/16/2016	1606C90-31A	Copper	0.4	1.3	ppm
039-31A	Girls Bathroom Sink Faucet #1	6/24/16 20:13	7/16/2016	1606C90-31A	Lead	5	15	ppb
039-32A	Girls Bathroom Sink Faucet #2	6/24/16 20:14	7/16/2016	1606C90-32A	Copper	0.4	1.3	ppm
039-32A	Girls Bathroom Sink Faucet #2	6/24/16 20:14	7/16/2016	1606C90-32A	Lead	ND	15	ppb
039-33A	Girls Bathroom Sink Faucet #3	6/24/16 20:16	7/16/2016	1606C90-33A	Copper	0.5	1.3	ppm
039-33A	Girls Bathroom Sink Faucet #3	6/24/16 20:16	7/16/2016	1606C90-33A	Lead	ND	15	ppb
039-34A	Girls Bathroom Water Spigot	6/24/16 20:18	7/16/2016	1606C90-34A	Copper	0.7	1.3	ppm
039-34A	Girls Bathroom Water Spigot	6/24/16 20:18	7/16/2016	1606C90-34A	Lead	12	15	ppb
039-35A	Sink Faucet Room 110	6/24/16 20:20	7/16/2016	1606C90-35A	Copper	0.4	1.3	ppm
039-35A	Sink Faucet Room 110	6/24/16 20:20	7/16/2016	1606C90-35A	Lead	2	15	ppb
039-36A	Drinking Fountain Room 110	6/24/16 20:20	7/16/2016	1606C90-36A	Copper	ND	1.3	ppm
039-36A	Drinking Fountain Room 110	6/24/16 20:20	7/16/2016	1606C90-36A	Lead	2	15	ppb
039-37A	Sink Faucet Room 111	6/24/16 20:21	7/16/2016	1606C90-37A	Copper	0.4	1.3	ppm
039-37A	Sink Faucet Room 111	6/24/16 20:21	7/16/2016	1606C90-37A	Lead	2	15	ppb
039-38A	Drinking Fountain Room 111	6/24/16 20:21	7/16/2016	1606C90-38A	Copper	ND	1.3	ppm
039-38A	Drinking Fountain Room 111	6/24/16 20:21	7/16/2016	1606C90-38A	Lead	1	15	ppb
039-39A	Art Infusion Room Sink Faucet	6/24/16 20:26	7/16/2016	1606C90-39A	Copper	0.3	1.3	ppm
039-39A	Art Infusion Room Sink Faucet	6/24/16 20:26	7/16/2016	1606C90-39A	Lead	2	15	ppb
039-40A	Drinking Fountain 1st Floor Hallway	6/24/16 20:26	7/16/2016	1606C90-40A	Copper	0.7	1.3	ppm
039-40A	Drinking Fountain 1st Floor Hallway	6/24/16 20:26	7/16/2016	1606C90-40A	Lead	1	15	ppb
039-41A	Rm 109A Janitors Slop Sink Faucet	6/24/16 20:28	7/16/2016	1606C90-41A	Copper	0.3	1.3	ppm
039-41A	Rm 109A Janitors Slop Sink Faucet	6/24/16 20:28	7/16/2016	1606C90-41A	Lead	3	15	ppb
039-42A	Room 109 Sink Faucet	6/24/16 20:28	7/16/2016	1606C90-42A	Copper	0.6	1.3	ppm
039-42A	Room 109 Sink Faucet	6/24/16 20:28	7/16/2016	1606C90-42A	Lead	1	15	ppb
039-43A	Room 109 Drinking Fountain	6/24/16 20:30	7/16/2016	1606C90-43A	Copper	ND	1.3	ppm
039-43A	Room 109 Drinking Fountain	6/24/16 20:30	7/16/2016	1606C90-43A	Lead	4	15	ppb
039-44A	2nd Floor Hallway Drinking Fountain	6/24/16 20:39	7/16/2016	1606C90-44A	Copper	ND	1.3	ppm
039-44A	2nd Floor Hallway Drinking Fountain	6/24/16 20:39	7/16/2016	1606C90-44A	Lead	ND	15	ppb
039-45A	Girls Bathroom Sink Faucet	6/24/16 20:40	7/16/2016	1606C90-45A	Copper	0.4	1.3	ppm
039-45A	Girls Bathroom Sink Faucet	6/24/16 20:40	7/16/2016	1606C90-45A	Lead	1	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Glencoe Elementary School

Sample Identification # and Location		Collection Date	Analysis Date	Sample ID	Analyte	Results	EPA Action Level	Units
039-46A	Girls Bathroom Water Spigot	6/24/16 20:42	7/16/2016	1606C90-46A	Copper	0.6	1.3	ppm
039-46A	Girls Bathroom Water Spigot	6/24/16 20:42	7/16/2016	1606C90-46A	Lead	2	15	ppb
039-47A	Faculty Room Sink Faucet	6/24/16 20:42	7/16/2016	1606C90-47A	Copper	0.3	1.3	ppm
039-47A	Faculty Room Sink Faucet	6/24/16 20:42	7/16/2016	1606C90-47A	Lead	1	15	ppb
039-48A	Bathroom Sink Faucet #1	6/24/16 20:44	7/16/2016	1606C90-48A	Copper	0.3	1.3	ppm
039-48A	Bathroom Sink Faucet #1	6/24/16 20:44	7/16/2016	1606C90-48A	Lead	2	15	ppb
039-49A	Bathroom Sink Faucet #2	6/24/16 20:46	7/16/2016	1606C90-49A	Copper	0.3	1.3	ppm
039-49A	Bathroom Sink Faucet #2	6/24/16 20:46	7/16/2016	1606C90-49A	Lead	2	15	ppb
039-50A	Bathroom Water Spigot	6/24/16 20:46	7/16/2016	1606C90-50A	Copper	0.4	1.3	ppm
039-50A	Bathroom Water Spigot	6/24/16 20:46	7/16/2016	1606C90-50A	Lead	2	15	ppb
039-51A	Custodial Room 5 Slop Sink Faucet	6/24/16 20:49	7/16/2016	1606C90-51A	Copper	0.4	1.3	ppm
039-51A	Custodial Room 5 Slop Sink Faucet	6/24/16 20:49	7/16/2016	1606C90-51A	Lead	1	15	ppb
039-52A	Boys Bathroom Sink Faucet	6/24/16 20:51	7/16/2016	1606C90-52A	Copper	0.3	1.3	ppm
039-52A	Boys Bathroom Sink Faucet	6/24/16 20:51	7/16/2016	1606C90-52A	Lead	3	15	ppb
039-53A	Boys Bathroom Water Spigot	6/24/16 20:51	7/16/2016	1606C90-53A	Copper	0.2	1.3	ppm
039-53A	Boys Bathroom Water Spigot	6/24/16 20:51	7/16/2016	1606C90-53A	Lead	15.0	15	ppb
039-54A	Room 205 Sink Faucet	6/24/16 20:54	7/16/2016	1606C90-54A	Copper	0.4	1.3	ppm
039-54A	Room 205 Sink Faucet	6/24/16 20:54	7/16/2016	1606C90-54A	Lead	3	15	ppb
039-55A	2nd Floor Hallway Drinking Fountain	6/24/16 20:54	7/16/2016	1606C90-55A	Copper	0.4	1.3	ppm
039-55A	2nd Floor Hallway Drinking Fountain	6/24/16 20:54	7/16/2016	1606C90-55A	Lead	3	15	ppb
039-56A	Room 202 Sink Faucet	6/24/16 20:57	7/17/2016	1606C90-56A	Copper	0.9	1.3	ppm
039-56A	Room 202 Sink Faucet	6/24/16 20:57	7/16/2016	1606C90-56A	Lead	2	15	ppb
039-57A	Room 202 Drinking Fountain	6/24/16 20:57	7/16/2016	1606C90-57A	Copper	ND	1.3	ppm
039-57A	Room 202 Drinking Fountain	6/24/16 20:57	7/16/2016	1606C90-57A	Lead	ND	15	ppb
039-58A	Outside Water Spigot #1	6/24/16 21:00	7/16/2016	1606C90-58A	Copper	0.6	1.3	ppm
039-58A	Outside Water Spigot #1	6/24/16 21:00	7/16/2016	1606C90-58A	Lead	4	15	ppb
039-59A	Outside Water Spigot #2	6/24/16 21:03	7/16/2016	1606C90-59A	Copper	0.4	1.3	ppm
039-59A	Outside Water Spigot #2	6/24/16 21:03	7/16/2016	1606C90-59A	Lead	10	15	ppb
039-60A	Outside Water Spigot #3	6/24/16 21:08	7/16/2016	1606C90-60A	Copper	0.4	1.3	ppm
039-60A	Outside Water Spigot #3	6/24/16 21:08	7/16/2016	1606C90-60A	Lead	9	15	ppb
039-61A	Outside Water Spigot #4	6/24/16 21:12	7/16/2016	1606C90-61A	Copper	0.6	1.3	ppm
039-61A	Outside Water Spigot #4	6/24/16 21:12	7/16/2016	1606C90-61A	Lead	5	15	ppb
039-62A	Outside Water Spigot #5	6/24/16 21:15	7/16/2016	1606C90-62A	Copper	0.5	1.3	ppm
039-62A	Outside Water Spigot #5	6/24/16 21:15	7/16/2016	1606C90-62A	Lead	7	15	ppb
039-63A	Outside Water Spigot #6	6/24/16 21:18	7/16/2016	1606C90-63A	Copper	0.7	1.3	ppm
039-63A	Outside Water Spigot #6	6/24/16 21:18	7/16/2016	1606C90-63A	Lead	13	15	ppb
039-64A	Outside Water Spigot #7	6/24/16 21:20	7/16/2016	1606C90-64A	Copper	0.2	1.3	ppm
039-64A	Outside Water Spigot #7	6/24/16 21:20	7/16/2016	1606C90-64A	Lead	8	15	ppb
039-65A	P-1 Sink Faucet	6/24/16 21:23	7/16/2016	1606C90-65A	Copper	0.4	1.3	ppm
039-65A	P-1 Sink Faucet	6/24/16 21:23	7/16/2016	1606C90-65A	Lead	ND	15	ppb
039-66A	Outside Water Spigot #8	6/24/16 21:26	7/16/2016	1606C90-66A	Copper	0.7	1.3	ppm
039-66A	Outside Water Spigot #8	6/24/16 21:26	7/16/2016	1606C90-66A	Lead	6	15	ppb
039-67A	Outside Water Spigot #9	6/24/16 21:29	7/17/2016	1606C90-67A	Copper	1.1	1.3	ppm
039-67A	Outside Water Spigot #9	6/24/16 21:29	7/16/2016	1606C90-67A	Lead	17	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Glencoe Elementary School

Sample Identification # and Location	Collection Date	Analysis Date	Sample ID	Analyte	Results	EPA Action Level	Units
EPA Action Level for Lead of 15 ppb				ND = Non detect			
EPA Action Level for Copper of 1.3 ppm							

Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.