

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Grant High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
040-01A Room 13 Sink Faucet Basement	6/30/16 1:20	7/9/16 16:50	606302301	Copper	0.1	1.3	ppm
040-01A Room 13 Sink Faucet Basement	6/30/16 1:20	7/9/16 16:50	606302301	Lead	40	15	ppb
040-02A Room 19 Sink Faucet Basement	6/30/16 1:22	7/9/16 16:50	606302302	Copper	0.0	1.3	ppm
040-02A Room 19 Sink Faucet Basement	6/30/16 1:22	7/9/16 16:50	606302302	Lead	36	15	ppb
040-03A Mens Sink Faucet Basement	6/30/16 1:24	7/9/16 16:50	606302303	Copper	0.1	1.3	ppm
040-03A Mens Sink Faucet Basement	6/30/16 1:24	7/9/16 16:50	606302303	Lead	16	15	ppb
040-04A Womens Sink Faucet Basement	6/30/16 1:26	7/9/16 16:50	606302304	Copper	0.0	1.3	ppm
040-04A Womens Sink Faucet Basement	6/30/16 1:26	7/9/16 16:50	606302304	Lead	26	15	ppb
040-05A Hall Drinking Fountain Basement	6/30/16 1:28	7/10/16 11:46	606302305	Copper	0.1	1.3	ppm
040-05A Hall Drinking Fountain Basement	6/30/16 1:28	7/10/16 11:46	606302305	Lead	7	15	ppb
040-06A Janitor's Closet by Room 19 Basement	6/30/16 1:20	7/10/16 11:47	606302306	Copper	0.0	1.3	ppm
040-06A Janitor's Closet by Room 19 Basement	6/30/16 1:20	7/10/16 11:47	606302306	Lead	3	15	ppb
040-07A Girls Sink Faucet (1) 1st Floor	6/30/16 1:33	7/10/16 13:31	606302307	Copper	0.0	1.3	ppm
040-07A Girls Sink Faucet (1) 1st Floor	6/30/16 1:33	7/10/16 13:31	606302307	Lead	9	15	ppb
040-08A Girls Sink Faucet (2) 1st Floor	6/30/16 1:35	7/10/16 13:33	606302308	Copper	0.1	1.3	ppm
040-08A Girls Sink Faucet (2) 1st Floor	6/30/16 1:35	7/10/16 13:33	606302308	Lead	17	15	ppb
040-09A Girls Sink Faucet (3) 1st Floor	6/30/16 1:37	7/10/16 13:33	606302309	Copper	0.4	1.3	ppm
040-09A Girls Sink Faucet (3) 1st Floor	6/30/16 1:37	7/10/16 13:33	606302309	Lead	31	15	ppb
040-10A Girls Sink Faucet (4) 1st Floor	6/30/16 1:39	7/10/16 13:33	606302310	Copper	0.0	1.3	ppm
040-10A Girls Sink Faucet (4) 1st Floor	6/30/16 1:39	7/10/16 13:33	606302310	Lead	7	15	ppb
040-11A Girls Sink Faucet (5) 1st Floor	6/30/16 1:41	7/10/16 13:33	606302311	Copper	0.1	1.3	ppm
040-11A Girls Sink Faucet (5) 1st Floor	6/30/16 1:41	7/10/16 13:33	606302311	Lead	20	15	ppb
040-12A Office Bathroom Sink Faucet	6/30/16 1:24	7/10/16 13:33	606302312	Copper	0.1	1.3	ppm
040-12A Office Bathroom Sink Faucet	6/30/16 1:24	7/10/16 13:33	606302312	Lead	49	15	ppb
040-13A Nurse Office Exam Room 1 Corner	6/30/16 1:25	7/10/16 13:33	606302313	Copper	0.5	1.3	ppm
040-13A Nurse Office Exam Room 1 Corner	6/30/16 1:25	7/10/16 13:33	606302313	Lead	19	15	ppb
040-14A Nurse Office Back Corner Room Sink Faucet (1)	6/30/16 1:25	7/10/16 13:33	606302314	Copper	0.7	1.3	ppm
040-14A Nurse Office Back Corner Room Sink Faucet (1)	6/30/16 1:25	7/10/16 13:33	606302314	Lead	17	15	ppb
040-15A Nurse Office Back Room Sink Faucet (2)	6/30/16 1:27	7/10/16 13:33	606302315	Copper	0.2	1.3	ppm
040-15A Nurse Office Back Room Sink Faucet (2)	6/30/16 1:27	7/10/16 13:33	606302315	Lead	8	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Grant High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
040-16A Nurse Office Back Room Sink Faucet (3)	6/30/16 1:30	7/10/16 13:33	606302316	Copper	0.4	1.3	ppm
040-16A Nurse Office Back Room Sink Faucet (3)	6/30/16 1:30	7/10/16 13:33	606302316	Lead	10	15	ppb
040-17A Nurse Bathroom Sink Faucet	6/30/16 1:32	7/10/16 13:33	606302317	Copper	0.3	1.3	ppm
040-17A Nurse Bathroom Sink Faucet	6/30/16 1:32	7/10/16 13:33	606302317	Lead	8	15	ppb
040-18A Nurse Office Eyewash	6/30/16 1:32	7/10/16 13:33	606302318	Copper	0.3	1.3	ppm
040-18A Nurse Office Eyewash	6/30/16 1:32	7/10/16 13:33	606302318	Lead	3	15	ppb
040-19A Back Area Sink Faucet	6/30/16 1:33	7/10/16 13:33	606302319	Copper	0.4	1.3	ppm
040-19A Back Area Sink Faucet	6/30/16 1:33	7/10/16 13:33	606302319	Lead	5	15	ppb
040-20A Hall Drinking Fountain	6/30/16 1:35	7/10/16 13:33	606302320	Copper	0.6	1.3	ppm
040-20A Hall Drinking Fountain	6/30/16 1:35	7/10/16 13:33	606302320	Lead	3	15	ppb
040-21A Womens Room 109 Sink Faucet	6/30/16 1:36	7/10/16 13:33	606302321	Copper	0.0	1.3	ppm
040-21A Womens Room 109 Sink Faucet	6/30/16 1:36	7/10/16 13:33	606302321	Lead	13	15	ppb
040-22A Cust Closet Sink Faucet	6/30/16 1:41	7/10/16 13:34	606302322	Copper	0.1	1.3	ppm
040-22A Cust Closet Sink Faucet	6/30/16 1:41	7/10/16 13:34	606302322	Lead	4	15	ppb
040-23A Hall by 113 Drinking Fountain	6/30/16 1:46	7/10/16 13:34	606302323	Copper	0.1	1.3	ppm
040-23A Hall by 113 Drinking Fountain	6/30/16 1:46	7/10/16 13:34	606302323	Lead	4	15	ppb
040-24A Boys Bathroom by 113 Sink Faucet (1)	6/30/16 1:48	7/10/16 13:34	606302324	Copper	0.1	1.3	ppm
040-24A Boys Bathroom by 113 Sink Faucet (1)	6/30/16 1:48	7/10/16 13:34	606302324	Lead	15.0	15	ppb
040-25A Boys Bathroom Sink Faucet (2)	6/30/16 1:50	7/10/16 13:34	606302325	Copper	0.1	1.3	ppm
040-25A Boys Bathroom Sink Faucet (2)	6/30/16 1:50	7/10/16 13:34	606302325	Lead	9	15	ppb
040-26A Boys Bathroom Sink Faucet (3)	6/30/16 1:52	7/10/16 13:34	606302326	Copper	0.1	1.3	ppm
040-26A Boys Bathroom Sink Faucet (3)	6/30/16 1:52	7/10/16 13:34	606302326	Lead	12	15	ppb
040-27A Boys Bathroom Sink Faucet (4)	6/30/16 1:54	7/10/16 13:34	606302327	Copper	0.0	1.3	ppm
040-27A Boys Bathroom Sink Faucet (4)	6/30/16 1:54	7/10/16 13:34	606302327	Lead	6	15	ppb
040-28A Boys Bathroom Sink Faucet (5)	6/30/16 1:56	7/10/16 13:34	606302328	Copper	0.1	1.3	ppm
040-28A Boys Bathroom Sink Faucet (5)	6/30/16 1:56	7/10/16 13:34	606302328	Lead	8	15	ppb
040-29A Mens Bathroom Sink Faucet	6/30/16 1:58	7/10/16 13:34	606302329	Copper	0.1	1.3	ppm
040-29A Mens Bathroom Sink Faucet	6/30/16 1:58	7/10/16 13:34	606302329	Lead	8	15	ppb
040-30A Womens Bathroom Sink Faucet	6/30/16 2:00	7/10/16 13:34	606302330	Copper	0.1	1.3	ppm
040-30A Womens Bathroom Sink Faucet	6/30/16 2:00	7/10/16 13:34	606302330	Lead	6	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Grant High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
040-31A Office Sink Faucet	6/30/16 2:02	7/10/16 13:34	606302331	Copper	0.0	1.3	ppm
040-31A Office Sink Faucet	6/30/16 2:02	7/10/16 13:34	606302331	Lead	2	15	ppb
040-32A Hall by Office Drinking Fountain (Bottle Fill)	6/30/16 2:12	7/10/16 13:34	606302332	Copper	0.4	1.3	ppm
040-32A Hall by Office Drinking Fountain (Bottle Fill)	6/30/16 2:12	7/10/16 13:34	606302332	Lead	1	15	ppb
040-33A Kitchen Hand Sink Basement	6/30/16 2:06	7/10/16 13:34	606302333	Copper	0.1	1.3	ppm
040-33A Kitchen Hand Sink Basement	6/30/16 2:06	7/10/16 13:34	606302333	Lead	1	15	ppb
040-34A Kitchen Dish Sink Sink Faucet Dish Room	6/30/16 2:05	7/10/16 13:34	606302334	Copper	0.3	1.3	ppm
040-34A Kitchen Dish Sink Sink Faucet Dish Room	6/30/16 2:05	7/10/16 13:34	606302334	Lead	18	15	ppb
040-35A Kitchen Corner Sink Sink Faucet	6/30/16 2:06	7/10/16 13:34	606302335	Copper	0.7	1.3	ppm
040-35A Kitchen Corner Sink Sink Faucet	6/30/16 2:06	7/10/16 13:34	606302335	Lead	134	15	ppb
040-36A Kitchen Water Spigot	6/30/16 2:08	7/10/16 13:35	606302336	Copper	0.0	1.3	ppm
040-36A Kitchen Water Spigot	6/30/16 2:08	7/10/16 13:35	606302336	Lead	10	15	ppb
040-37A Kitchen Bathroom Sink Faucet (1)	6/30/16 2:09	7/10/16 13:35	606302337	Copper	0.0	1.3	ppm
040-37A Kitchen Bathroom Sink Faucet (1)	6/30/16 2:09	7/10/16 13:35	606302337	Lead	2	15	ppb
040-38A Kitchen Bathroom Sink Faucet (2)	6/30/16 2:10	7/10/16 13:35	606302338	Copper	0.0	1.3	ppm
040-38A Kitchen Bathroom Sink Faucet (2)	6/30/16 2:10	7/10/16 13:35	606302338	Lead	0	15	ppb
040-39A Kitchen Janitor's Closet Sink Faucet	6/30/16 2:12	7/10/16 13:35	606302339	Copper	0.0	1.3	ppm
040-39A Kitchen Janitor's Closet Sink Faucet	6/30/16 2:12	7/10/16 13:35	606302339	Lead	0	15	ppb
040-40A Kitchen Prep Sink (center)	6/30/16 2:16	7/10/16 13:35	606302340	Copper	0.0	1.3	ppm
040-40A Kitchen Prep Sink (center)	6/30/16 2:16	7/10/16 13:35	606302340	Lead	0	15	ppb
040-41A Kitchen Prep Sink Sink Faucet (1)	6/30/16 2:16	7/10/16 13:35	606302341	Copper	0.1	1.3	ppm
040-41A Kitchen Prep Sink Sink Faucet (1)	6/30/16 2:16	7/10/16 13:35	606302341	Lead	7	15	ppb
040-42A Kitchen Prep Sink Sink Faucet (2)	6/30/16 2:18	7/10/16 13:35	606302342	Copper	0.0	1.3	ppm
040-42A Kitchen Prep Sink Sink Faucet (2)	6/30/16 2:18	7/10/16 13:35	606302342	Lead	0	15	ppb
040-43A Kitchen Prep Sink Sink Faucet (3)	6/30/16 2:19	7/10/16 13:35	606302343	Copper	0.0	1.3	ppm
040-43A Kitchen Prep Sink Sink Faucet (3)	6/30/16 2:19	7/10/16 13:35	606302343	Lead	ND	15	ppb
040-44A Kitchen Prep Sink Sink Faucet (4)	6/30/16 2:22	7/10/16 13:35	606302344	Copper	0.0	1.3	ppm
040-44A Kitchen Prep Sink Sink Faucet (4)	6/30/16 2:22	7/10/16 13:35	606302344	Lead	0	15	ppb
040-45A Kitchen Sink Faucet (1)	6/30/16 2:43	7/10/16 13:35	606302345	Copper	0.2	1.3	ppm
040-45A Kitchen Sink Faucet (1)	6/30/16 2:43	7/10/16 13:35	606302345	Lead	16	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Grant High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
040-46A Kitchen Sink Faucet (2)	6/30/16 2:45	7/10/16 13:36	606302346	Copper	0.7	1.3	ppm
040-46A Kitchen Sink Faucet (2)	6/30/16 2:45	7/10/16 13:36	606302346	Lead	11	15	ppb
040-47A Kitchen Sink Faucet (3)	6/30/16 2:47	7/10/16 13:36	606302347	Copper	0.1	1.3	ppm
040-47A Kitchen Sink Faucet (3)	6/30/16 2:47	7/10/16 13:36	606302347	Lead	36	15	ppb
040-48A Kitchen Bathroom Sink Faucet	6/30/16 2:37	7/10/16 13:36	606302348	Copper	0.5	1.3	ppm
040-48A Kitchen Bathroom Sink Faucet	6/30/16 2:37	7/10/16 13:36	606302348	Lead	26	15	ppb
040-49A Kitchen Serving Line Sink Faucet	6/30/16 2:40	7/9/16 16:20	606302349	Copper	6.3	1.3	ppm
040-49A Kitchen Serving Line Sink Faucet	6/30/16 2:40	7/9/16 16:20	606302349	Lead	1300	15	ppb
040-50A Kitchen Bathroom by Serving Line Sink Faucet	6/30/16 2:42	7/10/16 13:36	606302350	Copper	0.0	1.3	ppm
040-50A Kitchen Bathroom by Serving Line Sink Faucet	6/30/16 2:42	7/10/16 13:36	606302350	Lead	8	15	ppb
040-51A Ladies (Auditorium) Sink Faucet	6/30/16 3:07	7/10/16 13:37	606302351	Copper	0.0	1.3	ppm
040-51A Ladies (Auditorium) Sink Faucet	6/30/16 3:07	7/10/16 13:37	606302351	Lead	106	15	ppb
040-52A Bathroom Sink Faucet (1)	6/30/16 3:10	7/10/16 13:37	606302352	Copper	0.0	1.3	ppm
040-52A Bathroom Sink Faucet (1)	6/30/16 3:10	7/10/16 13:37	606302352	Lead	18	15	ppb
040-53A Bathroom Sink Faucet (2)	6/30/16 3:12	7/10/16 13:37	606302353	Copper	0.0	1.3	ppm
040-53A Bathroom Sink Faucet (2)	6/30/16 3:12	7/10/16 13:37	606302353	Lead	18	15	ppb
040-54A Prep Room Sink Sink Faucet	6/30/16 3:15	7/10/16 13:37	606302354	Copper	0.1	1.3	ppm
040-54A Prep Room Sink Sink Faucet	6/30/16 3:15	7/10/16 13:37	606302354	Lead	78	15	ppb
040-55A Bathroom behind Stage Sink Faucet (1)	6/30/16 3:17	7/10/16 13:37	606302355	Copper	0.0	1.3	ppm
040-55A Bathroom behind Stage Sink Faucet (1)	6/30/16 3:17	7/10/16 13:37	606302355	Lead	11	15	ppb
040-56A Audi-Prep Room Sink Faucet (2)	6/30/16 3:10	7/10/16 13:37	606302356	Copper	0.1	1.3	ppm
040-56A Audi-Prep Room Sink Faucet (2)	6/30/16 3:10	7/10/16 13:37	606302356	Lead	21	15	ppb
040-57A Room 120 (IT area) Sink Faucet	6/30/16 3:15	7/10/16 13:37	606302357	Copper	0.1	1.3	ppm
040-57A Room 120 (IT area) Sink Faucet	6/30/16 3:15	7/10/16 13:37	606302357	Lead	23	15	ppb
040-58A Library Sink Faucet	6/30/16 3:27	7/10/16 13:37	606302358	Copper	0.1	1.3	ppm
040-58A Library Sink Faucet	6/30/16 3:27	7/10/16 13:37	606302358	Lead	8	15	ppb
040-59A Library Janitor's Closet Sink Faucet	6/30/16 3:30	7/10/16 13:37	606302359	Copper	0.0	1.3	ppm
040-59A Library Janitor's Closet Sink Faucet	6/30/16 3:30	7/10/16 13:37	606302359	Lead	6	15	ppb
040-60A Hall by Library Drinking Fountain	6/30/16 3:32	7/10/16 13:37	606302360	Copper	0.0	1.3	ppm
040-60A Hall by Library Drinking Fountain	6/30/16 3:32	7/10/16 13:37	606302360	Lead	34	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Grant High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
040-61A Girls Bathroom Sink Faucet (1)	6/30/16 3:36	7/10/16 13:37	606302361	Copper	0.1	1.3	ppm
040-61A Girls Bathroom Sink Faucet (1)	6/30/16 3:36	7/10/16 13:37	606302361	Lead	43	15	ppb
040-62A Girls Bathroom Sink Faucet (2)	6/30/16 3:37	7/10/16 13:37	606302362	Copper	0.0	1.3	ppm
040-62A Girls Bathroom Sink Faucet (2)	6/30/16 3:37	7/10/16 13:37	606302362	Lead	13	15	ppb
040-63A Girls Bathroom Sink Faucet (3)	6/30/16 3:38	7/10/16 13:37	606302363	Copper	0.3	1.3	ppm
040-63A Girls Bathroom Sink Faucet (3)	6/30/16 3:38	7/10/16 13:37	606302363	Lead	5	15	ppb
040-64A Girls Bathroom Sink Faucet (4)	6/30/16 3:39	7/10/16 13:37	606302364	Copper	0.1	1.3	ppm
040-64A Girls Bathroom Sink Faucet (4)	6/30/16 3:39	7/10/16 13:37	606302364	Lead	18	15	ppb
040-65A Janitor's Closet Sink Faucet	6/30/16 3:41	7/10/16 13:37	606302365	Copper	0.1	1.3	ppm
040-65A Janitor's Closet Sink Faucet	6/30/16 3:41	7/10/16 13:37	606302365	Lead	2	15	ppb
040-66A Boys Sink Faucet (1)	6/30/16 3:43	7/10/16 13:37	606302366	Copper	0.5	1.3	ppm
040-66A Boys Sink Faucet (1)	6/30/16 3:43	7/10/16 13:37	606302366	Lead	6	15	ppb
040-67A Boys Sink Faucet (2)	6/30/16 3:29	7/11/16 11:35	606302367	Copper	0.5	1.3	ppm
040-67A Boys Sink Faucet (2)	6/30/16 3:29	7/11/16 11:35	606302367	Lead	9	15	ppb
040-68A Boys Sink Faucet (3)	6/30/16 3:31	7/11/16 11:35	606302368	Copper	0.7	1.3	ppm
040-68A Boys Sink Faucet (3)	6/30/16 3:31	7/11/16 11:35	606302368	Lead	6	15	ppb
040-69A Boys Sink Faucet (4)	6/30/16 3:33	7/11/16 11:35	606302369	Copper	0.7	1.3	ppm
040-69A Boys Sink Faucet (4)	6/30/16 3:33	7/11/16 11:35	606302369	Lead	12	15	ppb
040-70A Hall Drinking Fountain	6/30/16 3:35	7/11/16 11:35	606302370	Copper	0.1	1.3	ppm
040-70A Hall Drinking Fountain	6/30/16 3:35	7/11/16 11:35	606302370	Lead	8	15	ppb
040-71A Room 138 Sink Faucet (1)	6/30/16 3:38	7/11/16 11:35	606302371	Copper	0.0	1.3	ppm
040-71A Room 138 Sink Faucet (1)	6/30/16 3:38	7/11/16 11:35	606302371	Lead	4	15	ppb
040-72A Room 138 Sink Faucet (2)	6/30/16 3:40	7/11/16 11:35	606302372	Copper	0.1	1.3	ppm
040-72A Room 138 Sink Faucet (2)	6/30/16 3:40	7/11/16 11:35	606302372	Lead	3	15	ppb
040-73A Girls Sink Faucet (1)	6/30/16 3:43	7/11/16 11:35	606302373	Copper	0.1	1.3	ppm
040-73A Girls Sink Faucet (1)	6/30/16 3:43	7/11/16 11:35	606302373	Lead	6	15	ppb
040-74A Girls Sink Faucet (2)	6/30/16 3:45	7/11/16 11:35	606302374	Copper	0.0	1.3	ppm
040-74A Girls Sink Faucet (2)	6/30/16 3:45	7/11/16 11:35	606302374	Lead	7	15	ppb
040-75A Girls Sink Faucet (3)	6/30/16 3:47	7/11/16 11:36	606302375	Copper	0.2	1.3	ppm
040-75A Girls Sink Faucet (3)	6/30/16 3:47	7/11/16 11:36	606302375	Lead	18	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Grant High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
040-76A Room 141 Sink Faucet (1)	6/30/16 3:50	7/11/16 11:36	606302376	Copper	0.1	1.3	ppm
040-76A Room 141 Sink Faucet (1)	6/30/16 3:50	7/11/16 11:36	606302376	Lead	14	15	ppb
040-77A Room 141 Sink Faucet (2)	6/30/16 3:52	7/11/16 11:37	606302377	Copper	0.0	1.3	ppm
040-77A Room 141 Sink Faucet (2)	6/30/16 3:52	7/11/16 11:37	606302377	Lead	9	15	ppb
040-78A Room 141 Sink Faucet (3)	6/30/16 3:48	7/11/16 11:37	606302378	Copper	0.0	1.3	ppm
040-78A Room 141 Sink Faucet (3)	6/30/16 3:48	7/11/16 11:37	606302378	Lead	11	15	ppb
040-79A Room 141 Sink Faucet (4)	6/30/16 3:50	7/11/16 11:37	606302379	Copper	0.0	1.3	ppm
040-79A Room 141 Sink Faucet (4)	6/30/16 3:50	7/11/16 11:37	606302379	Lead	12	15	ppb
040-80A Room 141 Sink Faucet (5)	6/30/16 3:52	7/11/16 11:37	606302380	Copper	0.1	1.3	ppm
040-80A Room 141 Sink Faucet (5)	6/30/16 3:52	7/11/16 11:37	606302380	Lead	60	15	ppb
040-81A Room 141 Sink Faucet (6)	6/30/16 3:56	7/11/16 11:37	606302381	Copper	0.0	1.3	ppm
040-81A Room 141 Sink Faucet (6)	6/30/16 3:56	7/11/16 11:37	606302381	Lead	24	15	ppb
040-82A Room 139 Sink Faucet (1)	6/30/16 3:58	7/11/16 11:37	606302382	Copper	0.0	1.3	ppm
040-82A Room 139 Sink Faucet (1)	6/30/16 3:58	7/11/16 11:37	606302382	Lead	12	15	ppb
040-83A Room 139 Sink Faucet (2)	6/30/16 4:00	7/11/16 11:37	606302383	Copper	0.1	1.3	ppm
040-83A Room 139 Sink Faucet (2)	6/30/16 4:00	7/11/16 11:37	606302383	Lead	11	15	ppb
040-84A Room 139 Sink Faucet (3)	6/30/16 4:02	7/11/16 11:37	606302384	Copper	0.1	1.3	ppm
040-84A Room 139 Sink Faucet (3)	6/30/16 4:02	7/11/16 11:37	606302384	Lead	2	15	ppb
040-85A Room 139 Sink Faucet (4)	6/30/16 4:04	7/11/16 11:37	606302385	Copper	0.1	1.3	ppm
040-85A Room 139 Sink Faucet (4)	6/30/16 4:04	7/11/16 11:37	606302385	Lead	14	15	ppb
040-86A Room 143 Sink Faucet	6/30/16 4:06	7/11/16 11:37	606302386	Copper	0.0	1.3	ppm
040-86A Room 143 Sink Faucet	6/30/16 4:06	7/11/16 11:37	606302386	Lead	14	15	ppb
040-87A Room 143 Bathroom Sink Faucet	6/30/16 4:10	7/11/16 12:10	606302387	Copper	0.0	1.3	ppm
040-87A Room 143 Bathroom Sink Faucet	6/30/16 4:10	7/11/16 12:10	606302387	Lead	14.6	15	ppb
040-88A Room 145 Sink Faucet (1)	6/30/16 4:12	7/11/16 12:10	606302388	Copper	0.0	1.3	ppm
040-88A Room 145 Sink Faucet (1)	6/30/16 4:12	7/11/16 12:10	606302388	Lead	5	15	ppb
040-89A Room 145 Sink Faucet (2)	6/30/16 4:01	7/11/16 12:10	606302389	Copper	0.0	1.3	ppm
040-89A Room 145 Sink Faucet (2)	6/30/16 4:01	7/11/16 12:10	606302389	Lead	13	15	ppb
040-90A Room 145 Sink Faucet (3)	6/30/16 4:03	7/11/16 12:10	606302390	Copper	0.2	1.3	ppm
040-90A Room 145 Sink Faucet (3)	6/30/16 4:03	7/11/16 12:10	606302390	Lead	37	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Grant High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
040-91A Hall by Room 45 Drinking Fountain Basement	6/30/16 4:22	7/11/16 12:10	606302391	Copper	0.0	1.3	ppm
040-91A Hall by Room 45 Drinking Fountain Basement	6/30/16 4:22	7/11/16 12:10	606302391	Lead	3	15	ppb
040-92A Room 33 Photo Lab Sink Faucet (1) Basement	6/30/16 4:25	7/11/16 12:10	606302392	Copper	0.1	1.3	ppm
040-92A Room 33 Photo Lab Sink Faucet (1) Basement	6/30/16 4:25	7/11/16 12:10	606302392	Lead	1	15	ppb
040-93A Room 33 Photo Lab Sink Faucet (2) Basement	6/30/16 4:27	7/11/16 12:10	606302393	Copper	0.1	1.3	ppm
040-93A Room 33 Photo Lab Sink Faucet (2) Basement	6/30/16 4:27	7/11/16 12:10	606302393	Lead	3	15	ppb
040-94A Room 33 Sink Faucet Basement	6/30/16 4:29	7/11/16 12:10	606302394	Copper	0.1	1.3	ppm
040-94A Room 33 Sink Faucet Basement	6/30/16 4:29	7/11/16 12:10	606302394	Lead	2	15	ppb
040-95A Room 33 Drinking Fountain Basement	6/30/16 4:31	7/11/16 12:10	606302395	Copper	0.0	1.3	ppm
040-95A Room 33 Drinking Fountain Basement	6/30/16 4:31	7/11/16 12:10	606302395	Lead	5	15	ppb
040-96A Staff Bathroom Basement (1)	6/30/16 4:34	7/11/16 12:10	606302396	Copper	0.0	1.3	ppm
040-96A Staff Bathroom Basement (1)	6/30/16 4:34	7/11/16 12:10	606302396	Lead	9	15	ppb
040-97A Staff Bathroom Basement (2)	6/30/16 4:36	7/11/16 12:10	606302397	Copper	0.0	1.3	ppm
040-97A Staff Bathroom Basement (2)	6/30/16 4:36	7/11/16 12:10	606302397	Lead	19	15	ppb
040-98A Room 31 Sink Faucet Basement	6/30/16 4:38	7/11/16 12:10	606302398	Copper	0.0	1.3	ppm
040-98A Room 31 Sink Faucet Basement	6/30/16 4:38	7/11/16 12:10	606302398	Lead	8	15	ppb
040-99A Room 31 Drinking Fountain Basement	6/30/16 4:40	7/11/16 12:10	606302399	Copper	0.0	1.3	ppm
040-99A Room 31 Drinking Fountain Basement	6/30/16 4:40	7/11/16 12:10	606302399	Lead	6	15	ppb
040-100A Room 31 Bathroom Sink Faucet Basement	6/30/16 4:26	7/11/16 12:10	6063023100	Copper	0.8	1.3	ppm
040-100A Room 31 Bathroom Sink Faucet Basement	6/30/16 4:26	7/11/16 12:10	6063023100	Lead	342	15	ppb
040-101A Janitor's Closet Sink Faucet Basement	6/30/16 4:28	7/11/16 12:10	6063023101	Copper	0.2	1.3	ppm
040-101A Janitor's Closet Sink Faucet Basement	6/30/16 4:28	7/11/16 12:10	6063023101	Lead	9	15	ppb
040-102A Room 32 Sink Faucet Basement (1)	6/30/16 4:32	7/11/16 12:10	6063023102	Copper	0.9	1.3	ppm
040-102A Room 32 Sink Faucet Basement (1)	6/30/16 4:32	7/11/16 12:10	6063023102	Lead	6	15	ppb
040-103A Room 32 Sink Faucet Basement (2)	6/30/16 4:33	7/11/16 12:10	6063023103	Copper	0.0	1.3	ppm
040-103A Room 32 Sink Faucet Basement (2)	6/30/16 4:33	7/11/16 12:10	6063023103	Lead	14	15	ppb
040-104A Room 34 Sink Faucet Basement (3)	6/30/16 4:35	7/11/16 12:10	6063023104	Copper	0.2	1.3	ppm
040-104A Room 34 Sink Faucet Basement (3)	6/30/16 4:35	7/11/16 12:10	6063023104	Lead	2	15	ppb
040-105A Room 34 Sink Faucet Basement (4)	6/30/16 4:37	7/11/16 12:11	6063023105	Copper	0.2	1.3	ppm
040-105A Room 34 Sink Faucet Basement (4)	6/30/16 4:37	7/11/16 12:11	6063023105	Lead	1	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Grant High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
040-106A Room 207 Sink Faucet 2nd Floor	6/30/16 5:00	7/11/16 12:11	6063023106	Copper	0.1	1.3	ppm
040-106A Room 207 Sink Faucet 2nd Floor	6/30/16 5:00	7/11/16 12:11	6063023106	Lead	58	15	ppb
040-107A Room 203 Sink Faucet 2nd Floor	6/30/16 5:05	7/11/16 12:11	6063023107	Copper	0.1	1.3	ppm
040-107A Room 203 Sink Faucet 2nd Floor	6/30/16 5:05	7/11/16 12:11	6063023107	Lead	7	15	ppb
040-108A Hall by Custodian Closet Drinking Fountain 2nd Floor	6/30/16 5:08	7/11/16 12:11	6063023108	Copper	0.4	1.3	ppm
040-108A Hall by Custodian Closet Drinking Fountain 2nd Floor	6/30/16 5:08	7/11/16 12:11	6063023108	Lead	11	15	ppb
040-109A Janitor's Closet 2nd Floor	6/30/16 5:10	7/11/16 12:11	6063023109	Copper	0.0	1.3	ppm
040-109A Janitor's Closet 2nd Floor	6/30/16 5:10	7/11/16 12:11	6063023109	Lead	3	15	ppb
040-110A Hall by Boys Drinking Fountain 2nd Floor	6/30/16 5:13	7/11/16 12:11	6063023110	Copper	1.9	1.3	ppm
040-110A Hall by Boys Drinking Fountain 2nd Floor	6/30/16 5:13	7/11/16 12:11	6063023110	Lead	33	15	ppb
040-111A Boys Sink Faucet (1) 2nd Floor	6/30/16 5:01	7/11/16 12:11	6063023111	Copper	0.0	1.3	ppm
040-111A Boys Sink Faucet (1) 2nd Floor	6/30/16 5:01	7/11/16 12:11	6063023111	Lead	34	15	ppb
040-112A Boys Sink Faucet (2) 2nd Floor	6/30/16 5:03	7/11/16 12:11	6063023112	Copper	0.1	1.3	ppm
040-112A Boys Sink Faucet (2) 2nd Floor	6/30/16 5:03	7/11/16 12:11	6063023112	Lead	11	15	ppb
040-113A Boys Sink Faucet (3) 2nd Floor	6/30/16 5:06	7/11/16 12:11	6063023113	Copper	0.4	1.3	ppm
040-113A Boys Sink Faucet (3) 2nd Floor	6/30/16 5:06	7/11/16 12:11	6063023113	Lead	75	15	ppb
040-114A Boys Sink Faucet (4) 2nd Floor	6/30/16 5:08	7/11/16 12:11	6063023114	Copper	0.2	1.3	ppm
040-114A Boys Sink Faucet (4) 2nd Floor	6/30/16 5:08	7/11/16 12:11	6063023114	Lead	14	15	ppb
040-115A Boys Sink Faucet (5) 2nd Floor	6/30/16 5:10	7/11/16 12:11	6063023115	Copper	0.0	1.3	ppm
040-115A Boys Sink Faucet (5) 2nd Floor	6/30/16 5:10	7/11/16 12:11	6063023115	Lead	22	15	ppb
040-116A Room 217 Sink Faucet 2nd Floor	6/30/16 5:13	7/11/16 12:11	6063023116	Copper	0.2	1.3	ppm
040-116A Room 217 Sink Faucet 2nd Floor	6/30/16 5:13	7/11/16 12:11	6063023116	Lead	8	15	ppb
040-117A Room 225 Sink Faucet (1) 2nd Floor	6/30/16 5:16	7/10/16 14:01	6063023117	Copper	0.1	1.3	ppm
040-117A Room 225 Sink Faucet (1) 2nd Floor	6/30/16 5:16	7/10/16 14:01	6063023117	Lead	41	15	ppb
040-118A Room 225 Sink Faucet (2) 2nd Floor	6/30/16 5:18	7/10/16 14:01	6063023118	Copper	0.1	1.3	ppm
040-118A Room 225 Sink Faucet (2) 2nd Floor	6/30/16 5:18	7/10/16 14:01	6063023118	Lead	68	15	ppb
040-119A Girls Bathroom (1) 2nd Floor	6/30/16 5:15	7/10/16 14:01	6063023119	Copper	0.1	1.3	ppm
040-119A Girls Bathroom (1) 2nd Floor	6/30/16 5:15	7/10/16 14:01	6063023119	Lead	7	15	ppb
040-120A Girls Bathroom (2) 2nd Floor	6/30/16 5:17	7/10/16 14:01	6063023120	Copper	0.6	1.3	ppm
040-120A Girls Bathroom (2) 2nd Floor	6/30/16 5:17	7/10/16 14:01	6063023120	Lead	107	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Grant High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
040-121A Girls Bathroom (3) 2nd Floor	6/30/16 5:19	7/10/16 14:01	6063023121	Copper	0.3	1.3	ppm
040-121A Girls Bathroom (3) 2nd Floor	6/30/16 5:19	7/10/16 14:01	6063023121	Lead	23	15	ppb
040-122A Sink Faucet in back of Science Room 7	6/30/16 7:06	7/9/16 16:18	6063023122	Copper	0.5	1.3	ppm
040-122A Sink Faucet in back of Science Room 7	6/30/16 7:06	7/9/16 16:18	6063023122	Lead	374	15	ppb
040-123A Sink Faucet in Room 57 (1)	6/30/16 7:08	7/10/16 14:01	6063023123	Copper	0.4	1.3	ppm
040-123A Sink Faucet in Room 57 (1)	6/30/16 7:08	7/10/16 14:01	6063023123	Lead	37	15	ppb
040-124A Sink Faucet in Room 57 2nd Floor (2)	6/30/16 7:10	7/10/16 14:01	6063023124	Copper	0.2	1.3	ppm
040-124A Sink Faucet in Room 57 2nd Floor (2)	6/30/16 7:10	7/10/16 14:01	6063023124	Lead	66	15	ppb
040-125A Sink Faucet in Room 57 2nd Floor (3)	6/30/16 7:12	7/10/16 14:01	6063023125	Copper	0.2	1.3	ppm
040-125A Sink Faucet in Room 57 2nd Floor (3)	6/30/16 7:12	7/10/16 14:01	6063023125	Lead	61	15	ppb
040-126A Sink Faucet in Room 57 2nd Floor (4)	6/30/16 7:14	7/9/16 16:10	6063023126	Copper	0.3	1.3	ppm
040-126A Sink Faucet in Room 57 2nd Floor (4)	6/30/16 7:14	7/9/16 16:10	6063023126	Lead	69	15	ppb
040-127A Sink Faucet in Room 57 2nd Floor (5)	6/30/16 7:16	7/10/16 14:01	6063023127	Copper	0.3	1.3	ppm
040-127A Sink Faucet in Room 57 2nd Floor (5)	6/30/16 7:16	7/10/16 14:01	6063023127	Lead	56	15	ppb
040-128A Sink Faucet in Room 57 2nd Floor (6)	6/30/16 7:18	7/10/16 14:01	6063023128	Copper	0.2	1.3	ppm
040-128A Sink Faucet in Room 57 2nd Floor (6)	6/30/16 7:18	7/10/16 14:01	6063023128	Lead	35	15	ppb
040-129A Sink Faucet in Room 57 2nd Floor (7)	6/30/16 7:21	7/9/16 16:10	6063023129	Copper	0.1	1.3	ppm
040-129A Sink Faucet in Room 57 2nd Floor (7)	6/30/16 7:21	7/9/16 16:10	6063023129	Lead	220	15	ppb
040-130A Sink Faucet in Room 57 2nd Floor (8)	6/30/16 7:22	7/9/16 16:10	6063023130	Copper	0.2	1.3	ppm
040-130A Sink Faucet in Room 57 2nd Floor (8)	6/30/16 7:22	7/9/16 16:10	6063023130	Lead	193	15	ppb
040-131A Sink Faucet in Room 57 2nd Floor (9)	6/30/16 7:24	7/9/16 16:10	6063023131	Copper	0.3	1.3	ppm
040-131A Sink Faucet in Room 57 2nd Floor (9)	6/30/16 7:24	7/9/16 16:10	6063023131	Lead	297	15	ppb
040-132A Sink Faucet in Room 57 2nd Floor (10)	6/30/16 7:26	7/9/16 16:10	6063023132	Copper	0.2	1.3	ppm
040-132A Sink Faucet in Room 57 2nd Floor (10)	6/30/16 7:26	7/9/16 16:10	6063023132	Lead	413	15	ppb
040-133A Sink Faucet in Room 57 2nd Floor (11)	6/30/16 6:25	7/9/16 16:10	6063023133	Copper	0.9	1.3	ppm
040-133A Sink Faucet in Room 57 2nd Floor (11)	6/30/16 6:25	7/9/16 16:10	6063023133	Lead	83	15	ppb
040-134A Sink Faucet in Room 57 2nd Floor (12)	6/30/16 6:27	7/10/16 14:02	6063023134	Copper	0.3	1.3	ppm
040-134A Sink Faucet in Room 57 2nd Floor (12)	6/30/16 6:27	7/10/16 14:02	6063023134	Lead	55	15	ppb
040-135A Sink Faucet in Room 57 2nd Floor (13)	6/30/16 6:29	7/10/16 14:02	6063023135	Copper	0.3	1.3	ppm
040-135A Sink Faucet in Room 57 2nd Floor (13)	6/30/16 6:29	7/10/16 14:02	6063023135	Lead	279	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Grant High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
040-136A Sink Faucet in Room 57 2nd Floor (14)	6/30/16 6:31	7/10/16 14:02	6063023136	Copper	0.1	1.3	ppm
040-136A Sink Faucet in Room 57 2nd Floor (14)	6/30/16 6:31	7/11/16 12:23	6063023136	Lead	508	15	ppb
040-137A Sink Faucet in Room 57 2nd Floor (15)	6/30/16 6:33	7/9/16 16:04	6063023137	Copper	0.5	1.3	ppm
040-137A Sink Faucet in Room 57 2nd Floor (15)	6/30/16 6:33	7/9/16 16:04	6063023137	Lead	248	15	ppb
040-138A Sink Faucet in Room 57 2nd Floor (16)	6/30/16 6:35	7/9/16 16:10	6063023138	Copper	0.2	1.3	ppm
040-138A Sink Faucet in Room 57 2nd Floor (16)	6/30/16 6:35	7/9/16 16:10	6063023138	Lead	135	15	ppb
040-139A Sink Faucet in Room 57 2nd Floor (17)	6/30/16 6:39	7/9/16 16:10	6063023139	Copper	0.3	1.3	ppm
040-139A Sink Faucet in Room 57 2nd Floor (17)	6/30/16 6:39	7/9/16 16:10	6063023139	Lead	83	15	ppb
040-140A Sink Faucet in Room 57 2nd Floor (18)	6/30/16 6:39	7/9/16 16:10	6063023140	Copper	0.3	1.3	ppm
040-140A Sink Faucet in Room 57 2nd Floor (18)	6/30/16 6:39	7/9/16 16:10	6063023140	Lead	336	15	ppb
040-141A Sink Faucet in Room 57 2nd Floor (19)	6/30/16 6:41	7/9/16 16:02	6063023141	Copper	0.2	1.3	ppm
040-141A Sink Faucet in Room 57 2nd Floor (19)	6/30/16 6:41	7/9/16 16:02	6063023141	Lead	106	15	ppb
040-142A Sink Faucet in Room 57 2nd Floor (20)	6/30/16 6:43	7/9/16 16:02	6063023142	Copper	0.2	1.3	ppm
040-142A Sink Faucet in Room 57 2nd Floor (20)	6/30/16 6:43	7/9/16 16:02	6063023142	Lead	140	15	ppb
040-143A Sink Faucet in Room 57 (21)	6/30/16 6:45	7/9/16 16:03	6063023143	Copper	0.2	1.3	ppm
040-143A Sink Faucet in Room 57 (21)	6/30/16 6:45	7/9/16 16:03	6063023143	Lead	91	15	ppb
040-144A Sink Faucet in Room 57 (22)	6/30/16 6:20	7/9/16 16:03	6063023144	Copper	0.2	1.3	ppm
040-144A Sink Faucet in Room 57 (22)	6/30/16 6:20	7/9/16 16:03	6063023144	Lead	92	15	ppb
040-145A Sink Faucet in Room 57 (23)	6/30/16 6:22	7/10/16 14:02	6063023145	Copper	0.2	1.3	ppm
040-145A Sink Faucet in Room 57 (23)	6/30/16 6:22	7/10/16 14:02	6063023145	Lead	52	15	ppb
040-146A Sink Faucet in Room 57 (24)	6/30/16 6:24	7/10/16 14:02	6063023146	Copper	0.2	1.3	ppm
040-146A Sink Faucet in Room 57 (24)	6/30/16 6:24	7/10/16 14:02	6063023146	Lead	45	15	ppb
040-147A Sink Faucet in Room 57 (25)	6/30/16 6:26	7/9/16 16:03	6063023147	Copper	0.1	1.3	ppm
040-147A Sink Faucet in Room 57 (25)	6/30/16 6:26	7/9/16 16:03	6063023147	Lead	353	15	ppb
040-148A Sink Faucet in Room 57 (26)	6/30/16 6:28	7/10/16 14:02	6063023148	Copper	0.1	1.3	ppm
040-148A Sink Faucet in Room 57 (26)	6/30/16 6:28	7/10/16 14:02	6063023148	Lead	25	15	ppb
040-149A Sink Faucet in Room 57 (27)	6/30/16 6:30	7/10/16 14:02	6063023149	Copper	0.2	1.3	ppm
040-149A Sink Faucet in Room 57 (27)	6/30/16 6:30	7/10/16 14:02	6063023149	Lead	196	15	ppb
040-150A Sink Faucet in Room 57 (28)	6/30/16 6:32	7/9/16 16:03	6063023150	Copper	0.1	1.3	ppm
040-150A Sink Faucet in Room 57 (28)	6/30/16 6:32	7/9/16 16:03	6063023150	Lead	415	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Grant High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
040-151A Sink Faucet in Room 57 (29)	6/30/16 6:34	7/10/16 14:02	6063023151	Copper	0.2	1.3	ppm
040-151A Sink Faucet in Room 57 (29)	6/30/16 6:34	7/10/16 14:02	6063023151	Lead	112	15	ppb
040-152A Sink Faucet in Room 57 (30)	6/30/16 6:36	7/10/16 14:02	6063023152	Copper	0.0	1.3	ppm
040-152A Sink Faucet in Room 57 (30)	6/30/16 6:36	7/10/16 14:02	6063023152	Lead	1	15	ppb
040-153A Sink Faucet in Room 57 (31)	6/30/16 6:38	7/10/16 14:02	6063023153	Copper	0.0	1.3	ppm
040-153A Sink Faucet in Room 57 (31)	6/30/16 6:38	7/10/16 14:02	6063023153	Lead	3	15	ppb
040-154A Drinking Fountain in between Room 7 & LLR5	6/30/16 7:24	7/10/16 14:02	6063023154	Copper	0.0	1.3	ppm
040-154A Drinking Fountain in between Room 7 & LLR5	6/30/16 7:24	7/10/16 14:02	6063023154	Lead	11	15	ppb
040-155A Sink Faucet in between Room 57 & LLR5	6/30/16 7:08	7/10/16 14:02	6063023155	Copper	0.1	1.3	ppm
040-155A Sink Faucet in between Room 57 & LLR5	6/30/16 7:08	7/10/16 14:02	6063023155	Lead	44	15	ppb
040-156A Sink Faucet in between Room 57 & LLR5	6/30/16 7:10	7/10/16 14:02	6063023156	Copper	0.0	1.3	ppm
040-156A Sink Faucet in between Room 57 & LLR5	6/30/16 7:10	7/10/16 14:02	6063023156	Lead	57	15	ppb
040-157A Sink Faucet in 59 (1)	6/30/16 7:12	7/9/16 16:03	6063023157	Copper	0.1	1.3	ppm
040-157A Sink Faucet in 59 (1)	6/30/16 7:12	7/9/16 16:03	6063023157	Lead	498	15	ppb
040-158A Sink Faucet in 59 (2)	6/30/16 7:14	7/10/16 14:02	6063023158	Copper	0.1	1.3	ppm
040-158A Sink Faucet in 59 (2)	6/30/16 7:14	7/10/16 14:02	6063023158	Lead	494	15	ppb
040-159A Sink Faucet in 59 (3)	6/30/16 7:16	7/10/16 14:03	6063023159	Copper	0.1	1.3	ppm
040-159A Sink Faucet in 59 (3)	6/30/16 7:16	7/10/16 14:03	6063023159	Lead	49	15	ppb
040-160A Sink Faucet in 59 (4)	6/30/16 7:18	7/10/16 14:03	6063023160	Copper	0.2	1.3	ppm
040-160A Sink Faucet in 59 (4)	6/30/16 7:18	7/11/16 12:23	6063023160	Lead	626	15	ppb
040-161A Sink Faucet in Room 58 (1)	6/30/16 7:20	7/9/16 16:03	6063023161	Copper	0.1	1.3	ppm
040-161A Sink Faucet in Room 58 (1)	6/30/16 7:20	7/9/16 16:03	6063023161	Lead	77	15	ppb
040-162A Sink Faucet in Room 58 (2)	6/30/16 7:22	7/14/16 11:36	6063023162	Copper	0.0	1.3	ppm
040-162A Sink Faucet in Room 58 (2)	6/30/16 7:22	7/14/16 11:36	6063023162	Lead	43	15	ppb
040-163A Sink Faucet in Room 51 (1)	6/30/16 6:30	7/9/16 16:03	6063023163	Copper	0.1	1.3	ppm
040-163A Sink Faucet in Room 51 (1)	6/30/16 6:30	7/9/16 16:03	6063023163	Lead	134	15	ppb
040-164A Sink Faucet in Room 51 (2)	6/30/16 6:32	7/9/16 16:03	6063023164	Copper	0.1	1.3	ppm
040-164A Sink Faucet in Room 51 (2)	6/30/16 6:32	7/9/16 16:03	6063023164	Lead	95	15	ppb
040-165A Sink Faucet in Room 51 (3)	6/30/16 6:34	7/9/16 16:24	6063023165	Copper	0.1	1.3	ppm
040-165A Sink Faucet in Room 51 (3)	6/30/16 6:34	7/9/16 16:24	6063023165	Lead	93	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Grant High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
040-166A Sink Faucet in Room 51 (4)	6/30/16 6:20	7/9/16 16:24	6063023166	Copper	0.1	1.3	ppm
040-166A Sink Faucet in Room 51 (4)	6/30/16 6:20	7/9/16 16:24	6063023166	Lead	125	15	ppb
040-167A Sink Faucet in Room 51 (5)	6/30/16 6:22	7/9/16 16:20	6063023167	Copper	0.1	1.3	ppm
040-167A Sink Faucet in Room 51 (5)	6/30/16 6:22	7/9/16 16:20	6063023167	Lead	120	15	ppb
040-168A Sink Faucet in Room 51 (6)	6/30/16 6:24	7/9/16 16:20	6063023168	Copper	0.1	1.3	ppm
040-168A Sink Faucet in Room 51 (6)	6/30/16 6:24	7/9/16 16:20	6063023168	Lead	122	15	ppb
040-169A Sink Faucet in Room 52 (1)	6/30/16 6:30	7/10/16 14:04	6063023169	Copper	0.0	1.3	ppm
040-169A Sink Faucet in Room 52 (1)	6/30/16 6:30	7/10/16 14:04	6063023169	Lead	27	15	ppb
040-170A Sink Faucet in Room 52 (2)	6/30/16 6:32	7/10/16 14:04	6063023170	Copper	0.1	1.3	ppm
040-170A Sink Faucet in Room 52 (2)	6/30/16 6:32	7/10/16 14:04	6063023170	Lead	77	15	ppb
040-171A Sink Faucet in Room 52 (3)	6/30/16 6:34	7/10/16 14:04	6063023171	Copper	0.0	1.3	ppm
040-171A Sink Faucet in Room 52 (3)	6/30/16 6:34	7/10/16 14:04	6063023171	Lead	48	15	ppb
040-172A Sink Faucet in Room 52 (4)	6/30/16 6:36	7/10/16 14:04	6063023172	Copper	0.0	1.3	ppm
040-172A Sink Faucet in Room 52 (4)	6/30/16 6:36	7/10/16 14:04	6063023172	Lead	40	15	ppb
040-173A Sink Faucet in Room 52 (5)	6/30/16 6:38	7/10/16 14:05	6063023173	Copper	0.0	1.3	ppm
040-173A Sink Faucet in Room 52 (5)	6/30/16 6:38	7/10/16 14:05	6063023173	Lead	9	15	ppb
040-174A Sink Faucet in Room 52 (6)	6/30/16 6:40	7/10/16 14:05	6063023174	Copper	0.1	1.3	ppm
040-174A Sink Faucet in Room 52 (6)	6/30/16 6:40	7/10/16 14:05	6063023174	Lead	25	15	ppb
040-175A Sink Faucet in between Room 52 & 53	6/30/16 6:42	7/10/16 14:05	6063023175	Copper	0.0	1.3	ppm
040-175A Sink Faucet in between Room 52 & 53	6/30/16 6:42	7/10/16 14:05	6063023175	Lead	41	15	ppb
040-176A Drinking Fountain in Room 53	6/30/16 6:44	7/10/16 14:05	6063023176	Copper	0.0	1.3	ppm
040-176A Drinking Fountain in Room 53	6/30/16 6:44	7/10/16 14:05	6063023176	Lead	11	15	ppb
040-177A Sink Faucet in Room 53 (1)	6/30/16 6:46	7/10/16 14:05	6063023177	Copper	0.0	1.3	ppm
040-177A Sink Faucet in Room 53 (1)	6/30/16 6:46	7/10/16 14:05	6063023177	Lead	25	15	ppb
040-178A Sink Faucet in Room 53 (2)	6/30/16 6:48	7/10/16 14:05	6063023178	Copper	0.0	1.3	ppm
040-178A Sink Faucet in Room 53 (2)	6/30/16 6:48	7/10/16 14:05	6063023178	Lead	14.5	15	ppb
040-179A Sink Faucet in Room 53 (3)	6/30/16 6:50	7/10/16 14:05	6063023179	Copper	0.0	1.3	ppm
040-179A Sink Faucet in Room 53 (3)	6/30/16 6:50	7/10/16 14:05	6063023179	Lead	20	15	ppb
040-180A Sink Faucet in Room 53 (4)	6/30/16 6:52	7/10/16 14:05	6063023180	Copper	0.0	1.3	ppm
040-180A Sink Faucet in Room 53 (4)	6/30/16 6:52	7/10/16 14:05	6063023180	Lead	21	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Grant High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
040-181A Sink Faucet in Room 53 (5)	6/30/16 6:54	7/10/16 14:05	6063023181	Copper	0.0	1.3	ppm
040-181A Sink Faucet in Room 53 (5)	6/30/16 6:54	7/10/16 14:05	6063023181	Lead	22	15	ppb
040-182A Sink Faucet in Room 53 (6)	6/30/16 6:56	7/10/16 14:06	6063023182	Copper	0.0	1.3	ppm
040-182A Sink Faucet in Room 53 (6)	6/30/16 6:56	7/10/16 14:06	6063023182	Lead	41	15	ppb
040-183A Sink Faucet in Room 54 (1)	6/30/16 6:58	7/10/16 14:06	6063023183	Copper	0.1	1.3	ppm
040-183A Sink Faucet in Room 54 (1)	6/30/16 6:58	7/10/16 14:06	6063023183	Lead	95	15	ppb
040-184A Sink Faucet in Room 54 (2)	6/30/16 7:00	7/10/16 14:06	6063023184	Copper	0.0	1.3	ppm
040-184A Sink Faucet in Room 54 (2)	6/30/16 7:00	7/10/16 14:06	6063023184	Lead	10	15	ppb
040-185A Sink Faucet in Room 54 (3)	6/30/16 7:02	7/10/16 14:06	6063023185	Copper	0.0	1.3	ppm
040-185A Sink Faucet in Room 54 (3)	6/30/16 7:02	7/10/16 14:06	6063023185	Lead	35	15	ppb
040-186A Sink Faucet in Room 54 (4)	6/30/16 7:04	7/10/16 14:06	6063023186	Copper	0.0	1.3	ppm
040-186A Sink Faucet in Room 54 (4)	6/30/16 7:04	7/10/16 14:06	6063023186	Lead	46	15	ppb
040-187A Sink Faucet in Room 54 (5)	6/30/16 7:06	7/10/16 14:06	6063023187	Copper	0.0	1.3	ppm
040-187A Sink Faucet in Room 54 (5)	6/30/16 7:06	7/10/16 14:06	6063023187	Lead	1	15	ppb
040-188A Sink Faucet in Room 54 (6)	6/30/16 6:48	7/10/16 14:06	6063023188	Copper	0.0	1.3	ppm
040-188A Sink Faucet in Room 54 (6)	6/30/16 6:48	7/10/16 14:06	6063023188	Lead	21	15	ppb
040-189A Sink Faucet in Room 55 (1)	6/30/16 6:51	7/10/16 14:06	6063023189	Copper	0.0	1.3	ppm
040-189A Sink Faucet in Room 55 (1)	6/30/16 6:51	7/10/16 14:06	6063023189	Lead	20	15	ppb
040-190A Sink Faucet in Room 55 (2)	6/30/16 6:53	7/10/16 14:06	6063023190	Copper	0.2	1.3	ppm
040-190A Sink Faucet in Room 55 (2)	6/30/16 6:53	7/10/16 14:06	6063023190	Lead	14	15	ppb
040-191A Sink Faucet in Room 55 (3)	6/30/16 6:55	7/10/16 14:06	6063023191	Copper	0.0	1.3	ppm
040-191A Sink Faucet in Room 55 (3)	6/30/16 6:55	7/10/16 14:06	6063023191	Lead	19	15	ppb
040-192A Sink Faucet in Room 55 (4)	6/30/16 6:57	7/11/16 12:12	6063023192	Copper	0.2	1.3	ppm
040-192A Sink Faucet in Room 55 (4)	6/30/16 6:57	7/11/16 12:12	6063023192	Lead	16	15	ppb
040-193A Drinking Fountain in Room 55	6/30/16 6:59	7/11/16 12:12	6063023193	Copper	0.0	1.3	ppm
040-193A Drinking Fountain in Room 55	6/30/16 6:59	7/11/16 12:12	6063023193	Lead	6	15	ppb
040-194A Drinking Fountain in Weight Room	6/30/16 8:20	7/11/16 12:12	6063023194	Copper	0.0	1.3	ppm
040-194A Drinking Fountain in Weight Room	6/30/16 8:20	7/11/16 12:12	6063023194	Lead	0	15	ppb
040-195A Sink Faucet in Weight Room	6/30/16 8:22	7/11/16 12:12	6063023195	Copper	0.2	1.3	ppm
040-195A Sink Faucet in Weight Room	6/30/16 8:22	7/11/16 12:12	6063023195	Lead	3	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Grant High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
040-196A Sink Faucet in Girls Restroom of Weight Room	6/30/16 8:24	7/11/16 12:12	6063023196	Copper	0.1	1.3	ppm
040-196A Sink Faucet in Girls Restroom of Weight Room	6/30/16 8:24	7/11/16 12:12	6063023196	Lead	1	15	ppb
040-197A Sink Faucet in Mens Restroom of Weight Room	6/30/16 8:26	7/11/16 12:12	6063023197	Copper	0.6	1.3	ppm
040-197A Sink Faucet in Mens Restroom of Weight Room	6/30/16 8:26	7/11/16 12:12	6063023197	Lead	17	15	ppb
040-198A Sink Faucet in Janitors Closet	6/30/16 8:28	7/9/16 16:24	6063023198	Copper	0.3	1.3	ppm
040-198A Sink Faucet in Janitors Closet	6/30/16 8:28	7/9/16 16:24	6063023198	Lead	170	15	ppb
040-199A Spigot in Janitors Closet of Weight Room	6/30/16 9:30	7/11/16 12:12	6063023199	Copper	0.0	1.3	ppm
040-199A Spigot in Janitors Closet of Weight Room	6/30/16 9:30	7/11/16 12:12	6063023199	Lead	2	15	ppb
040-200A Eye Wash Station in Janitor Closet Weight	6/30/16 9:32	7/11/16 12:12	6063023200	Copper	0.4	1.3	ppm
040-200A Eye Wash Station in Janitor Closet Weight	6/30/16 9:32	7/11/16 12:12	6063023200	Lead	597	15	ppb
040-201A Janitor Closet Sink Faucet	6/30/16 9:34	7/11/16 12:12	6063023201	Copper	0.0	1.3	ppm
040-201A Janitor Closet Sink Faucet	6/30/16 9:34	7/11/16 12:12	6063023201	Lead	1	15	ppb
040-202A Shower Head in Boys Locker Room #1	6/30/16 8:34	7/11/16 12:12	6063023202	Copper	1.5	1.3	ppm
040-202A Shower Head in Boys Locker Room #1	6/30/16 8:34	7/11/16 12:12	6063023202	Lead	20	15	ppb
040-203A Shower Head in Boys Locker Room #2	6/30/16 8:36	7/11/16 12:13	6063023203	Copper	1.1	1.3	ppm
040-203A Shower Head in Boys Locker Room #2	6/30/16 8:36	7/11/16 12:13	6063023203	Lead	26	15	ppb
040-204A Shower Head in Boys Locker Room #3	6/30/16 8:38	7/11/16 12:13	6063023204	Copper	0.7	1.3	ppm
040-204A Shower Head in Boys Locker Room #3	6/30/16 8:38	7/11/16 12:13	6063023204	Lead	54	15	ppb
040-205A Shower Head in Boys Locker Room #4	6/30/16 8:40	7/11/16 12:13	6063023205	Copper	1.2	1.3	ppm
040-205A Shower Head in Boys Locker Room #4	6/30/16 8:40	7/11/16 12:13	6063023205	Lead	90	15	ppb
040-206A Shower Head in Boys Locker Room #5	6/30/16 8:42	7/11/16 12:13	6063023206	Copper	1.2	1.3	ppm
040-206A Shower Head in Boys Locker Room #5	6/30/16 8:42	7/11/16 12:13	6063023206	Lead	78	15	ppb
040-207A Shower Head in Boys Locker Room #6	6/30/16 8:44	7/11/16 12:13	6063023207	Copper	1.2	1.3	ppm
040-207A Shower Head in Boys Locker Room #6	6/30/16 8:44	7/11/16 12:13	6063023207	Lead	97	15	ppb
040-208A Shower Head in Boys Locker Room #7	6/30/16 8:46	7/11/16 12:13	6063023208	Copper	0.8	1.3	ppm
040-208A Shower Head in Boys Locker Room #7	6/30/16 8:46	7/11/16 12:13	6063023208	Lead	75	15	ppb
040-209A Shower Head in Boys Locker Room #8	6/30/16 8:49	7/11/16 12:13	6063023209	Copper	1.2	1.3	ppm
040-209A Shower Head in Boys Locker Room #8	6/30/16 8:49	7/11/16 12:13	6063023209	Lead	73	15	ppb
040-210A Shower Head in Boys Locker Room below New Gym #1	6/30/16 8:20	7/11/16 12:13	6063023210	Copper	1.6	1.3	ppm
040-210A Shower Head in Boys Locker Room below New Gym #1	6/30/16 8:20	7/11/16 12:13	6063023210	Lead	93	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Grant High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
040-211A Shower Head in Boys Locker Room below New Gym #2	6/30/16 8:22	7/11/16 12:13	6063023211	Copper	1.4	1.3	ppm
040-211A Shower Head in Boys Locker Room below New Gym #2	6/30/16 8:22	7/11/16 12:13	6063023211	Lead	61	15	ppb
040-212A Shower Head in Boys Locker Room below New Gym #3	6/30/16 8:24	7/11/16 12:13	6063023212	Copper	1.6	1.3	ppm
040-212A Shower Head in Boys Locker Room below New Gym #3	6/30/16 8:24	7/11/16 12:13	6063023212	Lead	106	15	ppb
040-213A Shower Head in Boys Locker Room below New Gym #4	6/30/16 8:26	7/11/16 12:14	6063023213	Copper	1.8	1.3	ppm
040-213A Shower Head in Boys Locker Room below New Gym #4	6/30/16 8:26	7/11/16 12:14	6063023213	Lead	109	15	ppb
040-214A Shower Head in Boys Locker Room below New Gym #5	6/30/16 8:28	7/11/16 12:14	6063023214	Copper	1.4	1.3	ppm
040-214A Shower Head in Boys Locker Room below New Gym #5	6/30/16 8:28	7/11/16 12:14	6063023214	Lead	129	15	ppb
040-215A Shower Head in Boys Locker Room below New Gym #6	6/30/16 8:30	7/11/16 12:14	6063023215	Copper	1.8	1.3	ppm
040-215A Shower Head in Boys Locker Room below New Gym #6	6/30/16 8:30	7/11/16 12:14	6063023215	Lead	143	15	ppb
040-216A Shower Head in Boys Locker Room below New Gym #7	6/30/16 8:32	7/11/16 12:14	6063023216	Copper	1.4	1.3	ppm
040-216A Shower Head in Boys Locker Room below New Gym #7	6/30/16 8:32	7/11/16 12:14	6063023216	Lead	75	15	ppb
040-217A Shower Head in Boys Locker Room below New Gym #8	6/30/16 8:34	7/11/16 12:14	6063023217	Copper	1.6	1.3	ppm
040-217A Shower Head in Boys Locker Room below New Gym #8	6/30/16 8:34	7/11/16 12:14	6063023217	Lead	101	15	ppb
040-218A Shower Head in Boys Locker Room below New Gym #9	6/30/16 8:36	7/11/16 12:14	6063023218	Copper	1.5	1.3	ppm
040-218A Shower Head in Boys Locker Room below New Gym #9	6/30/16 8:36	7/11/16 12:14	6063023218	Lead	135	15	ppb
040-219A Shower Head in Boys Locker Room below New Gym #10	6/30/16 8:38	7/11/16 12:14	6063023219	Copper	1.5	1.3	ppm
040-219A Shower Head in Boys Locker Room below New Gym #10	6/30/16 8:38	7/11/16 12:14	6063023219	Lead	134	15	ppb
040-220A Shower Head in Boys Locker Room below New Gym #11	6/30/16 8:40	7/11/16 12:14	6063023220	Copper	1.6	1.3	ppm
040-220A Shower Head in Boys Locker Room below New Gym #11	6/30/16 8:40	7/11/16 12:14	6063023220	Lead	80	15	ppb
040-221A Hand Wash Sink Faucet in Boys Locker Room	6/30/16 8:23	7/11/16 12:14	6063023221	Copper	0.4	1.3	ppm
040-221A Hand Wash Sink Faucet in Boys Locker Room	6/30/16 8:23	7/11/16 12:14	6063023221	Lead	2	15	ppb
040-222A Spigot in Boys Locker Room Bathroom	6/30/16 8:25	7/11/16 12:14	6063023222	Copper	0.8	1.3	ppm
040-222A Spigot in Boys Locker Room Bathroom	6/30/16 8:25	7/11/16 12:14	6063023222	Lead	23	15	ppb
040-223A Drinking Fountain in Boys Locker Room	6/30/16 8:44	7/11/16 12:14	6063023223	Copper	0.1	1.3	ppm
040-223A Drinking Fountain in Boys Locker Room	6/30/16 8:44	7/11/16 12:14	6063023223	Lead	1	15	ppb
040-224A Sink Faucet in Coaches Locker Room in Boys Locker Room	6/30/16 8:58	7/11/16 12:14	6063023224	Copper	0.0	1.3	ppm
040-224A Sink Faucet in Coaches Locker Room in Boys Locker Room	6/30/16 8:58	7/11/16 12:14	6063023224	Lead	6	15	ppb
040-225A Shower Head in Coaches Locker Room of Boys Locker Room	6/30/16 9:00	7/11/16 12:14	6063023225	Copper	0.1	1.3	ppm
040-225A Shower Head in Coaches Locker Room of Boys Locker Room	6/30/16 9:00	7/11/16 12:14	6063023225	Lead	1	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Grant High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
040-226A Drinking Fountain in Gym #1	6/30/16 9:17	7/11/16 12:14	6063023226	Copper	0.2	1.3	ppm
040-226A Drinking Fountain in Gym #1	6/30/16 9:17	7/11/16 12:14	6063023226	Lead	0	15	ppb
040-227A Drinking Fountain in Gym #2	6/30/16 9:19	7/11/16 12:14	6063023227	Copper	0.3	1.3	ppm
040-227A Drinking Fountain in Gym #2	6/30/16 9:19	7/11/16 12:14	6063023227	Lead	1	15	ppb
040-228A Sink Faucet in Janitors Closet of Gym	6/30/16 9:21	7/11/16 12:14	6063023228	Copper	0.1	1.3	ppm
040-228A Sink Faucet in Janitors Closet of Gym	6/30/16 9:21	7/11/16 12:14	6063023228	Lead	1	15	ppb
040-229A Mens Restroom in Gym	6/30/16 9:27	7/11/16 12:14	6063023229	Copper	0.1	1.3	ppm
040-229A Mens Restroom in Gym	6/30/16 9:27	7/11/16 12:14	6063023229	Lead	40	15	ppb
040-230A Sink Faucet in between W&M Restroom in Gym	6/30/16 9:29	7/11/16 12:14	6063023230	Copper	0.1	1.3	ppm
040-230A Sink Faucet in between W&M Restroom in Gym	6/30/16 9:29	7/11/16 12:14	6063023230	Lead	106	15	ppb
040-231A Drinking Fountain in Bathrooms of Gym	6/30/16 9:31	7/11/16 12:14	6063023231	Copper	0.1	1.3	ppm
040-231A Drinking Fountain in Bathrooms of Gym	6/30/16 9:31	7/11/16 12:14	6063023231	Lead	3	15	ppb
040-232A Sink Faucet in Womens Restroom of Gym	6/30/16 9:30	7/11/16 12:14	6063023232	Copper	0.1	1.3	ppm
040-232A Sink Faucet in Womens Restroom of Gym	6/30/16 9:30	7/11/16 12:14	6063023232	Lead	7	15	ppb
040-233A Sink Faucet Dance Room/Multi Purpose Room under Gym	6/30/16 9:28	7/9/16 16:24	6063023233	Copper	0.1	1.3	ppm
040-233A Sink Faucet Dance Room/Multi Purpose Room under Gym	6/30/16 9:28	7/9/16 16:24	6063023233	Lead	29	15	ppb
040-234A Ice Machine inside First Aid Room of Old Gym	6/30/16 9:34	7/11/16 12:16	6063023234	Copper	0.0	1.3	ppm
040-234A Ice Machine inside First Aid Room of Old Gym	6/30/16 9:34	7/11/16 12:16	6063023234	Lead	0	15	ppb
040-235A Ice Bathroom Sink Faucet in First Aid Room	6/30/16 9:36	7/11/16 12:16	6063023235	Copper	0.0	1.3	ppm
040-235A Ice Bathroom Sink Faucet in First Aid Room	6/30/16 9:36	7/11/16 12:16	6063023235	Lead	2	15	ppb
040-236A Sink Faucet in Coaches Office	6/30/16 9:50	7/11/16 12:16	6063023236	Copper	0.1	1.3	ppm
040-236A Sink Faucet in Coaches Office	6/30/16 9:50	7/11/16 12:16	6063023236	Lead	12	15	ppb
040-237A Drinking Fountain by Womens Coach's Office	6/30/16 9:52	7/11/16 12:16	6063023237	Copper	0.6	1.3	ppm
040-237A Drinking Fountain by Womens Coach's Office	6/30/16 9:52	7/11/16 12:16	6063023237	Lead	1	15	ppb
040-238A Sink Faucet by Womens Coach's Office	6/30/16 9:54	7/11/16 12:16	6063023238	Copper	0.0	1.3	ppm
040-238A Sink Faucet by Womens Coach's Office	6/30/16 9:54	7/11/16 12:16	6063023238	Lead	6	15	ppb
040-239A Shower Head in Womens Coach's Office	6/30/16 9:56	7/11/16 12:16	6063023239	Copper	0.3	1.3	ppm
040-239A Shower Head in Womens Coach's Office	6/30/16 9:56	7/11/16 12:16	6063023239	Lead	33	15	ppb
040-240A Sink Faucet in Womens Locker Room Old Gym #1	6/30/16 10:02	7/11/16 12:16	6063023240	Copper	0.1	1.3	ppm
040-240A Sink Faucet in Womens Locker Room Old Gym #1	6/30/16 10:02	7/11/16 12:16	6063023240	Lead	14	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Grant High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
040-241A Sink Faucet in Womens Locker Room Old Gym #2	6/30/16 10:00	7/11/16 12:16	6063023241	Copper	0.1	1.3	ppm
040-241A Sink Faucet in Womens Locker Room Old Gym #2	6/30/16 10:00	7/11/16 12:16	6063023241	Lead	5	15	ppb
040-242A Janitor Closet Sink Faucet in Womens Locker Room	6/30/16 9:58	7/11/16 12:16	6063023242	Copper	0.0	1.3	ppm
040-242A Janitor Closet Sink Faucet in Womens Locker Room	6/30/16 9:58	7/11/16 12:16	6063023242	Lead	1	15	ppb
040-243A Shower Head in Womens Locker Room #1	6/30/16 10:04	7/11/16 12:16	6063023243	Copper	0.2	1.3	ppm
040-243A Shower Head in Womens Locker Room #1	6/30/16 10:04	7/11/16 12:16	6063023243	Lead	5	15	ppb
040-244A Shower Head in Womens Locker Room #2	6/30/16 10:06	7/11/16 12:18	6063023244	Copper	0.2	1.3	ppm
040-244A Shower Head in Womens Locker Room #2	6/30/16 10:06	7/11/16 12:18	6063023244	Lead	2	15	ppb
040-245A Shower Head in Womens Locker Room #3	6/30/16 10:08	7/11/16 12:18	6063023245	Copper	0.4	1.3	ppm
040-245A Shower Head in Womens Locker Room #3	6/30/16 10:08	7/11/16 12:18	6063023245	Lead	26	15	ppb
040-246A Shower Head in Womens Locker Room #4	6/30/16 10:10	7/11/16 12:18	6063023246	Copper	0.4	1.3	ppm
040-246A Shower Head in Womens Locker Room #4	6/30/16 10:10	7/11/16 12:18	6063023246	Lead	21	15	ppb
040-248A Shower Head in Womens Locker Room #5	6/30/16 10:14	7/11/16 12:18	6063023248	Copper	1.3	1.3	ppm
040-248A Shower Head in Womens Locker Room #5	6/30/16 10:14	7/11/16 12:18	6063023248	Lead	171	15	ppb
040-249A Shower Head in Womens Locker Room #6	6/30/16 10:16	7/11/16 12:18	6063023249	Copper	1.3	1.3	ppm
040-249A Shower Head in Womens Locker Room #6	6/30/16 10:16	7/11/16 12:18	6063023249	Lead	337	15	ppb
040-250A Shower Head in Womens Locker Room #7	6/30/16 10:18	7/11/16 12:18	6063023250	Copper	0.4	1.3	ppm
040-250A Shower Head in Womens Locker Room #7	6/30/16 10:18	7/11/16 12:18	6063023250	Lead	105	15	ppb
040-251A Shower Head in Womens Locker Room #8	6/30/16 10:20	7/11/16 12:18	6063023251	Copper	0.5	1.3	ppm
040-251A Shower Head in Womens Locker Room #8	6/30/16 10:20	7/11/16 12:18	6063023251	Lead	83	15	ppb
040-252A Shower Head in Womens Locker Room #9	6/30/16 10:22	7/11/16 12:18	6063023252	Copper	0.5	1.3	ppm
040-252A Shower Head in Womens Locker Room #9	6/30/16 10:22	7/11/16 12:18	6063023252	Lead	105	15	ppb
040-253A Shower Head in Womens Locker Room #10	6/30/16 10:24	7/11/16 12:18	6063023253	Copper	0.5	1.3	ppm
040-253A Shower Head in Womens Locker Room #10	6/30/16 10:24	7/11/16 12:18	6063023253	Lead	70	15	ppb
040-254A Shower Head in Womens Locker Room #11	6/30/16 10:26	7/11/16 12:18	6063023254	Copper	0.5	1.3	ppm
040-254A Shower Head in Womens Locker Room #11	6/30/16 10:26	7/11/16 12:18	6063023254	Lead	76	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Grant High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
040-255A Shower Head in Womens Locker Room #12	6/30/16 10:28	7/11/16 12:19	6063023255	Copper	0.5	1.3	ppm
040-255A Shower Head in Womens Locker Room #12	6/30/16 10:28	7/11/16 12:19	6063023255	Lead	63	15	ppb
040-256A Shower Head in Womens Locker Room #13	6/30/16 10:30	7/11/16 12:19	6063023256	Copper	0.5	1.3	ppm
040-256A Shower Head in Womens Locker Room #13	6/30/16 10:30	7/11/16 12:19	6063023256	Lead	72	15	ppb
040-257A Shower Head in Womens Locker Room #14	6/30/16 10:32	7/11/16 12:19	6063023257	Copper	0.5	1.3	ppm
040-257A Shower Head in Womens Locker Room #14	6/30/16 10:32	7/11/16 12:19	6063023257	Lead	57	15	ppb
040-259A Shower Head in Womens Locker Room #15	6/30/16 10:36	7/11/16 12:19	6063023259	Copper	0.5	1.3	ppm
040-259A Shower Head in Womens Locker Room #15	6/30/16 10:36	7/11/16 12:19	6063023259	Lead	52	15	ppb
040-260A Shower Head in Womens Locker Room #16	6/30/16 10:38	7/11/16 12:19	6063023260	Copper	0.5	1.3	ppm
040-260A Shower Head in Womens Locker Room #16	6/30/16 10:38	7/11/16 12:19	6063023260	Lead	52	15	ppb
040-261A Shower Head in Womens Locker Room #17	6/30/16 10:40	7/11/16 12:19	6063023261	Copper	0.0	1.3	ppm
040-261A Shower Head in Womens Locker Room #17	6/30/16 10:40	7/11/16 12:19	6063023261	Lead	1	15	ppb
040-262A Shower Head in Womens Locker Room #18	6/30/16 10:42	7/11/16 12:19	6063023262	Copper	0.1	1.3	ppm
040-262A Shower Head in Womens Locker Room #18	6/30/16 10:42	7/11/16 12:19	6063023262	Lead	6	15	ppb
040-263A Shower Head in Womens Locker Room #19	6/30/16 10:44	7/11/16 12:19	6063023263	Copper	0.0	1.3	ppm
040-263A Shower Head in Womens Locker Room #19	6/30/16 10:44	7/11/16 12:19	6063023263	Lead	1	15	ppb
040-264A Shower Head in Womens Locker Room #20	6/30/16 10:46	7/11/16 12:19	6063023264	Copper	0.0	1.3	ppm
040-264A Shower Head in Womens Locker Room #20	6/30/16 10:46	7/11/16 12:19	6063023264	Lead	1	15	ppb
040-265A Shower Head in Womens Locker Room #21	6/30/16 9:55	7/11/16 12:19	6063023265	Copper	1.4	1.3	ppm
040-265A Shower Head in Womens Locker Room #21	6/30/16 9:55	7/11/16 12:19	6063023265	Lead	295	15	ppb
040-266A Shower Head in Womens Locker Room #22	6/30/16 9:57	7/11/16 12:19	6063023266	Copper	1.0	1.3	ppm
040-266A Shower Head in Womens Locker Room #22	6/30/16 9:57	7/11/16 12:19	6063023266	Lead	213	15	ppb
040-267A Shower Head in Womens Locker Room #23	6/30/16 9:59	7/11/16 12:19	6063023267	Copper	1.0	1.3	ppm
040-267A Shower Head in Womens Locker Room #23	6/30/16 9:59	7/11/16 12:19	6063023267	Lead	155	15	ppb
040-268A Sink Faucet in Janitors Closet Womens Locker Room	6/30/16 10:02	7/9/16 16:24	6063023268	Copper	4.3	1.3	ppm
040-268A Sink Faucet in Janitors Closet Womens Locker Room	6/30/16 10:02	7/9/16 16:24	6063023268	Lead	143	15	ppb
040-269A Drinking Fountain in other side of Womens Locker Room	6/30/16 9:49	7/11/16 12:19	6063023269	Copper	0.0	1.3	ppm
040-269A Drinking Fountain in other side of Womens Locker Room	6/30/16 9:49	7/11/16 12:19	6063023269	Lead	16	15	ppb
040-270A Spigot outside New Gym by Main Entrance	6/30/16 10:22	7/11/16 12:19	6063023270	Copper	0.0	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Grant High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
040-270A Spigot outside New Gym by Main Entrance	6/30/16 10:22	7/11/16 12:19	6063023270	Lead	1	15	ppb
040-271A Spigot outside Weight Room	6/30/16 10:20	7/11/16 12:19	6063023271	Copper	0.1	1.3	ppm
040-271A Spigot outside Weight Room	6/30/16 10:20	7/11/16 12:19	6063023271	Lead	49	15	ppb
040-272A Spigot outside South Side Gym #1	6/30/16 10:23	7/11/16 12:19	6063023272	Copper	0.1	1.3	ppm
040-272A Spigot outside South Side Gym #1	6/30/16 10:23	7/11/16 12:19	6063023272	Lead	7	15	ppb
040-273A Spigot outside South Side Gym #2	6/30/16 10:26	7/11/16 12:20	6063023273	Copper	0.1	1.3	ppm
040-273A Spigot outside South Side Gym #2	6/30/16 10:26	7/11/16 12:20	6063023273	Lead	52	15	ppb
040-274A Spigot outside South Side Gym #3	6/30/16 10:28	7/11/16 12:20	6063023274	Copper	0.1	1.3	ppm
040-274A Spigot outside South Side Gym #3	6/30/16 10:28	7/11/16 12:20	6063023274	Lead	5	15	ppb
040-275A Spigot outside East Side Old Gym	6/30/16 10:30	7/11/16 12:20	6063023275	Copper	0.0	1.3	ppm
040-275A Spigot outside East Side Old Gym	6/30/16 10:30	7/11/16 12:20	6063023275	Lead	18	15	ppb
040-276A Spigot outside S3	6/30/16 10:45	7/11/16 12:20	6063023276	Copper	0.2	1.3	ppm
040-276A Spigot outside S3	6/30/16 10:45	7/11/16 12:20	6063023276	Lead	73	15	ppb
040-277A Spigot outside S1	6/30/16 10:48	7/11/16 12:20	6063023277	Copper	0.1	1.3	ppm
040-277A Spigot outside S1	6/30/16 10:48	7/11/16 12:20	6063023277	Lead	20	15	ppb
040-278A Spigot outside S7	6/30/16 10:51	7/9/16 16:24	6063023278	Copper	0.0	1.3	ppm
040-278A Spigot outside S7	6/30/16 10:51	7/9/16 16:24	6063023278	Lead	17	15	ppb
040-279A Spigot outside S6	6/30/16 10:54	7/11/16 12:20	6063023279	Copper	0.1	1.3	ppm
040-279A Spigot outside S6	6/30/16 10:54	7/11/16 12:20	6063023279	Lead	7	15	ppb
040-280A Spigot outside S5156	6/30/16 10:57	7/11/16 12:20	6063023280	Copper	0.0	1.3	ppm
040-280A Spigot outside S5156	6/30/16 10:57	7/11/16 12:20	6063023280	Lead	15.2	15	ppb
040-281A Spigot outside Office	6/30/16 11:00	7/11/16 12:20	6063023281	Copper	0.0	1.3	ppm
040-281A Spigot outside Office	6/30/16 11:00	7/11/16 12:20	6063023281	Lead	28	15	ppb
040-282A Spigot outside Southern Wall of Weight Room	6/30/16 11:03	7/11/16 12:20	6063023282	Copper	0.0	1.3	ppm
040-282A Spigot outside Southern Wall of Weight Room	6/30/16 11:03	7/11/16 12:20	6063023282	Lead	17	15	ppb
040-283A Spigot outside Southeast Doors Main Building	6/30/16 11:06	7/11/16 12:20	6063023283	Copper	0.0	1.3	ppm
040-283A Spigot outside Southeast Doors Main Building	6/30/16 11:06	7/11/16 12:20	6063023283	Lead	10	15	ppb
040-284A Spigot outside Main Entrance #1	6/30/16 11:09	7/11/16 12:20	6063023284	Copper	0.0	1.3	ppm
040-284A Spigot outside Main Entrance #1	6/30/16 11:09	7/11/16 12:20	6063023284	Lead	3	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Grant High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
040-285A Spigot outside Main Entrance #2	6/30/16 11:12	7/11/16 12:20	6063023285	Copper	0.0	1.3	ppm
040-285A Spigot outside Main Entrance #2	6/30/16 11:12	7/11/16 12:20	6063023285	Lead	13	15	ppb
040-286A Spigot outside Room 124	6/30/16 11:15	7/11/16 12:20	6063023286	Copper	0.0	1.3	ppm
040-286A Spigot outside Room 124	6/30/16 11:15	7/11/16 12:20	6063023286	Lead	4	15	ppb
040-287A Spigot by Garden	6/30/16 11:42	7/11/16 12:20	6063023287	Copper	0.0	1.3	ppm
040-287A Spigot by Garden	6/30/16 11:42	7/11/16 12:20	6063023287	Lead	17	15	ppb
040-288A Spigot in Garden #1	6/30/16 11:30	7/11/16 12:21	6063023288	Copper	0.0	1.3	ppm
040-288A Spigot in Garden #1	6/30/16 11:30	7/11/16 12:21	6063023288	Lead	2	15	ppb
040-289A Spigot in Garden #2	6/30/16 11:34	7/11/16 12:21	6063023289	Copper	0.0	1.3	ppm
040-289A Spigot in Garden #2	6/30/16 11:34	7/11/16 12:21	6063023289	Lead	ND	15	ppb
040-290A Spigot in Garden #3	6/30/16 11:36	7/11/16 12:21	6063023290	Copper	0.4	1.3	ppm
040-290A Spigot in Garden #3	6/30/16 11:36	7/11/16 12:21	6063023290	Lead	212	15	ppb
040-291A Spigot in Garden #4	6/30/16 11:39	7/11/16 12:21	6063023291	Copper	0.0	1.3	ppm
040-291A Spigot in Garden #4	6/30/16 11:39	7/11/16 12:21	6063023291	Lead	1	15	ppb
040-292A Spigot in Garden #5	6/30/16 11:28	7/11/16 12:21	6063023292	Copper	0.0	1.3	ppm
040-292A Spigot in Garden #5	6/30/16 11:28	7/11/16 12:21	6063023292	Lead	ND	15	ppb
040-293A Spigot by Room 137	6/30/16 11:20	7/11/16 12:21	6063023293	Copper	0.2	1.3	ppm
040-293A Spigot by Room 137	6/30/16 11:20	7/11/16 12:21	6063023293	Lead	30	15	ppb
040-294A Spigot by Room 143	6/30/16 11:17	7/11/16 12:21	6063023294	Copper	1.0	1.3	ppm
040-294A Spigot by Room 143	6/30/16 11:17	7/11/16 12:21	6063023294	Lead	216	15	ppb
040-295A Spigot by Room 129	6/30/16 11:12	7/11/16 12:21	6063023295	Copper	0.1	1.3	ppm
040-295A Spigot by Room 129	6/30/16 11:12	7/11/16 12:21	6063023295	Lead	18	15	ppb
040-296A Spigot by Auditorium	6/30/16 11:04	7/11/16 12:21	6063023296	Copper	0.0	1.3	ppm
040-296A Spigot by Auditorium	6/30/16 11:04	7/11/16 12:21	6063023296	Lead	7	15	ppb
040-298A Girls Sink Faucet (4) 2nd Floor	6/30/16 5:31	7/11/16 12:21	6063023297	Copper	0.1	1.3	ppm
040-298A Girls Sink Faucet (4) 2nd Floor	6/30/16 5:31	7/11/16 12:21	6063023297	Lead	8	15	ppb
040-299A Girls Sink Faucet (5) 2nd Floor	6/30/16 5:33	7/11/16 12:22	6063023298	Copper	0.2	1.3	ppm
040-299A Girls Sink Faucet (5) 2nd Floor	6/30/16 5:33	7/11/16 12:22	6063023298	Lead	22	15	ppb
040-300A Hall by 230 Drinking Fountain 2nd Floor	6/30/16 5:35	7/11/16 12:22	6063023299	Copper	0.1	1.3	ppm
040-300A Hall by 230 Drinking Fountain 2nd Floor	6/30/16 5:35	7/11/16 12:22	6063023299	Lead	18	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Grant High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
040-301A Hall by 231 Drinking Fountain 2nd Floor	6/30/16 5:37	7/11/16 12:22	6063023300	Copper	0.0	1.3	ppm
040-301A Hall by 231 Drinking Fountain 2nd Floor	6/30/16 5:37	7/11/16 12:22	6063023300	Lead	2	15	ppb
040-302A 237 Sink Faucet 2nd Floor	6/30/16 5:40	7/14/16 9:30	6063023301	Copper	0.9	1.3	ppm
040-302A 237 Sink Faucet 2nd Floor	6/30/16 5:40	7/14/16 11:06	6063023301	Lead	57600	15	ppb
040-A 237 Sink Faucet 2nd Floor - Retest	8/17/16 16:50	9/1/16 10:53	608232001	Copper	0.0	1.3	ppm
040-A 237 Sink Faucet 2nd Floor - Retest	8/17/16 16:50	9/1/16 10:53	608232001	Lead	0	15	ppb
040-303A 235 Sink Faucet (1) 2nd Floor	6/30/16 5:42	7/11/16 12:22	6063023302	Copper	0.1	1.3	ppm
040-303A 235 Sink Faucet (1) 2nd Floor	6/30/16 5:42	7/11/16 12:22	6063023302	Lead	8	15	ppb
040-304A 235 Sink Faucet (2) 2nd Floor	6/30/16 5:44	7/11/16 12:22	6063023303	Copper	0.0	1.3	ppm
040-304A 235 Sink Faucet (2) 2nd Floor	6/30/16 5:44	7/11/16 12:22	6063023303	Lead	11	15	ppb
040-305A 235 Sink Faucet (3) 2nd Floor	6/30/16 5:46	7/11/16 12:22	6063023304	Copper	0.3	1.3	ppm
040-305A 235 Sink Faucet (3) 2nd Floor	6/30/16 5:46	7/11/16 12:22	6063023304	Lead	68	15	ppb
040-306A Room 239 Lab Part Sink Faucet 2nd Floor	6/30/16 5:49	7/11/16 12:22	6063023305	Copper	0.0	1.3	ppm
040-306A Room 239 Lab Part Sink Faucet 2nd Floor	6/30/16 5:49	7/11/16 12:22	6063023305	Lead	5	15	ppb
040-307A Room 239 Sink Faucet (1) 2nd Floor	6/30/16 5:51	7/11/16 12:22	6063023306	Copper	0.5	1.3	ppm
040-307A Room 239 Sink Faucet (1) 2nd Floor	6/30/16 5:51	7/11/16 12:22	6063023306	Lead	74	15	ppb
040-308A Room 239 Sink Faucet (2) 2nd Floor	6/30/16 5:53	7/11/16 12:22	6063023307	Copper	0.4	1.3	ppm
040-308A Room 239 Sink Faucet (2) 2nd Floor	6/30/16 5:53	7/11/16 12:22	6063023307	Lead	14	15	ppb
040-309A Room 239 Sink Faucet (3) 2nd Floor	6/30/16 5:35	7/11/16 12:22	6063023308	Copper	0.4	1.3	ppm
040-309A Room 239 Sink Faucet (3) 2nd Floor	6/30/16 5:35	7/11/16 12:22	6063023308	Lead	36	15	ppb
040-310A Room 239 Sink Faucet (4) 2nd Floor	6/30/16 5:37	7/11/16 12:22	6063023309	Copper	0.2	1.3	ppm
040-310A Room 239 Sink Faucet (4) 2nd Floor	6/30/16 5:37	7/11/16 12:22	6063023309	Lead	39	15	ppb
040-311A Room 241 Sink Faucet 2nd Floor	6/30/16 5:38	7/11/16 12:22	6063023310	Copper	0.1	1.3	ppm
040-311A Room 241 Sink Faucet 2nd Floor	6/30/16 5:38	7/11/16 12:22	6063023310	Lead	4	15	ppb
040-312A Room between 241 & 245 Sink Faucet 2nd Floor	6/30/16 5:42	7/11/16 12:22	6063023311	Copper	0.1	1.3	ppm
040-312A Room between 241 & 245 Sink Faucet 2nd Floor	6/30/16 5:42	7/11/16 12:22	6063023311	Lead	10	15	ppb
040-313A Room 245 Sink Faucet 2nd Floor	6/30/16 5:45	7/11/16 12:22	6063023312	Copper	0.0	1.3	ppm
040-313A Room 245 Sink Faucet 2nd Floor	6/30/16 5:45	7/11/16 12:22	6063023312	Lead	2	15	ppb
040-314A Room 243 Sink Faucet (1) 2nd Floor	6/30/16 5:50	7/11/16 12:22	6063023313	Copper	0.4	1.3	ppm
040-314A Room 243 Sink Faucet (1) 2nd Floor	6/30/16 5:50	7/11/16 12:22	6063023313	Lead	10	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Grant High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
040-315A Room 243 Sink Faucet (2) 2nd Floor	6/30/16 5:52	7/11/16 12:22	6063023314	Copper	0.5	1.3	ppm
040-315A Room 243 Sink Faucet (2) 2nd Floor	6/30/16 5:52	7/11/16 12:22	6063023314	Lead	19	15	ppb
040-316A Room 243 Sink Faucet (3) 2nd Floor	6/30/16 5:55	7/11/16 12:22	6063023315	Copper	0.6	1.3	ppm
040-316A Room 243 Sink Faucet (3) 2nd Floor	6/30/16 5:55	7/11/16 12:22	6063023315	Lead	8	15	ppb
040-317A Room 243 Sink Faucet (4) 2nd Floor	6/30/16 5:57	7/11/16 12:22	6063023316	Copper	0.7	1.3	ppm
040-317A Room 243 Sink Faucet (4) 2nd Floor	6/30/16 5:57	7/11/16 12:22	6063023316	Lead	5	15	ppb
040-318A Janitor's Closet by Chorus Room Sink Faucet 2nd Floor	6/30/16 6:00	7/11/16 12:22	6063023317	Copper	0.1	1.3	ppm
040-318A Janitor's Closet by Chorus Room Sink Faucet 2nd Floor	6/30/16 6:00	7/11/16 12:22	6063023317	Lead	6	15	ppb
040-319A Staff Bathroom by Chorus Room Sink Faucet 2nd Floor	6/30/16 6:03	7/11/16 12:22	6063023318	Copper	0.0	1.3	ppm
040-319A Staff Bathroom by Chorus Room Sink Faucet 2nd Floor	6/30/16 6:03	7/11/16 12:22	6063023318	Lead	1	15	ppb
040-320A Boiler Room Bathroom Sink Faucet Upstairs	6/30/16 12:04	7/11/16 12:22	6063023319	Copper	0.1	1.3	ppm
040-320A Boiler Room Bathroom Sink Faucet Upstairs	6/30/16 12:04	7/11/16 12:22	6063023319	Lead	8	15	ppb
040-321A Boiler Room Sink Faucet	6/30/16 12:12	7/11/16 12:22	6063023320	Copper	0.2	1.3	ppm
040-321A Boiler Room Sink Faucet	6/30/16 12:12	7/11/16 12:22	6063023320	Lead	12	15	ppb
040-322A Boiler Room Spigot on Wall	6/30/16 12:09	7/14/16 9:30	6063023321	Copper	0.3	1.3	ppm
040-322A Boiler Room Spigot on Wall	6/30/16 12:09	7/14/16 11:08	6063023321	Lead	181	15	ppb
040-270-A Old Gym Women Locker Room West Faucet	6/30/16 10:03	7/11/16 12:22	6063023322	Copper	0.4	1.3	ppm
040-270-A Old Gym Women Locker Room West Faucet	6/30/16 10:03	7/11/16 12:22	6063023322	Lead	4	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

ND = Non detect

Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.