

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Robert Gray Middle School

| Sample Identification # and Location                 | Date & Time Collected | Date & Time Analyzed | Container ID | Analyte | Results | EPA Action Limit | Units |
|------------------------------------------------------|-----------------------|----------------------|--------------|---------|---------|------------------|-------|
| 074-01A Boiler Room Shower                           | 6/20/16 8:54          | 7/6/16 9:56          | 606220901    | Copper  | 16.9    | 1.3              | ppm   |
| 074-01A Boiler Room Shower                           | 6/20/16 8:54          | 7/1/16 17:24         | 606220901    | Lead    | 278     | 15               | ppb   |
| 074-02A Boiler Room Sink                             | 6/20/16 8:56          | 7/5/16 14:02         | 606220902    | Copper  | 0.2     | 1.3              | ppm   |
| 074-02A Boiler Room Sink                             | 6/20/16 8:56          | 7/5/16 14:02         | 606220902    | Lead    | 5       | 15               | ppb   |
| 074-03A Drinking Fountain in Gym, Near Boys Bathroom | 6/20/16 8:59          | 7/5/16 14:02         | 606220903    | Copper  | 0.8     | 1.3              | ppm   |
| 074-03A Drinking Fountain in Gym, Near Boys Bathroom | 6/20/16 8:59          | 7/5/16 14:02         | 606220903    | Lead    | 1       | 15               | ppb   |
| 074-04A Drinking Fountain Inside Boys RM129          | 6/20/16 9:04          | 7/5/16 14:03         | 606220904    | Copper  | 1.2     | 1.3              | ppm   |
| 074-04A Drinking Fountain Inside Boys RM129          | 6/20/16 9:04          | 7/5/16 14:03         | 606220904    | Lead    | 21      | 15               | ppb   |
| 074-05A Boys Locker Room Sink Faucet RM129           | 6/20/16 9:06          | 7/5/16 14:03         | 606220905    | Copper  | 0.5     | 1.3              | ppm   |
| 074-05A Boys Locker Room Sink Faucet RM129           | 6/20/16 9:06          | 7/5/16 14:03         | 606220905    | Lead    | 8       | 15               | ppb   |
| 074-06A Girls Locker Room Spigot RM128               | 6/20/16 9:09          | 7/5/16 14:03         | 606220906    | Copper  | 0.2     | 1.3              | ppm   |
| 074-06A Girls Locker Room Spigot RM128               | 6/20/16 9:09          | 7/5/16 14:03         | 606220906    | Lead    | 12      | 15               | ppb   |
| 074-07A Girls Locker Room Sink Faucet RM128          | 6/20/16 9:27          | 7/5/16 14:03         | 606220907    | Copper  | 0.1     | 1.3              | ppm   |
| 074-07A Girls Locker Room Sink Faucet RM128          | 6/20/16 9:27          | 7/5/16 14:03         | 606220907    | Lead    | 9       | 15               | ppb   |
| 074-08A Classroom 125 Sink Faucet                    | 6/20/16 9:42          | 7/5/16 14:03         | 606220908    | Copper  | 1.30    | 1.3              | ppm   |
| 074-08A Classroom 125 Sink Faucet                    | 6/20/16 9:42          | 7/5/16 14:03         | 606220908    | Lead    | 0       | 15               | ppb   |
| 074-09A Boys Bathroom 112E Sink                      | 6/20/16 6:45          | 7/5/16 14:03         | 606220909    | Copper  | 0.2     | 1.3              | ppm   |
| 074-09A Boys Bathroom 112E Sink                      | 6/20/16 6:45          | 7/5/16 14:03         | 606220909    | Lead    | 33      | 15               | ppb   |
| 074-10A Boys Bathroom 112E Sink                      | 6/20/16 9:48          | 7/5/16 14:03         | 606220910    | Copper  | 0.9     | 1.3              | ppm   |
| 074-10A Boys Bathroom 112E Sink                      | 6/20/16 9:48          | 7/5/16 14:03         | 606220910    | Lead    | 20      | 15               | ppb   |
| 074-11A Boys Bathroom 112E Sink                      | 6/20/16 9:52          | 7/5/16 14:03         | 606220911    | Copper  | 0.3     | 1.3              | ppm   |
| 074-11A Boys Bathroom 112E Sink                      | 6/20/16 9:52          | 7/5/16 14:03         | 606220911    | Lead    | 12      | 15               | ppb   |
| 074-12A Boys Bathroom 112E Spigot                    | 6/20/16 9:55          | 7/5/16 14:03         | 606220912    | Copper  | 0.1     | 1.3              | ppm   |
| 074-12A Boys Bathroom 112E Spigot                    | 6/20/16 9:55          | 7/5/16 14:03         | 606220912    | Lead    | 47      | 15               | ppb   |
| 074-13A Custodial Closet 112D Sink                   | 6/20/16 9:58          | 7/5/16 14:03         | 606220913    | Copper  | 0.8     | 1.3              | ppm   |
| 074-13A Custodial Closet 112D Sink                   | 6/20/16 9:58          | 7/5/16 14:03         | 606220913    | Lead    | 2       | 15               | ppb   |
| 074-14A Girls bathroom 112C Sink                     | 6/20/16 10:03         | 7/5/16 14:03         | 606220914    | Copper  | 0.2     | 1.3              | ppm   |
| 074-14A Girls bathroom 112C Sink                     | 6/20/16 10:03         | 7/5/16 14:03         | 606220914    | Lead    | 36      | 15               | ppb   |
| 074-15A Girls Bathroom 112C Sink                     | 6/20/16 10:05         | 7/5/16 14:04         | 606220915    | Copper  | 0.3     | 1.3              | ppm   |
| 074-15A Girls Bathroom 112C Sink                     | 6/20/16 10:05         | 7/5/16 14:04         | 606220915    | Lead    | 20      | 15               | ppb   |
| 074-16A Girls Bathroom 112C Sink                     | 6/20/16 10:09         | 7/5/16 14:04         | 606220916    | Copper  | 0.5     | 1.3              | ppm   |
| 074-16A Girls Bathroom 112C Sink                     | 6/20/16 10:09         | 7/5/16 14:04         | 606220916    | Lead    | 24      | 15               | ppb   |
| 074-17A Girls Bathroom 112C Spigot                   | 6/20/16 10:10         | 7/5/16 14:04         | 606220917    | Copper  | 0.2     | 1.3              | ppm   |
| 074-17A Girls Bathroom 112C Spigot                   | 6/20/16 10:10         | 7/5/16 14:04         | 606220917    | Lead    | 25      | 15               | ppb   |
| 074-18A Classroom 111 Sink Faucet                    | 6/20/16 10:12         | 7/5/16 14:04         | 606220918    | Copper  | 0.9     | 1.3              | ppm   |
| 074-18A Classroom 111 Sink Faucet                    | 6/20/16 10:12         | 7/5/16 14:04         | 606220918    | Lead    | 14      | 15               | ppb   |
| 074-19A Classroom 112 Sink Faucet                    | 6/20/16 10:15         | 7/5/16 14:04         | 606220919    | Copper  | 0.9     | 1.3              | ppm   |
| 074-19A Classroom 112 Sink Faucet                    | 6/20/16 10:15         | 7/5/16 14:04         | 606220919    | Lead    | 5       | 15               | ppb   |
| 074-20A Classroom 112 Boys Bathroom Sink             | 6/20/16 10:19         | 7/5/16 14:04         | 606220920    | Copper  | 0.5     | 1.3              | ppm   |
| 074-20A Classroom 112 Boys Bathroom Sink             | 6/20/16 10:19         | 7/5/16 14:04         | 606220920    | Lead    | 1       | 15               | ppb   |
| 074-21A Classroom 112 Girls Bathroom Sink            | 6/20/16 10:21         | 7/5/16 14:04         | 606220921    | Copper  | 0.4     | 1.3              | ppm   |
| 074-21A Classroom 112 Girls Bathroom Sink            | 6/20/16 10:21         | 7/5/16 14:04         | 606220921    | Lead    | 55      | 15               | ppb   |
| 074-22A Classroom 114 Sink                           | 6/20/16 10:24         | 7/5/16 14:04         | 606220922    | Copper  | 0.9     | 1.3              | ppm   |
| 074-22A Classroom 114 Sink                           | 6/20/16 10:24         | 7/5/16 14:04         | 606220922    | Lead    | 18      | 15               | ppb   |
| 074-23A Classroom 113 Sink                           | 6/20/16 10:26         | 7/5/16 14:04         | 606220923    | Copper  | 0.9     | 1.3              | ppm   |
| 074-23A Classroom 113 Sink                           | 6/20/16 10:26         | 7/5/16 14:04         | 606220923    | Lead    | 23      | 15               | ppb   |
| 074-24A Classroom 115 Sink                           | 6/20/16 10:28         | 7/5/16 14:04         | 606220924    | Copper  | 1.0     | 1.3              | ppm   |
| 074-24A Classroom 115 Sink                           | 6/20/16 10:28         | 7/5/16 14:04         | 606220924    | Lead    | 11      | 15               | ppb   |
| 074-25A Classroom 116 Sink                           | 6/20/16 10:31         | 7/5/16 14:04         | 606220925    | Copper  | 1.1     | 1.3              | ppm   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Robert Gray Middle School

| Sample Identification # and Location | Date & Time Collected | Date & Time Analyzed | Container ID | Analyte | Results | EPA Action Limit | Units |
|--------------------------------------|-----------------------|----------------------|--------------|---------|---------|------------------|-------|
| 074-25A Classroom 116 Sink           | 6/20/16 10:31         | 7/5/16 14:04         | 606220925    | Lead    | 9       | 15               | ppb   |
| 074-26A Storeroom 116A Sink          | 6/20/16 10:33         | 7/5/16 14:04         | 606220926    | Copper  | 0.1     | 1.3              | ppm   |
| 074-26A Storeroom 116A Sink          | 6/20/16 10:33         | 7/5/16 14:04         | 606220926    | Lead    | 40      | 15               | ppb   |
| 074-27A Classroom 117 Sink           | 6/20/16 10:36         | 7/5/16 14:04         | 606220927    | Copper  | 1.2     | 1.3              | ppm   |
| 074-27A Classroom 117 Sink           | 6/20/16 10:36         | 7/5/16 14:04         | 606220927    | Lead    | 13      | 15               | ppb   |
| 074-28A Classroom 118 Sink           | 6/20/16 10:38         | 7/5/16 14:04         | 606220928    | Copper  | 1.1     | 1.3              | ppm   |
| 074-28A Classroom 118 Sink           | 6/20/16 10:38         | 7/5/16 14:04         | 606220928    | Lead    | 7       | 15               | ppb   |
| 074-29A Classroom 120 Sink           | 6/20/16 10:41         | 7/5/16 14:04         | 606220929    | Copper  | 1.1     | 1.3              | ppm   |
| 074-29A Classroom 120 Sink           | 6/20/16 10:41         | 7/5/16 14:04         | 606220929    | Lead    | 6       | 15               | ppb   |
| 074-30A Classroom 119 Sink           | 6/20/16 10:43         | 7/5/16 14:04         | 606220930    | Copper  | 1.1     | 1.3              | ppm   |
| 074-30A Classroom 119 Sink           | 6/20/16 10:43         | 7/5/16 14:04         | 606220930    | Lead    | 8       | 15               | ppb   |
| 074-31A Classroom 121 Sink           | 6/20/16 10:45         | 7/5/16 14:04         | 606220931    | Copper  | 1.0     | 1.3              | ppm   |
| 074-31A Classroom 121 Sink           | 6/20/16 10:45         | 7/5/16 14:04         | 606220931    | Lead    | 13      | 15               | ppb   |
| 074-32A Classroom 122 Sink           | 6/20/16 10:47         | 7/5/16 14:04         | 606220932    | Copper  | 1.1     | 1.3              | ppm   |
| 074-32A Classroom 122 Sink           | 6/20/16 10:47         | 7/5/16 14:04         | 606220932    | Lead    | 8       | 15               | ppb   |
| 074-33A Classroom 123 Sink           | 6/20/16 10:50         | 7/5/16 14:04         | 606220933    | Copper  | 0.9     | 1.3              | ppm   |
| 074-33A Classroom 123 Sink           | 6/20/16 10:50         | 7/5/16 14:04         | 606220933    | Lead    | 9       | 15               | ppb   |
| 074-34A Boys Bathroom 123 A Sink     | 6/20/16 10:51         | 7/5/16 14:05         | 606220934    | Copper  | 0.1     | 1.3              | ppm   |
| 074-34A Boys Bathroom 123 A Sink     | 6/20/16 10:51         | 7/5/16 14:05         | 606220934    | Lead    | 24      | 15               | ppb   |
| 074-35A Boys Bathroom 123A Sink      | 6/20/16 10:53         | 7/5/16 14:05         | 606220935    | Copper  | 0.1     | 1.3              | ppm   |
| 074-35A Boys Bathroom 123A Sink      | 6/20/16 10:53         | 7/5/16 14:05         | 606220935    | Lead    | 17      | 15               | ppb   |
| 074-36A Boys Bathroom 123A Spigot    | 6/20/16 10:55         | 7/5/16 14:05         | 606220936    | Copper  | 0.2     | 1.3              | ppm   |
| 074-36A Boys Bathroom 123A Spigot    | 6/20/16 10:55         | 7/5/16 14:05         | 606220936    | Lead    | 10      | 15               | ppb   |
| 074-37A Girls Bathroom 124A Sink     | 6/20/16 10:54         | 7/5/16 14:05         | 606220937    | Copper  | 0.3     | 1.3              | ppm   |
| 074-37A Girls Bathroom 124A Sink     | 6/20/16 10:54         | 7/5/16 14:05         | 606220937    | Lead    | 36      | 15               | ppb   |
| 074-38A Girls Bathroom 124A Sink     | 6/20/16 10:57         | 7/5/16 14:05         | 606220938    | Copper  | 0.5     | 1.3              | ppm   |
| 074-38A Girls Bathroom 124A Sink     | 6/20/16 10:57         | 7/5/16 14:05         | 606220938    | Lead    | 14      | 15               | ppb   |
| 074-39A Girls Bathroom 124A Sink     | 6/20/16 10:58         | 7/5/16 14:05         | 606220939    | Copper  | 0.2     | 1.3              | ppm   |
| 074-39A Girls Bathroom 124A Sink     | 6/20/16 10:58         | 7/5/16 14:05         | 606220939    | Lead    | 16      | 15               | ppb   |
| 074-40A Classroom 124 Sink           | 6/20/16 10:59         | 7/5/16 14:05         | 606220940    | Copper  | 0.8     | 1.3              | ppm   |
| 074-40A Classroom 124 Sink           | 6/20/16 10:59         | 7/5/16 14:05         | 606220940    | Lead    | 4       | 15               | ppb   |
| 074-41A Gym Instructor Sink 127C     | 6/20/16 9:14          | 7/5/16 14:05         | 606220941    | Copper  | 0.2     | 1.3              | ppm   |
| 074-41A Gym Instructor Sink 127C     | 6/20/16 9:14          | 7/5/16 14:05         | 606220941    | Lead    | 26      | 15               | ppb   |
| 074-42A Gym Instructor Shower 127    | 6/20/16 9:27          | 7/5/16 14:05         | 606220942    | Copper  | 0.2     | 1.3              | ppm   |
| 074-42A Gym Instructor Shower 127    | 6/20/16 9:27          | 7/5/16 14:05         | 606220942    | Lead    | 149     | 15               | ppb   |
| 074-43A G31 Sink 1                   | 6/20/16 11:13         | 7/5/16 14:05         | 606220943    | Copper  | 0.3     | 1.3              | ppm   |
| 074-43A G31 Sink 1                   | 6/20/16 11:13         | 7/5/16 14:05         | 606220943    | Lead    | 2       | 15               | ppb   |
| 074-44A G31 Sink 2                   | 6/20/16 11:15         | 7/5/16 14:05         | 606220944    | Copper  | 0.4     | 1.3              | ppm   |
| 074-44A G31 Sink 2                   | 6/20/16 11:15         | 7/5/16 14:05         | 606220944    | Lead    | 2       | 15               | ppb   |
| 074-45A G31 Sink 3                   | 6/20/16 11:16         | 7/5/16 14:05         | 606220945    | Copper  | 0.3     | 1.3              | ppm   |
| 074-45A G31 Sink 3                   | 6/20/16 11:16         | 7/5/16 14:05         | 606220945    | Lead    | 4       | 15               | ppb   |
| 074-46A G31 Handwash Sink            | 6/20/16 11:18         | 7/5/16 14:06         | 606220946    | Copper  | 0.3     | 1.3              | ppm   |
| 074-46A G31 Handwash Sink            | 6/20/16 11:18         | 7/5/16 14:06         | 606220946    | Lead    | 15.1    | 15               | ppb   |
| 074- 47A G22 Sink 1                  | 6/20/16 11:21         | 7/5/16 14:06         | 606220947    | Copper  | 0.5     | 1.3              | ppm   |
| 074- 47A G22 Sink 1                  | 6/20/16 11:21         | 7/5/16 14:06         | 606220947    | Lead    | 26      | 15               | ppb   |
| 074-48A G22 Sink 2                   | 6/20/16 11:23         | 7/5/16 14:06         | 606220948    | Copper  | 0.5     | 1.3              | ppm   |
| 074-48A G22 Sink 2                   | 6/20/16 11:23         | 7/5/16 14:06         | 606220948    | Lead    | 33      | 15               | ppb   |
| 074-49A G22 Sink 3                   | 6/20/16 11:24         | 7/5/16 14:06         | 606220949    | Copper  | 0.6     | 1.3              | ppm   |
| 074-49A G22 Sink 3                   | 6/20/16 11:24         | 7/5/16 14:06         | 606220949    | Lead    | 23      | 15               | ppb   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Robert Gray Middle School

| Sample Identification # and Location    | Date & Time Collected | Date & Time Analyzed | Container ID | Analyte | Results | EPA Action Limit | Units |
|-----------------------------------------|-----------------------|----------------------|--------------|---------|---------|------------------|-------|
| 074-50A G22 Sink 4                      | 6/20/16 11:26         | 7/5/16 14:06         | 606220950    | Copper  | 0.8     | 1.3              | ppm   |
| 074-50A G22 Sink 4                      | 6/20/16 11:26         | 7/5/16 14:06         | 606220950    | Lead    | 33      | 15               | ppb   |
| 074-51A G20 Custodial Sink              | 6/20/16 11:29         | 7/5/16 14:06         | 606220951    | Copper  | 0.3     | 1.3              | ppm   |
| 074-51A G20 Custodial Sink              | 6/20/16 11:29         | 7/5/16 14:06         | 606220951    | Lead    | 98      | 15               | ppb   |
| 074-52A G22 Single Sink in Red Counter  | 6/20/16 11:31         | 7/5/16 14:06         | 606220952    | Copper  | 0.5     | 1.3              | ppm   |
| 074-52A G22 Single Sink in Red Counter  | 6/20/16 11:31         | 7/5/16 14:06         | 606220952    | Lead    | 20      | 15               | ppb   |
| 074-53A G22 Sink w/Drinking Fountain    | 6/20/16 11:33         | 7/5/16 14:06         | 606220953    | Copper  | 0.5     | 1.3              | ppm   |
| 074-53A G22 Sink w/Drinking Fountain    | 6/20/16 11:33         | 7/5/16 14:06         | 606220953    | Lead    | 28      | 15               | ppb   |
| 074-54A Room 217 Sink                   | 6/20/16 11:36         | 7/5/16 14:06         | 606220954    | Copper  | 0.5     | 1.3              | ppm   |
| 074-54A Room 217 Sink                   | 6/20/16 11:36         | 7/5/16 14:06         | 606220954    | Lead    | 18      | 15               | ppb   |
| 074-55A G7 Music Room Sink              | 6/20/16 11:38         | 7/5/16 14:06         | 606220955    | Copper  | 0.4     | 1.3              | ppm   |
| 074-55A G7 Music Room Sink              | 6/20/16 11:38         | 7/5/16 14:06         | 606220955    | Lead    | 22      | 15               | ppb   |
| 074-56A Sandbox G1A Bathroom Sink       | 6/20/16 11:40         | 7/5/16 14:06         | 606220956    | Copper  | 0.8     | 1.3              | ppm   |
| 074-56A Sandbox G1A Bathroom Sink       | 6/20/16 11:40         | 7/5/16 14:06         | 606220956    | Lead    | 19      | 15               | ppb   |
| 074-57A Custodial Closet GIC Sink       | 6/20/16 11:43         | 7/5/16 14:06         | 606220957    | Copper  | 0.1     | 1.3              | ppm   |
| 074-57A Custodial Closet GIC Sink       | 6/20/16 11:43         | 7/5/16 14:06         | 606220957    | Lead    | 40      | 15               | ppb   |
| 074-58A Faculty Womens 95A Sink         | 6/20/16 9:31          | 7/5/16 14:06         | 606220958    | Copper  | 0.1     | 1.3              | ppm   |
| 074-58A Faculty Womens 95A Sink         | 6/20/16 9:31          | 7/5/16 14:06         | 606220958    | Lead    | 19      | 15               | ppb   |
| 074-59A Staff Unisex 95B Sink           | 6/20/16 9:34          | 7/5/16 14:06         | 606220959    | Copper  | 0.2     | 1.3              | ppm   |
| 074-59A Staff Unisex 95B Sink           | 6/20/16 9:34          | 7/5/16 14:06         | 606220959    | Lead    | 31      | 15               | ppb   |
| 074-60A Kitchen Bathroom 97D Sink       | 6/20/16 11:53         | 7/5/16 14:06         | 606220960    | Copper  | 0.4     | 1.3              | ppm   |
| 074-60A Kitchen Bathroom 97D Sink       | 6/20/16 11:53         | 7/5/16 14:06         | 606220960    | Lead    | 14      | 15               | ppb   |
| 074-61A Spigot Near Refrigerator        | 6/20/16 11:59         | 7/1/16 17:24         | 606220961    | Copper  | 3.0     | 1.3              | ppm   |
| 074-61A Spigot Near Refrigerator        | 6/20/16 11:59         | 7/1/16 17:24         | 606220961    | Lead    | 23      | 15               | ppb   |
| 074-62A Kitchen Handwash Sink           | 6/20/16 11:56         | 7/5/16 14:06         | 606220962    | Copper  | 0.9     | 1.3              | ppm   |
| 074-62A Kitchen Handwash Sink           | 6/20/16 11:56         | 7/5/16 14:06         | 606220962    | Lead    | 12      | 15               | ppb   |
| 074-63A Kitchen Food Prep Sink Handheld | 6/20/16 11:58         | 7/5/16 14:07         | 606220963    | Copper  | 0.7     | 1.3              | ppm   |
| 074-63A Kitchen Food Prep Sink Handheld | 6/20/16 11:58         | 7/5/16 14:07         | 606220963    | Lead    | 24      | 15               | ppb   |
| 074-64A Kitchen Food Prep Sink Spigot   | 6/20/16 11:59         | 7/5/16 14:07         | 606220964    | Copper  | 0.1     | 1.3              | ppm   |
| 074-64A Kitchen Food Prep Sink Spigot   | 6/20/16 11:59         | 7/5/16 14:07         | 606220964    | Lead    | 12      | 15               | ppb   |
| 074-65A Kitchen Food Prep Sink          | 6/20/16 12:01         | 7/5/16 14:07         | 606220965    | Copper  | 0.3     | 1.3              | ppm   |
| 074-65A Kitchen Food Prep Sink          | 6/20/16 12:01         | 7/5/16 14:07         | 606220965    | Lead    | 3       | 15               | ppb   |
| 074-66A Girls Bathroom 94A Sink         | 6/20/16 12:05         | 7/5/16 14:07         | 606220966    | Copper  | 1.28    | 1.3              | ppm   |
| 074-66A Girls Bathroom 94A Sink 1       | 6/20/16 12:05         | 7/5/16 14:07         | 606220966    | Lead    | 25      | 15               | ppb   |
| 074-67A Girls Bathroom 94A Sink 1       | 6/20/16 12:07         | 7/5/16 14:07         | 606220967    | Copper  | 1.27    | 1.3              | ppm   |
| 074-67A Girls Bathroom 94A Sink 2       | 6/20/16 12:07         | 7/5/16 14:07         | 606220967    | Lead    | 29      | 15               | ppb   |
| 074-68A Girls Bathroom 94A Sink 2       | 6/20/16 12:09         | 7/5/16 14:07         | 606220968    | Copper  | 1.1     | 1.3              | ppm   |
| 074-68A Girls Bathroom 94A Sink         | 6/20/16 12:09         | 7/5/16 14:07         | 606220968    | Lead    | 26      | 15               | ppb   |
| 074-69A Girls Bathroom 94A Spigot       | 6/20/16 12:10         | 7/5/16 14:07         | 606220969    | Copper  | 0.1     | 1.3              | ppm   |
| 074-69A Girls Bathroom 94A Spigot       | 6/20/16 12:10         | 7/5/16 14:07         | 606220969    | Lead    | 29      | 15               | ppb   |
| 074-70A Custodial Sink RM94B            | 6/20/16 12:13         | 7/5/16 14:07         | 606220970    | Copper  | 0.4     | 1.3              | ppm   |
| 074-70A Custodial Sink RM94B            | 6/20/16 12:13         | 7/5/16 14:07         | 606220970    | Lead    | 14.8    | 15               | ppb   |
| 074-71A Boys Bathroom 94C Sink 1        | 6/20/16 12:20         | 7/5/16 14:07         | 606220971    | Copper  | 0.2     | 1.3              | ppm   |
| 074-71A Boys Bathroom 94C Sink 1        | 6/20/16 12:20         | 7/5/16 14:07         | 606220971    | Lead    | 19      | 15               | ppb   |
| 074-72A Boys Bathroom 94C Sink 2        | 6/20/16 12:23         | 7/5/16 14:07         | 606220972    | Copper  | 0.2     | 1.3              | ppm   |
| 074-72A Boys Bathroom 94C Sink 2        | 6/20/16 12:23         | 7/5/16 14:07         | 606220972    | Lead    | 21      | 15               | ppb   |
| 074-73A Boys Bathroom 94C Sink          | 6/20/16 12:26         | 7/5/16 14:07         | 606220973    | Copper  | 0.2     | 1.3              | ppm   |
| 074-73A Boys Bathroom 94C Sink          | 6/20/16 12:26         | 7/5/16 14:07         | 606220973    | Lead    | 7       | 15               | ppb   |
| 074-74A Boys Bathroom 94C Spigot        | 6/20/16 12:28         | 7/5/16 14:07         | 606220974    | Copper  | 0.1     | 1.3              | ppm   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Robert Gray Middle School

| Sample Identification # and Location               | Date & Time Collected | Date & Time Analyzed | Container ID | Analyte | Results | EPA Action Limit | Units |
|----------------------------------------------------|-----------------------|----------------------|--------------|---------|---------|------------------|-------|
| 074-74A Boys Bathroom 94C Spigot                   | 6/20/16 12:28         | 7/5/16 14:07         | 606220974    | Lead    | 13      | 15               | ppb   |
| 074-75A Media Center 109 Sink                      | 6/20/16 12:38         | 7/5/16 14:07         | 606220975    | Copper  | 1.1     | 1.3              | ppm   |
| 074-75A Media Center 109 Sink                      | 6/20/16 12:38         | 7/5/16 14:07         | 606220975    | Lead    | 2       | 15               | ppb   |
| 074-76A Office Work 100M 99A Sink                  | 6/20/16 12:40         | 7/5/16 14:08         | 606220976    | Copper  | 0.1     | 1.3              | ppm   |
| 074-76A Office Work 100M 99A Sink                  | 6/20/16 12:40         | 7/5/16 14:08         | 606220976    | Lead    | 6       | 15               | ppb   |
| 074-77A Nurse Bathroom 99H                         | 6/20/16 12:45         | 7/5/16 14:08         | 606220977    | Copper  | 0.3     | 1.3              | ppm   |
| 074-77A Nurse Bathroom 99H                         | 6/20/16 12:45         | 7/5/16 14:08         | 606220977    | Lead    | 2       | 15               | ppb   |
| 074-78A Room 99F Sink (Near Nurse)                 | 6/20/16 12:48         | 7/5/16 14:08         | 606220978    | Copper  | 0.1     | 1.3              | ppm   |
| 074-78A Room 99F Sink (Near Nurse)                 | 6/20/16 12:48         | 7/5/16 14:08         | 606220978    | Lead    | 80      | 15               | ppb   |
| 074-79A Classroom 107 Sink                         | 6/20/16 12:52         | 7/5/16 14:08         | 606220979    | Copper  | 1.31    | 1.3              | ppm   |
| 074-79A Classroom 107 Sink                         | 6/20/16 12:52         | 7/5/16 14:08         | 606220979    | Lead    | 0       | 15               | ppb   |
| 074-80A Classroom 107 Drinking Fountain            | 6/20/16 12:54         | 7/5/16 14:08         | 606220980    | Copper  | 1.1     | 1.3              | ppm   |
| 074-80A Classroom 107 Drinking Fountain            | 6/20/16 12:54         | 7/5/16 14:08         | 606220980    | Lead    | 1       | 15               | ppb   |
| 074-81A Classroom 106 Snk                          | 6/20/16 12:58         | 7/5/16 14:08         | 606220981    | Copper  | 1.1     | 1.3              | ppm   |
| 074-81A Classroom 106 Snk                          | 6/20/16 12:58         | 7/5/16 14:08         | 606220981    | Lead    | 6       | 15               | ppb   |
| 074-82A Classroom 100 Sink                         | 6/20/16 12:59         | 7/5/16 14:08         | 606220982    | Copper  | 1.0     | 1.3              | ppm   |
| 074-82A Classroom 100 Sink                         | 6/20/16 12:59         | 7/5/16 14:08         | 606220982    | Lead    | 35      | 15               | ppb   |
| 074-83A Classroom 100 Drinking Fountain            | 6/20/16 13:04         | 7/5/16 14:08         | 606220983    | Copper  | 1.1     | 1.3              | ppm   |
| 074-83A Classroom 100 Drinking Fountain            | 6/20/16 13:04         | 7/5/16 14:08         | 606220983    | Lead    | 1       | 15               | ppb   |
| 074-84A Classroom 105 Sink                         | 6/20/16 13:06         | 7/5/16 14:08         | 606220984    | Copper  | 1.2     | 1.3              | ppm   |
| 074-84A Classroom 105 Sink                         | 6/20/16 13:06         | 7/5/16 14:08         | 606220984    | Lead    | 20      | 15               | ppb   |
| 074-85A Classroom 104 Sink                         | 6/20/16 13:10         | 7/5/16 14:09         | 606220985    | Copper  | 0.8     | 1.3              | ppm   |
| 074-85A Classroom 104 Sink                         | 6/20/16 13:10         | 7/5/16 14:09         | 606220985    | Lead    | 1       | 15               | ppb   |
| 074-86A Classroom 104 Drinking Fountain - Low Flow | 6/20/16 13:13         | 7/5/16 14:09         | 606220986    | Copper  | 0.9     | 1.3              | ppm   |
| 074-86A Classroom 104 Drinking Fountain - Low Flow | 6/20/16 13:13         | 7/5/16 14:09         | 606220986    | Lead    | 3       | 15               | ppb   |
| 074-87A Classroom 101 Handwash Sink                | 6/20/16 13:17         | 7/5/16 14:09         | 606220987    | Copper  | 0.5     | 1.3              | ppm   |
| 074-87A Classroom 101 Handwash Sink                | 6/20/16 13:17         | 7/5/16 14:09         | 606220987    | Lead    | 4       | 15               | ppb   |
| 074-88A Classroom 101 Sink 1L                      | 6/20/16 13:19         | 7/5/16 14:09         | 606220988    | Copper  | 0.8     | 1.3              | ppm   |
| 074-88A Classroom 101 Sink 1L                      | 6/20/16 13:19         | 7/5/16 14:09         | 606220988    | Lead    | 50      | 15               | ppb   |
| 074-89A Classroom 101 Sink 2L                      | 6/20/16 13:22         | 7/5/16 14:09         | 606220989    | Copper  | 0.8     | 1.3              | ppm   |
| 074-89A Classroom 101 Sink 2L                      | 6/20/16 13:22         | 7/5/16 14:09         | 606220989    | Lead    | 4       | 15               | ppb   |
| 074-90A Classroom 101 Sink 3L                      | 6/20/16 13:26         | 7/5/16 14:10         | 606220990    | Copper  | 0.9     | 1.3              | ppm   |
| 074-90A Classroom 101 Sink 3L                      | 6/20/16 13:26         | 7/5/16 14:10         | 606220990    | Lead    | 22      | 15               | ppb   |
| 074-91A Classroom 101 Sink 4L                      | 6/20/16 13:29         | 7/5/16 14:10         | 606220991    | Copper  | 0.5     | 1.3              | ppm   |
| 074-91A Classroom 101 Sink 4L                      | 6/20/16 13:29         | 7/5/16 14:10         | 606220991    | Lead    | 2       | 15               | ppb   |
| 074-92A Classroom 101 Sink 5R w/Eyewash            | 6/20/16 13:32         | 7/5/16 14:10         | 606220992    | Copper  | 0.6     | 1.3              | ppm   |
| 074-92A Classroom 101 Sink 5R w/Eyewash            | 6/20/16 13:32         | 7/5/16 14:10         | 606220992    | Lead    | 8       | 15               | ppb   |
| 074-93A Classroom 101 Eyewash                      | 6/20/16 13:35         | 7/5/16 14:10         | 606220993    | Copper  | 0.7     | 1.3              | ppm   |
| 074-93A Classroom 101 Eyewash                      | 6/20/16 13:35         | 7/5/16 14:10         | 606220993    | Lead    | 1       | 15               | ppb   |
| 074-94A Classroom 101 Closet Eyewash               | 6/20/16 13:40         | 7/5/16 14:10         | 606220994    | Copper  | 0.0     | 1.3              | ppm   |
| 074-94A Classroom 101 Closet Eyewash               | 6/20/16 13:40         | 7/5/16 14:10         | 606220994    | Lead    | 19      | 15               | ppb   |
| 074-95A Classroom 101 Closet Sink L                | 6/20/16 13:44         | 7/5/16 14:10         | 606220995    | Copper  | 0.3     | 1.3              | ppm   |
| 074-95A Classroom 101 Closet Sink L                | 6/20/16 13:44         | 7/5/16 14:10         | 606220995    | Lead    | 153     | 15               | ppb   |
| 074-96A Classroom 101 Closet Sink R                | 6/20/16 13:47         | 7/5/16 14:10         | 606220996    | Copper  | 0.6     | 1.3              | ppm   |
| 074-96A Classroom 101 Closet Sink R                | 6/20/16 13:47         | 7/5/16 14:10         | 606220996    | Lead    | 19      | 15               | ppb   |
| 074-97A Classroom 103 Handwash Sink                | 6/20/16 13:51         | 7/5/16 14:11         | 606220997    | Copper  | 0.4     | 1.3              | ppm   |
| 074-97A Classroom 103 Handwash Sink                | 6/20/16 13:51         | 7/5/16 14:11         | 606220997    | Lead    | 4       | 15               | ppb   |
| 074-98A Classroom 103 Sink 1L                      | 6/20/16 13:55         | 7/5/16 14:11         | 606220998    | Copper  | 0.5     | 1.3              | ppm   |
| 074-98A Classroom 103 Sink 1L                      | 6/20/16 13:55         | 7/5/16 14:11         | 606220998    | Lead    | 40      | 15               | ppb   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Robert Gray Middle School

| Sample Identification # and Location     | Date & Time Collected | Date & Time Analyzed | Container ID | Analyte | Results | EPA Action Limit | Units |
|------------------------------------------|-----------------------|----------------------|--------------|---------|---------|------------------|-------|
| 074-99A Classroom 103 Sink 2L            | 6/20/16 13:57         | 7/5/16 14:11         | 606220999    | Copper  | 0.4     | 1.3              | ppm   |
| 074-99A Classroom 103 Sink 2L            | 6/20/16 13:57         | 7/5/16 14:11         | 606220999    | Lead    | 8       | 15               | ppb   |
| 074-100A Classroom 103 Sink 3L           | 6/20/16 14:00         | 7/5/16 14:11         | 6062209100   | Copper  | 0.5     | 1.3              | ppm   |
| 074-100A Classroom 103 Sink 3L           | 6/20/16 14:00         | 7/5/16 14:11         | 6062209100   | Lead    | 70      | 15               | ppb   |
| 074-101A Classroom 103 Sink 4L           | 6/20/16 14:02         | 7/5/16 14:11         | 6062209101   | Copper  | 0.4     | 1.3              | ppm   |
| 074-101A Classroom 103 Sink 4L           | 6/20/16 14:02         | 7/5/16 14:11         | 6062209101   | Lead    | 2       | 15               | ppb   |
| 074-102A Classroom 103 Sink 5L           | 6/20/16 14:05         | 7/5/16 14:11         | 6062209102   | Copper  | 0.4     | 1.3              | ppm   |
| 074-102A Classroom 103 Sink 5L           | 6/20/16 14:05         | 7/5/16 14:11         | 6062209102   | Lead    | 156     | 15               | ppb   |
| 074-103A Classroom 103 Sink 6L           | 6/20/16 14:09         | 7/5/16 14:11         | 6062209103   | Copper  | 0.6     | 1.3              | ppm   |
| 074-103A Classroom 103 Sink 6L           | 6/20/16 14:09         | 7/5/16 14:11         | 6062209103   | Lead    | 6       | 15               | ppb   |
| 074-104A Classroom 103 Sink 7R w/Eyewash | 6/20/16 14:12         | 7/5/16 14:11         | 6062209104   | Copper  | 0.4     | 1.3              | ppm   |
| 074-104A Classroom 103 Sink 7R w/Eyewash | 6/20/16 14:12         | 7/5/16 14:11         | 6062209104   | Lead    | 2       | 15               | ppb   |
| 074-105A Classroom 103 Eyewash           | 6/20/16 14:15         | 7/5/16 13:15         | 6062209105   | Copper  | 0.5     | 1.3              | ppm   |
| 074-105A Classroom 103 Eyewash           | 6/20/16 14:15         | 7/5/16 13:15         | 6062209105   | Lead    | 3       | 15               | ppb   |
| 074-106A Classroom 102 Sink w/Eyewash    | 6/20/16 12:45         | 7/1/16 17:21         | 6062209106   | Copper  | 0.7     | 1.3              | ppm   |
| 074-106A Classroom 102 Sink w/Eyewash    | 6/20/16 12:45         | 7/1/16 17:21         | 6062209106   | Lead    | 12      | 15               | ppb   |
| 074-107A Classroom 105 Sink 2L           | 6/20/16 12:47         | 7/1/16 17:21         | 6062209107   | Copper  | 1.6     | 1.3              | ppm   |
| 074-107A Classroom 105 Sink 2L           | 6/20/16 12:47         | 7/1/16 17:21         | 6062209107   | Lead    | 119     | 15               | ppb   |
| 074-108A Classroom 102 Sink 3L           | 6/20/16 12:51         | 7/1/16 17:21         | 6062209108   | Copper  | 0.9     | 1.3              | ppm   |
| 074-108A Classroom 102 Sink 3L           | 6/20/16 12:51         | 7/1/16 17:21         | 6062209108   | Lead    | 23      | 15               | ppb   |
| 074-109A Classroom 102 Sink 4L           | 6/20/16 12:54         | 7/5/16 13:15         | 6062209109   | Copper  | 1.1     | 1.3              | ppm   |
| 074-109A Classroom 102 Sink 4L           | 6/20/16 12:54         | 7/5/16 13:15         | 6062209109   | Lead    | 64      | 15               | ppb   |
| 074-110A Classroom 102 Sink 5L           | 6/20/16 12:55         | 7/5/16 13:15         | 6062209110   | Copper  | 0.5     | 1.3              | ppm   |
| 074-110A Classroom 102 Sink 5L           | 6/20/16 12:55         | 7/5/16 13:15         | 6062209110   | Lead    | 13      | 15               | ppb   |
| 074-111A Classroom 102 Sink 6L           | 6/20/16 12:58         | 7/5/16 13:15         | 6062209111   | Copper  | 0.3     | 1.3              | ppm   |
| 074-111A Classroom 102 Sink 6L           | 6/20/16 12:58         | 7/5/16 13:15         | 6062209111   | Lead    | 9       | 15               | ppb   |
| 074-112A Classroom 102 Sink 7L           | 6/20/16 13:00         | 7/5/16 13:15         | 6062209112   | Copper  | 0.2     | 1.3              | ppm   |
| 074-112A Classroom 102 Sink 7L           | 6/20/16 13:00         | 7/5/16 13:15         | 6062209112   | Lead    | 65      | 15               | ppb   |
| 074-113A Classroom 102 Sink 8R           | 6/20/16 13:02         | 7/5/16 13:15         | 6062209113   | Copper  | 0.3     | 1.3              | ppm   |
| 074-113A Classroom 102 Sink 8R           | 6/20/16 13:02         | 7/5/16 13:15         | 6062209113   | Lead    | 5       | 15               | ppb   |
| 074-114A Classroom 102 Eyewash           | 6/20/16 13:04         | 7/5/16 13:15         | 6062209114   | Copper  | 0.5     | 1.3              | ppm   |
| 074-114A Classroom 102 Eyewash           | 6/20/16 13:04         | 7/5/16 13:15         | 6062209114   | Lead    | 33      | 15               | ppb   |
| 074-115A Girls Bathroom Sink 1           | 6/20/16 13:16         | 7/5/16 13:15         | 6062209115   | Copper  | 0.4     | 1.3              | ppm   |
| 074-115A Girls Bathroom Sink 1           | 6/20/16 13:16         | 7/5/16 13:15         | 6062209115   | Lead    | 15.4    | 15               | ppb   |
| 074-116A Girls Bathroom Sink 2           | 6/20/16 13:18         | 7/5/16 13:15         | 6062209116   | Copper  | 0.5     | 1.3              | ppm   |
| 074-116A Girls Bathroom Sink 2           | 6/20/16 13:18         | 7/5/16 13:15         | 6062209116   | Lead    | 16      | 15               | ppb   |
| 074-117A Girls Bathroom Sink 3           | 6/20/16 13:20         | 7/5/16 13:15         | 6062209117   | Copper  | 0.2     | 1.3              | ppm   |
| 074-117A Girls Bathroom Sink 3           | 6/20/16 13:20         | 7/5/16 13:15         | 6062209117   | Lead    | 18      | 15               | ppb   |
| 074-118A Girls Bathroom Spigot           | 6/20/16 13:22         | 7/5/16 13:16         | 6062209118   | Copper  | 0.1     | 1.3              | ppm   |
| 074-118A Girls Bathroom Spigot           | 6/20/16 13:22         | 7/5/16 13:16         | 6062209118   | Lead    | 18      | 15               | ppb   |
| 074-119A Boys Bathroom Sink 1            | 6/20/16 13:26         | 7/5/16 13:16         | 6062209119   | Copper  | 0.2     | 1.3              | ppm   |
| 074-119A Boys Bathroom Sink 1            | 6/20/16 13:26         | 7/5/16 13:16         | 6062209119   | Lead    | 31      | 15               | ppb   |
| 074-120A Boys Bathroom Sink 2            | 6/20/16 13:27         | 7/5/16 13:16         | 6062209120   | Copper  | 0.2     | 1.3              | ppm   |
| 074-120A Boys Bathroom Sink 2            | 6/20/16 13:27         | 7/5/16 13:16         | 6062209120   | Lead    | 13      | 15               | ppb   |
| 074-121A Boys Bathroom Sink 3            | 6/20/16 13:29         | 7/5/16 13:16         | 6062209121   | Copper  | 0.3     | 1.3              | ppm   |
| 074-121A Boys Bathroom Sink 3            | 6/20/16 13:29         | 7/5/16 13:16         | 6062209121   | Lead    | 28      | 15               | ppb   |
| 074-122A Boys Bathroom Spigot            | 6/20/16 13:31         | 7/5/16 13:16         | 6062209122   | Copper  | 0.2     | 1.3              | ppm   |
| 074-122A Boys Bathroom Spigot            | 6/20/16 13:31         | 7/5/16 13:16         | 6062209122   | Lead    | 14      | 15               | ppb   |
| 074-123A Custodial Closet Sink           | 6/20/16 13:34         | 7/5/16 13:16         | 6062209123   | Copper  | 0.0     | 1.3              | ppm   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Robert Gray Middle School

| Sample Identification # and Location                     | Date & Time Collected | Date & Time Analyzed | Container ID | Analyte | Results | EPA Action Limit | Units |
|----------------------------------------------------------|-----------------------|----------------------|--------------|---------|---------|------------------|-------|
| 074-123A Custodial Closet Sink                           | 6/20/16 13:34         | 7/5/16 13:16         | 6062209123   | Lead    | 8       | 15               | ppb   |
| 074-124A Water Spigot 1                                  | 6/20/16 13:29         | 7/5/16 13:16         | 6062209124   | Copper  | 0.1     | 1.3              | ppm   |
| 074-124A Water Spigot 1                                  | 6/20/16 13:29         | 7/5/16 13:16         | 6062209124   | Lead    | 34      | 15               | ppb   |
| 074-125A Water Spigot 2                                  | 6/20/16 13:32         | 7/1/16 17:21         | 6062209125   | Copper  | 1.1     | 1.3              | ppm   |
| 074-125A Water Spigot 2                                  | 6/20/16 13:32         | 7/1/16 17:21         | 6062209125   | Lead    | 122     | 15               | ppb   |
| 074-126A Water Spigot 3                                  | 6/20/16 13:36         | 7/5/16 13:16         | 6062209126   | Copper  | 0.1     | 1.3              | ppm   |
| 074-126A Water Spigot 3                                  | 6/20/16 13:36         | 7/5/16 13:16         | 6062209126   | Lead    | 59      | 15               | ppb   |
| 074-127A Water Spigot 4                                  | 6/20/16 13:40         | 7/1/16 17:21         | 6062209127   | Copper  | 0.8     | 1.3              | ppm   |
| 074-127A Water Spigot 4                                  | 6/20/16 13:40         | 7/1/16 17:21         | 6062209127   | Lead    | 95      | 15               | ppb   |
| 074-128A Water Spigot 5                                  | 6/20/16 13:45         | 7/1/16 17:22         | 6062209128   | Copper  | 0.5     | 1.3              | ppm   |
| 074-128A Water Spigot 5                                  | 6/20/16 13:45         | 7/1/16 17:22         | 6062209128   | Lead    | 166     | 15               | ppb   |
| 074-129A Water Spigot 6                                  | 6/20/16 13:48         | 7/1/16 17:22         | 6062209129   | Copper  | 0.1     | 1.3              | ppm   |
| 074-129A Water Spigot 6                                  | 6/20/16 13:48         | 7/1/16 17:22         | 6062209129   | Lead    | 94      | 15               | ppb   |
| 074-130A Water Spigot 7                                  | 6/20/16 13:54         | 7/5/16 13:16         | 6062209130   | Copper  | 0.2     | 1.3              | ppm   |
| 074-130A Water Spigot 7                                  | 6/20/16 13:54         | 7/5/16 13:16         | 6062209130   | Lead    | 249     | 15               | ppb   |
| 074-131A Water Spigot 8                                  | 6/20/16 13:58         | 7/5/16 13:16         | 6062209131   | Copper  | 0.2     | 1.3              | ppm   |
| 074-131A Water Spigot 8                                  | 6/20/16 13:58         | 7/5/16 13:16         | 6062209131   | Lead    | 319     | 15               | ppb   |
| 074-132A Water Spigot 9                                  | 6/20/16 14:02         | 7/5/16 13:17         | 6062209132   | Copper  | 0.1     | 1.3              | ppm   |
| 074-132A Water Spigot 9                                  | 6/20/16 14:02         | 7/5/16 13:17         | 6062209132   | Lead    | 42      | 15               | ppb   |
| 074-133A Water Spigot 10                                 | 6/20/16 14:07         | 7/1/16 17:22         | 6062209133   | Copper  | 1.8     | 1.3              | ppm   |
| 074-133A Water Spigot 10                                 | 6/20/16 14:07         | 7/1/16 17:22         | 6062209133   | Lead    | 110     | 15               | ppb   |
| 074-134A Water Spigot 11                                 | 6/20/16 14:16         | 7/5/16 13:17         | 6062209134   | Copper  | 0.8     | 1.3              | ppm   |
| 074-134A Water Spigot 11                                 | 6/20/16 14:16         | 7/5/16 13:17         | 6062209134   | Lead    | 205     | 15               | ppb   |
| 074-135A Water Spigot 12                                 | 6/20/16 14:17         | 7/5/16 13:17         | 6062209135   | Copper  | 0.0     | 1.3              | ppm   |
| 074-135A Water Spigot 12                                 | 6/20/16 14:17         | 7/5/16 13:17         | 6062209135   | Lead    | 14.8    | 15               | ppb   |
| 074-136A Water Spigot 13                                 | 6/20/16 14:21         | 7/5/16 13:17         | 6062209136   | Copper  | 0.0     | 1.3              | ppm   |
| 074-136A Water Spigot 13                                 | 6/20/16 14:21         | 7/5/16 13:17         | 6062209136   | Lead    | 72      | 15               | ppb   |
| 074-137A Water Spigot 14                                 | 6/20/16 14:25         | 7/5/16 13:17         | 6062209137   | Copper  | 0.6     | 1.3              | ppm   |
| 074-137A Water Spigot 14                                 | 6/20/16 14:25         | 7/5/16 13:17         | 6062209137   | Lead    | 41      | 15               | ppb   |
| 074-138A Water Spigot 15                                 | 6/20/16 14:29         | 7/1/16 17:22         | 6062209138   | Copper  | 2.5     | 1.3              | ppm   |
| 074-138A Water Spigot 15                                 | 6/20/16 14:29         | 7/1/16 17:22         | 6062209138   | Lead    | 438     | 15               | ppb   |
| 074-139A Outside Boiler Room Drinking Fountain           | 8/20/16 6:14          | 8/26/16 11:41        | 608232101    | Copper  | 2.3     | 1.3              | ppm   |
| 074-139A Outside Boiler Room Drinking Fountain           | 8/20/16 6:14          | 8/25/16 11:22        | 608232101    | Lead    | 7       | 15               | ppb   |
| 074-140A Gymnasium Drinking Fountain (1)                 | 8/20/16 6:18          | 8/26/16 11:41        | 608232102    | Copper  | 1.1     | 1.3              | ppm   |
| 074-140A Gymnasium Drinking Fountain (1)                 | 8/20/16 6:18          | 8/25/16 11:21        | 608232102    | Lead    | 3       | 15               | ppb   |
| 074-141A Gymnasium Drinking Fountain (2)                 | 8/20/16 6:25          | 8/26/16 11:42        | 608232103    | Copper  | 1.3     | 1.3              | ppm   |
| 074-141A Gymnasium Drinking Fountain (2)                 | 8/20/16 6:25          | 8/25/16 11:21        | 608232103    | Lead    | 4       | 15               | ppb   |
| 074-142A Boys Locker Room Drinking Fountain              | 8/20/16 6:27          | 8/26/16 11:42        | 608232104    | Copper  | 1.7     | 1.3              | ppm   |
| 074-142A Boys Locker Room Drinking Fountain              | 8/20/16 6:27          | 8/25/16 11:21        | 608232104    | Lead    | 5       | 15               | ppb   |
| 074-143A Girls Locker Room Drinking Fountain             | 8/20/16 6:31          | 8/26/16 11:42        | 608232105    | Copper  | 1.8     | 1.3              | ppm   |
| 074-143A Girls Locker Room Drinking Fountain             | 8/20/16 6:31          | 8/25/16 11:23        | 608232105    | Lead    | 7       | 15               | ppb   |
| 074-144A Room 126 Drinking Fountain                      | 8/20/16 6:38          | 8/26/16 11:42        | 608232106    | Copper  | 1.9     | 1.3              | ppm   |
| 074-144A Room 126 Drinking Fountain                      | 8/20/16 6:38          | 8/25/16 11:32        | 608232106    | Lead    | 1       | 15               | ppb   |
| 074-145A Hallway Across From Room 112E Drinking Fountain | 8/20/16 6:42          | 8/26/16 11:42        | 608232107    | Copper  | 1.4     | 1.3              | ppm   |
| 074-145A Hallway Across From Room 112E Drinking Fountain | 8/20/16 6:42          | 8/25/16 11:32        | 608232107    | Lead    | 1       | 15               | ppb   |
| 074-146A Room 111 Drinking Fountain                      | 8/20/16 6:46          | 8/26/16 11:42        | 608232108    | Copper  | 1.7     | 1.3              | ppm   |
| 074-146A Room 111 Drinking Fountain                      | 8/20/16 6:46          | 8/25/16 11:34        | 608232108    | Lead    | 5       | 15               | ppb   |
| 074-147A Room 112 Drinking Fountain                      | 8/20/16 6:49          | 8/26/16 11:42        | 608232109    | Copper  | 1.9     | 1.3              | ppm   |
| 074-147A Room 112 Drinking Fountain                      | 8/20/16 6:49          | 8/25/16 11:34        | 608232109    | Lead    | 44      | 15               | ppb   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Robert Gray Middle School

| Sample Identification # and Location                  | Date & Time Collected | Date & Time Analyzed | Container ID | Analyte | Results | EPA Action Limit | Units |
|-------------------------------------------------------|-----------------------|----------------------|--------------|---------|---------|------------------|-------|
| 074-148A Room 114 Drinking Fountain                   | 8/20/16 6:57          | 8/26/16 11:43        | 608232110    | Copper  | 1.8     | 1.3              | ppm   |
| 074-148A Room 114 Drinking Fountain                   | 8/20/16 6:57          | 8/25/16 11:34        | 608232110    | Lead    | 16      | 15               | ppb   |
| 074-149A Room 113 Drinking Fountain                   | 8/20/16 6:58          | 8/26/16 11:43        | 608232111    | Copper  | 1.6     | 1.3              | ppm   |
| 074-149A Room 113 Drinking Fountain                   | 8/20/16 6:58          | 8/25/16 11:35        | 608232111    | Lead    | 10      | 15               | ppb   |
| 074-150A Hallway between 116 & 114 Drinking Fountain  | 8/20/16 6:59          | 8/26/16 11:44        | 608232112    | Copper  | 1.7     | 1.3              | ppm   |
| 074-150A Hallway between 116 & 114 Drinking Fountain  | 8/20/16 6:59          | 8/25/16 11:35        | 608232112    | Lead    | 5       | 15               | ppb   |
| 074-151A Room 115 Drinking Fountain                   | 8/20/16 7:03          | 8/26/16 11:44        | 608232113    | Copper  | 1.6     | 1.3              | ppm   |
| 074-151A Room 115 Drinking Fountain                   | 8/20/16 7:03          | 8/25/16 11:35        | 608232113    | Lead    | 3       | 15               | ppb   |
| 074-152A Room 116 Drinking Fountain                   | 8/20/16 7:05          | 8/26/16 11:44        | 608232114    | Copper  | 1.9     | 1.3              | ppm   |
| 074-152A Room 116 Drinking Fountain                   | 8/20/16 7:05          | 8/25/16 11:36        | 608232114    | Lead    | 3       | 15               | ppb   |
| 074-153A Room 117 Drinking Fountain                   | 8/20/16 7:09          | 8/26/16 11:44        | 608232115    | Copper  | 1.8     | 1.3              | ppm   |
| 074-153A Room 117 Drinking Fountain                   | 8/20/16 7:09          | 8/25/16 11:36        | 608232115    | Lead    | 3       | 15               | ppb   |
| 074-154A Room 118 Drinking Fountain                   | 8/20/16 7:11          | 8/26/16 11:45        | 608232116    | Copper  | 1.8     | 1.3              | ppm   |
| 074-154A Room 118 Drinking Fountain                   | 8/20/16 7:11          | 8/25/16 12:07        | 608232116    | Lead    | 13      | 15               | ppb   |
| 074-155A Room 120 Drinking Fountain                   | 8/20/16 7:41          | 8/26/16 11:45        | 608232117    | Copper  | 1.9     | 1.3              | ppm   |
| 074-155A Room 120 Drinking Fountain                   | 8/20/16 7:41          | 8/25/16 11:52        | 608232117    | Lead    | 7       | 15               | ppb   |
| 074-156A Room 119 Drinking Fountain                   | 8/20/16 7:21          | 8/26/16 11:45        | 608232118    | Copper  | 1.6     | 1.3              | ppm   |
| 074-156A Room 119 Drinking Fountain                   | 8/20/16 7:21          | 8/25/16 11:52        | 608232118    | Lead    | 4       | 15               | ppb   |
| 074-157A Room 121 Drinking Fountain                   | 8/20/16 7:25          | 8/26/16 11:46        | 608232119    | Copper  | 2.0     | 1.3              | ppm   |
| 074-157A Room 121 Drinking Fountain                   | 8/20/16 7:25          | 8/25/16 11:53        | 608232119    | Lead    | 4       | 15               | ppb   |
| 074-158A Room 122 Drinking Fountain                   | 8/20/16 7:26          | 8/26/16 11:46        | 608232120    | Copper  | 2.0     | 1.3              | ppm   |
| 074-158A Room 122 Drinking Fountain                   | 8/20/16 7:26          | 8/25/16 11:53        | 608232120    | Lead    | 3       | 15               | ppb   |
| 074-159A Room 123 Drinking Fountain                   | 8/20/16 7:30          | 8/26/16 11:46        | 608232121    | Copper  | 1.6     | 1.3              | ppm   |
| 074-159A Room 123 Drinking Fountain                   | 8/20/16 7:30          | 8/25/16 11:54        | 608232121    | Lead    | 27      | 15               | ppb   |
| 074-160A Room 124 Drinking Fountain                   | 8/20/16 7:34          | 8/26/16 11:47        | 608232122    | Copper  | 2.3     | 1.3              | ppm   |
| 074-160A Room 124 Drinking Fountain                   | 8/20/16 7:34          | 8/25/16 11:54        | 608232122    | Lead    | 14      | 15               | ppb   |
| 074-161A Hallway Outside Room 124 Drinking Fountain   | 8/20/16 7:39          | 8/26/16 11:47        | 608232123    | Copper  | 2.2     | 1.3              | ppm   |
| 074-161A Hallway Outside Room 124 Drinking Fountain   | 8/20/16 7:39          | 8/25/16 11:54        | 608232123    | Lead    | 3       | 15               | ppb   |
| 074-162A Room G31 Drinking Fountain                   | 8/20/16 7:45          | 8/25/16 11:55        | 608232124    | Copper  | 0.6     | 1.3              | ppm   |
| 074-162A Room G31 Drinking Fountain                   | 8/20/16 7:45          | 8/25/16 11:55        | 608232124    | Lead    | 24      | 15               | ppb   |
| 074-163A Room 222 Drinking Fountain                   | 8/20/16 7:52          | 8/25/16 11:55        | 608232125    | Copper  | 0.7     | 1.3              | ppm   |
| 074-163A Room 222 Drinking Fountain                   | 8/20/16 7:52          | 8/25/16 11:55        | 608232125    | Lead    | 29      | 15               | ppb   |
| 074-164A Room 217 Drinking Fountain                   | 8/20/16 7:57          | 8/25/16 12:11        | 608232126    | Copper  | 0.4     | 1.3              | ppm   |
| 074-164A Room 217 Drinking Fountain                   | 8/20/16 7:57          | 8/25/16 12:11        | 608232126    | Lead    | 25      | 15               | ppb   |
| 074-165A Room 207 Drinking Fountain                   | 8/20/16 8:05          | 8/25/16 11:59        | 608232127    | Copper  | 0.4     | 1.3              | ppm   |
| 074-165A Room 207 Drinking Fountain                   | 8/20/16 8:05          | 8/25/16 11:59        | 608232127    | Lead    | 17      | 15               | ppb   |
| 074-166A Cafetorium Drinking Fountain                 | 8/20/16 8:35          | 8/26/16 11:47        | 608232128    | Copper  | 1.2     | 1.3              | ppm   |
| 074-166A Cafetorium Drinking Fountain                 | 8/20/16 8:35          | 8/25/16 12:00        | 608232128    | Lead    | 16      | 15               | ppb   |
| 074-167A Hallway Outside Cafetorium Drinking Fountain | 8/20/16 8:28          | 8/26/16 11:48        | 608232129    | Copper  | 1.7     | 1.3              | ppm   |
| 074-167A Hallway Outside Cafetorium Drinking Fountain | 8/20/16 8:28          | 8/25/16 12:00        | 608232129    | Lead    | 2       | 15               | ppb   |
| 074-168A Hallway Outside Drinking Fountain            | 8/20/16 8:43          | 8/25/16 12:00        | 608232130    | Copper  | 0.1     | 1.3              | ppm   |
| 074-168A Hallway Outside Drinking Fountain            | 8/20/16 8:43          | 8/25/16 12:00        | 608232130    | Lead    | 18      | 15               | ppb   |
| 074-169A Room 107 Drinking Fountain                   | 8/20/16 8:32          | 8/26/16 11:48        | 608232131    | Copper  | 2.0     | 1.3              | ppm   |
| 074-169A Room 107 Drinking Fountain                   | 8/20/16 8:32          | 8/25/16 12:01        | 608232131    | Lead    | 9       | 15               | ppb   |
| 074-170A Room 106 Drinking Fountain                   | 8/20/16 8:28          | 8/26/16 11:48        | 608232132    | Copper  | 1.6     | 1.3              | ppm   |
| 074-170A Room 106 Drinking Fountain                   | 8/20/16 8:28          | 8/25/16 12:08        | 608232132    | Lead    | 2       | 15               | ppb   |
| 074-171A Room 100 Drinking Fountain                   | 8/20/16 8:26          | 8/26/16 11:48        | 608232133    | Copper  | 1.5     | 1.3              | ppm   |
| 074-171A Room 100 Drinking Fountain                   | 8/20/16 8:26          | 8/25/16 12:02        | 608232133    | Lead    | 3       | 15               | ppb   |
| 074-172A Room 105 Drinking Fountain                   | 8/20/16 8:17          | 8/26/16 11:48        | 608232134    | Copper  | 1.6     | 1.3              | ppm   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Robert Gray Middle School

| Sample Identification # and Location                 | Date & Time Collected | Date & Time Analyzed | Container ID | Analyte | Results | EPA Action Limit | Units |
|------------------------------------------------------|-----------------------|----------------------|--------------|---------|---------|------------------|-------|
| 074-172A Room 105 Drinking Fountain                  | 8/20/16 8:17          | 8/25/16 12:04        | 608232134    | Lead    | 1       | 15               | ppb   |
| 074-173A Hallway Between 105 & 104 Drinking Fountain | 8/20/16 8:20          | 8/26/16 11:49        | 608232135    | Copper  | 1.4     | 1.3              | ppm   |
| 074-173A Hallway Between 105 & 104 Drinking Fountain | 8/20/16 8:20          | 8/25/16 12:04        | 608232135    | Lead    | 2       | 15               | ppb   |
| 074-174A Room 104 Drinking Fountain                  | 8/20/16 8:22          | 8/26/16 11:31        | 608232136    | Copper  | 1.3     | 1.3              | ppm   |
| 074-174A Room 104 Drinking Fountain                  | 8/20/16 8:22          | 8/26/16 11:31        | 608232136    | Lead    | 43      | 15               | ppb   |

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.