

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Grout Elementary School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
042-BR-01A	Boiler Room Sink Faucet	6/15/2016 2:00:00 AM	6/18/2016 8:36:00 AM	BB65082	Copper	0.0	1.3	PPM
042-BR-01A	Boiler Room Sink Faucet	6/15/2016 2:00:00 AM	6/18/2016 8:36:00 AM	BB65082	Lead	3	15	PPB
042-BCRD-02A	Basement CRD Sink Faucet 1	6/15/2016 2:03:00 AM	6/18/2016 8:40:00 AM	BB65083	Copper	0.0	1.3	PPM
042-BCRD-02A	Basement CRD Sink Faucet 1	6/15/2016 2:03:00 AM	6/18/2016 8:40:00 AM	BB65083	Lead	3	15	PPB
042-BCRD-03A	Basement CRD Sink Faucet 1	6/15/2016 2:05:00 AM	6/18/2016 8:43:00 AM	BB65084	Copper	0.1	1.3	PPM
042-BCRD-03A	Basement CRD Sink Faucet 1	6/15/2016 2:05:00 AM	6/18/2016 8:43:00 AM	BB65084	Lead	4	15	PPB
042-BCRD-04A	Basement CRD Drinking Fountain	6/15/2016 2:07:00 AM	6/18/2016 8:46:00 AM	BB65085	Copper	0.0	1.3	PPM
042-BCRD-04A	Basement CRD Drinking Fountain	6/15/2016 2:07:00 AM	6/18/2016 8:46:00 AM	BB65085	Lead	12	15	PPB
042-BCRB-05A	Basement Room B Sink Faucet 2	6/15/2016 2:10:00 AM	6/18/2016 8:49:00 AM	BB65086	Copper	0.0	1.3	PPM
042-BCRB-05A	Basement Room B Sink Faucet 2	6/15/2016 2:10:00 AM	6/18/2016 8:49:00 AM	BB65086	Lead	23	15	PPB
042-B8BR-06A	Basement Bathroom B8 Sink Faucet	6/15/2016 2:14:00 AM	6/18/2016 8:52:00 AM	BB65087	Copper	0.0	1.3	PPM
042-B8BR-06A	Basement Bathroom B8 Sink Faucet	6/15/2016 2:14:00 AM	6/18/2016 8:52:00 AM	BB65087	Lead	4	15	PPB
042-BJC-07A	Basement Janitor B10 Sink Faucet	6/15/2016 2:18:00 AM	6/18/2016 8:55:00 AM	BB65088	Copper	0.0	1.3	PPM
042-BJC-07A	Basement Janitor B10 Sink Faucet	6/15/2016 2:18:00 AM	6/18/2016 8:55:00 AM	BB65088	Lead	1	15	PPB
042-BHDF1-08A	Basement Hall Drinking Fountain 1	6/15/2016 2:23:00 AM	6/18/2016 8:58:00 AM	BB65089	Copper	0.0	1.3	PPM
042-BHDF1-08A	Basement Hall Drinking Fountain 1	6/15/2016 2:23:00 AM	6/18/2016 8:58:00 AM	BB65089	Lead	2	15	PPB
042-BHDF2-09A	Basement Hall Drinking Fountain 2	6/15/2016 2:25:00 AM	6/18/2016 9:01:00 AM	BB65090	Copper	0.0	1.3	PPM
042-BHDF2-09A	Basement Hall Drinking Fountain 2	6/15/2016 2:25:00 AM	6/18/2016 9:01:00 AM	BB65090	Lead	2	15	PPB
042-BHDF3-10A	Basement Hall Drinking Fountain 3	6/15/2016 2:27:00 AM	6/18/2016 9:04:00 AM	BB65091	Copper	0.0	1.3	PPM
042-BHDF3-10A	Basement Hall Drinking Fountain 3	6/15/2016 2:27:00 AM	6/18/2016 9:04:00 AM	BB65091	Lead	2	15	PPB
042-BHDF4-11A	Basement Hall Drinking Fountain 4	6/15/2016 2:29:00 AM	6/18/2016 9:19:00 AM	BB65092	Copper	0.0	1.3	PPM
042-BHDF4-11A	Basement Hall Drinking Fountain 4	6/15/2016 2:29:00 AM	6/18/2016 9:19:00 AM	BB65092	Lead	4	15	PPB
042-BCRA-12A	Basement Classroom A B12 Bathroom Sink	6/15/2016 2:35:00 AM	6/21/2016 9:33:00 AM	BB65093	Copper	0.0	1.3	PPM
042-BCRA-12A	Basement Classroom A B12 Bathroom Sink	6/15/2016 2:35:00 AM	6/21/2016 9:33:00 AM	BB65093	Lead	0	15	PPB
042-BCRA-13A	Basement Classroom A B12 Bathroom Sink Faucet	6/15/2016 2:37:00 AM	6/18/2016 9:25:00 AM	BB65094	Copper	0.1	1.3	PPM
042-BCRA-13A	Basement Classroom A B12 Bathroom Sink Faucet	6/15/2016 2:37:00 AM	6/18/2016 9:25:00 AM	BB65094	Lead	12	15	PPB
042-J109A-14A	1st Floor 109A Janitor Sink Faucet	6/15/2016 2:40:00 AM	6/18/2016 9:28:00 AM	BB65095	Copper	0.0	1.3	PPM
042-J109A-14A	1st Floor 109A Janitor Sink Faucet	6/15/2016 2:40:00 AM	6/18/2016 9:28:00 AM	BB65095	Lead	3	15	PPB
042-HDF5-15A	Hall Drinking Fountain 5	6/15/2016 2:43:00 AM	6/18/2016 9:31:00 AM	BB65096	Copper	0.0	1.3	PPM
042-HDF5-15A	Hall Drinking Fountain 5	6/15/2016 2:43:00 AM	6/18/2016 9:31:00 AM	BB65096	Lead	5	15	PPB
042-HDF6-16A	Hall Drinking Fountain 6	6/15/2016 2:45:00 AM	6/18/2016 9:34:00 AM	BB65097	Copper	0.0	1.3	PPM
042-HDF6-16A	Hall Drinking Fountain 6	6/15/2016 2:45:00 AM	6/18/2016 9:34:00 AM	BB65097	Lead	3	15	PPB
042-BBR1-17A	Boys Bathroom 1 Sink Faucet 1	6/15/2016 2:49:00 AM	6/18/2016 9:37:00 AM	BB65098	Copper	0.0	1.3	PPM
042-BBR1-17A	Boys Bathroom 1 Sink Faucet 1	6/15/2016 2:49:00 AM	6/18/2016 9:37:00 AM	BB65098	Lead	30	15	PPB
042-BBR1-18A	Boys Bathroom 1 Sink Faucet 2	6/15/2016 2:51:00 AM	6/18/2016 9:40:00 AM	BB65099	Copper	0.0	1.3	PPM
042-BBR1-18A	Boys Bathroom 1 Sink Faucet 2	6/15/2016 2:51:00 AM	6/18/2016 9:40:00 AM	BB65099	Lead	4	15	PPB
042-BBR1-19A	Boys Bathroom Water Spigot	6/15/2016 2:53:00 AM	6/18/2016 9:43:00 AM	BB65100	Copper	0.0	1.3	PPM
042-BBR1-19A	Boys Bathroom Water Spigot	6/15/2016 2:53:00 AM	6/18/2016 9:43:00 AM	BB65100	Lead	2	15	PPB
042-TBR1-20A	Teacher Bathroom Sink Faucet	6/15/2016 3:00:00 AM	6/18/2016 9:46:00 AM	BB65101	Copper	0.0	1.3	PPM
042-TBR1-20A	Teacher Bathroom Sink Faucet	6/15/2016 3:00:00 AM	6/18/2016 9:46:00 AM	BB65101	Lead	3	15	PPB
042-R106-21A	Staff Room 106 Sink Faucet	6/15/2016 3:03:00 AM	6/18/2016 10:11:00 AM	BB65102	Copper	0.2	1.3	PPM
042-R106-21A	Staff Room 106 Sink Faucet	6/15/2016 3:03:00 AM	6/18/2016 10:11:00 AM	BB65102	Lead	5	15	PPB
042-R106-WC-22A	Room 106A Water Cooler	6/15/2016 3:05:00 AM	6/18/2016 10:14:00 AM	BB65103	Copper	0.0	1.3	PPM
042-R106-WC-22A	Room 106A Water Cooler	6/15/2016 3:05:00 AM	6/18/2016 10:14:00 AM	BB65103	Lead	3	15	PPB
042-HDF7-23A	Hall Drinking Fountain 7	6/15/2016 3:08:00 AM	6/18/2016 10:17:00 AM	BB65104	Copper	0.1	1.3	PPM
042-HDF7-23A	Hall Drinking Fountain 7	6/15/2016 3:08:00 AM	6/18/2016 10:17:00 AM	BB65104	Lead	16	15	PPB
042-HGRR1-24A	Hall Girls Restroom 1 Sink Faucet 1	6/15/2016 3:12:00 AM	6/18/2016 10:20:00 AM	BB65105	Copper	0.0	1.3	PPM
042-HGRR1-24A	Hall Girls Restroom 1 Sink Faucet 1	6/15/2016 3:12:00 AM	6/18/2016 10:20:00 AM	BB65105	Lead	4	15	PPB
042-HGRR1-25A	Hall Girls Restroom 1 Sink Faucet 2	6/15/2016 3:14:00 AM	6/18/2016 10:23:00 AM	BB65106	Copper	0.0	1.3	PPM
042-HGRR1-25A	Hall Girls Restroom 1 Sink Faucet 2	6/15/2016 3:14:00 AM	6/18/2016 10:23:00 AM	BB65106	Lead	5	15	PPB
042-HGRR1-26A	Hall Girls Restroom Water Spigot	6/15/2016 3:16:00 AM	6/18/2016 10:26:00 AM	BB65107	Copper	0.0	1.3	PPM
042-HGRR1-26A	Hall Girls Restroom Water Spigot	6/15/2016 3:16:00 AM	6/18/2016 10:26:00 AM	BB65107	Lead	2	15	PPB
042-CR104-27A	Classroom 104 Sink Faucet	6/15/2016 3:20:00 AM	6/18/2016 10:29:00 AM	BB65108	Copper	0.3	1.3	PPM
042-CR104-27A	Classroom 104 Sink Faucet	6/15/2016 3:20:00 AM	6/18/2016 10:29:00 AM	BB65108	Lead	2	15	PPB
042-CR104-28A	Classroom 104 Drinking Fountain	6/15/2016 3:22:00 AM	6/18/2016 10:32:00 AM	BB65109	Copper	0.3	1.3	PPM
042-CR104-28A	Classroom 104 Drinking Fountain	6/15/2016 3:22:00 AM	6/18/2016 10:32:00 AM	BB65109	Lead	3	15	PPB
042-CR103-29A	Classroom 103 Sink Faucet	6/15/2016 3:25:00 AM	6/18/2016 10:35:00 AM	BB65110	Copper	0.0	1.3	PPM
042-CR103-29A	Classroom 103 Sink Faucet	6/15/2016 3:25:00 AM	6/18/2016 10:35:00 AM	BB65110	Lead	5	15	PPB

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Grout Elementary School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
042-CR103-30A	Classroom 103 Drinking Fountain	6/15/2016 3:27:00 AM	6/18/2016 10:38:00 AM	BB65111	Copper	0.0	1.3	PPM
042-CR103-30A	Classroom 103 Drinking Fountain	6/15/2016 3:27:00 AM	6/18/2016 10:38:00 AM	BB65111	Lead	7	15	PPB
042-HBRR2-31A	Hall Boys Restroom 2 Sink Faucet 1	6/15/2016 3:32:00 AM	7/3/2016 11:40:00 AM	BB65112	Copper	0.2	1.3	PPM
042-HBRR2-31A	Hall Boys Restroom 2 Sink Faucet 1	6/15/2016 3:32:00 AM	7/3/2016 11:40:00 AM	BB65112	Lead	12	15	PPB
042-HBRR2-32A	Hall Boys Restroom 2 Sink Faucet 2	6/15/2016 3:34:00 AM	6/18/2016 10:56:00 AM	BB65113	Copper	0.1	1.3	PPM
042-HBRR2-32A	Hall Boys Restroom 2 Sink Faucet 2	6/15/2016 3:34:00 AM	6/18/2016 10:56:00 AM	BB65113	Lead	3	15	PPB
042-HBRR2-33A	Hall Boys Restroom 2 Water Spigot	6/15/2016 3:36:00 AM	6/18/2016 10:59:00 AM	BB65114	Copper	0.0	1.3	PPM
042-HBRR2-33A	Hall Boys Restroom 2 Water Spigot	6/15/2016 3:36:00 AM	6/18/2016 10:59:00 AM	BB65114	Lead	1	15	PPB
042-TRR-34A	Teachers Restroom Sink Faucet	6/15/2016 3:41:00 AM	6/18/2016 11:02:00 AM	BB65115	Copper	0.1	1.3	PPM
042-TRR-34A	Teachers Restroom Sink Faucet	6/15/2016 3:41:00 AM	6/18/2016 11:02:00 AM	BB65115	Lead	7	15	PPB
042-CR102-35A	Classroom 102 Sink Faucet	6/15/2016 3:46:00 AM	6/18/2016 11:05:00 AM	BB65116	Copper	0.0	1.3	PPM
042-CR102-35A	Classroom 102 Sink Faucet	6/15/2016 3:46:00 AM	6/18/2016 11:05:00 AM	BB65116	Lead	7	15	PPB
042-KITRR-36A	Kitchen Restroom Sink Faucet	6/15/2016 3:49:00 AM	6/18/2016 11:08:00 AM	BB65117	Copper	0.1	1.3	PPM
042-KITRR-36A	Kitchen Restroom Sink Faucet	6/15/2016 3:49:00 AM	6/18/2016 11:08:00 AM	BB65117	Lead	8	15	PPB
042-KHS-37A	Kitchen Hand Sink Faucet	6/15/2016 3:54:00 AM	6/18/2016 11:11:00 AM	BB65118	Copper	0.1	1.3	PPM
042-KHS-37A	Kitchen Hand Sink Faucet	6/15/2016 3:54:00 AM	6/18/2016 11:11:00 AM	BB65118	Lead	12	15	PPB
042-KDS-38A	Kitchen Dish Sink Faucet	6/15/2016 3:56:00 AM	6/18/2016 11:14:00 AM	BB65119	Copper	0.1	1.3	PPM
042-KDS-38A	Kitchen Dish Sink Faucet	6/15/2016 3:56:00 AM	6/18/2016 11:14:00 AM	BB65119	Lead	8	15	PPB
042-KFPS-39A	Kitchen Food Prep Sink Sprayer	6/15/2016 4:00:00 AM	6/18/2016 11:17:00 AM	BB65120	Copper	0.0	1.3	PPM
042-KFPS-39A	Kitchen Food Prep Sink Sprayer	6/15/2016 4:00:00 AM	6/18/2016 11:17:00 AM	BB65120	Lead	4	15	PPB
042-KFPS-40A	Kitchen Food Prep Sink Eyewash	6/15/2016 4:01:00 AM	6/18/2016 11:20:00 AM	BB65121	Copper	0.1	1.3	PPM
042-KFPS-40A	Kitchen Food Prep Sink Eyewash	6/15/2016 4:01:00 AM	6/18/2016 11:20:00 AM	BB65121	Lead	2	15	PPB
042-KFPS-41A	Kitchen Food Prep Sink Water Spigot	6/15/2016 4:03:00 AM	6/18/2016 11:41:00 AM	BB65122	Copper	0.2	1.3	PPM
042-KFPS-41A	Kitchen Food Prep Sink Water Spigot	6/15/2016 4:03:00 AM	6/18/2016 11:41:00 AM	BB65122	Lead	2	15	PPB
042-CR101-42A	Classroom 101 Sink Faucet	6/15/2016 4:07:00 AM	6/18/2016 11:44:00 AM	BB65123	Copper	0.0	1.3	PPM
042-CR101-42A	Classroom 101 Sink Faucet	6/15/2016 4:07:00 AM	6/18/2016 11:44:00 AM	BB65123	Lead	10	15	PPB
042-EG-43A	East Gym Janitor Sink Faucet	6/15/2016 4:15:00 AM	6/18/2016 11:48:00 AM	BB65124	Copper	0.0	1.3	PPM
042-EG-43A	East Gym Janitor Sink Faucet	6/15/2016 4:15:00 AM	6/18/2016 11:48:00 AM	BB65124	Lead	6	15	PPB
042-CR112-44A	Classroom 112 Sink Faucet	6/15/2016 4:20:00 AM	6/18/2016 11:51:00 AM	BB65125	Copper	0.3	1.3	PPM
042-CR112-44A	Classroom 112 Sink Faucet	6/15/2016 4:20:00 AM	6/18/2016 11:51:00 AM	BB65125	Lead	9	15	PPB
042-CR111-45A	Classroom 111 Sink Faucet	6/15/2016 4:25:00 AM	6/18/2016 11:54:00 AM	BB65126	Copper	0.0	1.3	PPM
042-CR111-45A	Classroom 111 Sink Faucet	6/15/2016 4:25:00 AM	6/18/2016 11:54:00 AM	BB65126	Lead	5	15	PPB
042-CR11-46A	Classroom 111 Drinking Fountain	6/15/2016 4:27:00 AM	6/18/2016 11:57:00 AM	BB65127	Copper	0.3	1.3	PPM
042-CR11-46A	Classroom 111 Drinking Fountain	6/15/2016 4:27:00 AM	6/18/2016 11:57:00 AM	BB65127	Lead	3	15	PPB
042-HDF12-47A	Hall Drinking Fountain 12	6/15/2016 4:32:00 AM	6/18/2016 12:00:00 PM	BB65128	Copper	0.0	1.3	PPM
042-HDF12-47A	Hall Drinking Fountain 12	6/15/2016 4:32:00 AM	6/18/2016 12:00:00 PM	BB65128	Lead	1	15	PPB
042-HDF13-48A	Hall Drinking Fountain 13	6/15/2016 4:35:00 AM	6/18/2016 12:03:00 PM	BB65129	Copper	0.0	1.3	PPM
042-HDF13-48A	Hall Drinking Fountain 13	6/15/2016 4:35:00 AM	6/18/2016 12:03:00 PM	BB65129	Lead	1	15	PPB
042-HDF14-49A	Hall Drinking Fountain 14	6/16/2016 4:36:00 AM	6/18/2016 12:06:00 PM	BB65130	Copper	0.0	1.3	PPM
042-HDF14-49A	Hall Drinking Fountain 14	6/16/2016 4:36:00 AM	6/18/2016 12:06:00 PM	BB65130	Lead	1	15	PPB
042-HDF15-50A	Hall Drinking Fountain 15	6/16/2016 4:38:00 AM	6/18/2016 12:09:00 PM	BB65131	Copper	0.0	1.3	PPM
042-HDF15-50A	Hall Drinking Fountain 15	6/16/2016 4:38:00 AM	6/18/2016 12:09:00 PM	BB65131	Lead	1	15	PPB
042-GRR2-51A	Girls Restroom 2 Sink Faucet 1	6/16/2016 4:41:00 AM	6/18/2016 12:24:00 PM	BB65132	Copper	0.0	1.3	PPM
042-GRR2-51A	Girls Restroom 2 Sink Faucet 1	6/16/2016 4:41:00 AM	6/18/2016 12:24:00 PM	BB65132	Lead	2	15	PPB
042-GRR2-52A	Girls Restroom 2 Sink Faucet 2	6/16/2016 4:43:00 AM	6/18/2016 12:27:00 PM	BB65133	Copper	0.0	1.3	PPM
042-GRR2-52A	Girls Restroom 2 Sink Faucet 2	6/16/2016 4:43:00 AM	6/18/2016 12:27:00 PM	BB65133	Lead	8	15	PPB
042-GRR2-53A	Girls Restroom 2 Water Spigot	6/16/2016 4:45:00 AM	6/18/2016 12:30:00 PM	BB65134	Copper	0.0	1.3	PPM
042-GRR2-53A	Girls Restroom 2 Water Spigot	6/16/2016 4:45:00 AM	6/18/2016 12:30:00 PM	BB65134	Lead	3	15	PPB
042-CR110-54A	Classroom 110 Sink Faucet	6/16/2016 4:50:00 AM	6/18/2016 12:33:00 PM	BB65135	Copper	0.4	1.3	PPM
042-CR110-54A	Classroom 110 Sink Faucet	6/16/2016 4:50:00 AM	6/18/2016 12:33:00 PM	BB65135	Lead	7	15	PPB
042-CR110-55A	Classroom 110 Drinking Fountain	6/16/2016 4:52:00 AM	6/18/2016 12:36:00 PM	BB65136	Copper	0.4	1.3	PPM
042-CR110-55A	Classroom 110 Drinking Fountain	6/16/2016 4:52:00 AM	6/18/2016 12:36:00 PM	BB65136	Lead	1	15	PPB
042-CR109-56A	Classroom 109 Sink Faucet	6/16/2016 4:55:00 AM	6/18/2016 12:39:00 PM	BB65137	Copper	0.4	1.3	PPM
042-CR109-56A	Classroom 109 Sink Faucet	6/16/2016 4:55:00 AM	6/18/2016 12:39:00 PM	BB65137	Lead	1	15	PPB
042-CR109-57A	Classroom 109 Drinking Fountain	6/16/2016 4:57:00 AM	6/18/2016 12:42:00 PM	BB65138	Copper	0.3	1.3	PPM
042-CR109-57A	Classroom 109 Drinking Fountain	6/16/2016 4:57:00 AM	6/18/2016 12:42:00 PM	BB65138	Lead	3	15	PPB
042-CR105-58A	Classroom 105 Sink Faucet	6/16/2016 5:00:00 AM	6/18/2016 12:45:00 PM	BB65139	Copper	0.3	1.3	PPM
042-CR105-58A	Classroom 105 Sink Faucet	6/16/2016 5:00:00 AM	6/18/2016 12:45:00 PM	BB65139	Lead	2	15	PPB

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Grout Elementary School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
042-CR105-59A	Classroom 105 Drinking Fountain	6/16/2016 5:02:00 AM	6/18/2016 12:48:00 PM	BB65140	Copper	0.2	1.3	PPM
042-CR105-59A	Classroom 105 Drinking Fountain	6/16/2016 5:02:00 AM	6/18/2016 12:48:00 PM	BB65140	Lead	2	15	PPB
042-HDF16-60A	Hall Drinking Fountain 16	6/16/2016 5:06:00 AM	6/18/2016 12:51:00 PM	BB65141	Copper	0.0	1.3	PPM
042-HDF16-60A	Hall Drinking Fountain 16	6/16/2016 5:06:00 AM	6/18/2016 12:51:00 PM	BB65141	Lead	13	15	PPB
042-HDF17-61A	Hall Drinking Fountain 17	6/16/2016 5:08:00 AM	6/18/2016 1:12:00 PM	BB65142	Copper	0.0	1.3	PPM
042-HDF17-61A	Hall Drinking Fountain 17	6/16/2016 5:08:00 AM	6/18/2016 1:12:00 PM	BB65142	Lead	21	15	PPB
042-HDF18-62A	Hall Drinking Fountain 18	6/16/2016 5:10:00 AM	6/18/2016 1:15:00 PM	BB65143	Copper	0.0	1.3	PPM
042-HDF18-62A	Hall Drinking Fountain 18	6/16/2016 5:10:00 AM	6/18/2016 1:15:00 PM	BB65143	Lead	12	15	PPB
042-HDF19-63A	Hall Drinking Fountain 19	6/16/2016 5:12:00 AM	6/18/2016 1:18:00 PM	BB65144	Copper	0.0	1.3	PPM
042-HDF19-63A	Hall Drinking Fountain 19	6/16/2016 5:12:00 AM	6/18/2016 1:18:00 PM	BB65144	Lead	27	15	PPB
042-BRR3-64A	Boys Restroom 3 Sink Faucet 1	6/16/2016 5:14:00 AM	6/18/2016 1:21:00 PM	BB65145	Copper	0.0	1.3	PPM
042-BRR3-64A	Boys Restroom 3 Sink Faucet 1	6/16/2016 5:14:00 AM	6/18/2016 1:21:00 PM	BB65145	Lead	23	15	PPB
042-BRR3-65A	Boys Restroom 3 Sink Faucet 2	6/16/2016 5:16:00 AM	6/18/2016 1:24:00 PM	BB65146	Copper	0.0	1.3	PPM
042-BRR3-65A	Boys Restroom 3 Sink Faucet 2	6/16/2016 5:16:00 AM	6/18/2016 1:24:00 PM	BB65146	Lead	17	15	PPB
042-BRR3-66A	Boys Restroom 3 Water Spigot	6/16/2016 5:18:00 AM	6/18/2016 1:27:00 PM	BB65147	Copper	0.0	1.3	PPM
042-BRR3-66A	Boys Restroom 3 Water Spigot	6/16/2016 5:18:00 AM	6/18/2016 1:27:00 PM	BB65147	Lead	14.5	15	PPB
042-TRR-67A	Teacher Restroom Sink Faucet	6/16/2016 5:21:00 AM	6/18/2016 1:30:00 PM	BB65148	Copper	0.1	1.3	PPM
042-TRR-67A	Teacher Restroom Sink Faucet	6/16/2016 5:21:00 AM	6/18/2016 1:30:00 PM	BB65148	Lead	35	15	PPB
042-GRR3-68A	Girls Restroom 3 Sink Faucet 1	6/16/2016 5:23:00 AM	6/18/2016 1:33:00 PM	BB65149	Copper	0.0	1.3	PPM
042-GRR3-68A	Girls Restroom 3 Sink Faucet 1	6/16/2016 5:23:00 AM	6/18/2016 1:33:00 PM	BB65149	Lead	12	15	PPB
042-GRR3-69A	Girls Restroom 3 Sink Faucet 2	6/16/2016 5:25:00 AM	6/18/2016 1:37:00 PM	BB65150	Copper	0.0	1.3	PPM
042-GRR3-69A	Girls Restroom 3 Sink Faucet 2	6/16/2016 5:25:00 AM	6/18/2016 1:37:00 PM	BB65150	Lead	14	15	PPB
042-GRR3-70A	Girls Restroom 3 Water Spigot	6/16/2016 5:27:00 AM	6/18/2016 1:40:00 PM	BB65151	Copper	0.0	1.3	PPM
042-GRR3-70A	Girls Restroom 3 Water Spigot	6/16/2016 5:27:00 AM	6/18/2016 1:40:00 PM	BB65151	Lead	5	15	PPB
042-HDF20-71A	Hall Drinking Fountain 20	6/16/2016 5:30:00 AM	6/18/2016 1:55:00 PM	BB65152	Copper	0.0	1.3	PPM
042-HDF20-71A	Hall Drinking Fountain 20	6/16/2016 5:30:00 AM	6/18/2016 1:55:00 PM	BB65152	Lead	4	15	PPB
042-HDF21-72A	Hall Drinking Fountain 21	6/16/2016 5:32:00 AM	6/18/2016 1:58:00 PM	BB65153	Copper	0.0	1.3	PPM
042-HDF21-72A	Hall Drinking Fountain 21	6/16/2016 5:32:00 AM	6/18/2016 1:58:00 PM	BB65153	Lead	2	15	PPB
042-HDF22-73A	Hall Drinking Fountain 22	6/16/2016 5:34:00 AM	6/18/2016 2:01:00 PM	BB65154	Copper	0.0	1.3	PPM
042-HDF22-73A	Hall Drinking Fountain 22	6/16/2016 5:34:00 AM	6/18/2016 2:01:00 PM	BB65154	Lead	1	15	PPB
042-HDF23-74A	Hall Drinking Fountain 23	6/16/2016 5:37:00 AM	6/18/2016 2:04:00 PM	BB65155	Copper	0.0	1.3	PPM
042-HDF23-74A	Hall Drinking Fountain 23	6/16/2016 5:37:00 AM	6/18/2016 2:04:00 PM	BB65155	Lead	2	15	PPB
042-TL-75A	Teachers Lounge Sink Faucet	6/16/2016 5:34:00 AM	6/18/2016 2:07:00 PM	BB65156	Copper	0.0	1.3	PPM
042-TL-75A	Teachers Lounge Sink Faucet	6/16/2016 5:34:00 AM	6/18/2016 2:07:00 PM	BB65156	Lead	8	15	PPB
042-JS-76A	2nd Floor Janitor Closet Sink Faucet	6/16/2016 5:40:00 AM	6/18/2016 2:10:00 PM	BB65157	Copper	0.1	1.3	PPM
042-JS-76A	2nd Floor Janitor Closet Sink Faucet	6/16/2016 5:40:00 AM	6/18/2016 2:10:00 PM	BB65157	Lead	13	15	PPB
042-BRR4-77A	Boys Restroom 4 Sink Faucet 1	6/16/2016 5:41:00 AM	6/18/2016 2:13:00 PM	BB65158	Copper	0.0	1.3	PPM
042-BRR4-77A	Boys Restroom 4 Sink Faucet 1	6/16/2016 5:41:00 AM	6/18/2016 2:13:00 PM	BB65158	Lead	4	15	PPB
042-BRR4-78A	Boys Restroom 4 Sink Faucet 2	6/16/2016 5:42:00 AM	6/18/2016 2:16:00 PM	BB65159	Copper	0.0	1.3	PPM
042-BRR4-78A	Boys Restroom 4 Sink Faucet 2	6/16/2016 5:42:00 AM	6/18/2016 2:16:00 PM	BB65159	Lead	5	15	PPB
042-BRR4-79A	Boys Restroom 4 Water Spigot	6/16/2016 5:43:00 AM	6/18/2016 2:19:00 PM	BB65160	Copper	0.0	1.3	PPM
042-BRR4-79A	Boys Restroom 4 Water Spigot	6/16/2016 5:43:00 AM	6/18/2016 2:19:00 PM	BB65160	Lead	4	15	PPB
042-HDF24-80A	Hall Drinking Fountain 24	6/16/2016 5:45:00 AM	6/18/2016 2:22:00 PM	BB65161	Copper	0.0	1.3	PPM
042-HDF24-80A	Hall Drinking Fountain 24	6/16/2016 5:45:00 AM	6/18/2016 2:22:00 PM	BB65161	Lead	6	15	PPB
042-HDF25-81A	Hall Drinking Fountain 25	6/16/2016 5:45:00 AM	6/18/2016 2:43:00 PM	BB65162	Copper	0.0	1.3	PPM
042-HDF25-81A	Hall Drinking Fountain 25	6/16/2016 5:45:00 AM	6/18/2016 2:43:00 PM	BB65162	Lead	7	15	PPB
042-GRR4-82A	Girls Restroom 4 Sink Faucet 1	6/16/2016 5:46:00 AM	6/18/2016 2:46:00 PM	BB65163	Copper	0.0	1.3	PPM
042-GRR4-82A	Girls Restroom 4 Sink Faucet 1	6/16/2016 5:46:00 AM	6/18/2016 2:46:00 PM	BB65163	Lead	3	15	PPB
042-GRR4-83A	Girls Restroom 4 Sink Faucet 2	6/16/2016 5:47:00 AM	6/18/2016 2:49:00 PM	BB65164	Copper	0.0	1.3	PPM
042-GRR4-83A	Girls Restroom 4 Sink Faucet 2	6/16/2016 5:47:00 AM	6/18/2016 2:49:00 PM	BB65164	Lead	4	15	PPB
042-GRR4-84A	Girls Restroom 4 Water Spigot	6/16/2016 5:48:00 AM	6/18/2016 2:52:00 PM	BB65165	Copper	0.0	1.3	PPM
042-GRR4-84A	Girls Restroom 4 Water Spigot	6/16/2016 5:48:00 AM	6/18/2016 2:52:00 PM	BB65165	Lead	2	15	PPB
042-HDF26-85A	2nd Floor Hall Drinking Fountain 26	6/16/2016 5:50:00 AM	6/18/2016 2:55:00 PM	BB65166	Copper	0.0	1.3	PPM
042-HDF26-85A	2nd Floor Hall Drinking Fountain 26	6/16/2016 5:50:00 AM	6/18/2016 2:55:00 PM	BB65166	Lead	4	15	PPB
042-HDF27-86A	2nd Floor Hall Drinking Fountain 27	6/16/2016 5:52:00 AM	6/18/2016 2:58:00 PM	BB65167	Copper	0.0	1.3	PPM
042-HDF27-86A	2nd Floor Hall Drinking Fountain 27	6/16/2016 5:52:00 AM	6/18/2016 2:58:00 PM	BB65167	Lead	2	15	PPB
042-HDF28-87A	2nd Floor Hall Drinking Fountain 28	6/16/2016 5:52:00 AM	6/21/2016 9:36:00 AM	BB65168	Copper	0.0	1.3	PPM
042-HDF28-87A	2nd Floor Hall Drinking Fountain 28	6/16/2016 5:52:00 AM	6/21/2016 9:36:00 AM	BB65168	Lead	5	15	PPB

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Grout Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA	Units
						Action Level	
042-HDF29-88A	2nd Floor Hall Drinking Fountain 29	6/16/2016 5:54:00 AM	6/21/2016 9:39:00 AM	BB65169	Copper	0.0	1.3 PPM
042-HDF29-88A	2nd Floor Hall Drinking Fountain 29	6/16/2016 5:54:00 AM	6/21/2016 9:39:00 AM	BB65169	Lead	12	15 PPB
042-HDF30-89A	Basement Hall Drinking Fountain 30	6/16/2016 5:56:00 AM	6/18/2016 3:07:00 PM	BB65170	Copper	0.0	1.3 PPM
042-HDF30-89A	Basement Hall Drinking Fountain 30	6/16/2016 5:56:00 AM	6/18/2016 3:07:00 PM	BB65170	Lead	14.6	15 PPB
042-HDF31-90A	Basement Hall Drinking Fountain 31	6/16/2016 5:57:00 AM	6/18/2016 3:10:00 PM	BB65171	Copper	0.0	1.3 PPM
042-HDF31-90A	Basement Hall Drinking Fountain 31	6/16/2016 5:57:00 AM	6/18/2016 3:10:00 PM	BB65171	Lead	14.8	15 PPB
042-HDF32-91A	Basement Hall Drinking Fountain 32	6/16/2016 5:58:00 AM	6/21/2016 9:12:00 AM	BB65172	Copper	0.0	1.3 PPM
042-HDF32-91A	Basement Hall Drinking Fountain 32	6/16/2016 5:58:00 AM	6/21/2016 9:12:00 AM	BB65172	Lead	6	15 PPB
042-HDF33-92A	Basement Hall Drinking Fountain 33	6/16/2016 6:00:00 AM	6/21/2016 9:15:00 AM	BB65173	Copper	0.0	1.3 PPM
042-HDF33-92A	Basement Hall Drinking Fountain 33	6/16/2016 6:00:00 AM	6/21/2016 9:15:00 AM	BB65173	Lead	5	15 PPB
042-WS1-93A	Exterior Water Spigot 1	6/16/2016 6:01:00 AM	6/21/2016 9:18:00 AM	BB65174	Copper	0.0	1.3 PPM
042-WS1-93A	Exterior Water Spigot 1	6/16/2016 6:01:00 AM	6/21/2016 9:18:00 AM	BB65174	Lead	2	15 PPB
042-WS2-94A	Exterior Water Spigot 2	6/16/2016 6:01:00 AM	6/21/2016 9:21:00 AM	BB65175	Copper	0.0	1.3 PPM
042-WS2-94A	Exterior Water Spigot 2	6/16/2016 6:01:00 AM	6/21/2016 9:21:00 AM	BB65175	Lead	12	15 PPB
042-WS3-95A	Exterior Water Spigot 3	6/16/2016 6:03:00 AM	6/21/2016 9:24:00 AM	BB65176	Copper	0.0	1.3 PPM
042-WS3-95A	Exterior Water Spigot 3	6/16/2016 6:03:00 AM	6/21/2016 9:24:00 AM	BB65176	Lead	7	15 PPB
042-WS4-96A	Exterior Water Spigot 4	6/16/2016 6:05:00 AM	6/21/2016 9:27:00 AM	BB65177	Copper	0.0	1.3 PPM
042-WS4-96A	Exterior Water Spigot 4	6/16/2016 6:05:00 AM	6/21/2016 9:27:00 AM	BB65177	Lead	25	15 PPB
042-WS5-97A	Exterior Water Spigot 5	6/16/2016 6:07:00 AM	6/21/2016 9:30:00 AM	BB65178	Copper	0.0	1.3 PPM
042-WS5-97A	Exterior Water Spigot 5	6/16/2016 6:07:00 AM	6/21/2016 9:30:00 AM	BB65178	Lead	2	15 PPB

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.