

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Harrison Park Middle School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
043-01A Office Sink Faucet	6/20/16 8:45	6/29/16 16:59	606220001	Copper	0.1	1.3	ppm
043-01A Office Sink Faucet	6/20/16 8:45	6/29/16 16:59	606220001	Lead	4	15	ppb
043-02A Janitors Closet Sink Faucet	6/20/16 8:47	6/29/16 17:00	606220002	Copper	0.1	1.3	ppm
043-02A Janitors Closet Sink Faucet	6/20/16 8:47	6/29/16 17:00	606220002	Lead	9	15	ppb
043-03A Office Restroom Sink Faucet	6/20/16 8:47	6/29/16 17:00	606220003	Copper	0.1	1.3	ppm
043-03A Office Restroom Sink Faucet	6/20/16 8:47	6/29/16 17:00	606220003	Lead	4	15	ppb
043-04A Office Back Sink Faucet	6/20/16 8:49	6/29/16 17:00	606220004	Copper	0.1	1.3	ppm
043-04A Office Back Sink Faucet	6/20/16 8:49	6/29/16 17:00	606220004	Lead	15.0	15	ppb
043-05A Classroom 110 Sink Faucet	6/20/16 8:50	6/29/16 17:00	606220005	Copper	0.0	1.3	ppm
043-05A Classroom 110 Sink Faucet	6/20/16 8:50	6/29/16 17:00	606220005	Lead	2	15	ppb
043-06A Classroom 114 Sink Faucet	6/20/16 8:52	6/29/16 17:00	606220006	Copper	0.3	1.3	ppm
043-06A Classroom 114 Sink Faucet	6/20/16 8:52	6/29/16 17:00	606220006	Lead	116	15	ppb
043-07A Classroom 114 Drinking Fountain	6/20/16 8:52	6/29/16 17:00	606220007	Copper	0.0	1.3	ppm
043-07A Classroom 114 Drinking Fountain	6/20/16 8:52	6/29/16 17:00	606220007	Lead	7	15	ppb
043-08A Girls Restroom Sink Faucet 116 Left	6/20/16 8:53	6/29/16 17:00	606220008	Copper	0.3	1.3	ppm
043-08A Girls Restroom Sink Faucet 116 Left	6/20/16 8:53	6/29/16 17:00	606220008	Lead	36	15	ppb
043-09A Girls Restroom Sink Faucet 116 Right	6/20/16 8:53	6/29/16 17:00	606220009	Copper	0.1	1.3	ppm
043-09A Girls Restroom Sink Faucet 116 Right	6/20/16 8:53	6/29/16 17:00	606220009	Lead	29	15	ppb
043-10A Classroom 118 Sink Faucet	6/20/16 8:56	6/29/16 17:03	606220010	Copper	0.1	1.3	ppm
043-10A Classroom 118 Sink Faucet	6/20/16 8:56	6/29/16 17:03	606220010	Lead	22	15	ppb
043-11A Classroom 118 Drinking Fountain	6/20/16 8:53	6/29/16 17:03	606220011	Copper	0.1	1.3	ppm
043-11A Classroom 118 Drinking Fountain	6/20/16 8:53	6/29/16 17:03	606220011	Lead	6	15	ppb
043-12A Classroom 120 Sink Faucet	6/20/16 8:56	6/29/16 17:03	606220012	Copper	0.1	1.3	ppm
043-12A Classroom 120 Sink Faucet	6/20/16 8:56	6/29/16 17:03	606220012	Lead	44	15	ppb
043-13A Classroom 122 Drinking Fountain	6/20/16 8:58	6/29/16 17:03	606220013	Copper	0.0	1.3	ppm
043-13A Classroom 122 Drinking Fountain	6/20/16 8:58	6/29/16 17:03	606220013	Lead	5	15	ppb
043-14A Girls Restroom Sink Faucet	6/20/16 8:59	6/29/16 17:03	606220014	Copper	0.0	1.3	ppm
043-14A Girls Restroom Sink Faucet	6/20/16 8:59	6/29/16 17:03	606220014	Lead	11	15	ppb
043-15A Boys Restroom Sink Faucet Left	6/20/16 9:03	6/29/16 17:03	606220015	Copper	0.1	1.3	ppm
043-15A Boys Restroom Sink Faucet Left	6/20/16 9:03	6/29/16 17:03	606220015	Lead	23	15	ppb
043-16A Boys Restroom Sink Faucet Right	6/20/16 9:03	6/29/16 17:03	606220016	Copper	0.1	1.3	ppm
043-16A Boys Restroom Sink Faucet Right	6/20/16 9:03	6/29/16 17:03	606220016	Lead	97	15	ppb
043-17A Boys Restroom Sink Faucet Spigot	6/20/16 9:03	6/30/16 18:38	606220017	Copper	1.2	1.3	ppm
043-17A Boys Restroom Sink Faucet Spigot	6/20/16 9:03	6/30/16 18:38	606220017	Lead	370	15	ppb
043-18A Gym Small Drinking Fountain North	6/20/16 9:12	6/29/16 17:03	606220018	Copper	0.0	1.3	ppm
043-18A Gym Small Drinking Fountain North	6/20/16 9:12	6/29/16 17:03	606220018	Lead	1	15	ppb
043-20A Gym Small Drinking Fountain South	6/20/16 9:04	6/29/16 17:03	606220019	Copper	0.0	1.3	ppm
043-20A Gym Small Drinking Fountain South	6/20/16 9:04	6/29/16 17:03	606220019	Lead	1	15	ppb
043-22A Gym Large Drinking Fountain	6/20/16 9:15	6/30/16 14:02	606220020	Copper	1.5	1.3	ppm
043-22A Gym Large Drinking Fountain	6/20/16 9:15	6/29/16 17:03	606220020	Lead	22	15	ppb
043-23A Coach Shower	6/20/16 9:08	6/29/16 17:03	606220021	Copper	0.2	1.3	ppm
043-23A Coach Shower	6/20/16 9:08	6/29/16 17:03	606220021	Lead	24	15	ppb
043-24A Locker Room Drinking Fountain	6/20/16 9:17	6/29/16 17:03	606220022	Copper	0.0	1.3	ppm
043-24A Locker Room Drinking Fountain	6/20/16 9:17	6/29/16 17:03	606220022	Lead	12	15	ppb
043-25A Locker Room Sink Faucet Left	6/20/16 9:19	6/29/16 17:04	606220023	Copper	0.2	1.3	ppm
043-25A Locker Room Sink Faucet Left	6/20/16 9:19	6/29/16 17:04	606220023	Lead	112	15	ppb
043-26A Locker Room Sink Faucet Left Middle	6/20/16 9:19	6/29/16 17:04	606220024	Copper	0.1	1.3	ppm
043-26A Locker Room Sink Faucet Left Middle	6/20/16 9:19	6/29/16 17:04	606220024	Lead	26	15	ppb
043-27A Locker Room Sink Faucet Right Middle	6/20/16 9:19	6/29/16 17:04	606220025	Copper	0.1	1.3	ppm
043-27A Locker Room Sink Faucet Right Middle	6/20/16 9:19	6/29/16 17:04	606220025	Lead	16	15	ppb
043-28A Locker Room Sink Faucet Right	6/20/16 9:21	6/29/16 17:04	606220026	Copper	0.1	1.3	ppm
043-28A Locker Room Sink Faucet Right	6/20/16 9:21	6/29/16 17:04	606220026	Lead	26	15	ppb
043-29A Locker Room Sink Faucet Spigot	6/20/16 9:24	6/29/16 17:04	606220027	Copper	0.2	1.3	ppm
043-29A Locker Room Sink Faucet Spigot	6/20/16 9:24	7/1/16 7:57	606220027	Lead	1040	15	ppb
043-30A Classroom 121 Sink Faucet	6/20/16 9:25	6/29/16 17:04	606220028	Copper	0.2	1.3	ppm
043-30A Classroom 121 Sink Faucet	6/20/16 9:25	6/29/16 17:04	606220028	Lead	5	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Harrison Park Middle School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
043-31A Classroom 121 Drinking Fountain	6/20/16 9:25	6/29/16 17:08	606220029	Copper	0.1	1.3	ppm
043-31A Classroom 121 Drinking Fountain	6/20/16 9:25	6/29/16 17:08	606220029	Lead	2	15	ppb
043-32A Classroom 119 Sink Faucet	6/20/16 9:28	6/29/16 17:09	606220030	Copper	0.2	1.3	ppm
043-32A Classroom 119 Sink Faucet	6/20/16 9:28	6/29/16 17:09	606220030	Lead	32	15	ppb
043-33A Classroom 119 Drinking Fountain	6/20/16 9:28	6/29/16 17:09	606220031	Copper	0.0	1.3	ppm
043-33A Classroom 119 Drinking Fountain	6/20/16 9:28	6/29/16 17:09	606220031	Lead	1	15	ppb
043-34A Boys Bathroom Sink Faucet R117	6/20/16 9:29	6/29/16 17:09	606220032	Copper	0.0	1.3	ppm
043-34A Boys Bathroom Sink Faucet R117	6/20/16 9:29	6/29/16 17:09	606220032	Lead	19	15	ppb
043-35A Classroom 115 Sink Faucet	6/20/16 9:31	6/29/16 17:11	606220033	Copper	0.1	1.3	ppm
043-35A Classroom 115 Sink Faucet	6/20/16 9:31	6/29/16 17:11	606220033	Lead	17	15	ppb
043-36A Classroom 115 Drinking Fountain	6/20/16 9:31	6/29/16 17:11	606220034	Copper	0.0	1.3	ppm
043-36A Classroom 115 Drinking Fountain	6/20/16 9:31	6/29/16 17:11	606220034	Lead	5	15	ppb
043-37A Classroom B162 Sink Faucet	6/20/16 9:34	6/29/16 17:11	606220035	Copper	0.3	1.3	ppm
043-37A Classroom B162 Sink Faucet	6/20/16 9:34	6/29/16 17:11	606220035	Lead	7	15	ppb
043-38A Classroom B162 Drinking Fountain	6/20/16 9:34	6/29/16 17:11	606220036	Copper	0.3	1.3	ppm
043-38A Classroom B162 Drinking Fountain	6/20/16 9:34	6/29/16 17:11	606220036	Lead	1	15	ppb
043-39A Classroom B164 Sink Faucet Right	6/20/16 9:35	6/29/16 17:11	606220037	Copper	0.3	1.3	ppm
043-39A Classroom B164 Sink Faucet Right	6/20/16 9:35	6/29/16 17:11	606220037	Lead	0	15	ppb
043-40A Classroom B164 Eye Wash	6/20/16 9:37	6/29/16 17:11	606220038	Copper	0.3	1.3	ppm
043-40A Classroom B164 Eye Wash	6/20/16 9:37	6/29/16 17:11	606220038	Lead	16	15	ppb
043-41A Classroom B164 Sink Faucet Left	6/20/16 9:37	6/29/16 17:11	606220039	Copper	0.3	1.3	ppm
043-41A Classroom B164 Sink Faucet Left	6/20/16 9:37	6/29/16 17:11	606220039	Lead	0	15	ppb
043-42A Classroom B166 Sink Faucet	6/20/16 9:38	6/29/16 17:11	606220040	Copper	0.1	1.3	ppm
043-42A Classroom B166 Sink Faucet	6/20/16 9:38	6/29/16 17:11	606220040	Lead	4	15	ppb
043-43A Classroom B166 Drinking Fountain	6/20/16 9:38	6/29/16 17:11	606220041	Copper	0.1	1.3	ppm
043-43A Classroom B166 Drinking Fountain	6/20/16 9:38	6/29/16 17:11	606220041	Lead	2	15	ppb
043-44A Classroom B168 Sink Faucet	6/20/16 9:41	6/29/16 17:11	606220042	Copper	0.4	1.3	ppm
043-44A Classroom B168 Sink Faucet	6/20/16 9:41	6/29/16 17:11	606220042	Lead	24	15	ppb
043-45A Classroom B168 Drinking Fountain	6/20/16 9:41	6/29/16 17:12	606220043	Copper	0.4	1.3	ppm
043-45A Classroom B168 Drinking Fountain	6/20/16 9:41	6/29/16 17:12	606220043	Lead	2	15	ppb
043-46A Classroom 185 Sink Faucet	6/20/16 9:43	6/29/16 17:12	606220044	Copper	0.6	1.3	ppm
043-46A Classroom 185 Sink Faucet	6/20/16 9:43	6/29/16 17:12	606220044	Lead	1	15	ppb
043-47A Classroom 185 Drinking Fountain	6/20/16 9:43	6/29/16 17:12	606220045	Copper	1.0	1.3	ppm
043-47A Classroom 185 Drinking Fountain	6/20/16 9:43	6/29/16 17:12	606220045	Lead	1	15	ppb
043-48A Classroom 184 Sink Faucet	6/20/16 9:44	6/29/16 17:12	606220046	Copper	0.8	1.3	ppm
043-48A Classroom 184 Sink Faucet	6/20/16 9:44	6/29/16 17:12	606220046	Lead	1	15	ppb
043-49A Classroom 184 Drinking Fountain	6/20/16 9:44	6/29/16 17:12	606220047	Copper	0.8	1.3	ppm
043-49A Classroom 184 Drinking Fountain	6/20/16 9:44	6/29/16 17:12	606220047	Lead	1	15	ppb
043-50A Room 183 Sink Faucet	6/20/16 9:46	6/29/16 17:12	606220048	Copper	0.2	1.3	ppm
043-50A Room 183 Sink Faucet	6/20/16 9:46	6/29/16 17:12	606220048	Lead	26	15	ppb
043-51A Classroom 182 Sink Faucet	6/20/16 9:49	6/29/16 17:12	606220049	Copper	0.5	1.3	ppm
043-51A Classroom 182 Sink Faucet	6/20/16 9:49	6/29/16 17:12	606220049	Lead	4	15	ppb
043-52A Classroom 182 Drinking Fountain	6/20/16 9:49	6/29/16 17:12	606220050	Copper	0.9	1.3	ppm
043-52A Classroom 182 Drinking Fountain	6/20/16 9:49	6/29/16 17:12	606220050	Lead	3	15	ppb
043-53A Classroom 181 Sink Faucet 1	6/20/16 9:49	6/29/16 17:12	606220051	Copper	0.4	1.3	ppm
043-53A Classroom 181 Sink Faucet 1	6/20/16 9:49	6/29/16 17:12	606220051	Lead	1	15	ppb
043-54A Classroom 181 Sink Faucet Eye Wash	6/20/16 9:51	6/29/16 17:12	606220052	Copper	0.1	1.3	ppm
043-54A Classroom 181 Sink Faucet Eye Wash	6/20/16 9:51	6/29/16 17:12	606220052	Lead	31	15	ppb
043-55A Classroom 181 Sink Faucet 2	6/20/16 9:53	6/29/16 17:13	606220053	Copper	0.3	1.3	ppm
043-55A Classroom 181 Sink Faucet 2	6/20/16 9:53	6/29/16 17:13	606220053	Lead	1	15	ppb
043-56A Classroom 181 Drinking Fountain	6/20/16 9:53	6/29/16 17:13	606220054	Copper	0.5	1.3	ppm
043-56A Classroom 181 Drinking Fountain	6/20/16 9:53	6/29/16 17:13	606220054	Lead	3	15	ppb
043-57A Girls Bathroom Sink Faucet 1	6/20/16 9:55	6/29/16 17:13	606220055	Copper	0.6	1.3	ppm
043-57A Girls Bathroom Sink Faucet 1	6/20/16 9:55	6/29/16 17:13	606220055	Lead	3	15	ppb
043-58A Girls Bathroom Sink Faucet 2	6/20/16 9:55	6/29/16 17:13	606220056	Copper	0.5	1.3	ppm
043-58A Girls Bathroom Sink Faucet 2	6/20/16 9:55	6/29/16 17:13	606220056	Lead	3	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Harrison Park Middle School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
043-59A Boys Bathroom Sink Faucet 1	6/20/16 9:58	6/29/16 17:13	606220057	Copper	0.4	1.3	ppm
043-59A Boys Bathroom Sink Faucet 1	6/20/16 9:58	6/29/16 17:13	606220057	Lead	7	15	ppb
043-60A Boys Bathroom Sink Faucet 2	6/20/16 9:58	6/29/16 17:13	606220058	Copper	0.3	1.3	ppm
043-60A Boys Bathroom Sink Faucet 2	6/20/16 9:58	6/29/16 17:13	606220058	Lead	2	15	ppb
043-61A Boys Bathroom Sink Faucet 3	6/20/16 9:58	6/29/16 17:13	606220059	Copper	0.4	1.3	ppm
043-61A Boys Bathroom Sink Faucet 3	6/20/16 9:58	6/29/16 17:13	606220059	Lead	4	15	ppb
043-62A Classroom 178 Sink Faucet	6/20/16 9:59	6/29/16 17:13	606220060	Copper	0.5	1.3	ppm
043-62A Classroom 178 Sink Faucet	6/20/16 9:59	6/29/16 17:13	606220060	Lead	2	15	ppb
043-63A Classroom 178 Drinking Fountain	6/20/16 9:59	7/1/16 7:57	606220061	Copper	0.7	1.3	ppm
043-63A Classroom 178 Drinking Fountain	6/20/16 9:59	6/29/16 17:13	606220061	Lead	3	15	ppb
043-64A Classroom 177 Sink Faucet	6/20/16 10:04	6/29/16 16:52	606220062	Copper	0.5	1.3	ppm
043-64A Classroom 177 Sink Faucet	6/20/16 10:04	6/29/16 16:52	606220062	Lead	2	15	ppb
043-65A Classroom 177 Drinking Fountain	6/20/16 10:04	6/29/16 16:52	606220063	Copper	0.4	1.3	ppm
043-65A Classroom 177 Drinking Fountain	6/20/16 10:04	6/29/16 16:52	606220063	Lead	1	15	ppb
043-66A Classroom 176 Sink Faucet	6/20/16 10:08	6/29/16 16:52	606220064	Copper	0.6	1.3	ppm
043-66A Classroom 176 Sink Faucet	6/20/16 10:08	6/30/16 10:17	606220064	Copper	0.6	1.3	ppm
043-66A Classroom 176 Sink Faucet	6/20/16 10:08	6/29/16 16:52	606220064	Lead	4	15	ppb
043-67A Classroom 176 Drinking Fountain	6/20/16 10:08	6/30/16 10:17	606220065	Copper	0.9	1.3	ppm
043-67A Classroom 176 Drinking Fountain	6/20/16 10:08	6/29/16 16:52	606220065	Copper	1.0	1.3	ppm
043-67A Classroom 176 Drinking Fountain	6/20/16 10:08	6/29/16 16:52	606220065	Lead	2	15	ppb
043-68A Classroom 175 Sink Faucet	6/20/16 10:11	6/29/16 16:52	606220066	Copper	0.6	1.3	ppm
043-68A Classroom 175 Sink Faucet	6/20/16 10:11	6/30/16 10:17	606220066	Copper	0.7	1.3	ppm
043-68A Classroom 175 Sink Faucet	6/20/16 10:11	6/29/16 16:52	606220066	Lead	3	15	ppb
043-69A Classroom 175 Drinking Fountain	6/20/16 10:11	6/29/16 16:52	606220067	Copper	0.8	1.3	ppm
043-69A Classroom 175 Drinking Fountain	6/20/16 10:11	6/29/16 16:52	606220067	Lead	2	15	ppb
043-70A Room Water Spigot 185D Sink Faucet	6/20/16 10:14	6/29/16 16:52	606220068	Copper	0.3	1.3	ppm
043-70A Room Water Spigot 185D Sink Faucet	6/20/16 10:14	6/29/16 16:52	606220068	Lead	7	15	ppb
043-71A Room 185C Sink Faucet	6/20/16 10:17	6/29/16 16:52	606220069	Copper	0.3	1.3	ppm
043-71A Room 185C Sink Faucet	6/20/16 10:17	6/29/16 16:52	606220069	Lead	18	15	ppb
043-72A Room 185A Sink Faucet	6/20/16 10:15	6/29/16 16:52	606220070	Copper	0.2	1.3	ppm
043-72A Room 185A Sink Faucet	6/20/16 10:15	6/29/16 16:52	606220070	Lead	1	15	ppb
043-74A Girls Restroom Sink Faucet	6/20/16 10:19	6/29/16 16:52	606220071	Copper	0.3	1.3	ppm
043-74A Girls Restroom Sink Faucet	6/20/16 10:19	6/29/16 16:52	606220071	Lead	7	15	ppb
043-75A Girls Hand Wash Sink Faucet	6/20/16 10:21	6/29/16 16:53	606220072	Copper	0.2	1.3	ppm
043-75A Girls Hand Wash Sink Faucet	6/20/16 10:21	6/29/16 16:53	606220072	Lead	2	15	ppb
043-76A 2nd Floor Classroom 169A Sink Faucet	6/20/16 10:24	6/29/16 16:53	606220073	Copper	0.3	1.3	ppm
043-76A 2nd Floor Classroom 169A Sink Faucet	6/20/16 10:24	6/29/16 16:53	606220073	Lead	10	15	ppb
043-77A 2nd Floor Classroom 169B Sink Faucet	6/20/16 10:26	6/29/16 16:53	606220074	Copper	0.3	1.3	ppm
043-77A 2nd Floor Classroom 169B Sink Faucet	6/20/16 10:26	6/29/16 16:53	606220074	Lead	3	15	ppb
043-78A 2nd Floor Classroom 169B Drinking Fountain	6/20/16 10:26	7/1/16 7:57	606220075	Copper	0.8	1.3	ppm
043-78A 2nd Floor Classroom 169B Drinking Fountain	6/20/16 10:26	6/29/16 16:53	606220075	Copper	0.8	1.3	ppm
043-78A 2nd Floor Classroom 169B Drinking Fountain	6/20/16 10:26	6/29/16 16:53	606220075	Lead	3	15	ppb
043-79A Shop Sink Faucet	6/20/16 10:26	6/29/16 16:53	606220076	Copper	0.3	1.3	ppm
043-79A Shop Sink Faucet	6/20/16 10:26	6/29/16 16:53	606220076	Lead	5	15	ppb
043-80A Shop Drinking Fountain	6/20/16 10:26	6/29/16 16:53	606220077	Copper	0.3	1.3	ppm
043-80A Shop Drinking Fountain	6/20/16 10:26	6/29/16 16:53	606220077	Lead	6	15	ppb
043-81A Health Center Breakroom Sink Faucet	6/20/16 10:31	6/29/16 16:53	606220078	Copper	0.8	1.3	ppm
043-81A Health Center Breakroom Sink Faucet	6/20/16 10:31	6/29/16 16:53	606220078	Lead	3	15	ppb
043-82A Exam Room 1 Sink Faucet	6/20/16 10:31	6/29/16 16:53	606220079	Copper	0.4	1.3	ppm
043-82A Exam Room 1 Sink Faucet	6/20/16 10:31	6/29/16 16:53	606220079	Lead	4	15	ppb
043-83A Exam Room 2 Sink Faucet	6/20/16 10:34	6/29/16 16:53	606220080	Copper	0.4	1.3	ppm
043-83A Exam Room 2 Sink Faucet	6/20/16 10:34	6/29/16 16:53	606220080	Lead	9	15	ppb
043-84A Lab Sink Faucet 1	6/20/16 10:33	6/29/16 16:53	606220081	Copper	0.5	1.3	ppm
043-84A Lab Sink Faucet 1	6/20/16 10:33	6/29/16 16:53	606220081	Lead	8	15	ppb
043-85A Lab Eye Wash	6/20/16 10:33	6/29/16 16:54	606220082	Copper	0.3	1.3	ppm
043-85A Lab Eye Wash	6/20/16 10:33	6/29/16 16:54	606220082	Lead	1	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Harrison Park Middle School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
043-86A Lab Sink Faucet 2	6/20/16 10:34	6/30/16 10:18	606220083	Copper	0.7	1.3	ppm
043-86A Lab Sink Faucet 2	6/20/16 10:34	6/29/16 16:54	606220083	Lead	30	15	ppb
043-87A Bathroom Sink Faucet	6/20/16 10:38	7/1/16 7:57	606220084	Copper	0.5	1.3	ppm
043-87A Bathroom Sink Faucet	6/20/16 10:38	6/29/16 16:54	606220084	Lead	4	15	ppb
043-88A Nurse Sink Faucet	6/20/16 10:40	6/30/16 10:18	606220085	Copper	0.6	1.3	ppm
043-88A Nurse Sink Faucet	6/20/16 10:40	6/29/16 16:54	606220085	Lead	7	15	ppb
043-89A Teachers Lounge Sink Faucet	6/20/16 10:39	6/29/16 16:54	606220086	Copper	0.5	1.3	ppm
043-89A Teachers Lounge Sink Faucet	6/20/16 10:39	6/29/16 16:54	606220086	Lead	1	15	ppb
043-90A Store Room Sink Faucet 1	6/20/16 10:44	6/29/16 16:54	606220087	Copper	0.2	1.3	ppm
043-90A Store Room Sink Faucet 1	6/20/16 10:44	6/29/16 16:54	606220087	Lead	28	15	ppb
043-91A Store Room Sink Faucet 2	6/20/16 10:43	6/29/16 16:54	606220088	Copper	0.1	1.3	ppm
043-91A Store Room Sink Faucet 2	6/20/16 10:43	6/29/16 16:54	606220088	Lead	6	15	ppb
043-92A Cafeteria Drinking Fountain 1	6/20/16 10:48	6/29/16 16:54	606220089	Copper	0.0	1.3	ppm
043-92A Cafeteria Drinking Fountain 1	6/20/16 10:48	6/29/16 16:54	606220089	Lead	9	15	ppb
043-93A Cafeteria Drinking Fountain 2	6/20/16 10:51	6/29/16 16:54	606220090	Copper	0.0	1.3	ppm
043-93A Cafeteria Drinking Fountain 2	6/20/16 10:51	6/29/16 16:54	606220090	Lead	6	15	ppb
043-94A Kitchen White Hand Wash Sink Faucet Near Outside Door	6/20/16 10:47	6/29/16 16:54	606220091	Copper	0.1	1.3	ppm
043-94A Kitchen White Hand Wash Sink Faucet Near Outside Door	6/20/16 10:47	6/29/16 16:54	606220091	Lead	11	15	ppb
043-95A Kitchen Food Prep Sink Faucet Sprayer	6/20/16 10:47	6/29/16 16:54	606220092	Copper	0.1	1.3	ppm
043-95A Kitchen Food Prep Sink Faucet Sprayer	6/20/16 10:47	6/29/16 16:54	606220092	Lead	2	15	ppb
043-96A Kitchen Food Prep Sink Faucet	6/20/16 10:49	6/29/16 16:54	606220093	Copper	0.1	1.3	ppm
043-96A Kitchen Food Prep Sink Faucet	6/20/16 10:49	6/29/16 16:54	606220093	Lead	11	15	ppb
043-97A Kitchen Sink Faucet 2 Tub Dish Wash	6/20/16 10:56	6/29/16 16:54	606220094	Copper	0.1	1.3	ppm
043-97A Kitchen Sink Faucet 2 Tub Dish Wash	6/20/16 10:56	6/29/16 16:54	606220094	Lead	4	15	ppb
043-98A Kitchen Spray 2 Tub Wash Sink Faucet	6/20/16 10:56	6/29/16 16:54	606220095	Copper	0.0	1.3	ppm
043-98A Kitchen Spray 2 Tub Wash Sink Faucet	6/20/16 10:56	6/29/16 16:54	606220095	Lead	0	15	ppb
043-99A Kitchen Sink Faucet Small White	6/20/16 10:59	6/29/16 16:54	606220096	Copper	0.1	1.3	ppm
043-99A Kitchen Sink Faucet Small White	6/20/16 10:59	6/29/16 16:54	606220096	Lead	2	15	ppb
043-100A Kitchen Spigot	6/20/16 11:01	6/29/16 16:54	606220097	Copper	0.4	1.3	ppm
043-100A Kitchen Spigot	6/20/16 11:01	6/29/16 16:54	606220097	Lead	234	15	ppb
043-101A Kitchen Bathroom Sink Faucet	6/20/16 11:04	6/29/16 16:54	606220098	Copper	0.1	1.3	ppm
043-101A Kitchen Bathroom Sink Faucet	6/20/16 11:04	6/29/16 16:54	606220098	Lead	9	15	ppb
043-102A Girls Restroom Sink Faucet Left	6/20/16 11:06	6/29/16 16:55	606220099	Copper	0.3	1.3	ppm
043-102A Girls Restroom Sink Faucet Left	6/20/16 11:06	6/29/16 16:55	606220099	Lead	10	15	ppb
043-103A Girls Restroom Sink Faucet Right	6/20/16 11:06	6/29/16 17:21	6062200100	Copper	0.2	1.3	ppm
043-103A Girls Restroom Sink Faucet Right	6/20/16 11:06	6/29/16 17:21	6062200100	Lead	6	15	ppb
043-104A Classroom 149 Sink Faucet	6/20/16 11:07	6/29/16 16:55	6062200101	Copper	0.1	1.3	ppm
043-104A Classroom 149 Sink Faucet	6/20/16 11:07	6/29/16 16:55	6062200101	Lead	2	15	ppb
043-105A Classroom 149 Drinking Fountain	6/20/16 11:09	6/29/16 16:55	6062200102	Copper	0.0	1.3	ppm
043-105A Classroom 149 Drinking Fountain	6/20/16 11:09	6/29/16 16:55	6062200102	Lead	32	15	ppb
043-106A Boys Restroom Sink Faucet	6/20/16 11:10	6/29/16 16:55	6062200103	Copper	0.2	1.3	ppm
043-106A Boys Restroom Sink Faucet	6/20/16 11:10	6/29/16 16:55	6062200103	Lead	30	15	ppb
043-107A Library Sink Faucet	6/20/16 11:14	6/29/16 16:55	6062200104	Copper	0.4	1.3	ppm
043-107A Library Sink Faucet	6/20/16 11:14	6/29/16 16:55	6062200104	Lead	12	15	ppb
043-108A Classroom 145 Sink Faucet	6/20/16 11:14	6/29/16 16:55	6062200105	Copper	0.1	1.3	ppm
043-108A Classroom 145 Sink Faucet	6/20/16 11:14	6/29/16 16:55	6062200105	Lead	12	15	ppb
043-109A Janitors Closet Sink Faucet	6/20/16 11:16	6/29/16 16:55	6062200106	Copper	0.3	1.3	ppm
043-109A Janitors Closet Sink Faucet	6/20/16 11:16	6/29/16 16:55	6062200106	Lead	7	15	ppb
043-110A Girls Restroom Sink Faucet	6/20/16 11:17	6/29/16 16:55	6062200107	Copper	0.1	1.3	ppm
043-110A Girls Restroom Sink Faucet	6/20/16 11:17	6/29/16 16:55	6062200107	Lead	12	15	ppb
043-111A Girls Restroom Drinking Fountain	6/20/16 11:18	6/29/16 16:55	6062200108	Copper	0.0	1.3	ppm
043-111A Girls Restroom Drinking Fountain	6/20/16 11:18	6/29/16 16:55	6062200108	Lead	13	15	ppb
043-112A Mens Restroom Sink Faucet	6/20/16 11:19	6/29/16 16:55	6062200109	Copper	0.4	1.3	ppm
043-112A Mens Restroom Sink Faucet	6/20/16 11:19	6/29/16 16:55	6062200109	Lead	10	15	ppb
043-113A Classroom 163 Sink Faucet	6/20/16 11:22	6/29/16 16:55	6062200110	Copper	0.1	1.3	ppm
043-113A Classroom 163 Sink Faucet	6/20/16 11:22	6/29/16 16:55	6062200110	Lead	18	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Harrison Park Middle School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
043-114A Classroom 163 Drinking Fountain	6/20/16 11:23	6/29/16 16:55	6062200111	Copper	0.0	1.3	ppm
043-114A Classroom 163 Drinking Fountain	6/20/16 11:23	6/29/16 16:55	6062200111	Lead	6	15	ppb
043-115A Janitors Closet Sink Faucet	6/20/16 11:23	6/29/16 16:56	6062200112	Copper	0.2	1.3	ppm
043-115A Janitors Closet Sink Faucet	6/20/16 11:23	6/29/16 16:56	6062200112	Lead	4	15	ppb
043-116A Girls Bathroom Sink Faucet	6/20/16 11:25	6/29/16 16:56	6062200113	Copper	0.2	1.3	ppm
043-116A Girls Bathroom Sink Faucet	6/20/16 11:25	6/29/16 16:56	6062200113	Lead	5	15	ppb
043-117A Boys Bathroom Sink Faucet	6/20/16 11:28	6/29/16 16:56	6062200114	Copper	0.2	1.3	ppm
043-117A Boys Bathroom Sink Faucet	6/20/16 11:28	6/29/16 16:56	6062200114	Lead	2	15	ppb
043-118A Classroom 169 Sink Faucet	6/20/16 11:28	6/29/16 16:56	6062200115	Copper	0.1	1.3	ppm
043-118A Classroom 169 Sink Faucet	6/20/16 11:28	6/29/16 16:56	6062200115	Lead	10	15	ppb
043-119A Classroom 169 Drinking Fountain	6/20/16 11:28	6/29/16 16:56	6062200116	Copper	0.1	1.3	ppm
043-119A Classroom 169 Drinking Fountain	6/20/16 11:28	6/29/16 16:56	6062200116	Lead	7	15	ppb
043-120A Hallway Drinking Fountain	6/20/16 11:31	6/29/16 16:56	6062200117	Copper	0.0	1.3	ppm
043-120A Hallway Drinking Fountain	6/20/16 11:31	6/29/16 16:56	6062200117	Lead	29	15	ppb
043-121A Custodial Office Sink Faucet	6/20/16 11:32	6/29/16 16:56	6062200118	Copper	0.3	1.3	ppm
043-121A Custodial Office Sink Faucet	6/20/16 11:32	6/29/16 16:56	6062200118	Lead	8	15	ppb
043-122A Custodial Office Shower	6/20/16 11:34	6/29/16 16:56	6062200119	Copper	0.1	1.3	ppm
043-122A Custodial Office Shower	6/20/16 11:34	6/29/16 16:56	6062200119	Lead	6	15	ppb
043-123A Hall Drinking Fountain	6/20/16 11:34	6/29/16 16:56	6062200120	Copper	0.1	1.3	ppm
043-123A Hall Drinking Fountain	6/20/16 11:34	6/29/16 16:56	6062200120	Lead	14.6	15	ppb
043-124A Faculty Room 136 Sink Faucet	6/20/16 11:43	6/29/16 16:56	6062200121	Copper	0.1	1.3	ppm
043-124A Faculty Room 136 Sink Faucet	6/20/16 11:43	6/29/16 16:56	6062200121	Lead	24	15	ppb
043-125A Faculty Room 136 Drinking Fountain	6/20/16 11:44	6/29/16 16:57	6062200122	Copper	0.0	1.3	ppm
043-125A Faculty Room 136 Drinking Fountain	6/20/16 11:44	6/29/16 16:57	6062200122	Lead	13	15	ppb
043-126A Faculty Room 136 Bathroom Sink Faucet	6/20/16 11:42	6/29/16 16:57	6062200123	Copper	0.0	1.3	ppm
043-126A Faculty Room 136 Bathroom Sink Faucet	6/20/16 11:42	6/29/16 16:57	6062200123	Lead	2	15	ppb
043-127A Handy Restroom Bathroom Sink Faucet	6/20/16 11:45	6/29/16 16:57	6062200124	Copper	0.1	1.3	ppm
043-127A Handy Restroom Bathroom Sink Faucet	6/20/16 11:45	6/29/16 16:57	6062200124	Lead	3	15	ppb
043-128A Janitors Closet Sink Faucet	6/20/16 11:48	6/29/16 16:57	6062200125	Copper	0.1	1.3	ppm
043-128A Janitors Closet Sink Faucet	6/20/16 11:48	6/29/16 16:57	6062200125	Lead	5	15	ppb
043-129A Classroom 130 Sink Faucet	6/20/16 11:48	6/29/16 16:57	6062200126	Copper	0.2	1.3	ppm
043-129A Classroom 130 Sink Faucet	6/20/16 11:48	6/29/16 16:57	6062200126	Lead	5	15	ppb
043-130A Stage Sink Faucet	6/20/16 11:52	6/29/16 16:57	6062200127	Copper	0.1	1.3	ppm
043-130A Stage Sink Faucet	6/20/16 11:52	6/29/16 16:57	6062200127	Lead	7	15	ppb
043-131A Entry Drinking Fountain 1	6/20/16 11:52	6/29/16 16:57	6062200128	Copper	0.0	1.3	ppm
043-131A Entry Drinking Fountain 1	6/20/16 11:52	6/29/16 16:57	6062200128	Lead	1	15	ppb
043-132A Entry Drinking Fountain 2	6/20/16 11:55	6/29/16 16:57	6062200129	Copper	0.1	1.3	ppm
043-132A Entry Drinking Fountain 2	6/20/16 11:55	6/29/16 16:57	6062200129	Lead	6	15	ppb
043-133A Classroom 109 Drinking Fountain	6/20/16 11:55	6/29/16 16:57	6062200130	Copper	0.1	1.3	ppm
043-133A Classroom 109 Drinking Fountain	6/20/16 11:55	6/29/16 16:57	6062200130	Lead	16	15	ppb
043-134A Girls Bathroom Outside 109 Sink Faucet Left	6/20/16 11:59	6/29/16 16:57	6062200131	Copper	0.1	1.3	ppm
043-134A Girls Bathroom Outside 109 Sink Faucet Left	6/20/16 11:59	6/29/16 16:57	6062200131	Lead	22	15	ppb
043-135A Girls Bathroom Outside 109 Sink Faucet Right	6/20/16 11:59	6/29/16 16:58	6062200132	Copper	0.1	1.3	ppm
043-135A Girls Bathroom Outside 109 Sink Faucet Right	6/20/16 11:59	6/29/16 16:58	6062200132	Lead	27	15	ppb
043-136A Classroom 167 Sink Faucet	6/20/16 11:58	6/29/16 16:58	6062200133	Copper	0.1	1.3	ppm
043-136A Classroom 167 Sink Faucet	6/20/16 11:58	6/29/16 16:58	6062200133	Lead	26	15	ppb
043-137A Classroom 167 Drinking Fountain	6/20/16 11:59	6/29/16 16:58	6062200134	Copper	0.0	1.3	ppm
043-137A Classroom 167 Drinking Fountain	6/20/16 11:59	6/29/16 16:58	6062200134	Lead	13	15	ppb
043-138A Classroom 159 Sink Faucet Left	6/20/16 12:03	6/29/16 16:58	6062200135	Copper	0.3	1.3	ppm
043-138A Classroom 159 Sink Faucet Left	6/20/16 12:03	6/29/16 16:58	6062200135	Lead	0	15	ppb
043-140A Classroom 159 Sink Faucet Right	6/20/16 12:03	6/29/16 16:58	6062200136	Copper	0.3	1.3	ppm
043-140A Classroom 159 Sink Faucet Right	6/20/16 12:03	6/29/16 16:58	6062200136	Lead	1	15	ppb
043-141A Womens Restroom Near 168 Sink Faucet	6/20/16 12:03	6/29/16 16:58	6062200137	Copper	0.1	1.3	ppm
043-141A Womens Restroom Near 168 Sink Faucet	6/20/16 12:03	6/29/16 16:58	6062200137	Lead	10	15	ppb
043-142A Mens Restroom Near 168 Sink Faucet	6/20/16 12:06	6/29/16 16:58	6062200138	Copper	0.1	1.3	ppm
043-142A Mens Restroom Near 168 Sink Faucet	6/20/16 12:06	6/29/16 16:58	6062200138	Lead	3	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Harrison Park Middle School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
043-143A Classroom 158 Sink Faucet Left	6/20/16 12:08	6/29/16 16:58	6062200139	Copper	0.4	1.3	ppm
043-143A Classroom 158 Sink Faucet Left	6/20/16 12:08	6/29/16 16:58	6062200139	Lead	1	15	ppb
043-144A Classroom 158 Sink Faucet Right	6/20/16 12:04	6/29/16 16:58	6062200140	Copper	0.4	1.3	ppm
043-144A Classroom 158 Sink Faucet Right	6/20/16 12:04	6/29/16 16:58	6062200140	Lead	1	15	ppb
043-146A Courtyard #2 Outside Spigot	6/20/16 12:46	6/29/16 16:58	6062200141	Copper	0.0	1.3	ppm
043-146A Courtyard #2 Outside Spigot	6/20/16 12:46	6/29/16 16:58	6062200141	Lead	11	15	ppb
043-147A Courtyard #1 Outside Spigot	6/20/16 12:26	6/29/16 16:59	6062200142	Copper	0.1	1.3	ppm
043-147A Courtyard #1 Outside Spigot	6/20/16 12:26	6/29/16 16:59	6062200142	Lead	38	15	ppb
043-149A Outside Spigot West Side Near Gym 1	6/20/16 13:06	6/29/16 16:59	6062200143	Copper	0.1	1.3	ppm
043-149A Outside Spigot West Side Near Gym 1	6/20/16 13:06	6/29/16 16:59	6062200143	Lead	64	15	ppb
043-150A Outside Spigot West Side Near Gym 2	6/20/16 13:03	6/29/16 16:59	6062200144	Copper	0.0	1.3	ppm
043-150A Outside Spigot West Side Near Gym 2	6/20/16 13:03	6/29/16 16:59	6062200144	Lead	5	15	ppb
043-151A Outside Spigot East Side Near CR114	6/20/16 12:59	6/29/16 16:59	6062200145	Copper	0.3	1.3	ppm
043-151A Outside Spigot East Side Near CR114	6/20/16 12:59	6/29/16 16:59	6062200145	Lead	46	15	ppb
043-152A Outside Spigot East Side Near Audit	6/20/16 12:51	6/29/16 16:59	6062200146	Copper	0.1	1.3	ppm
043-152A Outside Spigot East Side Near Audit	6/20/16 12:51	6/29/16 16:59	6062200146	Lead	20	15	ppb
043-153A Outside Spigot East Side Near Library	6/20/16 12:55	6/29/16 16:59	6062200147	Copper	0.3	1.3	ppm
043-153A Outside Spigot East Side Near Library	6/20/16 12:55	6/29/16 16:59	6062200147	Lead	107	15	ppb
043-154A Kitchen Dish Sink Faucet	6/20/16 12:18	6/29/16 16:59	6062200148	Copper	0.2	1.3	ppm
043-154A Kitchen Dish Sink Faucet	6/20/16 12:18	6/29/16 16:59	6062200148	Lead	6	15	ppb
043-155A Janitors Closet Sink Faucet	6/20/16 12:15	6/29/16 16:59	6062200149	Copper	0.1	1.3	ppm
043-155A Janitors Closet Sink Faucet	6/20/16 12:15	6/29/16 16:59	6062200149	Lead	8	15	ppb
043-156A Hallway Water Fountain	6/20/16 12:15	6/29/16 16:59	6062200150	Copper	0.0	1.3	ppm
043-156A Hallway Water Fountain	6/20/16 12:15	6/29/16 16:59	6062200150	Lead	8	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.