

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Hayhurst Elementary School

Client Sample ID	Sample Location	Collection Date	Analysis Date	Sample ID	Analyte	Results	EPA	
							Action Level	Units
044-01A	Boiler Room Bathroom Sink Faucet Faucet	6/21/16 8:03	7/17/2016	1606D80-01A	Copper	ND	1.3	ppm
044-01A	Boiler Room Bathroom Sink Faucet Faucet	6/21/16 8:03	7/17/2016	1606D80-01A	Lead	10	15	ppb
044-02A	Gymnasium Office Bathroom Sink Faucet Faucet	6/21/16 8:05	7/17/2016	1606D80-02A	Copper	ND	1.3	ppm
044-02A	Gymnasium Office Bathroom Sink Faucet Faucet	6/21/16 8:05	7/17/2016	1606D80-02A	Lead	18	15	ppb
044-03A	Gymnasium Drinking Fountain	6/21/16 8:07	7/17/2016	1606D80-03A	Copper	ND	1.3	ppm
044-03A	Gymnasium Drinking Fountain	6/21/16 8:07	7/17/2016	1606D80-03A	Lead	17	15	ppb
044-04A	Girls Bathroom Near Gymnasium Sink Faucet 1	6/21/16 8:10	7/17/2016	1606D80-04A	Copper	ND	1.3	ppm
044-04A	Girls Bathroom Near Gymnasium Sink Faucet 1	6/21/16 8:10	7/17/2016	1606D80-04A	Lead	3	15	ppb
044-05A	Girls Bathroom Near Gymnasium Sink Faucet 2	6/21/16 8:12	7/17/2016	1606D80-05A	Copper	ND	1.3	ppm
044-05A	Girls Bathroom Near Gymnasium Sink Faucet 2	6/21/16 8:12	7/17/2016	1606D80-05A	Lead	3	15	ppb
044-06A	Girls Bathroom Near Gymnasium Water Spigot	6/21/16 8:15	7/17/2016	1606D80-06A	Copper	ND	1.3	ppm
044-06A	Girls Bathroom Near Gymnasium Water Spigot	6/21/16 8:15	7/17/2016	1606D80-06A	Lead	12	15	ppb
044-07A	Custodial-4 Near Gymnasium Sink Faucet Faucet	6/21/16 8:17	7/17/2016	1606D80-07A	Copper	ND	1.3	ppm
044-07A	Custodial-4 Near Gymnasium Sink Faucet Faucet	6/21/16 8:17	7/17/2016	1606D80-07A	Lead	1	15	ppb
044-08A	Boy Bathroom Near 14 Sink Faucet 1 (left)	6/21/16 8:11	7/17/2016	1606D80-08A	Copper	ND	1.3	ppm
044-08A	Boy Bathroom Near 14 Sink Faucet 1 (left)	6/21/16 8:11	7/17/2016	1606D80-08A	Lead	4	15	ppb
044-09A	Boy Bathroom Near 14 Sink Faucet 2 (right)	6/21/16 8:13	7/17/2016	1606D80-09A	Copper	ND	1.3	ppm
044-09A	Boy Bathroom Near 14 Sink Faucet 2 (right)	6/21/16 8:13	7/17/2016	1606D80-09A	Lead	4	15	ppb
044-10A	Boys Bathroom Near 14 Water Spigot	6/21/16 8:15	7/17/2016	1606D80-10A	Copper	ND	1.3	ppm
044-10A	Boys Bathroom Near 14 Water Spigot	6/21/16 8:15	7/17/2016	1606D80-10A	Lead	3	15	ppb
044-11A	Room 14 Sink Faucet	6/21/16 8:05	7/17/2016	1606D80-11A	Copper	ND	1.3	ppm
044-11A	Room 14 Sink Faucet	6/21/16 8:05	7/17/2016	1606D80-11A	Lead	3	15	ppb
044-12A	Room 14 Drinking Fountain	6/21/16 8:08	7/17/2016	1606D80-12A	Copper	ND	1.3	ppm
044-12A	Room 14 Drinking Fountain	6/21/16 8:08	7/17/2016	1606D80-12A	Lead	5	15	ppb
044-13A	Room 26 Sink Faucet	6/21/16 8:21	7/17/2016	1606D80-13A	Copper	ND	1.3	ppm
044-13A	Room 26 Sink Faucet	6/21/16 8:21	7/17/2016	1606D80-13A	Lead	21	15	ppb
044-14A	Room 15 Sink Faucet	6/21/16 8:13	7/17/2016	1606D80-14A	Copper	0.2	1.3	ppm
044-14A	Room 15 Sink Faucet	6/21/16 8:13	7/17/2016	1606D80-14A	Lead	25	15	ppb
044-15A	Room 15 Drinking Fountain	6/21/16 8:26	7/17/2016	1606D80-15A	Copper	0.1	1.3	ppm
044-15A	Room 15 Drinking Fountain	6/21/16 8:26	7/17/2016	1606D80-15A	Lead	11	15	ppb
044-16A	Room 25 Sink Faucet	6/21/16 8:29	7/17/2016	1606D80-16A	Copper	ND	1.3	ppm
044-16A	Room 25 Sink Faucet	6/21/16 8:29	7/17/2016	1606D80-16A	Lead	2	15	ppb
044-17A	Room 25 Drinking Fountain	6/21/16 8:32	7/17/2016	1606D80-17A	Copper	ND	1.3	ppm
044-17A	Room 25 Drinking Fountain	6/21/16 8:32	7/17/2016	1606D80-17A	Lead	2	15	ppb
044-18A	Room 16 Sink Faucet	6/21/16 8:36	7/17/2016	1606D80-18A	Copper	ND	1.3	ppm
044-18A	Room 16 Sink Faucet	6/21/16 8:36	7/17/2016	1606D80-18A	Lead	21	15	ppb
044-19A	Room 16 Drinking Fountain	6/21/16 8:39	7/17/2016	1606D80-19A	Copper	ND	1.3	ppm
044-19A	Room 16 Drinking Fountain	6/21/16 8:39	7/17/2016	1606D80-19A	Lead	5	15	ppb
044-20A	Room 24 Sink Faucet	6/21/16 8:44	7/17/2016	1606D80-20A	Copper	ND	1.3	ppm
044-20A	Room 24 Sink Faucet	6/21/16 8:44	7/17/2016	1606D80-20A	Lead	7	15	ppb
044-21A	Room 24 Drinking Fountain	6/21/16 8:47	7/17/2016	1606D80-21A	Copper	ND	1.3	ppm
044-21A	Room 24 Drinking Fountain	6/21/16 8:47	7/17/2016	1606D80-21A	Lead	3	15	ppb
044-22A	Room 17 Sink Faucet	6/21/16 8:50	7/17/2016	1606D80-22A	Copper	ND	1.3	ppm
044-22A	Room 17 Sink Faucet	6/21/16 8:50	7/17/2016	1606D80-22A	Lead	14	15	ppb
044-23A	Room 17 Drinking Fountain	6/21/16 8:52	7/17/2016	1606D80-23A	Copper	ND	1.3	ppm
044-23A	Room 17 Drinking Fountain	6/21/16 8:52	7/17/2016	1606D80-23A	Lead	5	15	ppb
044-24A	Room 23 Sink Faucet	6/21/16 8:55	7/17/2016	1606D80-24A	Copper	ND	1.3	ppm
044-24A	Room 23 Sink Faucet	6/21/16 8:55	7/17/2016	1606D80-24A	Lead	13	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Hayhurst Elementary School

Client Sample ID	Sample Location	Collection Date	Analysis Date	Sample ID	Analyte	Results	EPA	
							Action	Units
							Level	
044-25A	Room 23 Drinking Fountain	6/21/16 8:57	7/17/2016	1606D80-25A	Copper	ND	1.3	ppm
044-25A	Room 23 Drinking Fountain	6/21/16 8:57	7/17/2016	1606D80-25A	Lead	3	15	ppb
044-26A	Room 18 Sink Faucet	6/21/16 8:59	7/17/2016	1606D80-26A	Copper	ND	1.3	ppm
044-26A	Room 18 Sink Faucet	6/21/16 8:59	7/17/2016	1606D80-26A	Lead	10	15	ppb
044-27A	Room 18 Drinking Fountain	6/21/16 9:01	7/17/2016	1606D80-27A	Copper	ND	1.3	ppm
044-27A	Room 18 Drinking Fountain	6/21/16 9:01	7/17/2016	1606D80-27A	Lead	3	15	ppb
044-28A	Room 22 Sink Faucet	6/21/16 9:08	7/17/2016	1606D80-28A	Copper	0.1	1.3	ppm
044-28A	Room 22 Sink Faucet	6/21/16 9:08	7/17/2016	1606D80-28A	Lead	16	15	ppb
044-29A	Room 22 Drinking Fountain	6/21/16 9:10	7/17/2016	1606D80-29A	Copper	0.1	1.3	ppm
044-29A	Room 22 Drinking Fountain	6/21/16 9:10	7/17/2016	1606D80-29A	Lead	4	15	ppb
044-30A	Room 19 Sink Faucet	6/21/16 9:04	7/17/2016	1606D80-30A	Copper	ND	1.3	ppm
044-30A	Room 19 Sink Faucet	6/21/16 9:04	7/17/2016	1606D80-30A	Lead	6	15	ppb
044-31A	Room 19 Drinking Fountain	6/21/16 9:06	7/17/2016	1606D80-31A	Copper	ND	1.3	ppm
044-31A	Room 19 Drinking Fountain	6/21/16 9:06	7/17/2016	1606D80-31A	Lead	4	15	ppb
044-32A	Boys Bathroom Near 22 Sink Faucet (left)	6/21/16 9:13	7/17/2016	1606D80-32A	Copper	ND	1.3	ppm
044-32A	Boys Bathroom Near 22 Sink Faucet (left)	6/21/16 9:13	7/17/2016	1606D80-32A	Lead	3	15	ppb
044-33A	Boys Bathroom Near 22 Sink Faucet (right)	6/21/16 9:15	7/17/2016	1606D80-33A	Copper	ND	1.3	ppm
044-33A	Boys Bathroom Near 22 Sink Faucet (right)	6/21/16 9:15	7/17/2016	1606D80-33A	Lead	4	15	ppb
044-34A	Boys Bathroom Near 22 Water Spigot	6/21/16 9:16	7/17/2016	1606D80-34A	Copper	0.2	1.3	ppm
044-34A	Boys Bathroom Near 22 Water Spigot	6/21/16 9:16	7/17/2016	1606D80-34A	Lead	38	15	ppb
044-35A	Room 20 Sink Faucet	6/21/16 9:20	7/17/2016	1606D80-35A	Copper	0.1	1.3	ppm
044-35A	Room 20 Sink Faucet	6/21/16 9:20	7/17/2016	1606D80-35A	Lead	58	15	ppb
044-36A	Room 20 Drinking Fountain	6/21/16 9:22	7/17/2016	1606D80-36A	Copper	ND	1.3	ppm
044-36A	Room 20 Drinking Fountain	6/21/16 9:22	7/17/2016	1606D80-36A	Lead	3	15	ppb
044-37A	Custodian-3 Sink Faucet	6/21/16 9:20	7/17/2016	1606D80-37A	Copper	ND	1.3	ppm
044-37A	Custodian-3 Sink Faucet	6/21/16 9:20	7/17/2016	1606D80-37A	Lead	2	15	ppb
044-38A	Girls Bathroom Near 21 Sink Faucet 1 (left)	6/21/16 9:24	7/17/2016	1606D80-38A	Copper	0.2	1.3	ppm
044-38A	Girls Bathroom Near 21 Sink Faucet 1 (left)	6/21/16 9:24	7/17/2016	1606D80-38A	Lead	10	15	ppb
044-39A	Girls Bathroom Near 21 Sink Faucet 2 (right)	6/21/16 9:26	7/17/2016	1606D80-39A	Copper	ND	1.3	ppm
044-39A	Girls Bathroom Near 21 Sink Faucet 2 (right)	6/21/16 9:26	7/17/2016	1606D80-39A	Lead	7	15	ppb
044-40A	Girls Bathroom Near 21 Water Spigot	6/21/16 9:28	7/17/2016	1606D80-40A	Copper	0.2	1.3	ppm
044-40A	Girls Bathroom Near 21 Water Spigot	6/21/16 9:28	7/17/2016	1606D80-40A	Lead	12	15	ppb
044-41A	Rm 21 Sink Faucet 1 with Eyewash (left)	6/21/16 9:24	7/17/2016	1606D80-41A	Copper	ND	1.3	ppm
044-41A	Rm 21 Sink Faucet 1 with Eyewash (left)	6/21/16 9:24	7/17/2016	1606D80-41A	Lead	84	15	ppb
044-42A	Room 21 Eyewash (left)	6/21/16 9:25	7/17/2016	1606D80-42A	Copper	ND	1.3	ppm
044-42A	Room 21 Eyewash (left)	6/21/16 9:25	7/17/2016	1606D80-42A	Lead	2	15	ppb
044-43A	Room 21 Sink Faucet 2 (left)	6/21/16 9:26	7/17/2016	1606D80-43A	Copper	ND	1.3	ppm
044-43A	Room 21 Sink Faucet 2 (left)	6/21/16 9:26	7/17/2016	1606D80-43A	Lead	35	15	ppb
044-44A	Room 21 Sink Faucet 3 (right)	6/21/16 9:28	7/17/2016	1606D80-44A	Copper	ND	1.3	ppm
044-44A	Room 21 Sink Faucet 3 (right)	6/21/16 9:28	7/17/2016	1606D80-44A	Lead	11	15	ppb
044-45A	Room 21 Sink Faucet 4	6/21/16 9:30	7/17/2016	1606D80-45A	Copper	ND	1.3	ppm
044-45A	Room 21 Sink Faucet 4	6/21/16 9:30	7/17/2016	1606D80-45A	Lead	49	15	ppb
044-46A	Women's Faculty Restroom/Boiler Sink Faucet	6/21/16 9:35	7/17/2016	1606D80-46A	Copper	ND	1.3	ppm
044-46A	Women's Faculty Restroom/Boiler Sink Faucet	6/21/16 9:35	7/17/2016	1606D80-46A	Lead	5	15	ppb
044-47A	Drinking Fountain Hallway	6/21/16 10:45	7/17/2016	1606D80-47A	Copper	ND	1.3	ppm
044-47A	Drinking Fountain Hallway	6/21/16 10:45	7/17/2016	1606D80-47A	Lead	1	15	ppb
044-48A	Faculty Mens Bathroom Sink Faucet	6/21/16 9:40	7/17/2016	1606D80-48A	Copper	ND	1.3	ppm
044-48A	Faculty Mens Bathroom Sink Faucet	6/21/16 9:40	7/17/2016	1606D80-48A	Lead	4	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Hayhurst Elementary School

Client Sample ID	Sample Location	Collection Date	Analysis Date	Sample ID	Analyte	Results	EPA	
							Action	Units
							Level	
044-49A	Faculty Room 28 Sink Faucet	6/21/16 9:52	7/17/2016	1606D80-49A	Copper	ND	1.3	ppm
044-49A	Faculty Room 28 Sink Faucet	6/21/16 9:52	7/17/2016	1606D80-49A	Lead	12	15	ppb
044-50A	Kitchen Food Sink Faucet Nozzle	6/21/16 9:54	7/17/2016	1606D80-50A	Copper	0.3	1.3	ppm
044-50A	Kitchen Food Sink Faucet Nozzle	6/21/16 9:54	7/17/2016	1606D80-50A	Lead	14	15	ppb
044-51A	Kitchen Food Prep Sink Faucet	6/21/16 9:56	7/17/2016	1606D80-51A	Copper	0.1	1.3	ppm
044-51A	Kitchen Food Prep Sink Faucet	6/21/16 9:56	7/17/2016	1606D80-51A	Lead	13	15	ppb
044-52A	Kitchen Handwash Sink Faucet	6/21/16 10:03	7/17/2016	1606D80-52A	Copper	0.2	1.3	ppm
044-52A	Kitchen Handwash Sink Faucet	6/21/16 10:03	7/17/2016	1606D80-52A	Lead	14	15	ppb
044-53A	Kitchen Custodial Closet Sink Faucet	6/21/16 9:59	7/17/2016	1606D80-53A	Copper	ND	1.3	ppm
044-53A	Kitchen Custodial Closet Sink Faucet	6/21/16 9:59	7/17/2016	1606D80-53A	Lead	13	15	ppb
044-54A	Kitchen Bathroom Sink Faucet	6/21/16 10:01	7/17/2016	1606D80-54A	Copper	ND	1.3	ppm
044-54A	Kitchen Bathroom Sink Faucet	6/21/16 10:01	7/17/2016	1606D80-54A	Lead	200	15	ppb
044-55A	Cafeteria Drinking Fountain	6/21/16 10:07	7/17/2016	1606D80-55A	Copper	ND	1.3	ppm
044-55A	Cafeteria Drinking Fountain	6/21/16 10:07	7/17/2016	1606D80-55A	Lead	21	15	ppb
044-56A	Restroom Outside Cafeteria Sink Faucet 1	6/21/16 10:10	7/17/2016	1606D81-01A	Copper	ND	1.3	ppm
044-56A	Restroom Outside Cafeteria Sink Faucet 1	6/21/16 10:10	7/17/2016	1606D81-01A	Lead	6	15	ppb
044-57A	Restroom Outside Cafeteria Sink Faucet 2	6/21/16 10:12	7/17/2016	1606D81-02A	Copper	ND	1.3	ppm
044-57A	Restroom Outside Cafeteria Sink Faucet 2	6/21/16 10:12	7/17/2016	1606D81-02A	Lead	12	15	ppb
044-58A	Restroom Outside Cafeteria Water Spigot	6/21/16 10:14	7/17/2016	1606D81-03A	Copper	0.2	1.3	ppm
044-58A	Restroom Outside Cafeteria Water Spigot	6/21/16 10:14	7/17/2016	1606D81-03A	Lead	15.0	15	ppb
044-59A	Custodian 2 Sink Faucet	6/21/16 10:16	7/17/2016	1606D81-04A	Copper	ND	1.3	ppm
044-59A	Custodian 2 Sink Faucet	6/21/16 10:16	7/17/2016	1606D81-04A	Lead	6	15	ppb
044-60A	Boys Bathroom Sink Faucet 1	6/21/16 10:15	7/17/2016	1606D81-05A	Copper	ND	1.3	ppm
044-60A	Boys Bathroom Sink Faucet 1	6/21/16 10:15	7/17/2016	1606D81-05A	Lead	2	15	ppb
044-61A	Boys Bathroom Sink Faucet 2	6/21/16 10:19	7/17/2016	1606D81-06A	Copper	ND	1.3	ppm
044-61A	Boys Bathroom Sink Faucet 2	6/21/16 10:19	7/17/2016	1606D81-06A	Lead	5	15	ppb
044-62A	Boys Bathroom Water Spigot	6/21/16 10:17	7/17/2016	1606D81-07A	Copper	ND	1.3	ppm
044-62A	Boys Bathroom Water Spigot	6/21/16 10:17	7/17/2016	1606D81-07A	Lead	ND	15	ppb
044-63A	Office Bathroom Sink Faucet	6/21/16 10:22	7/17/2016	1606D81-08A	Copper	ND	1.3	ppm
044-63A	Office Bathroom Sink Faucet	6/21/16 10:22	7/17/2016	1606D81-08A	Lead	8	15	ppb
044-64A	Office Sink Faucet	6/21/16 10:24	7/17/2016	1606D81-09A	Copper	ND	1.3	ppm
044-64A	Office Sink Faucet	6/21/16 10:24	7/17/2016	1606D81-09A	Lead	6	15	ppb
044-65A	Library Sink Faucet	6/21/16 10:27	7/17/2016	1606D81-10A	Copper	0.2	1.3	ppm
044-65A	Library Sink Faucet	6/21/16 10:27	7/17/2016	1606D81-10A	Lead	11	15	ppb
044-66A	Library Drinking Fountain	6/21/16 10:29	7/17/2016	1606D81-11A	Copper	ND	1.3	ppm
044-66A	Library Drinking Fountain	6/21/16 10:29	7/17/2016	1606D81-11A	Lead	6	15	ppb
044-67A	Room 3 Sink Faucet	6/21/16 10:31	7/17/2016	1606D81-12A	Copper	ND	1.3	ppm
044-67A	Room 3 Sink Faucet	6/21/16 10:31	7/17/2016	1606D81-12A	Lead	12	15	ppb
044-68A	Room 3 Drinking Fountain	6/21/16 10:33	7/17/2016	1606D81-13A	Copper	ND	1.3	ppm
044-68A	Room 3 Drinking Fountain	6/21/16 10:33	7/17/2016	1606D81-13A	Lead	2	15	ppb
044-69A	Room 11 Sink Faucet	6/21/16 10:35	7/17/2016	1606D81-14A	Copper	ND	1.3	ppm
044-69A	Room 11 Sink Faucet	6/21/16 10:35	7/17/2016	1606D81-14A	Lead	7	15	ppb
044-70A	Room 11 Drinking Fountain	6/21/16 10:37	7/17/2016	1606D81-15A	Copper	ND	1.3	ppm
044-70A	Room 11 Drinking Fountain	6/21/16 10:37	7/17/2016	1606D81-15A	Lead	2	15	ppb
044-71A	Room 4 Sink Faucet	6/21/16 10:39	7/17/2016	1606D81-16A	Copper	ND	1.3	ppm
044-71A	Room 4 Sink Faucet	6/21/16 10:39	7/17/2016	1606D81-16A	Lead	13	15	ppb
044-72A	Room 4 Drinking Fountain	6/21/16 10:41	7/17/2016	1606D81-17A	Copper	ND	1.3	ppm
044-72A	Room 4 Drinking Fountain	6/21/16 10:41	7/17/2016	1606D81-17A	Lead	6	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Hayhurst Elementary School

Client Sample ID	Sample Location	Collection Date	Analysis Date	Sample ID	Analyte	Results	EPA	
							Action	Units
							Level	
044-73A	Room 10 Sink Faucet	6/21/16 10:45	7/17/2016	1606D81-18A	Copper	0.1	1.3	ppm
044-73A	Room 10 Sink Faucet	6/21/16 10:45	7/17/2016	1606D81-18A	Lead	6	15	ppb
044-74A	Room 10 Drinking Fountain	6/21/16 10:47	7/17/2016	1606D81-19A	Copper	0.1	1.3	ppm
044-74A	Room 10 Drinking Fountain	6/21/16 10:47	7/17/2016	1606D81-19A	Lead	2	15	ppb
044-75A	Room 5 Sink Faucet	6/21/16 10:48	7/17/2016	1606D81-20A	Copper	ND	1.3	ppm
044-75A	Room 5 Sink Faucet	6/21/16 10:48	7/17/2016	1606D81-20A	Lead	39	15	ppb
044-76A	Room 5 Drinking Fountain	6/21/16 10:51	7/17/2016	1606D81-21A	Copper	ND	1.3	ppm
044-76A	Room 5 Drinking Fountain	6/21/16 10:51	7/17/2016	1606D81-21A	Lead	10	15	ppb
044-77A	Drinking Fountain Near 5	6/21/16 10:53	7/17/2016	1606D81-22A	Copper	ND	1.3	ppm
044-77A	Drinking Fountain Near 5	6/21/16 10:53	7/17/2016	1606D81-22A	Lead	3	15	ppb
044-78A	Room 9 Sink Faucet	6/21/16 10:55	7/17/2016	1606D81-23A	Copper	ND	1.3	ppm
044-78A	Room 9 Sink Faucet	6/21/16 10:55	7/17/2016	1606D81-23A	Lead	2	15	ppb
044-79A	Room 6 Sink Faucet	6/21/16 10:57	7/17/2016	1606D81-24A	Copper	ND	1.3	ppm
044-79A	Room 6 Sink Faucet	6/21/16 10:57	7/17/2016	1606D81-24A	Lead	3	15	ppb
044-80A	Room 6 Drinking Fountain	6/21/16 10:59	7/17/2016	1606D81-25A	Copper	ND	1.3	ppm
044-80A	Room 6 Drinking Fountain	6/21/16 10:59	7/17/2016	1606D81-25A	Lead	3	15	ppb
044-81A	Boys Bathroom Sink Faucet 1 (left)	6/21/16 11:01	7/18/2016	1606D81-26A	Copper	ND	1.3	ppm
044-81A	Boys Bathroom Sink Faucet 1 (left)	6/21/16 11:01	7/18/2016	1606D81-26A	Lead	4	15	ppb
044-82A	Boys Bathroom Sink Faucet 2 (right)	6/21/16 11:03	7/18/2016	1606D81-27A	Copper	ND	1.3	ppm
044-82A	Boys Bathroom Sink Faucet 2 (right)	6/21/16 11:03	7/18/2016	1606D81-27A	Lead	3	15	ppb
044-83A	Custodian 1 Sink Faucet	6/21/16 10:11	7/18/2016	1606D81-28A	Copper	ND	1.3	ppm
044-83A	Custodian 1 Sink Faucet	6/21/16 10:11	7/18/2016	1606D81-28A	Lead	6	15	ppb
044-84A	Girls Bathroom Sink Faucet Single Room	6/21/16 10:14	7/18/2016	1606D81-29A	Copper	ND	1.3	ppm
044-84A	Girls Bathroom Sink Faucet Single Room	6/21/16 10:14	7/18/2016	1606D81-29A	Lead	9	15	ppb
044-85A	Girls Bathroom Sink Faucet 1	6/21/16 10:16	7/18/2016	1606D81-30A	Copper	ND	1.3	ppm
044-85A	Girls Bathroom Sink Faucet 1	6/21/16 10:16	7/18/2016	1606D81-30A	Lead	3	15	ppb
044-86A	Girls Bathroom Sink Faucet 2	6/21/16 10:18	7/18/2016	1606D81-31A	Copper	ND	1.3	ppm
044-86A	Girls Bathroom Sink Faucet 2	6/21/16 10:18	7/18/2016	1606D81-31A	Lead	2	15	ppb
044-87A	Girls Bathroom Water Spigot	6/21/16 10:20	7/18/2016	1606D81-32A	Copper	ND	1.3	ppm
044-87A	Girls Bathroom Water Spigot	6/21/16 10:20	7/18/2016	1606D81-32A	Lead	ND	15	ppb
044-88A	Room 8 Sink Faucet 1 (left)	6/21/16 10:05	7/18/2016	1606D81-33A	Copper	ND	1.3	ppm
044-88A	Room 8 Sink Faucet 1 (left)	6/21/16 10:05	7/18/2016	1606D81-33A	Lead	22	15	ppb
044-89A	Room 8 Drinking Fountain	6/21/16 10:07	7/18/2016	1606D81-34A	Copper	ND	1.3	ppm
044-89A	Room 8 Drinking Fountain	6/21/16 10:07	7/18/2016	1606D81-34A	Lead	2	15	ppb
044-90A	Room 8 Sink Faucet 2 (right)	6/21/16 10:09	7/18/2016	1606D81-35A	Copper	ND	1.3	ppm
044-90A	Room 8 Sink Faucet 2 (right)	6/21/16 10:09	7/18/2016	1606D81-35A	Lead	2	15	ppb
044-91A	Room 7 Drinking Fountain	6/21/16 11:09	7/18/2016	1606D81-36A	Copper	ND	1.3	ppm
044-91A	Room 7 Drinking Fountain	6/21/16 11:09	7/18/2016	1606D81-36A	Lead	ND	15	ppb
044-92A	Room 7 Sink Faucet (right)	6/21/16 11:07	7/18/2016	1606D81-37A	Copper	ND	1.3	ppm
044-92A	Room 7 Sink Faucet (right)	6/21/16 11:07	7/18/2016	1606D81-37A	Lead	10	15	ppb
044-93A	Room 7 Sink Faucet (left)	6/21/16 11:05	7/18/2016	1606D81-38A	Copper	ND	1.3	ppm
044-93A	Room 7 Sink Faucet (left)	6/21/16 11:05	7/18/2016	1606D81-38A	Lead	5	15	ppb
044-94A	Outside Water Spigot 1 in Courtyard (hose)	6/21/16 10:24	7/18/2016	1606D81-39A	Copper	ND	1.3	ppm
044-94A	Outside Water Spigot 1 in Courtyard (hose)	6/21/16 10:24	7/18/2016	1606D81-39A	Lead	ND	15	ppb
044-95A	Outside Water Spigot 2	6/21/16 10:23	7/18/2016	1606D81-40A	Copper	ND	1.3	ppm
044-95A	Outside Water Spigot 2	6/21/16 10:23	7/18/2016	1606D81-40A	Lead	7	15	ppb
044-96A	Outside Water Spigot 3	6/21/16 10:21	7/18/2016	1606D81-41A	Copper	0.2	1.3	ppm
044-96A	Outside Water Spigot 3	6/21/16 10:21	7/18/2016	1606D81-41A	Lead	21	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Hayhurst Elementary School

Client Sample ID	Sample Location	Collection Date	Analysis Date	Sample ID	Analyte	Results	EPA	
							Action Level	Units
044-97A	Outside Water Spigot 4	6/21/16 10:19	7/15/2016	1606D81-42A	Copper	0.5	1.3	ppm
044-97A	Outside Water Spigot 4	6/21/16 10:19	7/15/2016	1606D81-42A	Lead	33	15	ppb
044-98A	Outside Water Spigot 5	6/21/16 10:33	7/18/2016	1606D81-43A	Copper	ND	1.3	ppm
044-98A	Outside Water Spigot 5	6/21/16 10:33	7/18/2016	1606D81-43A	Lead	50	15	ppb
044-99A	Water Spigot 6	6/21/16 10:31	7/18/2016	1606D81-44A	Copper	ND	1.3	ppm
044-99A	Water Spigot 6	6/21/16 10:31	7/18/2016	1606D81-44A	Lead	650	15	ppb
044-100A	Water Spigot 7	6/21/16 10:28	7/18/2016	1606D81-45A	Copper	ND	1.3	ppm
044-100A	Water Spigot 7	6/21/16 10:28	7/18/2016	1606D81-45A	Lead	18	15	ppb
044-101A	Water Spigot 8 (hose)	6/21/16 10:25	7/18/2016	1606D81-46A	Copper	ND	1.3	ppm
044-101A	Water Spigot 8 (hose)	6/21/16 10:25	7/18/2016	1606D81-46A	Lead	3	15	ppb
044-102A	Hose Bib in Extra Room by Boiler Outside	6/21/16 10:42	7/18/2016	1606D81-47A	Copper	ND	1.3	ppm
044-102A	Hose Bib in Extra Room by Boiler Outside	6/21/16 10:42	7/18/2016	1606D81-47A	Lead	ND	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

ND = Non detect

Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.