

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Irvington Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
047-01A Boiler Room Sink	6/27/2016 01:25	7/5/2016 09:56	10353897001	Copper	0.0	1.3	ppm
047-01A Boiler Room Sink	6/27/2016 01:25	7/5/2016 09:56	10353897001	Lead	4	15	ppb
047-02A Kitchen Restroom Sink	6/27/2016 01:27	7/5/2016 09:59	10353897003	Copper	0.1	1.3	ppm
047-02A Kitchen Restroom Sink	6/27/2016 01:27	7/5/2016 09:59	10353897003	Lead	1	15	ppb
047-03A Kitchen Sink #1	6/27/2016 01:29	7/5/2016 10:00	10353897005	Copper	0.1	1.3	ppm
047-03A Kitchen Sink #1	6/27/2016 01:29	7/5/2016 10:00	10353897005	Lead	18	15	ppb
047-04A Kitchen Sink #2	6/27/2016 01:31	7/5/2016 10:01	10353897007	Copper	0.1	1.3	ppm
047-04A Kitchen Sink #2	6/27/2016 01:31	7/5/2016 10:01	10353897007	Lead	1	15	ppb
047-05A Kitchen Spray #1	6/27/2016 01:33	7/7/2016 16:23	10353897009	Copper	0.0	1.3	ppm
047-05A Kitchen Spray #1	6/27/2016 01:33	7/7/2016 16:23	10353897009	Lead	1	15	ppb
047-06A Kitchen Spigot	6/27/2016 01:35	7/7/2016 16:27	10353897011	Copper	0.2	1.3	ppm
047-06A Kitchen Spigot	6/27/2016 01:35	7/7/2016 16:27	10353897011	Lead	103	15	ppb
047-07A Kitchen Spray #2	6/27/2016 01:37	7/5/2016 15:30	10353897013	Copper	0.1	1.3	ppm
047-07A Kitchen Spray #2	6/27/2016 01:37	7/5/2016 15:30	10353897013	Lead	2	15	ppb
047-08A Girls Restroom Sink	6/27/2016 01:39	7/5/2016 10:02	10353897015	Copper	0.1	1.3	ppm
047-08A Girls Restroom Sink	6/27/2016 01:39	7/5/2016 10:02	10353897015	Lead	5	15	ppb
047-09A Girls Restroom Spigot	6/27/2016 01:41	7/5/2016 10:04	10353897017	Copper	0.2	1.3	ppm
047-09A Girls Restroom Spigot	6/27/2016 01:41	7/5/2016 10:04	10353897017	Lead	13	15	ppb
047-10A Hallway Fountain #1	6/27/2016 01:43	7/5/2016 10:05	10353897019	Copper	0.1	1.3	ppm
047-10A Hallway Fountain #1	6/27/2016 01:43	7/5/2016 10:05	10353897019	Lead	0	15	ppb
047-11A Hallway Fountain #2	6/27/2016 01:45	7/5/2016 10:12	10353897021	Copper	0.1	1.3	ppm
047-11A Hallway Fountain #2	6/27/2016 01:45	7/5/2016 10:12	10353897021	Lead	0	15	ppb
047-12A Hallway Fountain Bottle Fill	6/27/2016 01:47	7/8/2016 07:22	10353897023	Copper	0.2	1.3	ppm
047-12A Hallway Fountain Bottle Fill	6/27/2016 01:47	7/8/2016 07:22	10353897023	Lead	0	15	ppb
047-13A Boys Restroom Sink	6/27/2016 01:49	7/5/2016 10:14	10353897025	Copper	0.1	1.3	ppm
047-13A Boys Restroom Sink	6/27/2016 01:49	7/5/2016 10:14	10353897025	Lead	3	15	ppb
047-14A Room 112B Sink	6/27/2016 01:51	7/5/2016 10:16	10353897027	Copper	0.1	1.3	ppm
047-14A Room 112B Sink	6/27/2016 01:51	7/5/2016 10:16	10353897027	Lead	14.7	15	ppb
047-15A Room 111 Sink	6/27/2016 01:53	7/5/2016 10:17	10353897029	Copper	0.2	1.3	ppm
047-15A Room 111 Sink	6/27/2016 01:53	7/5/2016 10:17	10353897029	Lead	13	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Irvington Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
047-16A Room 111 Fountain	6/27/2016 01:55	7/5/2016 10:18	10353897031	Copper	0.2	1.3	ppm
047-16A Room 111 Fountain	6/27/2016 01:55	7/5/2016 10:18	10353897031	Lead	6	15	ppb
047-17A Room 111 Restroom Sink	6/27/2016 01:57	7/5/2016 10:20	10353897033	Copper	0.0	1.3	ppm
047-17A Room 111 Restroom Sink	6/27/2016 01:57	7/5/2016 10:20	10353897033	Lead	5	15	ppb
047-18A Room 110 Sink	6/27/2016 01:59	7/5/2016 10:21	10353897035	Copper	0.0	1.3	ppm
047-18A Room 110 Sink	6/27/2016 01:59	7/5/2016 10:21	10353897035	Lead	13	15	ppb
047-19A Room 110 Fountain	6/27/2016 02:01	7/5/2016 10:25	10353897037	Copper	0.1	1.3	ppm
047-19A Room 110 Fountain	6/27/2016 02:01	7/5/2016 10:25	10353897037	Lead	36	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Irvington Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
047-20A Hallway Fountain #1	6/27/2016 02:03	7/5/2016 10:26	10353897039	Copper	0.0	1.3	ppm
047-20A Hallway Fountain #1	6/27/2016 02:03	7/5/2016 10:26	10353897039	Lead	3	15	ppb
047-21A Hallway Fountain #2	6/27/2016 02:05	7/5/2016 13:01	10353897041	Copper	0.0	1.3	ppm
047-21A Hallway Fountain #2	6/27/2016 02:05	7/5/2016 13:01	10353897041	Lead	4	15	ppb
047-22A Custodial Sink	6/27/2016 02:07	7/5/2016 13:07	10353897043	Copper	0.0	1.3	ppm
047-22A Custodial Sink	6/27/2016 02:07	7/5/2016 13:07	10353897043	Lead	31	15	ppb
047-23A Room 109 Sink	6/27/2016 02:09	7/5/2016 13:08	10353897045	Copper	0.1	1.3	ppm
047-23A Room 109 Sink	6/27/2016 02:09	7/5/2016 13:08	10353897045	Lead	10	15	ppb
047-24A Room 109 Fountain	6/27/2016 02:11	7/5/2016 13:09	10353897047	Copper	0.0	1.3	ppm
047-24A Room 109 Fountain	6/27/2016 02:11	7/5/2016 13:09	10353897047	Lead	0	15	ppb
047-25A Office Sink	6/27/2016 02:13	7/5/2016 13:11	10353897049	Copper	0.1	1.3	ppm
047-25A Office Sink	6/27/2016 02:13	7/5/2016 13:11	10353897049	Lead	7	15	ppb
047-26A Teachers Lounge Sink	6/27/2016 02:15	7/6/2016 11:28	10353897051	Copper	0.4	1.3	ppm
047-26A Teachers Lounge Sink	6/27/2016 02:15	7/5/2016 13:20	10353897051	Lead	9	15	ppb
047-27A Teachers Lounge Dispenser	6/27/2016 02:17	7/5/2016 13:21	10353897053	Copper	0.2	1.3	ppm
047-27A Teachers Lounge Dispenser	6/27/2016 02:17	7/5/2016 13:21	10353897053	Lead	1	15	ppb
047-28A Gymnasium Fountain #1	6/27/2016 02:19	7/5/2016 13:23	10353897055	Copper	0.0	1.3	ppm
047-28A Gymnasium Fountain #1	6/27/2016 02:19	7/5/2016 13:23	10353897055	Lead	1	15	ppb
047-29A Gymnasium Fountain #2	6/27/2016 02:21	7/5/2016 13:25	10353897057	Copper	0.0	1.3	ppm
047-29A Gymnasium Fountain #2	6/27/2016 02:21	7/5/2016 13:25	10353897057	Lead	1	15	ppb
047-30A Girls Restroom Sink #1	6/27/2016 02:23	7/5/2016 13:27	10353897059	Copper	0.1	1.3	ppm
047-30A Girls Restroom Sink #1	6/27/2016 02:23	7/5/2016 13:27	10353897059	Lead	3	15	ppb
047-31A Girls Restroom Sink #2	6/27/2016 02:25	7/7/2016 08:19	10353897061	Copper	0.1	1.3	ppm
047-31A Girls Restroom Sink #2	6/27/2016 02:25	7/7/2016 08:19	10353897061	Lead	4	15	ppb
047-32A Girls Restroom Spigot	6/27/2016 02:27	7/7/2016 08:10	10353897063	Copper	0.1	1.3	ppm
047-32A Girls Restroom Spigot	6/27/2016 02:27	7/7/2016 08:10	10353897063	Lead	8	15	ppb
047-33A Room 106A Sink	6/27/2016 02:29	7/7/2016 08:11	10353897065	Copper	0.3	1.3	ppm
047-33A Room 106A Sink	6/27/2016 02:29	7/7/2016 08:11	10353897065	Lead	8	15	ppb
047-34A Hallway Fountain	6/27/2016 02:31	7/7/2016 08:12	10353897067	Copper	0.1	1.3	ppm
047-34A Hallway Fountain	6/27/2016 02:31	7/7/2016 08:12	10353897067	Lead	0	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Irvington Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
047-35A Room 106B Bathroom Sink #1	6/27/2016 02:33	7/7/2016 08:25	10353897069	Copper	0.1	1.3	ppm
047-35A Room 106B Bathroom Sink #1	6/27/2016 02:33	7/7/2016 08:25	10353897069	Lead	18	15	ppb
047-36A Room 106B Bathroom Sink #2	6/27/2016 02:35	7/6/2016 23:33	10353897071	Copper	0.2	1.3	ppm
047-36A Room 106B Bathroom Sink #2	6/27/2016 02:35	7/6/2016 23:33	10353897071	Lead	155	15	ppb
047-37A Principals Office Sink	6/27/2016 02:37	7/6/2016 23:35	10353897073	Copper	0.0	1.3	ppm
047-37A Principals Office Sink	6/27/2016 02:37	7/6/2016 23:35	10353897073	Lead	31	15	ppb
047-38A Room 105A Sink	6/27/2016 02:39	7/6/2016 23:36	10353897075	Copper	0.1	1.3	ppm
047-38A Room 105A Sink	6/27/2016 02:39	7/6/2016 23:36	10353897075	Lead	6	15	ppb
047-39A Media Center Sink	6/27/2016 02:41	7/6/2016 23:37	10353897077	Copper	0.3	1.3	ppm
047-39A Media Center Sink	6/27/2016 02:41	7/6/2016 23:37	10353897077	Lead	5	15	ppb
047-40A Hallway Fountain #1	6/27/2016 02:43	7/6/2016 23:39	10353897079	Copper	0.1	1.3	ppm
047-40A Hallway Fountain #1	6/27/2016 02:43	7/6/2016 23:39	10353897079	Lead	1	15	ppb
047-41A Hallway Fountain #2	6/27/2016 02:45	7/6/2016 23:40	10353897081	Copper	0.1	1.3	ppm
047-41A Hallway Fountain #2	6/27/2016 02:45	7/6/2016 23:40	10353897081	Lead	1	15	ppb
047-42A Hallway Fountain Bottle Fill	6/27/2016 02:47	7/6/2016 23:43	10353897083	Copper	0.1	1.3	ppm
047-42A Hallway Fountain Bottle Fill	6/27/2016 02:47	7/6/2016 23:43	10353897083	Lead	1	15	ppb
047-43A Room 104A Sink	6/27/2016 02:49	7/6/2016 23:44	10353897085	Copper	0.1	1.3	ppm
047-43A Room 104A Sink	6/27/2016 02:49	7/6/2016 23:44	10353897085	Lead	26	15	ppb
047-44A Boys Restroom Sink #1	6/27/2016 02:51	7/6/2016 23:46	10353897087	Copper	0.2	1.3	ppm
047-44A Boys Restroom Sink #1	6/27/2016 02:51	7/6/2016 23:46	10353897087	Lead	18	15	ppb
047-45A Boys Restroom Sink #2	6/27/2016 02:53	7/6/2016 23:50	10353897089	Copper	0.1	1.3	ppm
047-45A Boys Restroom Sink #2	6/27/2016 02:53	7/6/2016 23:50	10353897089	Lead	7	15	ppb
047-46A Boys Restroom Sink #3	6/27/2016 02:55	7/7/2016 18:13	10353897091	Copper	0.1	1.3	ppm
047-46A Boys Restroom Sink #3	6/27/2016 02:55	7/7/2016 18:13	10353897091	Lead	13	15	ppb
047-47A Boys Restroom Spigot	6/27/2016 02:57	7/6/2016 23:51	10353897093	Copper	0.1	1.3	ppm
047-47A Boys Restroom Spigot	6/27/2016 02:57	7/6/2016 23:51	10353897093	Lead	7	15	ppb
047-48A Faculty Restroom Sink	6/27/2016 02:59	7/7/2016 10:54	10353897095	Copper	0.9	1.3	ppm
047-48A Faculty Restroom Sink	6/27/2016 02:59	7/6/2016 23:52	10353897095	Lead	4	15	ppb
047-49A Faculty Restroom Spigot	6/27/2016 03:01	7/8/2016 08:01	10353897097	Copper	0.7	1.3	ppm
047-49A Faculty Restroom Spigot	6/27/2016 03:01	7/8/2016 08:01	10353897097	Lead	478	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Irvington Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
047-50A Room 102 Sink #1	6/27/2016 03:03	7/6/2016 23:54	10353897099	Copper	0.1	1.3	ppm
047-50A Room 102 Sink #1	6/27/2016 03:03	7/6/2016 23:54	10353897099	Lead	19	15	ppb
047-51A Room 102 Sink #2	6/27/2016 03:05	7/7/2016 12:05	10353897101	Copper	0.4	1.3	ppm
047-51A Room 102 Sink #2	6/27/2016 03:05	7/7/2016 12:05	10353897101	Lead	151	15	ppb
047-52A Hallway Fountain #1	6/27/2016 03:07	7/7/2016 11:32	10353897103	Copper	0.0	1.3	ppm
047-52A Hallway Fountain #1	6/27/2016 03:07	7/7/2016 11:32	10353897103	Lead	4	15	ppb
047-53A Hallway Fountain #2	6/27/2016 03:09	7/7/2016 11:38	10353897105	Copper	0.0	1.3	ppm
047-53A Hallway Fountain #2	6/27/2016 03:09	7/7/2016 11:38	10353897105	Lead	6	15	ppb
047-54A Custodial Sink	6/27/2016 03:11	7/7/2016 12:08	10353897107	Copper	0.0	1.3	ppm
047-54A Custodial Sink	6/27/2016 03:11	7/7/2016 12:08	10353897107	Lead	5	15	ppb
047-55A Room 101 Sink #1	6/27/2016 03:13	7/7/2016 11:39	10353897109	Copper	0.1	1.3	ppm
047-55A Room 101 Sink #1	6/27/2016 03:13	7/7/2016 11:39	10353897109	Lead	9	15	ppb
047-56A Room 101 Fountain	6/27/2016 03:15	7/7/2016 11:43	10353897111	Copper	0.1	1.3	ppm
047-56A Room 101 Fountain	6/27/2016 03:15	7/7/2016 11:43	10353897111	Lead	12	15	ppb
047-57A Room 101 Sink #2	6/27/2016 03:17	7/7/2016 11:45	10353897113	Copper	0.1	1.3	ppm
047-57A Room 101 Sink #2	6/27/2016 03:17	7/7/2016 11:45	10353897113	Lead	12	15	ppb
047-58A Hallway Fountain #1	6/27/2016 03:19	7/7/2016 11:46	10353897115	Copper	0.0	1.3	ppm
047-58A Hallway Fountain #1	6/27/2016 03:19	7/7/2016 11:46	10353897115	Lead	2	15	ppb
047-59A Hallway Fountain #2	6/27/2016 03:21	7/7/2016 11:47	10353897117	Copper	0.0	1.3	ppm
047-59A Hallway Fountain #2	6/27/2016 03:21	7/7/2016 11:47	10353897117	Lead	2	15	ppb
047-60A Boys Restroom Sink #1	6/27/2016 03:23	7/7/2016 11:49	10353897119	Copper	0.1	1.3	ppm
047-60A Boys Restroom Sink #1	6/27/2016 03:23	7/7/2016 11:49	10353897119	Lead	13	15	ppb
047-61A Boys Restroom Sink #2	6/27/2016 03:25	7/7/2016 11:50	10353897121	Copper	0.1	1.3	ppm
047-61A Boys Restroom Sink #2	6/27/2016 03:25	7/7/2016 11:50	10353897121	Lead	5	15	ppb
047-62A Boys Restroom Spigot	6/27/2016 03:27	7/7/2016 11:52	10353897123	Copper	0.1	1.3	ppm
047-62A Boys Restroom Spigot	6/27/2016 03:27	7/7/2016 11:52	10353897123	Lead	33	15	ppb
047-63A Hallway Fountain #1	6/27/2016 03:29	7/7/2016 11:53	10353897125	Copper	0.3	1.3	ppm
047-63A Hallway Fountain #1	6/27/2016 03:29	7/7/2016 11:53	10353897125	Lead	0	15	ppb
047-64A Hallway Fountain #2	6/27/2016 03:31	7/7/2016 11:56	10353897127	Copper	0.3	1.3	ppm
047-64A Hallway Fountain #2	6/27/2016 03:31	7/7/2016 11:56	10353897127	Lead	0	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Irvington Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
047-65A Hallway Fountain Bottle Fill	6/27/2016 03:33	7/8/2016 07:24	10353897129	Copper	0.3	1.3	ppm
047-65A Hallway Fountain Bottle Fill	6/27/2016 03:33	7/8/2016 07:24	10353897129	Lead	1	15	ppb
047-66A Office Restroom Sink	6/27/2016 03:35	7/7/2016 12:02	10353897131	Copper	0.2	1.3	ppm
047-66A Office Restroom Sink	6/27/2016 03:35	7/7/2016 12:02	10353897131	Lead	17	15	ppb
047-67A Hallway Fountain #1	6/27/2016 03:37	7/7/2016 12:04	10353897133	Copper	0.1	1.3	ppm
047-67A Hallway Fountain #1	6/27/2016 03:37	7/7/2016 12:04	10353897133	Lead	6	15	ppb
047-68A Hallway Fountain #2	6/27/2016 03:39	7/7/2016 12:05	10353897135	Copper	0.0	1.3	ppm
047-68A Hallway Fountain #2	6/27/2016 03:39	7/7/2016 12:05	10353897135	Lead	7	15	ppb
047-69A Hallway Fountain #3	6/27/2016 03:41	7/6/2016 18:54	10353897137	Copper	0.0	1.3	ppm
047-69A Hallway Fountain #3	6/27/2016 03:41	7/6/2016 18:54	10353897137	Lead	5	15	ppb
047-70A Hallway Fountain #4	6/27/2016 03:43	7/6/2016 19:00	10353897139	Copper	0.0	1.3	ppm
047-70A Hallway Fountain #4	6/27/2016 03:43	7/6/2016 19:00	10353897139	Lead	3	15	ppb
047-71A Girls Restroom Sink #1	6/27/2016 03:45	7/6/2016 19:01	10353897141	Copper	0.1	1.3	ppm
047-71A Girls Restroom Sink #1	6/27/2016 03:45	7/6/2016 19:01	10353897141	Lead	7	15	ppb
047-72A Girls Restroom Sink #2	6/27/2016 03:48	7/6/2016 19:03	10353897143	Copper	0.1	1.3	ppm
047-72A Girls Restroom Sink #2	6/27/2016 03:48	7/6/2016 19:03	10353897143	Lead	9	15	ppb
047-73A Girls Restroom Sink #3	6/27/2016 03:50	7/6/2016 19:04	10353897145	Copper	0.1	1.3	ppm
047-73A Girls Restroom Sink #3	6/27/2016 03:50	7/6/2016 19:04	10353897145	Lead	4	15	ppb
047-74A Girls Restroom Spigot	6/27/2016 03:52	7/6/2016 19:08	10353897147	Copper	0.0	1.3	ppm
047-74A Girls Restroom Spigot	6/27/2016 03:52	7/6/2016 19:08	10353897147	Lead	16	15	ppb
047-75A Hallway Fountain #1	6/27/2016 03:54	7/6/2016 19:10	10353897149	Copper	0.1	1.3	ppm
047-75A Hallway Fountain #1	6/27/2016 03:54	7/6/2016 19:10	10353897149	Lead	4	15	ppb
047-76A Hallway Fountain #2	6/27/2016 03:56	7/6/2016 19:11	10353897151	Copper	0.0	1.3	ppm
047-76A Hallway Fountain #2	6/27/2016 03:56	7/6/2016 19:11	10353897151	Lead	3	15	ppb
047-77A Room 212 Sink	6/27/2016 03:58	7/6/2016 19:12	10353897153	Copper	0.1	1.3	ppm
047-77A Room 212 Sink	6/27/2016 03:58	7/6/2016 19:12	10353897153	Lead	30	15	ppb
047-78A Room 214 Sink #1	6/27/2016 04:00	7/6/2016 19:14	10353897155	Copper	0.1	1.3	ppm
047-78A Room 214 Sink #1	6/27/2016 04:00	7/6/2016 19:14	10353897155	Lead	19	15	ppb
047-79A Room 214 Sink #2	6/27/2016 04:02	7/6/2016 19:16	10353897157	Copper	0.2	1.3	ppm
047-79A Room 214 Sink #2	6/27/2016 04:02	7/6/2016 19:16	10353897157	Lead	8	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Irvington Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
047-80A Room 214 Eyewash	6/27/2016 04:04	7/6/2016 19:18	10353897159	Copper	0.0	1.3	ppm
047-80A Room 214 Eyewash	6/27/2016 04:04	7/6/2016 19:18	10353897159	Lead	2	15	ppb
047-81A Room 214 Sink #3	6/27/2016 04:06	7/6/2016 19:19	10353897161	Copper	0.1	1.3	ppm
047-81A Room 214 Sink #3	6/27/2016 04:06	7/6/2016 19:19	10353897161	Lead	9	15	ppb
047-82A Custodial Sink	6/27/2016 04:08	7/7/2016 16:31	10353897163	Copper	0.0	1.3	ppm
047-82A Custodial Sink	6/27/2016 04:08	7/7/2016 16:31	10353897163	Lead	4	15	ppb
047-83A Outside Spigot #1	6/27/2016 04:10	7/6/2016 19:21	10353897165	Copper	0.0	1.3	ppm
047-83A Outside Spigot #1	6/27/2016 04:10	7/6/2016 19:21	10353897165	Lead	26	15	ppb
047-84A Outside Spigot #2	6/27/2016 04:12	7/6/2016 19:25	10353897167	Copper	0.0	1.3	ppm
047-84A Outside Spigot #2	6/27/2016 04:12	7/6/2016 19:25	10353897167	Lead	22	15	ppb
047-85A Outside Spigot #3	6/27/2016 04:14	7/6/2016 19:26	10353897169	Copper	0.0	1.3	ppm
047-85A Outside Spigot #3	6/27/2016 04:14	7/6/2016 19:26	10353897169	Lead	42	15	ppb
047-86A Outside Spigot #4	6/27/2016 04:16	7/7/2016 16:34	10353897171	Copper	0.0	1.3	ppm
047-86A Outside Spigot #4	6/27/2016 04:16	7/7/2016 16:34	10353897171	Lead	2	15	ppb
047-87A Outside Spigot #5	6/27/2016 04:18	7/7/2016 16:36	10353897173	Copper	0.4	1.3	ppm
047-87A Outside Spigot #5	6/27/2016 04:18	7/8/2016 07:25	10353897173	Lead	809	15	ppb
047-88A Outside Spigot #6	6/27/2016 04:20	7/7/2016 16:37	10353897175	Copper	0.2	1.3	ppm
047-88A Outside Spigot #6	6/27/16 4:20	7/8/16 7:26	10353897175	Lead	649.0	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.