

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Jackson Middle School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
048-01A	Boiler Room Lunch Room Sink Faucet	6/20/16 12:00 AM	7/3/16 2:57 PM	BB65914	Copper	0.1	1.3	ppm
048-01A	Boiler Room Lunch Room Sink Faucet	6/20/16 12:00 AM	7/3/16 2:57 PM	BB65914	Lead	3	15	ppb
048-02A	Boiler Room Custodial Locker Room Sink Faucet	6/20/16 12:02 AM	6/24/16 3:26 PM	BB65915	Copper	0.1	1.3	ppm
048-02A	Boiler Room Custodial Locker Room Sink Faucet	6/20/16 12:02 AM	6/24/16 3:26 PM	BB65915	Lead	13	15	ppb
048-03A	Boiler Room Custodial Locker Room Shower	6/20/16 12:04 AM	6/24/16 3:29 PM	BB65916	Copper	0.0	1.3	ppm
048-03A	Boiler Room Custodial Locker Room Shower	6/20/16 12:04 AM	6/24/16 3:29 PM	BB65916	Lead	14	15	ppb
048-04A	Kitchen Custodial Sink Faucet	6/20/16 12:06 AM	6/24/16 3:32 PM	BB65917	Copper	0.0	1.3	ppm
048-04A	Kitchen Custodial Sink Faucet	6/20/16 12:06 AM	6/24/16 3:32 PM	BB65917	Lead	5	15	ppb
048-07A	Kitchen Silver Handwash Sink Faucet	6/20/16 12:08 AM	6/24/16 3:35 PM	BB65918	Copper	0.0	1.3	ppm
048-07A	Kitchen Silver Handwash Sink Faucet	6/20/16 12:08 AM	6/24/16 3:35 PM	BB65918	Lead	1	15	ppb
048-08A	Kitchen Dishwash Sprayer	6/20/16 12:10 AM	6/24/16 3:38 PM	BB65919	Copper	0.0	1.3	ppm
048-08A	Kitchen Dishwash Sprayer	6/20/16 12:10 AM	6/24/16 3:38 PM	BB65919	Lead	4	15	ppb
048-09A	Kitchen Sanitize/Eyewash Sink Faucet	6/20/16 12:12 AM	6/24/16 3:41 PM	BB65920	Copper	0.0	1.3	ppm
048-09A	Kitchen Sanitize/Eyewash Sink Faucet	6/20/16 12:12 AM	6/24/16 3:41 PM	BB65920	Lead	7	15	ppb
048-10A	Kitchen No Tub Sink Faucet	6/20/16 12:14 AM	7/3/16 3:00 PM	BB65921	Copper	0.1	1.3	ppm
048-10A	Kitchen No Tub Sink Faucet	6/20/16 12:14 AM	7/3/16 3:00 PM	BB65921	Lead	128	15	ppb
048-11A	Kitchen Dishwasher Room Sanitize Sink Faucet	6/20/16 12:16 AM	6/24/16 3:44 PM	BB65922	Copper	0.0	1.3	ppm
048-11A	Kitchen Dishwasher Room Sanitize Sink Faucet	6/20/16 12:16 AM	6/24/16 3:44 PM	BB65922	Lead	6	15	ppb
048-12A	Kitchen Dishwasher Room Coils Sink Faucet	6/20/16 12:18 AM	6/24/16 3:47 PM	BB65923	Copper	0.1	1.3	ppm
048-12A	Kitchen Dishwasher Room Coils Sink Faucet	6/20/16 12:18 AM	6/24/16 3:47 PM	BB65923	Lead	23	15	ppb
048-13A	Kitchen 2 Tub Sink Near Window Sink Faucet	6/20/16 12:20 AM	6/24/16 3:50 PM	BB65924	Copper	0.0	1.3	ppm
048-13A	Kitchen 2 Tub Sink Near Window Sink Faucet	6/20/16 12:20 AM	6/24/16 3:50 PM	BB65924	Lead	5	15	ppb
048-14A	Kitchen White Handwash Sink Faucet	6/20/16 12:22 AM	6/24/16 3:53 PM	BB65925	Copper	0.1	1.3	ppm
048-14A	Kitchen White Handwash Sink Faucet	6/20/16 12:22 AM	6/24/16 3:53 PM	BB65925	Lead	3	15	ppb
048-15A	Boiler Room Slop Sink Faucet	6/20/16 12:26 AM	7/3/16 3:04 PM	BB65926	Copper	0.1	1.3	ppm
048-15A	Boiler Room Slop Sink Faucet	6/20/16 12:26 AM	7/3/16 3:04 PM	BB65926	Lead	14.5	15	ppb
048-16A	Kitchen Island near Checkers Sink faucet	6/20/16 12:30 AM	7/3/16 3:07 PM	BB65927	Copper	0.1	1.3	ppm
048-16A	Kitchen Island near Checkers Sink faucet	6/20/16 12:30 AM	7/3/16 3:07 PM	BB65927	Lead	18	15	ppb
048-17A	Kitchen Dishwasher Room Sprayer	6/20/16 12:32 AM	6/24/16 4:08 PM	BB65928	Copper	0.0	1.3	ppm
048-17A	Kitchen Dishwasher Room Sprayer	6/20/16 12:32 AM	6/24/16 4:08 PM	BB65928	Lead	1	15	ppb
048-18A	Kitchen Kettle Water Spigot (left)	6/20/16 12:34 AM	7/3/16 2:43 PM	BB65929	Copper	0.1	1.3	ppm
048-18A	Kitchen Kettle Water Spigot (left)	6/20/16 12:34 AM	7/3/16 2:43 PM	BB65929	Lead	25	15	ppb
048-19A	Kitchen Kettle Water Spigot (right)	6/20/16 12:36 AM	7/3/16 3:11 PM	BB65930	Copper	0.1	1.3	ppm
048-19A	Kitchen Kettle Water Spigot (right)	6/20/16 12:36 AM	7/3/16 3:11 PM	BB65930	Lead	29	15	ppb
048-20A	Matron Sink Faucet	6/20/16 12:40 AM	7/3/16 3:14 PM	BB65931	Copper	0.0	1.3	ppm
048-20A	Matron Sink Faucet	6/20/16 12:40 AM	7/3/16 3:14 PM	BB65931	Lead	34	15	ppb
048-21A	Men's Faculty Bathroom Sink Faucet	6/20/16 12:43 AM	7/3/16 3:46 PM	BB65932	Copper	0.1	1.3	ppm
048-21A	Men's Faculty Bathroom Sink Faucet	6/20/16 12:43 AM	7/3/16 3:46 PM	BB65932	Lead	8	15	ppb
048-22A	Women's Faculty Bathroom Sink Faucet	6/20/16 12:46 AM	6/24/16 4:11 PM	BB65933	Copper	0.0	1.3	ppm
048-22A	Women's Faculty Bathroom Sink Faucet	6/20/16 12:46 AM	6/24/16 4:11 PM	BB65933	Lead	4	15	ppb
048-23A	Women's Bathroom Sink Faucet (left)	6/20/16 12:50 AM	6/24/16 4:15 PM	BB65934	Copper	0.0	1.3	ppm
048-23A	Women's Bathroom Sink Faucet (left)	6/20/16 12:50 AM	6/24/16 4:15 PM	BB65934	Lead	13	15	ppb
048-24A	Women's Bathroom Sink Faucet (left middle)	6/20/16 12:52 AM	6/24/16 4:17 PM	BB65935	Copper	0.1	1.3	ppm
048-24A	Women's Bathroom Sink Faucet (left middle)	6/20/16 12:52 AM	6/24/16 4:17 PM	BB65935	Lead	62	15	ppb
048-25A	Women's Bathroom Sink Faucet (right middle)	6/20/16 12:54 AM	6/24/16 4:21 PM	BB65936	Copper	0.0	1.3	ppm
048-25A	Women's Bathroom Sink Faucet (right middle)	6/20/16 12:54 AM	6/24/16 4:21 PM	BB65936	Lead	7	15	ppb
048-26A	Women's Bathroom Sink Faucet (right)	6/20/16 12:56 AM	6/24/16 4:24 PM	BB65937	Copper	0.0	1.3	ppm
048-26A	Women's Bathroom Sink Faucet (right)	6/20/16 12:56 AM	6/24/16 4:24 PM	BB65937	Lead	9	15	ppb
048-27A	Women's Bathroom Water Spigot	6/20/16 12:58 AM	6/24/16 4:27 PM	BB65938	Copper	0.1	1.3	ppm
048-27A	Women's Bathroom Water Spigot	6/20/16 12:58 AM	6/24/16 4:27 PM	BB65938	Lead	11	15	ppb
048-28A	Men's Bathroom Sink Faucet (left)	6/20/16 1:03 AM	6/24/16 4:30 PM	BB65939	Copper	0.0	1.3	ppm
048-28A	Men's Bathroom Sink Faucet (left)	6/20/16 1:03 AM	6/24/16 4:30 PM	BB65939	Lead	29	15	ppb
048-29A	Men's Bathroom Sink Faucet (middle)	6/20/16 1:05 AM	6/24/16 4:33 PM	BB65940	Copper	0.0	1.3	ppm
048-29A	Men's Bathroom Sink Faucet (middle)	6/20/16 1:05 AM	6/24/16 4:33 PM	BB65940	Lead	35	15	ppb
048-30A	Men's Bathroom Sink Faucet (right)	6/20/16 1:07 AM	6/24/16 4:36 PM	BB65941	Copper	0.0	1.3	ppm
048-30A	Men's Bathroom Sink Faucet (right)	6/20/16 1:07 AM	6/24/16 4:36 PM	BB65941	Lead	27	15	ppb
048-31A	Men's Bathroom Water Spigot	6/20/16 1:09 AM	7/3/16 3:49 PM	BB65942	Copper	0.2	1.3	ppm
048-31A	Men's Bathroom Water Spigot	6/20/16 1:09 AM	7/3/16 3:49 PM	BB65942	Lead	523	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Jackson Middle School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
048-32A	Drinking Fountain next to Locker 513 (left)	6/20/16 1:13 AM	6/24/16 4:57 PM	BB65943	Copper	0.0	1.3	ppm
048-32A	Drinking Fountain next to Locker 513 (left)	6/20/16 1:13 AM	6/24/16 4:57 PM	BB65943	Lead	2	15	ppb
048-33A	Drinking Fountain next to Locker 513 (right)	6/20/16 1:15 AM	6/24/16 5:00 PM	BB65944	Copper	0.0	1.3	ppm
048-33A	Drinking Fountain next to Locker 513 (right)	6/20/16 1:15 AM	6/24/16 5:00 PM	BB65944	Lead	3	15	ppb
048-34A	C121 Choir Drinking Fountain	6/20/16 12:15 AM	6/24/16 5:03 PM	BB65945	Copper	0.0	1.3	ppm
048-34A	C121 Choir Drinking Fountain	6/20/16 12:15 AM	6/24/16 5:03 PM	BB65945	Lead	28	15	ppb
048-35A	C125 Band Drinking Fountain	6/20/16 12:17 AM	6/24/16 5:06 PM	BB65946	Copper	0.0	1.3	ppm
048-35A	C125 Band Drinking Fountain	6/20/16 12:17 AM	6/24/16 5:06 PM	BB65946	Lead	2	15	ppb
048-36A	Custodial next to Band Room Sink Faucet	6/20/16 12:20 AM	6/24/16 5:09 PM	BB65947	Copper	0.0	1.3	ppm
048-36A	Custodial next to Band Room Sink Faucet	6/20/16 12:20 AM	6/24/16 5:09 PM	BB65947	Lead	17	15	ppb
048-37A	C127 Work Shop Sink Faucet	6/20/16 12:25 AM	6/24/16 5:12 PM	BB65948	Copper	0.1	1.3	ppm
048-37A	C127 Work Shop Sink Faucet	6/20/16 12:25 AM	6/24/16 5:12 PM	BB65948	Lead	5	15	ppb
048-38A	C129 Boys Dressing Room Sink Faucet	6/20/16 12:28 AM	6/24/16 5:15 PM	BB65949	Copper	0.0	1.3	ppm
048-38A	C129 Boys Dressing Room Sink Faucet	6/20/16 12:28 AM	6/24/16 5:15 PM	BB65949	Lead	240	15	ppb
048-39A	C129 Boys Dressing Room Shower	6/20/16 12:32 AM	6/24/16 5:18 PM	BB65950	Copper	0.1	1.3	ppm
048-39A	C129 Boys Dressing Room Shower	6/20/16 12:32 AM	6/24/16 5:18 PM	BB65950	Lead	14	15	ppb
048-40A	C131 Girls Dressing Room Sink Faucet	6/20/16 12:35 AM	6/24/16 5:21 PM	BB65951	Copper	0.1	1.3	ppm
048-40A	C131 Girls Dressing Room Sink Faucet	6/20/16 12:35 AM	6/24/16 5:21 PM	BB65951	Lead	7	15	ppb
048-41A	C131 Girls Dressing Room Shower	6/20/16 12:40 AM	6/24/16 5:24 PM	BB65952	Copper	0.1	1.3	ppm
048-41A	C131 Girls Dressing Room Shower	6/20/16 12:40 AM	6/24/16 5:24 PM	BB65952	Lead	2	15	ppb
048-42A	C135 Home Economics Sink Faucet (left)	6/20/16 12:43 AM	6/24/16 5:39 PM	BB65953	Copper	0.0	1.3	ppm
048-42A	C135 Home Economics Sink Faucet (left)	6/20/16 12:43 AM	6/24/16 5:39 PM	BB65953	Lead	6	15	ppb
048-43A	C135 Home Economics Sink Faucet (left middle)	6/20/16 12:45 AM	6/24/16 5:42 PM	BB65954	Copper	0.1	1.3	ppm
048-43A	C135 Home Economics Sink Faucet (left middle)	6/20/16 12:45 AM	6/24/16 5:42 PM	BB65954	Lead	17	15	ppb
048-44A	C135 Home Economics Sink Faucet (right middle)	6/20/16 12:47 AM	6/24/16 5:45 PM	BB65955	Copper	0.0	1.3	ppm
048-44A	C135 Home Economics Sink Faucet (right middle)	6/20/16 12:47 AM	6/24/16 5:45 PM	BB65955	Lead	9	15	ppb
048-45A	C135 Home Economics Sink Faucet (right)	6/20/16 12:50 AM	7/3/16 3:53 PM	BB65956	Copper	0.1	1.3	ppm
048-45A	C135 Home Economics Sink Faucet (right)	6/20/16 12:50 AM	7/3/16 3:53 PM	BB65956	Lead	25	15	ppb
048-46A	C135 Home Economics Sink Faucet (by window)	6/20/16 12:53 AM	6/24/16 5:48 PM	BB65957	Copper	0.0	1.3	ppm
048-46A	C135 Home Economics Sink Faucet (by window)	6/20/16 12:53 AM	6/24/16 5:48 PM	BB65957	Lead	8	15	ppb
048-47A	C138 Art Sink Faucet (on window wall)	6/20/16 12:58 AM	6/24/16 5:51 PM	BB65958	Copper	0.1	1.3	ppm
048-47A	C138 Art Sink Faucet (on window wall)	6/20/16 12:58 AM	6/24/16 5:51 PM	BB65958	Lead	26	15	ppb
048-48A	C138 Art Sink Faucet (on door wall)	6/20/16 1:03 AM	6/24/16 5:54 PM	BB65959	Copper	0.1	1.3	ppm
048-48A	C138 Art Sink Faucet (on door wall)	6/20/16 1:03 AM	6/24/16 5:54 PM	BB65959	Lead	3	15	ppb
048-49A	C138 Art Sink Faucet (storage room)	6/20/16 1:05 AM	6/24/16 5:58 PM	BB65960	Copper	0.0	1.3	ppm
048-49A	C138 Art Sink Faucet (storage room)	6/20/16 1:05 AM	6/24/16 5:58 PM	BB65960	Lead	2	15	ppb
048-50A	Drinking Fountain next to C131 (left)	6/20/16 1:09 AM	6/24/16 6:00 PM	BB65961	Copper	0.0	1.3	ppm
048-50A	Drinking Fountain next to C131 (left)	6/20/16 1:09 AM	6/24/16 6:00 PM	BB65961	Lead	2	15	ppb
048-51A	Drinking Fountain next to C131 (right)	6/20/16 1:13 AM	6/24/16 6:04 PM	BB65962	Copper	0.0	1.3	ppm
048-51A	Drinking Fountain next to C131 (right)	6/20/16 1:13 AM	6/24/16 6:04 PM	BB65962	Lead	2	15	ppb
048-52A	Stage Sink Faucet	6/20/16 1:08 AM	6/24/16 6:07 PM	BB65963	Copper	0.0	1.3	ppm
048-52A	Stage Sink Faucet	6/20/16 1:08 AM	6/24/16 6:07 PM	BB65963	Lead	9	15	ppb
048-53A	D128 Classroom Sink Faucet	6/20/16 1:11 AM	6/24/16 6:28 PM	BB65964	Copper	0.0	1.3	ppm
048-53A	D128 Classroom Sink Faucet	6/20/16 1:11 AM	6/24/16 6:28 PM	BB65964	Lead	23	15	ppb
048-54A	Custodial next to D128 Sink Faucet	6/20/16 1:14 AM	6/24/16 6:31 PM	BB65965	Copper	0.0	1.3	ppm
048-54A	Custodial next to D128 Sink Faucet	6/20/16 1:14 AM	6/24/16 6:31 PM	BB65965	Lead	23	15	ppb
048-55A	Drinking Fountain near D128 (left)	6/20/16 1:17 AM	6/24/16 6:34 PM	BB65966	Copper	0.0	1.3	ppm
048-55A	Drinking Fountain near D128 (left)	6/20/16 1:17 AM	6/24/16 6:34 PM	BB65966	Lead	4	15	ppb
048-56A	Drinking Fountain near D128 (right)	6/20/16 1:20 AM	6/24/16 6:37 PM	BB65967	Copper	0.0	1.3	ppm
048-56A	Drinking Fountain near D128 (right)	6/20/16 1:20 AM	6/24/16 6:37 PM	BB65967	Lead	2	15	ppb
048-57A	D129 Sink Faucet	6/20/16 1:23 AM	6/24/16 6:40 PM	BB65968	Copper	0.0	1.3	ppm
048-57A	D129 Sink Faucet	6/20/16 1:23 AM	6/24/16 6:40 PM	BB65968	Lead	8	15	ppb
048-58A	G155 Storage in G154 Sink Faucet	6/20/16 1:27 AM	6/24/16 6:43 PM	BB65969	Copper	0.0	1.3	ppm
048-58A	G155 Storage in G154 Sink Faucet	6/20/16 1:27 AM	6/24/16 6:43 PM	BB65969	Lead	13	15	ppb
048-59A	G154 near G155 Sink Faucet	6/20/16 1:29 AM	6/24/16 6:46 PM	BB65970	Copper	0.0	1.3	ppm
048-59A	G154 near G155 Sink Faucet	6/20/16 1:29 AM	6/24/16 6:46 PM	BB65970	Lead	6	15	ppb
048-60A	G154 far left Sink Faucet	6/20/16 1:32 AM	6/24/16 6:49 PM	BB65971	Copper	0.0	1.3	ppm
048-60A	G154 far left Sink Faucet	6/20/16 1:32 AM	6/24/16 6:49 PM	BB65971	Lead	12	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Jackson Middle School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
048-61A	G154 right (near ducks fridge) Sink Faucet	6/20/16 1:35 AM	6/24/16 6:52 PM	BB65972	Copper	0.0	1.3	ppm
048-61A	G154 right (near ducks fridge) Sink Faucet	6/20/16 1:35 AM	6/24/16 6:52 PM	BB65972	Lead	4	15	ppb
048-62A	D119/116 Sink Faucet	6/20/16 1:39 AM	6/24/16 6:55 PM	BB65973	Copper	0.0	1.3	ppm
048-62A	D119/116 Sink Faucet	6/20/16 1:39 AM	6/24/16 6:55 PM	BB65973	Lead	112	15	ppb
048-63A	Main Office Sink Faucet	6/20/16 1:42 AM	6/24/16 7:10 PM	BB65974	Copper	0.0	1.3	ppm
048-63A	Main Office Sink Faucet	6/20/16 1:42 AM	6/24/16 7:10 PM	BB65974	Lead	4	15	ppb
048-64A	Nurse Sink Faucet	6/20/16 1:45 AM	6/24/16 7:13 PM	BB65975	Copper	0.0	1.3	ppm
048-64A	Nurse Sink Faucet	6/20/16 1:45 AM	6/24/16 7:13 PM	BB65975	Lead	18	15	ppb
048-65A	Mens Faculty Bathroom Sink Faucet	6/20/16 1:48 AM	6/24/16 7:16 PM	BB65976	Copper	0.0	1.3	ppm
048-65A	Mens Faculty Bathroom Sink Faucet	6/20/16 1:48 AM	6/24/16 7:16 PM	BB65976	Lead	3	15	ppb
048-66A	Drinking Fountain outside Office (left)	6/20/16 1:52 AM	6/24/16 7:19 PM	BB65977	Copper	0.0	1.3	ppm
048-66A	Drinking Fountain outside Office (left)	6/20/16 1:52 AM	6/24/16 7:19 PM	BB65977	Lead	2	15	ppb
048-67A	Drinking Fountain outside Office (right)	6/20/16 1:20 AM	6/24/16 7:22 PM	BB65978	Copper	0.0	1.3	ppm
048-67A	Drinking Fountain outside Office (right)	6/20/16 1:20 AM	6/24/16 7:22 PM	BB65978	Lead	2	15	ppb
048-68A	Staff Bathroom Sink Faucet	6/20/16 1:24 AM	6/24/16 7:25 PM	BB65979	Copper	0.0	1.3	ppm
048-68A	Staff Bathroom Sink Faucet	6/20/16 1:24 AM	6/24/16 7:25 PM	BB65979	Lead	9	15	ppb
048-69A	Boys Bathroom Sink Faucet (left)	6/20/16 1:27 AM	7/3/16 3:56 PM	BB65980	Copper	0.3	1.3	ppm
048-69A	Boys Bathroom Sink Faucet (left)	6/20/16 1:27 AM	7/3/16 3:56 PM	BB65980	Lead	11	15	ppb
048-70A	Boys Bathroom Sink Faucet (left middle)	6/20/16 1:29 AM	7/3/16 4:00 PM	BB65981	Copper	0.3	1.3	ppm
048-70A	Boys Bathroom Sink Faucet (left middle)	6/20/16 1:29 AM	7/3/16 4:00 PM	BB65981	Lead	11	15	ppb
048-71A	Boys Bathroom Sink Faucet (right middle)	6/20/16 1:31 AM	7/3/16 4:03 PM	BB65982	Copper	0.2	1.3	ppm
048-71A	Boys Bathroom Sink Faucet (right middle)	6/20/16 1:31 AM	7/3/16 4:03 PM	BB65982	Lead	9	15	ppb
048-72A	Boys Bathroom Sink Faucet (right)	6/20/16 1:33 AM	7/3/16 4:07 PM	BB65983	Copper	0.2	1.3	ppm
048-72A	Boys Bathroom Sink Faucet (right)	6/20/16 1:33 AM	7/3/16 4:07 PM	BB65983	Lead	8	15	ppb
048-73A	Boys Bathroom Water Spigot	6/20/16 1:36 AM	7/3/16 3:42 PM	BB65984	Copper	0.4	1.3	ppm
048-73A	Boys Bathroom Water Spigot	6/20/16 1:36 AM	7/3/16 3:42 PM	BB65984	Lead	93	15	ppb
048-74A	Drinking Fountain Between Bathrooms (left)	6/20/16 1:39 AM	7/3/16 4:10 PM	BB65985	Copper	0.2	1.3	ppm
048-74A	Drinking Fountain Between Bathrooms (left)	6/20/16 1:39 AM	7/3/16 4:10 PM	BB65985	Lead	13	15	ppb
048-75A	Drinking Fountain Between Bathrooms (right)	6/20/16 1:41 AM	7/3/16 4:14 PM	BB65986	Copper	0.1	1.3	ppm
048-75A	Drinking Fountain Between Bathrooms (right)	6/20/16 1:41 AM	7/3/16 4:14 PM	BB65986	Lead	6	15	ppb
048-76A	Girls Bathroom Sink Faucet (left)	6/20/16 1:44 AM	7/3/16 4:42 PM	BB65987	Copper	0.1	1.3	ppm
048-76A	Girls Bathroom Sink Faucet (left)	6/20/16 1:44 AM	7/3/16 4:42 PM	BB65987	Lead	6	15	ppb
048-77A	Girls Bathroom Sink Faucet (center)	6/20/16 1:46 AM	6/24/16 7:59 PM	BB65988	Copper	0.2	1.3	ppm
048-77A	Girls Bathroom Sink Faucet (center)	6/20/16 1:46 AM	6/24/16 7:59 PM	BB65988	Lead	39	15	ppb
048-78A	Girls Bathroom Sink Faucet (right)	6/20/16 1:48 AM	7/3/16 4:45 PM	BB65989	Copper	0.1	1.3	ppm
048-78A	Girls Bathroom Sink Faucet (right)	6/20/16 1:48 AM	7/3/16 4:45 PM	BB65989	Lead	8	15	ppb
048-79A	Girls Bathroom Water Spigot	6/20/16 1:50 AM	7/3/16 4:49 PM	BB65990	Copper	0.2	1.3	ppm
048-79A	Girls Bathroom Water Spigot	6/20/16 1:50 AM	7/3/16 4:49 PM	BB65990	Lead	53	15	ppb
048-80A	East Custodial Sink Faucet	6/20/16 1:54 AM	6/24/16 8:02 PM	BB65991	Copper	0.0	1.3	ppm
048-80A	East Custodial Sink Faucet	6/20/16 1:54 AM	6/24/16 8:02 PM	BB65991	Lead	2	15	ppb
048-81A	Instructional Materials Sink Faucet (1st floor)	6/20/16 1:57 AM	6/24/16 8:05 PM	BB65992	Copper	0.0	1.3	ppm
048-81A	Instructional Materials Sink Faucet (1st floor)	6/20/16 1:57 AM	6/24/16 8:05 PM	BB65992	Lead	5	15	ppb
048-82A	Instructional Materials Sink Faucet (2nd floor)	6/20/16 2:02 AM	6/24/16 8:08 PM	BB65993	Copper	0.0	1.3	ppm
048-82A	Instructional Materials Sink Faucet (2nd floor)	6/20/16 2:02 AM	6/24/16 8:08 PM	BB65993	Lead	3	15	ppb
048-83A	Staff Bathroom (2nd floor) Sink Faucet	6/20/16 2:06 AM	6/24/16 8:11 PM	BB65994	Copper	0.0	1.3	ppm
048-83A	Staff Bathroom (2nd floor) Sink Faucet	6/20/16 2:06 AM	6/24/16 8:11 PM	BB65994	Lead	14.5	15	ppb
048-84A	Girls Bathroom (2nd floor) Sink Faucet (left)	6/20/16 2:10 AM	7/3/16 4:52 PM	BB65995	Copper	0.1	1.3	ppm
048-84A	Girls Bathroom (2nd floor) Sink Faucet (left)	6/20/16 2:10 AM	7/3/16 4:52 PM	BB65995	Lead	8	15	ppb
048-85A	Girls Bathroom (2nd floor) Sink Faucet (middle)	6/20/16 2:12 AM	6/24/16 8:14 PM	BB65996	Copper	0.0	1.3	ppm
048-85A	Girls Bathroom (2nd floor) Sink Faucet (middle)	6/20/16 2:12 AM	6/24/16 8:14 PM	BB65996	Lead	7	15	ppb
048-86A	Girls Bathroom (2nd floor) Sink Faucet (right)	6/20/16 2:14 AM	6/24/16 8:17 PM	BB65997	Copper	0.1	1.3	ppm
048-86A	Girls Bathroom (2nd floor) Sink Faucet (right)	6/20/16 2:14 AM	6/24/16 8:17 PM	BB65997	Lead	6	15	ppb
048-88A	Boys Bathroom (2nd floor) Sink Faucet (left)	6/20/16 2:17 AM	6/24/16 8:20 PM	BB65998	Copper	0.1	1.3	ppm
048-88A	Boys Bathroom (2nd floor) Sink Faucet (left)	6/20/16 2:17 AM	6/24/16 8:20 PM	BB65998	Lead	15.3	15	ppb
048-89A	Boys Bathroom (2nd floor) Sink Faucet (middle)	6/20/16 2:19 AM	6/24/16 8:23 PM	BB65999	Copper	0.0	1.3	ppm
048-89A	Boys Bathroom (2nd floor) Sink Faucet (middle)	6/20/16 2:19 AM	6/24/16 8:23 PM	BB65999	Lead	7	15	ppb
048-90A	Boys Bathroom (2nd floor) Sink Faucet (right)	6/20/16 2:21 AM	6/24/16 8:26 PM	BB66000	Copper	0.0	1.3	ppm
048-90A	Boys Bathroom (2nd floor) Sink Faucet (right)	6/20/16 2:21 AM	6/24/16 8:26 PM	BB66000	Lead	22	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Jackson Middle School

Sample Identification # and Location		Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
048-92A	Mens Faculty Bathroom Sink Faucet (2nd Floor)	6/20/16 2:24 AM	6/24/16 8:41 PM	BB66001	Copper	0.0	1.3	ppm
048-92A	Mens Faculty Bathroom Sink Faucet (2nd Floor)	6/20/16 2:24 AM	6/24/16 8:41 PM	BB66001	Lead	7	15	ppb
048-93A	Custodial near Stage G3 Sink Faucet	6/20/16 2:27 AM	6/24/16 8:44 PM	BB66002	Copper	0.1	1.3	ppm
048-93A	Custodial near Stage G3 Sink Faucet	6/20/16 2:27 AM	6/24/16 8:44 PM	BB66002	Lead	2	15	ppb
048-94A	Drinking Fountain (2nd floor) near G3 (left)	6/20/16 2:30 AM	6/24/16 8:47 PM	BB66003	Copper	0.1	1.3	ppm
048-94A	Drinking Fountain (2nd floor) near G3 (left)	6/20/16 2:30 AM	6/24/16 8:47 PM	BB66003	Lead	0	15	ppb
048-95A	Drinking Fountain (2nd floor) near G3 (right)	6/20/16 2:32 AM	6/24/16 8:50 PM	BB66004	Copper	0.0	1.3	ppm
048-95A	Drinking Fountain (2nd floor) near G3 (right)	6/20/16 2:32 AM	6/24/16 8:50 PM	BB66004	Lead	3	15	ppb
048-96A	G130 Classroom Sink Faucet #1A	6/20/16 2:36 AM	6/24/16 8:53 PM	BB66005	Copper	0.2	1.3	ppm
048-96A	G130 Classroom Sink Faucet #1A	6/20/16 2:36 AM	6/24/16 8:53 PM	BB66005	Lead	52	15	ppb
048-97A	G130 Classroom Sink Faucet #1B	6/20/16 2:38 AM	6/24/16 8:56 PM	BB66006	Copper	0.1	1.3	ppm
048-97A	G130 Classroom Sink Faucet #1B	6/20/16 2:38 AM	6/24/16 8:56 PM	BB66006	Lead	57	15	ppb
048-98A	G130 Classroom Sink Faucet #2A	6/20/16 2:40 AM	6/24/16 8:59 PM	BB66007	Copper	0.2	1.3	ppm
048-98A	G130 Classroom Sink Faucet #2A	6/20/16 2:40 AM	6/24/16 8:59 PM	BB66007	Lead	88	15	ppb
048-99A	G130 Classroom Sink Faucet #2B	6/20/16 2:42 AM	7/3/16 4:56 PM	BB66008	Copper	0.1	1.3	ppm
048-99A	G130 Classroom Sink Faucet #2B	6/20/16 2:42 AM	7/3/16 4:56 PM	BB66008	Lead	188	15	ppb
048-100A	G130 Classroom Sink Faucet #3A	6/20/16 1:58 AM	6/24/16 9:02 PM	BB66009	Copper	0.3	1.3	ppm
048-100A	G130 Classroom Sink Faucet #3A	6/20/16 1:58 AM	6/24/16 9:02 PM	BB66009	Lead	46	15	ppb
048-101A	G130 Classroom Sink Faucet #3B	6/20/16 2:00 AM	6/24/16 9:05 PM	BB66010	Copper	0.3	1.3	ppm
048-101A	G130 Classroom Sink Faucet #3B	6/20/16 2:00 AM	6/24/16 9:05 PM	BB66010	Lead	77	15	ppb
048-102A	G130 Classroom Sink Faucet #4A	6/20/16 2:02 AM	6/24/16 9:08 PM	BB66011	Copper	0.3	1.3	ppm
048-102A	G130 Classroom Sink Faucet #4A	6/20/16 2:02 AM	6/24/16 9:08 PM	BB66011	Lead	21	15	ppb
048-104A	G130 Classroom Sink Faucet #5A	6/20/16 2:04 AM	6/24/16 9:30 PM	BB66012	Copper	0.0	1.3	ppm
048-104A	G130 Classroom Sink Faucet #5A	6/20/16 2:04 AM	6/24/16 9:30 PM	BB66012	Lead	13	15	ppb
048-105A	G130 Classroom Sink Faucet #5B	6/20/16 2:06 AM	6/24/16 9:32 PM	BB66013	Copper	0.1	1.3	ppm
048-105A	G130 Classroom Sink Faucet #5B	6/20/16 2:06 AM	6/24/16 9:32 PM	BB66013	Lead	65	15	ppb
048-106A	G130 Classroom Sink Faucet #6A	6/20/16 2:08 AM	6/24/16 9:36 PM	BB66014	Copper	0.0	1.3	ppm
048-106A	G130 Classroom Sink Faucet #6A	6/20/16 2:08 AM	6/24/16 9:36 PM	BB66014	Lead	4	15	ppb
048-107A	G130 Classroom Sink Faucet #6B	6/20/16 2:10 AM	6/24/16 9:39 PM	BB66015	Copper	0.1	1.3	ppm
048-107A	G130 Classroom Sink Faucet #6B	6/20/16 2:10 AM	6/24/16 9:39 PM	BB66015	Lead	24	15	ppb
048-108A	G130 Classroom Sink Faucet #7A	6/20/16 2:12 AM	6/24/16 9:42 PM	BB66016	Copper	0.0	1.3	ppm
048-108A	G130 Classroom Sink Faucet #7A	6/20/16 2:12 AM	6/24/16 9:42 PM	BB66016	Lead	8	15	ppb
048-109A	G130 Classroom Sink Faucet #7B	6/20/16 2:14 AM	6/24/16 9:45 PM	BB66017	Copper	0.1	1.3	ppm
048-109A	G130 Classroom Sink Faucet #7B	6/20/16 2:14 AM	6/24/16 9:45 PM	BB66017	Lead	9	15	ppb
048-110A	G130 Classroom Sink Faucet #8A	6/20/16 2:16 AM	6/24/16 9:48 PM	BB66018	Copper	0.1	1.3	ppm
048-110A	G130 Classroom Sink Faucet #8A	6/20/16 2:16 AM	6/24/16 9:48 PM	BB66018	Lead	14	15	ppb
048-111A	G130 Classroom Sink Faucet #8B	6/20/16 2:20 AM	6/24/16 9:51 PM	BB66019	Copper	0.0	1.3	ppm
048-111A	G130 Classroom Sink Faucet #8B	6/20/16 2:20 AM	6/24/16 9:51 PM	BB66019	Lead	2	15	ppb
048-112A	G130 Classroom Sink Faucet #9A	6/20/16 2:22 AM	6/24/16 9:54 PM	BB66020	Copper	0.0	1.3	ppm
048-112A	G130 Classroom Sink Faucet #9A	6/20/16 2:22 AM	6/24/16 9:54 PM	BB66020	Lead	6	15	ppb
048-113A	G130 Classroom Sink Faucet #9B	6/20/16 2:24 AM	6/24/16 9:57 PM	BB66021	Copper	0.0	1.3	ppm
048-113A	G130 Classroom Sink Faucet #9B	6/20/16 2:24 AM	6/24/16 9:57 PM	BB66021	Lead	5	15	ppb
048-114A	G130 Classroom Sink Faucet #10A	6/20/16 2:26 AM	6/25/16 8:41 AM	BB66022	Copper	0.0	1.3	ppm
048-114A	G130 Classroom Sink Faucet #10A	6/20/16 2:26 AM	6/25/16 8:41 AM	BB66022	Lead	10	15	ppb
048-115A	G130 Classroom Sink Faucet #10B	6/20/16 2:28 AM	6/25/16 8:44 AM	BB66023	Copper	0.0	1.3	ppm
048-115A	G130 Classroom Sink Faucet #10B	6/20/16 2:28 AM	6/25/16 8:44 AM	BB66023	Lead	1	15	ppb
048-116A	G130-G131 Connector Sink Faucet #1A	6/20/16 2:30 AM	6/25/16 8:47 AM	BB66024	Copper	0.1	1.3	ppm
048-116A	G130-G131 Connector Sink Faucet #1A	6/20/16 2:30 AM	6/25/16 8:47 AM	BB66024	Lead	82	15	ppb
048-117A	G130-G131 Connector Sink Faucet #1B	6/20/16 2:32 AM	6/25/16 8:50 AM	BB66025	Copper	0.0	1.3	ppm
048-117A	G130-G131 Connector Sink Faucet #1B	6/20/16 2:32 AM	6/25/16 8:50 AM	BB66025	Lead	6	15	ppb
048-118A	G130-G131 Connector Sink Faucet #2	6/20/16 2:34 AM	7/3/16 4:59 PM	BB66026	Copper	0.2	1.3	ppm
048-118A	G130-G131 Connector Sink Faucet #2	6/20/16 2:34 AM	7/3/16 4:59 PM	BB66026	Lead	506	15	ppb
048-119A	G131 Classroom Sink Faucet #1	6/20/16 2:36 AM	6/25/16 8:53 AM	BB66027	Copper	0.0	1.3	ppm
048-119A	G131 Classroom Sink Faucet #1	6/20/16 2:36 AM	6/25/16 8:53 AM	BB66027	Lead	11	15	ppb
048-120A	G131 Classroom Sink Faucet #2A	6/20/16 2:38 AM	7/3/16 5:03 PM	BB66028	Copper	0.1	1.3	ppm
048-120A	G131 Classroom Sink Faucet #2A	6/20/16 2:38 AM	7/3/16 5:03 PM	BB66028	Lead	114	15	ppb
048-121A	G131 Classroom Sink Faucet #2B	6/20/16 2:40 AM	7/3/16 5:06 PM	BB66029	Copper	0.0	1.3	ppm
048-121A	G131 Classroom Sink Faucet #2B	6/20/16 2:40 AM	7/3/16 5:06 PM	BB66029	Lead	30	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Jackson Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
048-122A G131 Classroom Sink Faucet #3	6/20/16 2:44 AM	6/25/16 8:56 AM	BB66030	Copper	0.0	1.3	ppm
048-122A G131 Classroom Sink Faucet #3	6/20/16 2:44 AM	6/25/16 8:56 AM	BB66030	Lead	107	15	ppb
048-123A G131 Classroom Sink Faucet #4	6/20/16 2:47 AM	7/3/16 5:10 PM	BB66031	Copper	0.1	1.3	ppm
048-123A G131 Classroom Sink Faucet #4	6/20/16 2:47 AM	7/3/16 5:10 PM	BB66031	Lead	35	15	ppb
048-124A G125 Shop Room Sink Faucet #1 (near courtyard door)	6/20/16 2:50 AM	7/3/16 5:13 PM	BB66032	Copper	0.2	1.3	ppm
048-124A G125 Shop Room Sink Faucet #1 (near courtyard door)	6/20/16 2:50 AM	7/3/16 5:13 PM	BB66032	Lead	257	15	ppb
048-125A G125 Shop Room Sink Faucet #2	6/20/16 2:52 AM	6/25/16 9:00 AM	BB66033	Copper	0.2	1.3	ppm
048-125A G125 Shop Room Sink Faucet #2	6/20/16 2:52 AM	6/25/16 9:00 AM	BB66033	Lead	152	15	ppb
048-126A Greenhouse Sink Faucet #1 (left)	6/20/16 2:54 AM	6/25/16 9:03 AM	BB66034	Copper	0.0	1.3	ppm
048-126A Greenhouse Sink Faucet #1 (left)	6/20/16 2:54 AM	6/25/16 9:03 AM	BB66034	Lead	41	15	ppb
048-127A Greenhouse Sink Faucet #2	6/20/16 2:57 AM	6/25/16 9:06 AM	BB66035	Copper	0.2	1.3	ppm
048-127A Greenhouse Sink Faucet #2	6/20/16 2:57 AM	6/25/16 9:06 AM	BB66035	Lead	195	15	ppb
048-128A Greenhouse Sink Faucet #3	6/20/16 3:01 AM	6/25/16 9:09 AM	BB66036	Copper	0.0	1.3	ppm
048-128A Greenhouse Sink Faucet #3	6/20/16 3:01 AM	6/25/16 9:09 AM	BB66036	Lead	29	15	ppb
048-129A Greenhouse Sink Faucet #4 (right)	6/20/16 3:04 AM	7/3/16 5:48 PM	BB66037	Copper	0.1	1.3	ppm
048-129A Greenhouse Sink Faucet #4 (right)	6/20/16 3:04 AM	7/3/16 5:48 PM	BB66037	Lead	338	15	ppb
048-130A Greenhouse Water Spigot (near 125 door)	6/20/16 3:07 AM	6/25/16 9:24 AM	BB66038	Copper	0.0	1.3	ppm
048-130A Greenhouse Water Spigot (near 125 door)	6/20/16 3:07 AM	6/25/16 9:24 AM	BB66038	Lead	16	15	ppb
048-131A Greenhouse Water Spigot (near window left)	6/20/16 3:10 AM	6/25/16 9:27 AM	BB66039	Copper	0.0	1.3	ppm
048-131A Greenhouse Water Spigot (near window left)	6/20/16 3:10 AM	6/25/16 9:27 AM	BB66039	Lead	11	15	ppb
048-132A Greenhouse Water Spigot (near window right)	6/20/16 3:12 AM	6/25/16 9:30 AM	BB66040	Copper	0.0	1.3	ppm
048-132A Greenhouse Water Spigot (near window right)	6/20/16 3:12 AM	6/25/16 9:30 AM	BB66040	Lead	2	15	ppb
048-133A G116 Sink Faucet #1 (white)	6/20/16 3:00 AM	6/25/16 9:33 AM	BB66041	Copper	0.0	1.3	ppm
048-133A G116 Sink Faucet #1 (white)	6/20/16 3:00 AM	6/25/16 9:33 AM	BB66041	Lead	21	15	ppb
048-134A G116 Sink Faucet #2A	6/20/16 3:02 AM	7/3/16 5:51 PM	BB66042	Copper	0.1	1.3	ppm
048-134A G116 Sink Faucet #2A	6/20/16 3:02 AM	7/3/16 5:51 PM	BB66042	Lead	272	15	ppb
048-135A G116 Sink Faucet #2B	6/20/16 3:04 AM	7/3/16 5:55 PM	BB66043	Copper	0.3	1.3	ppm
048-135A G116 Sink Faucet #2B	6/20/16 3:04 AM	7/3/16 5:55 PM	BB66043	Lead	779	15	ppb
048-136A G116 Sink Faucet #3A	6/20/16 3:06 AM	7/3/16 5:58 PM	BB66044	Copper	0.0	1.3	ppm
048-136A G116 Sink Faucet #3A	6/20/16 3:06 AM	7/3/16 5:58 PM	BB66044	Lead	38	15	ppb
048-137A G116 Sink Faucet #3B	6/20/16 3:08 AM	6/25/16 9:36 AM	BB66045	Copper	0.0	1.3	ppm
048-137A G116 Sink Faucet #3B	6/20/16 3:08 AM	6/25/16 9:36 AM	BB66045	Lead	35	15	ppb
048-138A G116 Sink Faucet #4	6/20/16 3:10 AM	6/25/16 9:39 AM	BB66046	Copper	0.0	1.3	ppm
048-138A G116 Sink Faucet #4	6/20/16 3:10 AM	6/25/16 9:39 AM	BB66046	Lead	6	15	ppb
048-139A G119 Prep Room Sink Faucet #1A (left)	6/20/16 3:12 AM	6/25/16 9:42 AM	BB66047	Copper	0.1	1.3	ppm
048-139A G119 Prep Room Sink Faucet #1A (left)	6/20/16 3:12 AM	6/25/16 9:42 AM	BB66047	Lead	62	15	ppb
048-140A G119 Prep Room Sink Faucet #1B (right)	6/20/16 3:14 AM	6/25/16 9:45 AM	BB66048	Copper	0.1	1.3	ppm
048-140A G119 Prep Room Sink Faucet #1B (right)	6/20/16 3:14 AM	6/25/16 9:45 AM	BB66048	Lead	75	15	ppb
048-141A G117 Science Lab Sink Faucet #1A	6/20/16 3:17 AM	7/3/16 6:02 PM	BB66049	Copper	0.3	1.3	ppm
048-141A G117 Science Lab Sink Faucet #1A	6/20/16 3:17 AM	7/3/16 6:02 PM	BB66049	Lead	9	15	ppb
048-142A G117 Science Lab Sink Faucet #1B	6/20/16 3:19 AM	6/25/16 9:48 AM	BB66050	Copper	0.2	1.3	ppm
048-142A G117 Science Lab Sink Faucet #1B	6/20/16 3:19 AM	6/25/16 9:48 AM	BB66050	Lead	22	15	ppb
048-143A G117 Science Lab Sink Faucet #2A	6/20/16 3:21 AM	6/25/16 9:51 AM	BB66051	Copper	0.2	1.3	ppm
048-143A G117 Science Lab Sink Faucet #2A	6/20/16 3:21 AM	6/25/16 9:51 AM	BB66051	Lead	75	15	ppb
048-144A G117 Science Lab Sink Faucet #2B	6/20/16 3:23 AM	6/25/16 10:12 AM	BB66052	Copper	0.2	1.3	ppm
048-144A G117 Science Lab Sink Faucet #2B	6/20/16 3:23 AM	6/25/16 10:12 AM	BB66052	Lead	128	15	ppb
048-145A G117 Science Lab Sink Faucet #3A	6/20/16 3:25 AM	6/25/16 9:01 PM	BB66053	Copper	0.8	1.3	ppm
048-145A G117 Science Lab Sink Faucet #3A	6/20/16 3:25 AM	6/25/16 9:01 PM	BB66053	Lead	153	15	ppb
048-146A G117 Science Lab Sink Faucet #3B	6/20/16 3:27 AM	6/25/16 10:18 AM	BB66054	Copper	0.1	1.3	ppm
048-146A G117 Science Lab Sink Faucet #3B	6/20/16 3:27 AM	6/25/16 10:18 AM	BB66054	Lead	53	15	ppb
048-147A G117 Science Lab Sink Faucet #4A	6/20/16 3:29 AM	6/25/16 10:21 AM	BB66055	Copper	0.2	1.3	ppm
048-147A G117 Science Lab Sink Faucet #4A	6/20/16 3:29 AM	6/25/16 10:21 AM	BB66055	Lead	109	15	ppb
048-148A G117 Science Lab Sink Faucet #4B	6/20/16 3:31 AM	6/25/16 10:24 AM	BB66056	Copper	0.3	1.3	ppm
048-148A G117 Science Lab Sink Faucet #4B	6/20/16 3:31 AM	6/25/16 10:24 AM	BB66056	Lead	681	15	ppb
048-149A G117 Science Lab Sink Faucet #5A	6/20/16 3:33 AM	6/25/16 10:27 AM	BB66057	Copper	0.3	1.3	ppm
048-149A G117 Science Lab Sink Faucet #5A	6/20/16 3:33 AM	6/25/16 10:27 AM	BB66057	Lead	32	15	ppb
048-150A G117 Science Lab Sink Faucet #5B	6/20/16 3:35 AM	6/25/16 10:30 AM	BB66058	Copper	0.2	1.3	ppm
048-150A G117 Science Lab Sink Faucet #5B	6/20/16 3:35 AM	6/25/16 10:30 AM	BB66058	Lead	17	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Jackson Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
048-151A G117 Science Lab Sink Faucet #6A	6/20/16 3:37 AM	6/25/16 10:33 AM	BB66059	Copper	0.2	1.3	ppm
048-151A G117 Science Lab Sink Faucet #6A	6/20/16 3:37 AM	6/25/16 10:33 AM	BB66059	Lead	77	15	ppb
048-152A G117 Science Lab Sink Faucet #6B	6/20/16 3:39 AM	7/3/16 6:05 PM	BB66060	Copper	0.5	1.3	ppm
048-152A G117 Science Lab Sink Faucet #6B	6/20/16 3:39 AM	7/3/16 6:05 PM	BB66060	Lead	774	15	ppb
048-153A G117 Science Lab Sink Faucet #7	6/20/16 3:41 AM	6/25/16 10:36 AM	BB66061	Copper	0.2	1.3	ppm
048-153A G117 Science Lab Sink Faucet #7	6/20/16 3:41 AM	6/25/16 10:36 AM	BB66061	Lead	57	15	ppb
048-154A G117 Science Lab Sink Faucet #8A	6/20/16 3:43 AM	6/25/16 10:39 AM	BB66062	Copper	0.2	1.3	ppm
048-154A G117 Science Lab Sink Faucet #8A	6/20/16 3:43 AM	6/25/16 10:39 AM	BB66062	Lead	98	15	ppb
048-155A G117 Science Lab Sink Faucet #8B	6/20/16 3:45 AM	6/25/16 10:57 AM	BB66063	Copper	0.1	1.3	ppm
048-155A G117 Science Lab Sink Faucet #8B	6/20/16 3:45 AM	6/25/16 10:57 AM	BB66063	Lead	19	15	ppb
048-156A G117 Science Lab Sink Faucet #9A	6/20/16 3:47 AM	6/25/16 11:01 AM	BB66064	Copper	0.2	1.3	ppm
048-156A G117 Science Lab Sink Faucet #9A	6/20/16 3:47 AM	6/25/16 11:01 AM	BB66064	Lead	36	15	ppb
048-157A G117 Science Lab Sink Faucet #9B	6/20/16 3:49 AM	7/3/16 5:44 PM	BB66065	Copper	0.3	1.3	ppm
048-157A G117 Science Lab Sink Faucet #9B	6/20/16 3:49 AM	7/3/16 5:44 PM	BB66065	Lead	706	15	ppb
048-158A G117 Science Lab Sink Faucet #10A	6/20/16 3:51 AM	7/3/16 6:09 PM	BB66066	Copper	0.3	1.3	ppm
048-158A G117 Science Lab Sink Faucet #10A	6/20/16 3:51 AM	7/3/16 6:09 PM	BB66066	Lead	396	15	ppb
048-159A G117 Science Lab Sink Faucet #10B	6/20/16 3:53 AM	7/3/16 6:12 PM	BB66067	Copper	0.2	1.3	ppm
048-159A G117 Science Lab Sink Faucet #10B	6/20/16 3:53 AM	7/3/16 7:02 PM	BB66067	Lead	936	15	ppb
048-160A Instructional Materials (west) 1st floor Sink Faucet	6/20/16 3:56 AM	6/25/16 11:04 AM	BB66068	Copper	0.0	1.3	ppm
048-160A Instructional Materials (west) 1st floor Sink Faucet	6/20/16 3:56 AM	6/25/16 11:04 AM	BB66068	Lead	50	15	ppb
048-161A Boys Bathroom West 1st floor Sink Faucet (left)	6/20/16 4:00 AM	6/25/16 11:07 AM	BB66069	Copper	0.1	1.3	ppm
048-161A Boys Bathroom West 1st floor Sink Faucet (left)	6/20/16 4:00 AM	6/25/16 11:07 AM	BB66069	Lead	6	15	ppb
048-162A Boys Bathroom West 1st floor Sink Faucet (middle right)	6/20/16 4:01 AM	6/25/16 11:10 AM	BB66070	Copper	0.0	1.3	ppm
048-162A Boys Bathroom West 1st floor Sink Faucet (middle right)	6/20/16 4:01 AM	6/25/16 11:10 AM	BB66070	Lead	7	15	ppb
048-163A Boys Bathroom West 1st floor Sink Faucet (right)	6/20/16 4:03 AM	7/3/16 6:16 PM	BB66071	Copper	0.1	1.3	ppm
048-163A Boys Bathroom West 1st floor Sink Faucet (right)	6/20/16 4:03 AM	7/3/16 6:16 PM	BB66071	Lead	9	15	ppb
048-164A Drinking Fountain between Boys and Girls Bathroom(west)	6/20/16 4:06 AM	6/25/16 11:13 AM	BB66072	Copper	0.2	1.3	ppm
048-164A Drinking Fountain between Boys and Girls Bathroom (west)	6/20/16 4:06 AM	6/25/16 11:13 AM	BB66072	Lead	8	15	ppb
048-165A Girls Bathroom west 1st floor Sink Faucet (left)	6/20/16 4:09 AM	7/5/16 10:00 AM	BB66073	Copper	0.1	1.3	ppm
048-165A Girls Bathroom west 1st floor Sink Faucet (left)	6/20/16 4:09 AM	7/5/16 10:00 AM	BB66073	Lead	12	15	ppb
048-166A Girls Bathroom west 1st floor Sink Faucet (middle)	6/20/16 3:20 AM	6/25/16 11:16 AM	BB66074	Copper	0.1	1.3	ppm
048-166A Girls Bathroom west 1st floor Sink Faucet (middle)	6/20/16 3:20 AM	6/25/16 11:16 AM	BB66074	Lead	8	15	ppb
048-167A Girls Bathroom west 1st floor Sink Faucet (right)	6/20/16 3:22 AM	6/25/16 11:19 AM	BB66075	Copper	0.1	1.3	ppm
048-167A Girls Bathroom west 1st floor Sink Faucet (right)	6/20/16 3:22 AM	6/25/16 11:19 AM	BB66075	Lead	6	15	ppb
048-168A Custodial west 1st floor Sink Faucet	6/20/16 3:26 AM	6/25/16 11:22 AM	BB66076	Copper	0.0	1.3	ppm
048-168A Custodial west 1st floor Sink Faucet	6/20/16 3:26 AM	6/25/16 11:22 AM	BB66076	Lead	1	15	ppb
048-169A Custodial west 2nd floor Sink Faucet	6/20/16 3:29 AM	7/5/16 10:04 AM	BB66077	Copper	0.0	1.3	ppm
048-169A Custodial west 2nd floor Sink Faucet	6/20/16 3:29 AM	7/5/16 10:04 AM	BB66077	Lead	63	15	ppb
048-170A Boys Bathroom west 2nd floor Sink Faucet (left)	6/20/16 3:33 AM	6/25/16 11:25 AM	BB66078	Copper	0.0	1.3	ppm
048-170A Boys Bathroom west 2nd floor Sink Faucet (left)	6/20/16 3:33 AM	6/25/16 11:25 AM	BB66078	Lead	18	15	ppb
048-171A Boys Bathroom west 2nd floor Sink Faucet (middle)	6/20/16 3:35 AM	6/25/16 11:46 AM	BB66079	Copper	0.0	1.3	ppm
048-171A Boys Bathroom west 2nd floor Sink Faucet (middle)	6/20/16 3:35 AM	6/25/16 11:46 AM	BB66079	Lead	5	15	ppb
048-172A Boys Bathroom west 2nd floor Sink Faucet (right)	6/20/16 3:37 AM	7/5/16 10:07 AM	BB66080	Copper	0.1	1.3	ppm
048-172A Boys Bathroom west 2nd floor Sink Faucet (right)	6/20/16 3:37 AM	7/5/16 10:07 AM	BB66080	Lead	11	15	ppb
048-173A Mens Handicap west 2nd floor Sink Faucet	6/20/16 3:40 AM	6/25/16 11:49 AM	BB66081	Copper	0.0	1.3	ppm
048-173A Mens Handicap west 2nd floor Sink Faucet	6/20/16 3:40 AM	6/25/16 11:49 AM	BB66081	Lead	8	15	ppb
048-174A Girls Bathroom west 2nd floor Sink Faucet (left)	6/20/16 3:45 AM	6/25/16 11:52 AM	BB66082	Copper	0.1	1.3	ppm
048-174A Girls Bathroom west 2nd floor Sink Faucet (left)	6/20/16 3:45 AM	6/25/16 11:52 AM	BB66082	Lead	13	15	ppb
048-175A Girls Bathroom west 2nd floor Sink Faucet (middle)	6/20/16 3:47 AM	6/25/16 11:55 AM	BB66083	Copper	0.0	1.3	ppm
048-175A Girls Bathroom west 2nd floor Sink Faucet (middle)	6/20/16 3:47 AM	6/25/16 11:55 AM	BB66083	Lead	9	15	ppb
048-176A Girls Bathroom west 2nd floor Sink Faucet (right)	6/20/16 3:49 AM	7/5/16 10:10 AM	BB66084	Copper	0.1	1.3	ppm
048-176A Girls Bathroom west 2nd floor Sink Faucet (right)	6/20/16 3:49 AM	7/5/16 10:10 AM	BB66084	Lead	7	15	ppb
048-177A Womens Staff Bathroom west 2nd floor Sink Faucet	6/20/16 4:20 AM	7/5/16 10:14 AM	BB66085	Copper	0.1	1.3	ppm
048-177A Womens Staff Bathroom west 2nd floor Sink Faucet	6/20/16 4:20 AM	7/5/16 10:14 AM	BB66085	Lead	10	15	ppb
048-178A Instructional Room west 2nd floor Sink Faucet	6/20/16 4:23 AM	6/25/16 11:58 AM	BB66086	Copper	0.0	1.3	ppm
048-178A Instructional Room west 2nd floor Sink Faucet	6/20/16 4:23 AM	6/25/16 11:58 AM	BB66086	Lead	5	15	ppb
048-179A Shop H-07 Custodial Sink Faucet	6/20/16 4:26 AM	6/25/16 12:01 PM	BB66087	Copper	0.0	1.3	ppm
048-179A Shop H-07 Custodial Sink Faucet	6/20/16 4:26 AM	6/25/16 12:01 PM	BB66087	Lead	13	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Jackson Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
048-180A Shop H-08 Girls Bathroom Sink Faucet	6/20/16 4:28 AM	6/25/16 12:04 PM	BB66088	Copper	0.0	1.3	ppm
048-180A Shop H-08 Girls Bathroom Sink Faucet	6/20/16 4:28 AM	6/25/16 12:04 PM	BB66088	Lead	4	15	ppb
048-181A Shop Drinking Fountain	6/20/16 4:30 AM	6/25/16 12:07 PM	BB66089	Copper	0.0	1.3	ppm
048-181A Shop Drinking Fountain	6/20/16 4:30 AM	6/25/16 12:07 PM	BB66089	Lead	9	15	ppb
048-182A Apparatus Room Drinking Fountain	6/20/16 4:32 AM	6/25/16 12:10 PM	BB66090	Copper	0.0	1.3	ppm
048-182A Apparatus Room Drinking Fountain	6/20/16 4:32 AM	6/25/16 12:10 PM	BB66090	Lead	3	15	ppb
048-183A Girls Locker Room Office Sink Faucet	6/20/16 4:36 AM	6/25/16 12:13 PM	BB66091	Copper	0.0	1.3	ppm
048-183A Girls Locker Room Office Sink Faucet	6/20/16 4:36 AM	6/25/16 12:13 PM	BB66091	Lead	18	15	ppb
048-184A Girls Locker Room Office Bathroom Sink Faucet	6/20/16 4:39 AM	6/25/16 3:46 PM	BB66092	Copper	0.1	1.3	ppm
048-184A Girls Locker Room Office Bathroom Sink Faucet	6/20/16 4:39 AM	6/25/16 3:46 PM	BB66092	Lead	24	15	ppb
048-185A Girls Locker Room Office Bathroom Shower	6/20/16 4:41 AM	6/25/16 3:49 PM	BB66093	Copper	0.0	1.3	ppm
048-185A Girls Locker Room Office Bathroom Shower	6/20/16 4:41 AM	6/25/16 3:49 PM	BB66093	Lead	11	15	ppb
048-186A Girls Locker Room Shower (Towel Room Side) #1	6/20/16 4:43 AM	7/5/16 6:58 PM	BB66094	Copper	2.7	1.3	ppm
048-186A Girls Locker Room Shower (Towel Room Side) #1	6/20/16 4:43 AM	7/5/16 9:57 AM	BB66094	Lead	139	15	ppb
048-187A Girls Locker Room Shower (Towel Room Side) #2	6/20/16 4:44 AM	7/5/16 10:17 AM	BB66095	Copper	0.5	1.3	ppm
048-187A Girls Locker Room Shower (Towel Room Side) #2	6/20/16 4:44 AM	7/5/16 10:17 AM	BB66095	Lead	38	15	ppb
048-188A Girls Locker Room Shower (Towel Room Side) #3	6/20/16 4:00 AM	7/5/16 10:21 AM	BB66096	Copper	0.3	1.3	ppm
048-188A Girls Locker Room Shower (Towel Room Side) #3	6/20/16 4:00 AM	7/5/16 10:21 AM	BB66096	Lead	127	15	ppb
048-189A Girls Locker Room Shower (Towel Room Side) #4	6/20/16 4:02 AM	7/5/16 10:24 AM	BB66097	Copper	0.3	1.3	ppm
048-189A Girls Locker Room Shower (Towel Room Side) #4	6/20/16 4:02 AM	7/5/16 10:24 AM	BB66097	Lead	120	15	ppb
048-190A Girls Locker Room Shower (Towel Room Side) #5	6/20/16 4:04 AM	7/5/16 10:28 AM	BB66098	Copper	0.1	1.3	ppm
048-190A Girls Locker Room Shower (Towel Room Side) #5	6/20/16 4:04 AM	7/5/16 10:28 AM	BB66098	Lead	198	15	ppb
048-191A Girls Locker Room Shower (Towel Room Side) #6	6/20/16 4:06 AM	7/5/16 10:59 AM	BB66099	Copper	0.2	1.3	ppm
048-191A Girls Locker Room Shower (Towel Room Side) #6	6/20/16 4:06 AM	7/5/16 10:59 AM	BB66099	Lead	174	15	ppb
048-192A Girls Locker Room Shower (Towel Room Side) #7	6/20/16 4:08 AM	7/5/16 11:03 AM	BB66100	Copper	0.2	1.3	ppm
048-192A Girls Locker Room Shower (Towel Room Side) #7	6/20/16 4:08 AM	7/5/16 11:03 AM	BB66100	Lead	140	15	ppb
048-193A Girls Locker Room Shower (Towel Room Side) #8	6/20/16 4:10 AM	7/5/16 11:06 AM	BB66101	Copper	0.4	1.3	ppm
048-193A Girls Locker Room Shower (Towel Room Side) #8	6/20/16 4:10 AM	7/5/16 11:06 AM	BB66101	Lead	284	15	ppb
048-194A Girls Locker Room Shower (Towel Room Side) #9	6/20/16 4:12 AM	7/5/16 7:08 PM	BB66102	Copper	0.8	1.3	ppm
048-194A Girls Locker Room Shower (Towel Room Side) #9	6/20/16 4:12 AM	7/5/16 7:08 PM	BB66102	Lead	269	15	ppb
048-195A Girls Locker Room Shower (Towel Room Side) #10	6/20/16 4:14 AM	7/5/16 11:13 AM	BB66103	Copper	0.4	1.3	ppm
048-195A Girls Locker Room Shower (Towel Room Side) #10	6/20/16 4:14 AM	7/5/16 11:13 AM	BB66103	Lead	327	15	ppb
048-196A Girls Locker Room Shower (Right Side) #1	6/20/16 4:18 AM	7/5/16 11:16 AM	BB66104	Copper	0.1	1.3	ppm
048-196A Girls Locker Room Shower (Right Side) #1	6/20/16 4:18 AM	7/5/16 11:16 AM	BB66104	Lead	46	15	ppb
048-197A Girls Locker Room Shower (Right Side) #2	6/20/16 4:20 AM	7/5/16 11:20 AM	BB66105	Copper	0.2	1.3	ppm
048-197A Girls Locker Room Shower (Right Side) #2	6/20/16 4:20 AM	7/5/16 11:20 AM	BB66105	Lead	66	15	ppb
048-198A Girls Locker Room Shower (Right Side) #3	6/20/16 4:22 AM	7/5/16 11:23 AM	BB66106	Copper	0.1	1.3	ppm
048-198A Girls Locker Room Shower (Right Side) #3	6/20/16 4:22 AM	7/5/16 11:23 AM	BB66106	Lead	24	15	ppb
048-199A Girls Locker Room Shower (Right Side) #4	6/20/16 4:49 AM	6/29/16 1:14 PM	BB66107	Copper	0.1	1.3	ppm
048-199A Girls Locker Room Shower (Right Side) #4	6/20/16 4:49 AM	6/29/16 1:14 PM	BB66107	Lead	47	15	ppb
048-200A Girls Locker Room Shower (Right Side) #5	6/20/16 4:51 AM	7/5/16 11:27 AM	BB66108	Copper	0.5	1.3	ppm
048-200A Girls Locker Room Shower (Right Side) #5	6/20/16 4:51 AM	7/5/16 11:27 AM	BB66108	Lead	50	15	ppb
048-201A Girls Locker Room Shower (Right Side) #6	6/20/16 4:53 AM	7/5/16 11:30 AM	BB66109	Copper	0.8	1.3	ppm
048-201A Girls Locker Room Shower (Right Side) #6	6/20/16 4:53 AM	7/5/16 11:30 AM	BB66109	Lead	68	15	ppb
048-202A Girls Locker Room Shower (Right Side) #7	6/20/16 4:55 AM	6/29/16 1:17 PM	BB66110	Copper	0.6	1.3	ppm
048-202A Girls Locker Room Shower (Right Side) #7	6/20/16 4:55 AM	6/29/16 1:17 PM	BB66110	Lead	63	15	ppb
048-203A Girls Locker Room Shower (Right Side) #8	6/20/16 4:57 AM	7/5/16 12:02 PM	BB66111	Copper	0.6	1.3	ppm
048-203A Girls Locker Room Shower (Right Side) #8	6/20/16 4:57 AM	7/5/16 12:02 PM	BB66111	Lead	65	15	ppb
048-204A Girls Locker Room Shower (Right Side) #9	6/20/16 5:00 AM	7/5/16 12:05 PM	BB66112	Copper	0.7	1.3	ppm
048-204A Girls Locker Room Shower (Right Side) #9	6/20/16 5:00 AM	7/5/16 12:05 PM	BB66112	Lead	97	15	ppb
048-205A Girls Locker Room Shower (Right Side) #10	6/20/16 5:01 AM	6/29/16 1:20 PM	BB66113	Copper	0.1	1.3	ppm
048-205A Girls Locker Room Shower (Right Side) #10	6/20/16 5:01 AM	6/29/16 1:20 PM	BB66113	Lead	27	15	ppb
048-206A Girls Locker Room Shower (Right Side) #11	6/20/16 5:03 AM	6/29/16 5:15 PM	BB66114	Copper	0.1	1.3	ppm
048-206A Girls Locker Room Shower (Right Side) #11	6/20/16 5:03 AM	6/29/16 5:15 PM	BB66114	Lead	26	15	ppb
048-207A Girls Locker Room Shower (Right Side) #12	6/20/16 5:05 AM	6/29/16 1:26 PM	BB66115	Copper	0.0	1.3	ppm
048-207A Girls Locker Room Shower (Right Side) #12	6/20/16 5:05 AM	6/29/16 1:26 PM	BB66115	Lead	17	15	ppb
048-208A Girls Locker Room Sink Faucet (left)	6/20/16 5:07 AM	6/29/16 1:29 PM	BB66116	Copper	0.0	1.3	ppm
048-208A Girls Locker Room Sink Faucet (left)	6/20/16 5:07 AM	6/29/16 1:29 PM	BB66116	Lead	21	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Jackson Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
048-209A Girls Locker Room Sink Faucet (middle)	6/20/16 5:09 AM	6/29/16 1:32 PM	BB66117	Copper	0.0	1.3	ppm
048-209A Girls Locker Room Sink Faucet (middle)	6/20/16 5:09 AM	6/29/16 1:32 PM	BB66117	Lead	31	15	ppb
048-210A Girls Locker Room Sink Faucet (right)	6/20/16 6:00 AM	6/29/16 1:35 PM	BB66118	Copper	0.0	1.3	ppm
048-210A Girls Locker Room Sink Faucet (right)	6/20/16 6:00 AM	6/29/16 1:35 PM	BB66118	Lead	6	15	ppb
048-211A Girls Locker Room Custodial Sink Faucet	6/20/16 6:03 AM	7/5/16 12:08 PM	BB66119	Copper	0.1	1.3	ppm
048-211A Girls Locker Room Custodial Sink Faucet	6/20/16 6:03 AM	7/5/16 12:08 PM	BB66119	Lead	48	15	ppb
048-212A Girls Locker Room Single Shower	6/20/16 6:06 AM	6/29/16 1:38 PM	BB66120	Copper	0.0	1.3	ppm
048-212A Girls Locker Room Single Shower	6/20/16 6:06 AM	6/29/16 1:38 PM	BB66120	Lead	21	15	ppb
048-213A Between Locker Rooms Whirlpool Faucets #1	6/20/16 6:09 AM	7/5/16 12:12 PM	BB66121	Copper	0.0	1.3	ppm
048-213A Between Locker Rooms Whirlpool Faucets #1	6/20/16 6:09 AM	7/5/16 12:12 PM	BB66121	Lead	316	15	ppb
048-214A Between Locker Rooms Whirlpool Faucets #2	6/20/16 6:11 AM	7/5/16 12:15 PM	BB66122	Copper	0.2	1.3	ppm
048-214A Between Locker Rooms Whirlpool Faucets #2	6/20/16 6:11 AM	7/5/16 12:15 PM	BB66122	Lead	318	15	ppb
048-215A Between Locker Rooms Whirlpool Faucets #4	6/20/16 6:13 AM	6/29/16 1:41 PM	BB66123	Copper	0.0	1.3	ppm
048-215A Between Locker Rooms Whirlpool Faucets #4	6/20/16 6:13 AM	6/29/16 1:41 PM	BB66123	Lead	84	15	ppb
048-216A Between Locker Rooms Whirlpool Faucets #5	6/20/16 6:15 AM	7/5/16 12:19 PM	BB66124	Copper	0.0	1.3	ppm
048-216A Between Locker Rooms Whirlpool Faucets #5	6/20/16 6:15 AM	7/5/16 12:19 PM	BB66124	Lead	140	15	ppb
048-217A Between Locker Rooms Whirlpool Faucets #6	6/20/16 6:17 AM	7/5/16 12:22 PM	BB66125	Copper	0.0	1.3	ppm
048-217A Between Locker Rooms Whirlpool Faucets #6	6/20/16 6:17 AM	7/5/16 12:22 PM	BB66125	Lead	152	15	ppb
048-218A Girls Locker Room Drinking Fountain	6/20/16 6:28 AM	6/29/16 1:56 PM	BB66126	Copper	0.0	1.3	ppm
048-218A Girls Locker Room Drinking Fountain	6/20/16 6:28 AM	6/29/16 1:56 PM	BB66126	Lead	2	15	ppb
048-219A Boys Locker Room Showers (Left Side) #1	6/20/16 6:40 AM	6/29/16 1:59 PM	BB66127	Copper	0.0	1.3	ppm
048-219A Boys Locker Room Showers (Left Side) #1	6/20/16 6:40 AM	6/29/16 1:59 PM	BB66127	Lead	0	15	ppb
048-220A Boys Locker Room Showers (Left Side) #2	6/20/16 6:42 AM	6/29/16 2:02 PM	BB66128	Copper	0.0	1.3	ppm
048-220A Boys Locker Room Showers (Left Side) #2	6/20/16 6:42 AM	6/29/16 2:02 PM	BB66128	Lead	1	15	ppb
048-221A Boys Locker Room Showers (Left Side) #3	6/20/16 6:30 AM	6/23/16 1:36 PM	BB66129	Copper	0.0	1.3	ppm
048-221A Boys Locker Room Showers (Left Side) #3	6/20/16 6:30 AM	6/23/16 1:36 PM	BB66129	Lead	2	15	ppb
048-222A Boys Locker Room Showers (Left Side) #4	6/20/16 6:32 AM	6/23/16 1:39 PM	BB66130	Copper	0.0	1.3	ppm
048-222A Boys Locker Room Showers (Left Side) #4	6/20/16 6:32 AM	6/23/16 1:39 PM	BB66130	Lead	0	15	ppb
048-223A Boys Locker Room Showers (Left Side) #5	6/20/16 6:34 AM	6/23/16 1:42 PM	BB66131	Copper	0.0	1.3	ppm
048-223A Boys Locker Room Showers (Left Side) #5	6/20/16 6:34 AM	6/23/16 1:42 PM	BB66131	Lead	2	15	ppb
048-224A Boys Locker Room Showers (Left Side) #6	6/20/16 6:36 AM	6/23/16 1:45 PM	BB66132	Copper	0.0	1.3	ppm
048-224A Boys Locker Room Showers (Left Side) #6	6/20/16 6:36 AM	6/23/16 1:45 PM	BB66132	Lead	0	15	ppb
048-225A Boys Locker Room Showers (Left Side) #7	6/20/16 6:38 AM	6/23/16 1:48 PM	BB66133	Copper	0.0	1.3	ppm
048-225A Boys Locker Room Showers (Left Side) #7	6/20/16 6:38 AM	6/23/16 1:48 PM	BB66133	Lead	0	15	ppb
048-226A Boys Locker Room Showers (Left Side) #8	6/20/16 6:40 AM	6/23/16 1:51 PM	BB66134	Copper	0.0	1.3	ppm
048-226A Boys Locker Room Showers (Left Side) #8	6/20/16 6:40 AM	6/23/16 1:51 PM	BB66134	Lead	1	15	ppb
048-227A Boys Locker Room Showers (Left Side) #9	6/20/16 6:42 AM	6/23/16 1:54 PM	BB66135	Copper	0.0	1.3	ppm
048-227A Boys Locker Room Showers (Left Side) #9	6/20/16 6:42 AM	6/23/16 1:54 PM	BB66135	Lead	1	15	ppb
048-228A Boys Locker Room Showers (Left Side) #10	6/20/16 6:44 AM	6/23/16 1:57 PM	BB66136	Copper	0.0	1.3	ppm
048-228A Boys Locker Room Showers (Left Side) #10	6/20/16 6:44 AM	6/23/16 1:57 PM	BB66136	Lead	1	15	ppb
048-229A Boys Locker Room Showers (Left Side) #11	6/20/16 6:46 AM	6/23/16 2:00 PM	BB66137	Copper	0.0	1.3	ppm
048-229A Boys Locker Room Showers (Left Side) #11	6/20/16 6:46 AM	6/23/16 2:00 PM	BB66137	Lead	1	15	ppb
048-230A Boys Locker Room Showers (Left Side) #12	6/20/16 6:48 AM	6/23/16 2:03 PM	BB66138	Copper	0.0	1.3	ppm
048-230A Boys Locker Room Showers (Left Side) #12	6/20/16 6:48 AM	6/23/16 2:03 PM	BB66138	Lead	1	15	ppb
048-231A Boys Locker Room Showers (Towel Room Side) #1	6/20/16 6:51 AM	6/23/16 2:18 PM	BB66139	Copper	0.0	1.3	ppm
048-231A Boys Locker Room Showers (Towel Room Side) #1	6/20/16 6:51 AM	6/23/16 2:18 PM	BB66139	Lead	1	15	ppb
048-232A Boys Locker Room Showers (Towel Room Side) #2	6/20/16 6:44 AM	6/23/16 2:21 PM	BB66140	Copper	0.1	1.3	ppm
048-232A Boys Locker Room Showers (Towel Room Side) #2	6/20/16 6:44 AM	6/23/16 2:21 PM	BB66140	Lead	41	15	ppb
048-233A Boys Locker Room Showers (Towel Room Side) #3	6/20/16 6:47 AM	6/23/16 2:24 PM	BB66141	Copper	0.2	1.3	ppm
048-233A Boys Locker Room Showers (Towel Room Side) #3	6/20/16 6:47 AM	6/23/16 2:24 PM	BB66141	Lead	16	15	ppb
048-234A Boys Locker Room Showers (Towel Room Side) #4	6/20/16 6:49 AM	6/23/16 2:27 PM	BB66142	Copper	0.2	1.3	ppm
048-234A Boys Locker Room Showers (Towel Room Side) #4	6/20/16 6:49 AM	6/23/16 2:27 PM	BB66142	Lead	28	15	ppb
048-235A Boys Locker Room Showers (Towel Room Side) #5	6/20/16 6:51 AM	6/23/16 2:30 PM	BB66143	Copper	0.2	1.3	ppm
048-235A Boys Locker Room Showers (Towel Room Side) #5	6/20/16 6:51 AM	6/23/16 2:30 PM	BB66143	Lead	25	15	ppb
048-236A Boys Locker Room Showers (Towel Room Side) #6	6/20/16 6:53 AM	6/23/16 2:33 PM	BB66144	Copper	0.1	1.3	ppm
048-236A Boys Locker Room Showers (Towel Room Side) #6	6/20/16 6:53 AM	6/23/16 2:33 PM	BB66144	Lead	8	15	ppb
048-237A Boys Locker Room Showers (Towel Room Side) #7	6/20/16 6:55 AM	6/23/16 2:36 PM	BB66145	Copper	0.1	1.3	ppm
048-237A Boys Locker Room Showers (Towel Room Side) #7	6/20/16 6:55 AM	6/23/16 2:36 PM	BB66145	Lead	8	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Jackson Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
048-238A Boys Locker Room Showers (Towel Room Side) #8	6/20/16 6:57 AM	6/23/16 2:39 PM	BB66146	Copper	0.2	1.3	ppm
048-238A Boys Locker Room Showers (Towel Room Side) #8	6/20/16 6:57 AM	6/23/16 2:39 PM	BB66146	Lead	32	15	ppb
048-239A Boys Locker Room Showers (Towel Room Side) #9	6/20/16 7:00 AM	6/23/16 2:42 PM	BB66147	Copper	0.5	1.3	ppm
048-239A Boys Locker Room Showers (Towel Room Side) #9	6/20/16 7:00 AM	6/23/16 2:42 PM	BB66147	Lead	18	15	ppb
048-240A Boys Locker Room Showers (Towel Room Side) #10	6/20/16 7:01 AM	6/23/16 2:45 PM	BB66148	Copper	0.3	1.3	ppm
048-240A Boys Locker Room Showers (Towel Room Side) #10	6/20/16 7:01 AM	6/23/16 2:45 PM	BB66148	Lead	26	15	ppb
048-241A Boys Locker Room Bathroom Sink Faucet (left)	6/20/16 7:06 AM	6/23/16 3:10 PM	BB66149	Copper	0.0	1.3	ppm
048-241A Boys Locker Room Bathroom Sink Faucet (left)	6/20/16 7:06 AM	6/23/16 3:10 PM	BB66149	Lead	3	15	ppb
048-242A Boys Locker Room Bathroom Sink Faucet (right)	6/20/16 7:08 AM	6/24/16 2:33 PM	BB66150	Copper	0.0	1.3	ppm
048-242A Boys Locker Room Bathroom Sink Faucet (right)	6/20/16 7:08 AM	6/24/16 2:33 PM	BB66150	Lead	3	15	ppb
048-244A Boys Locker Room Drinking Fountain near Team Room A	6/20/16 7:13 AM	6/23/16 3:16 PM	BB66151	Copper	0.0	1.3	ppm
048-244A Boys Locker Room Drinking Fountain near Team Room A	6/20/16 7:13 AM	6/23/16 3:16 PM	BB66151	Lead	2	15	ppb
048-245A Boys Locker Room Custodial Sink Faucet	6/20/16 7:15 AM	6/23/16 3:19 PM	BB66152	Copper	0.0	1.3	ppm
048-245A Boys Locker Room Custodial Sink Faucet	6/20/16 7:15 AM	6/23/16 3:19 PM	BB66152	Lead	3	15	ppb
048-246A Boys Locker Room Officials Sink Faucet	6/20/16 7:17 AM	6/23/16 3:22 PM	BB66153	Copper	0.0	1.3	ppm
048-246A Boys Locker Room Officials Sink Faucet	6/20/16 7:17 AM	6/23/16 3:22 PM	BB66153	Lead	38	15	ppb
048-247A Boys Locker Room Officials Shower	6/20/16 7:19 AM	6/23/16 3:25 PM	BB66154	Copper	0.0	1.3	ppm
048-247A Boys Locker Room Officials Shower	6/20/16 7:19 AM	6/23/16 3:25 PM	BB66154	Lead	25	15	ppb
048-248A Boys Locker Room Office Sink Faucet	6/20/16 7:21 AM	6/23/16 3:28 PM	BB66155	Copper	0.0	1.3	ppm
048-248A Boys Locker Room Office Sink Faucet	6/20/16 7:21 AM	6/23/16 3:28 PM	BB66155	Lead	24	15	ppb
048-249A Boys Coaches Locker Room Sink Faucet	6/20/16 7:23 AM	6/23/16 3:31 PM	BB66156	Copper	0.0	1.3	ppm
048-249A Boys Coaches Locker Room Sink Faucet	6/20/16 7:23 AM	6/23/16 3:31 PM	BB66156	Lead	8	15	ppb
048-250A Boys Coaches Locker Room Shower	6/20/16 7:25 AM	6/23/16 3:34 PM	BB66157	Copper	0.1	1.3	ppm
048-250A Boys Coaches Locker Room Shower	6/20/16 7:25 AM	6/23/16 3:34 PM	BB66157	Lead	3	15	ppb
048-251A Drinking Fountain outside A108 (left)	6/20/16 7:29 AM	6/23/16 3:37 PM	BB66158	Copper	0.0	1.3	ppm
048-251A Drinking Fountain outside A108 (left)	6/20/16 7:29 AM	6/23/16 3:37 PM	BB66158	Lead	32	15	ppb
048-252A Drinking Fountain outside A108 (right)	6/20/16 7:31 AM	6/23/16 3:52 PM	BB66159	Copper	0.0	1.3	ppm
048-252A Drinking Fountain outside A108 (right)	6/20/16 7:31 AM	6/23/16 3:52 PM	BB66159	Lead	23	15	ppb
048-253A Gym Drinking Fountain South	6/20/16 7:35 AM	6/23/16 3:55 PM	BB66160	Copper	0.0	1.3	ppm
048-253A Gym Drinking Fountain South	6/20/16 7:35 AM	6/23/16 3:55 PM	BB66160	Lead	2	15	ppb
048-254A Gym Drinking Fountain Middle	6/20/16 7:37 AM	6/23/16 3:58 PM	BB66161	Copper	0.0	1.3	ppm
048-254A Gym Drinking Fountain Middle	6/20/16 7:37 AM	6/23/16 3:58 PM	BB66161	Lead	3	15	ppb
048-255A Gym Drinking Fountain North	6/20/16 7:39 AM	6/23/16 4:01 PM	BB66162	Copper	0.0	1.3	ppm
048-255A Gym Drinking Fountain North	6/20/16 7:39 AM	6/23/16 4:01 PM	BB66162	Lead	1	15	ppb
048-256A B121 Custodial Sink Faucet	6/20/16 7:44 AM	7/5/16 12:26 PM	BB66163	Copper	0.1	1.3	ppm
048-256A B121 Custodial Sink Faucet	6/20/16 7:44 AM	7/5/16 12:26 PM	BB66163	Lead	7	15	ppb
048-257A Girls Restroom Outside Gym Sink Faucet (left)	6/20/16 7:47 AM	6/23/16 4:04 PM	BB66164	Copper	0.0	1.3	ppm
048-257A Girls Restroom Outside Gym Sink Faucet (left)	6/20/16 7:47 AM	6/23/16 4:04 PM	BB66164	Lead	86	15	ppb
048-258A Girls Restroom Outside Gym Sink Faucet (left middle)	6/20/16 7:49 AM	6/23/16 4:07 PM	BB66165	Copper	0.0	1.3	ppm
048-258A Girls Restroom Outside Gym Sink Faucet (left middle)	6/20/16 7:49 AM	6/23/16 4:07 PM	BB66165	Lead	23	15	ppb
048-259A Girls Restroom Outside Gym Sink Faucet (right middle)	6/20/16 7:51 AM	6/23/16 4:10 PM	BB66166	Copper	0.0	1.3	ppm
048-259A Girls Restroom Outside Gym Sink Faucet (right middle)	6/20/16 7:51 AM	6/23/16 4:10 PM	BB66166	Lead	8	15	ppb
048-260A Girls Restroom Outside Gym Sink Faucet (right)	6/20/16 7:53 AM	6/23/16 4:13 PM	BB66167	Copper	0.1	1.3	ppm
048-260A Girls Restroom Outside Gym Sink Faucet (right)	6/20/16 7:53 AM	6/23/16 4:13 PM	BB66167	Lead	11	15	ppb
048-261A Girls Restroom Outside Gym Water Spigot	6/20/16 7:55 AM	7/5/16 7:30 PM	BB66168	Copper	2.2	1.3	ppm
048-261A Girls Restroom Outside Gym Water Spigot	6/20/16 7:55 AM	7/5/16 12:29 PM	BB66168	Lead	334	15	ppb
048-262A Drinking Fountain Outside Gym/Girls Restroom	6/20/16 7:58 AM	6/23/16 4:16 PM	BB66169	Copper	0.0	1.3	ppm
048-262A Drinking Fountain Outside Gym/Girls Restroom	6/20/16 7:58 AM	6/23/16 4:16 PM	BB66169	Lead	0	15	ppb
048-263A Boys Restroom Outside Gym Sink Faucet (left)	6/20/16 8:05 AM	6/23/16 4:19 PM	BB66170	Copper	0.1	1.3	ppm
048-263A Boys Restroom Outside Gym Sink Faucet (left)	6/20/16 8:05 AM	6/23/16 4:19 PM	BB66170	Lead	15.3	15	ppb
048-264A Boys Restroom Outside Gym Sink Faucet (left middle)	6/20/16 8:07 AM	6/23/16 4:41 PM	BB66171	Copper	0.0	1.3	ppm
048-264A Boys Restroom Outside Gym Sink Faucet (left middle)	6/20/16 8:07 AM	6/23/16 4:41 PM	BB66171	Lead	7	15	ppb
048-265A Boys Restroom Outside Gym Sink Faucet (right middle)	6/20/16 7:00 AM	6/23/16 4:44 PM	BB66172	Copper	0.0	1.3	ppm
048-265A Boys Restroom Outside Gym Sink Faucet (right middle)	6/20/16 7:00 AM	6/23/16 4:44 PM	BB66172	Lead	5	15	ppb
048-266A Boys Restroom Outside Gym Sink Faucet (right)	6/20/16 7:02 AM	7/5/16 12:32 PM	BB66173	Copper	0.2	1.3	ppm
048-266A Boys Restroom Outside Gym Sink Faucet (right)	6/20/16 7:02 AM	7/5/16 12:32 PM	BB66173	Lead	17	15	ppb
048-267A Boys Restroom Outside Gym Water Spigot	6/20/16 7:04 AM	7/5/16 1:07 PM	BB66174	Copper	0.2	1.3	ppm
048-267A Boys Restroom Outside Gym Water Spigot	6/20/16 7:04 AM	7/5/16 1:07 PM	BB66174	Lead	6	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Jackson Middle School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
048-268A Cafeteria Roll Up Door Area Sink Faucet	6/20/16 7:07 AM	6/23/16 4:47 PM	BB66175	Copper	0.4	1.3	ppm
048-268A Cafeteria Roll Up Door Area Sink Faucet	6/20/16 7:07 AM	6/23/16 4:47 PM	BB66175	Lead	17	15	ppb
048-269A Cafeteria Exterior Drinking Fountain (left)	6/20/16 7:09 AM	6/23/16 4:50 PM	BB66176	Copper	0.0	1.3	ppm
048-269A Cafeteria Exterior Drinking Fountain (left)	6/20/16 7:09 AM	6/23/16 4:50 PM	BB66176	Lead	1	15	ppb
048-270A Cafeteria Exterior Drinking Fountain (right)	6/20/16 7:11 AM	6/23/16 4:53 PM	BB66177	Copper	0.0	1.3	ppm
048-270A Cafeteria Exterior Drinking Fountain (right)	6/20/16 7:11 AM	6/23/16 4:53 PM	BB66177	Lead	1	15	ppb
048-271A Faculty Dining Serving Area Sink Faucet	6/20/16 7:16 AM	6/23/16 4:56 PM	BB66178	Copper	0.1	1.3	ppm
048-271A Faculty Dining Serving Area Sink Faucet	6/20/16 7:16 AM	6/23/16 4:56 PM	BB66178	Lead	19	15	ppb
048-272A Outside Water Spigot outside front door	6/20/16 7:20 AM	6/23/16 4:59 PM	BB66179	Copper	0.4	1.3	ppm
048-272A Outside Water Spigot outside front door	6/20/16 7:20 AM	6/23/16 4:59 PM	BB66179	Lead	2	15	ppb
048-273A Outside Water Spigot near front handicap space	6/20/16 7:24 AM	6/23/16 5:02 PM	BB66180	Copper	0.0	1.3	ppm
048-273A Outside Water Spigot near front handicap space	6/20/16 7:24 AM	6/23/16 5:02 PM	BB66180	Lead	3	15	ppb
048-274A Outside Water Spigot outside resource center	6/20/16 7:30 AM	6/23/16 5:05 PM	BB66181	Copper	0.4	1.3	ppm
048-274A Outside Water Spigot outside resource center	6/20/16 7:30 AM	6/23/16 5:05 PM	BB66181	Lead	7	15	ppb
048-275A Outside hose for greenhouse	6/20/16 7:37 AM	6/23/16 5:08 PM	BB66182	Copper	0.0	1.3	ppm
048-275A Outside hose for greenhouse	6/20/16 7:37 AM	6/23/16 5:08 PM	BB66182	Lead	3	15	ppb
048-276A Outside Water Spigot shop rear	6/20/16 7:40 AM	6/24/16 7:28 PM	BB66183	Copper	0.1	1.3	ppm
048-276A Outside Water Spigot shop rear	6/20/16 7:40 AM	6/24/16 7:28 PM	BB66183	Lead	3	15	ppb
048-277A Outside Water Spigot shop front	6/20/16 7:46 AM	6/24/16 7:31 PM	BB66184	Copper	0.1	1.3	ppm
048-277A Outside Water Spigot shop front	6/20/16 7:46 AM	6/24/16 7:31 PM	BB66184	Lead	5	15	ppb
048-278A Outside Water Spigot baseball field (behind)	6/20/16 7:53 AM	7/5/16 1:11 PM	BB66185	Copper	0.8	1.3	ppm
048-278A Outside Water Spigot baseball field (behind)	6/20/16 7:53 AM	7/5/16 1:11 PM	BB66185	Lead	5	15	ppb
048-279A Outside Water Spigot near North side cafeteria	6/20/16 8:03 AM	6/24/16 7:35 PM	BB66186	Copper	0.0	1.3	ppm
048-279A Outside Water Spigot near North side cafeteria	6/20/16 8:03 AM	6/24/16 7:35 PM	BB66186	Lead	3	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.