

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample data
James John Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
049-01A Boiler Room Sink Faucet (1)	6/27/2016 18:28	7/8/2016 01:11	10354087001	Copper	0.1	1.3	ppm
049-01A Boiler Room Sink Faucet (1)	6/27/2016 18:28	7/8/2016 01:11	10354087001	Lead	10	15	ppb
049-02A Boiler Room Sink Faucet (2)	6/27/2016 18:28	7/8/2016 01:16	10354087003	Copper	0.0	1.3	ppm
049-02A Boiler Room Sink Faucet (2)	6/27/2016 18:28	7/8/2016 01:16	10354087003	Lead	11	15	ppb
049-03A Boiler Room Water Spigot (3)	6/27/2016 18:30	7/7/2016 16:38	10354087005	Copper	0.4	1.3	ppm
049-03A Boiler Room Water Spigot (3)	6/27/2016 18:30	7/7/2016 16:38	10354087005	Lead	159	15	ppb
049-04A Boiler Room Water Spigot (4)	6/27/2016 18:30	7/7/2016 16:40	10354087007	Copper	0.0	1.3	ppm
049-04A Boiler Room Water Spigot (4)	6/27/2016 18:30	7/7/2016 16:40	10354087007	Lead	14.8	15	ppb
049-05A Boiler Room Water Spigot (5)	6/27/2016 18:32	7/7/2016 18:15	10354087009	Copper	0.0	1.3	ppm
049-05A Boiler Room Water Spigot (5)	6/27/2016 18:32	7/7/2016 18:15	10354087009	Lead	16	15	ppb
049-06A Boiler Room Water Spigot (6)	6/27/2016 18:32	7/7/2016 18:16	10354087011	Copper	0.0	1.3	ppm
049-06A Boiler Room Water Spigot (6)	6/27/2016 18:32	7/7/2016 18:16	10354087011	Lead	5	15	ppb
049-07A Boiler Room Water Spigot (7)	6/27/2016 18:34	7/7/2016 18:17	10354087013	Copper	0.0	1.3	ppm
049-07A Boiler Room Water Spigot (7)	6/27/2016 18:34	7/7/2016 18:17	10354087013	Lead	23	15	ppb
049-08A Boiler Room Water Spigot (8)	6/27/2016 18:36	7/7/2016 18:18	10354087015	Copper	0.1	1.3	ppm
049-08A Boiler Room Water Spigot (8)	6/27/2016 18:36	7/7/2016 18:18	10354087015	Lead	12	15	ppb
049-09A Boiler Room Fan Room Water Spigot	6/27/2016 18:41	7/8/2016 07:28	10354087017	Copper	6.9	1.3	ppm
049-09A Boiler Room Fan Room Water Spigot	6/27/2016 18:41	7/8/2016 07:28	10354087017	Lead	2610	15	ppb
049-10A Cafeteria - Drinking Fountain (1)	6/27/2016 18:47	7/7/2016 18:20	10354087019	Copper	0.0	1.3	ppm
049-10A Cafeteria - Drinking Fountain (1)	6/27/2016 18:47	7/7/2016 18:20	10354087019	Lead	1	15	ppb
049-11A Cafeteria - Drinking Fountain (2)	6/27/2016 18:48	7/7/2016 18:21	10354087021	Copper	0.0	1.3	ppm
049-11A Cafeteria - Drinking Fountain (2)	6/27/2016 18:48	7/7/2016 18:21	10354087021	Lead	2	15	ppb
049-12A Kitchen Dish Sink Faucet	6/27/2016 18:53	7/7/2016 18:22	10354087023	Copper	0.1	1.3	ppm
049-12A Kitchen Dish Sink Faucet	6/27/2016 18:53	7/7/2016 18:22	10354087023	Lead	6	15	ppb
049-13A Kitchen Hand Sink Faucet	6/27/2016 18:55	7/7/2016 18:23	10354087025	Copper	0.2	1.3	ppm
049-13A Kitchen Hand Sink Faucet	6/27/2016 18:55	7/7/2016 18:23	10354087025	Lead	4	15	ppb
049-14A Kitchen Custodial Closet Sink Faucet	6/27/2016 18:56	7/7/2016 16:48	10354087027	Copper	0.1	1.3	ppm
049-14A Kitchen Custodial Closet Sink Faucet	6/27/2016 18:56	7/7/2016 16:48	10354087027	Lead	9	15	ppb
049-15A Kitchen Bathroom Sink Faucet	6/27/2016 18:57	7/7/2016 18:24	10354087029	Copper	0.2	1.3	ppm
049-15A Kitchen Bathroom Sink Faucet	6/27/2016 18:57	7/7/2016 18:24	10354087029	Lead	37	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample data
James John Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
049-16A Kitchen Food Preparation Sink Faucet (1)	6/27/2016 19:00	7/7/2016 18:30	10354087031	Copper	0.1	1.3	ppm
049-16A Kitchen Food Preparation Sink Faucet (1)	6/27/2016 19:00	7/7/2016 18:30	10354087031	Lead	6	15	ppb
049-17A Kitchen Food Preparation Sink Faucet (2)	6/27/2016 19:00	7/7/2016 18:31	10354087033	Copper	0.3	1.3	ppm
049-17A Kitchen Food Preparation Sink Faucet (2)	6/27/2016 19:00	7/7/2016 18:31	10354087033	Lead	22	15	ppb
049-18A Girls Bathroom Sink Faucet (1)	6/27/2016 19:13	7/7/2016 18:32	10354087035	Copper	0.2	1.3	ppm
049-18A Girls Bathroom Sink Faucet (1)	6/27/2016 19:13	7/7/2016 18:32	10354087035	Lead	46	15	ppb
049-19A Girls Bathroom Sink Faucet (2)	6/27/2016 19:13	7/7/2016 18:33	10354087037	Copper	0.1	1.3	ppm
049-19A Girls Bathroom Sink Faucet (2)	6/27/2016 19:13	7/7/2016 18:33	10354087037	Lead	12	15	ppb
049-20A Girls Bathroom Water Spigot	6/27/2016 19:15	7/7/2016 18:35	10354087039	Copper	0.0	1.3	ppm
049-20A Girls Bathroom Water Spigot	6/27/2016 19:15	7/7/2016 18:35	10354087039	Lead	57	15	ppb
049-21A Hall by Room 20 - Drinking Fountain	6/27/2016 19:17	7/7/2016 19:21	10354087041	Copper	0.0	1.3	ppm
049-21A Hall by Room 20 - Drinking Fountain	6/27/2016 19:17	7/7/2016 19:21	10354087041	Lead	6	15	ppb
049-22A Boys Bathroom Sink Faucet (1)	6/27/2016 19:20	7/7/2016 19:29	10354087043	Copper	0.1	1.3	ppm
049-22A Boys Bathroom Sink Faucet (1)	6/27/2016 19:20	7/7/2016 19:29	10354087043	Lead	7	15	ppb
049-23A Boys Bathroom Sink Faucet (2)	6/27/2016 19:22	7/7/2016 19:30	10354087045	Copper	0.0	1.3	ppm
049-23A Boys Bathroom Sink Faucet (2)	6/27/2016 19:22	7/7/2016 19:30	10354087045	Lead	5	15	ppb
049-24A Boys Bathroom Water Spigot	6/27/2016 19:23	7/7/2016 19:31	10354087047	Copper	0.0	1.3	ppm
049-24A Boys Bathroom Water Spigot	6/27/2016 19:23	7/7/2016 19:31	10354087047	Lead	29	15	ppb
049-25A Room 20 - Sink Faucet	6/27/2016 19:27	7/7/2016 19:32	10354087049	Copper	0.3	1.3	ppm
049-25A Room 20 - Sink Faucet	6/27/2016 19:27	7/7/2016 19:32	10354087049	Lead	8	15	ppb
049-26A Room 20 - Drinking Fountain	6/27/2016 19:27	7/7/2016 19:33	10354087051	Copper	0.0	1.3	ppm
049-26A Room 20 - Drinking Fountain	6/27/2016 19:27	7/7/2016 19:33	10354087051	Lead	4	15	ppb
049-27A Room 21 - Sink Faucet	6/27/2016 19:31	7/7/2016 22:25	10354087053	Copper	0.6	1.3	ppm
049-27A Room 21 - Sink Faucet	6/27/2016 19:31	7/7/2016 19:35	10354087053	Lead	9	15	ppb
049-28A Room 21 - Drinking Fountain	6/27/2016 19:31	7/7/2016 19:36	10354087055	Copper	0.0	1.3	ppm
049-28A Room 21 - Drinking Fountain	6/27/2016 19:31	7/7/2016 19:36	10354087055	Lead	2	15	ppb
049-29A Room 22 - Sink Faucet	6/27/2016 19:39	7/7/2016 19:37	10354087057	Copper	0.0	1.3	ppm
049-29A Room 22 - Sink Faucet	6/27/2016 19:39	7/7/2016 19:37	10354087057	Lead	15.3	15	ppb
049-30A Hall by Room 21 - Drinking Fountain (1)	6/27/2016 19:41	7/7/2016 19:38	10354087059	Copper	0.0	1.3	ppm
049-30A Hall by Room 21 - Drinking Fountain (1)	6/27/2016 19:41	7/7/2016 19:38	10354087059	Lead	5	15	ppb

Analysis by: Grant's Pass

Reviewed by: TRC Environmental Corp

2 of 8

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample data
James John Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
049-31A Hall by Room 21 - Drinking Fountain (2)	6/27/2016 19:41	7/7/2016 19:39	10354087061	Copper	0.0	1.3	ppm
049-31A Hall by Room 21 - Drinking Fountain (2)	6/27/2016 19:41	7/7/2016 19:39	10354087061	Lead	6	15	ppb
049-32A Staff BA Bathroom - Sink Faucet	6/27/2016 19:44	7/7/2016 22:27	10354087063	Copper	0.8	1.3	ppm
049-32A Staff BA Bathroom - Sink Faucet	6/27/2016 19:44	7/7/2016 19:44	10354087063	Lead	28	15	ppb
049-33A Custodial Closet Sink Faucet	6/27/2016 19:46	7/7/2016 19:45	10354087065	Copper	0.0	1.3	ppm
049-33A Custodial Closet Sink Faucet	6/27/2016 19:46	7/7/2016 19:45	10354087065	Lead	8	15	ppb
049-34A Office Bathroom - Sink Faucet	6/27/2016 19:51	7/7/2016 19:46	10354087067	Copper	0.2	1.3	ppm
049-34A Office Bathroom - Sink Faucet	6/27/2016 19:51	7/7/2016 19:46	10354087067	Lead	27	15	ppb
049-35A Office - (Nurse) Sink Faucet	6/27/2016 19:52	7/7/2016 22:28	10354087069	Copper	0.5	1.3	ppm
049-35A Office - (Nurse) Sink Faucet	6/27/2016 19:52	7/7/2016 19:48	10354087069	Lead	6	15	ppb
049-36A Room 28 - Sink Faucet	6/27/2016 19:56	7/7/2016 19:49	10354087071	Copper	0.3	1.3	ppm
049-36A Room 28 - Sink Faucet	6/27/2016 19:56	7/7/2016 19:49	10354087071	Lead	16	15	ppb
049-37A Room 28 - Drinking Fountain	6/27/2016 19:56	7/7/2016 19:50	10354087073	Copper	0.0	1.3	ppm
049-37A Room 28 - Drinking Fountain	6/27/2016 19:56	7/7/2016 19:50	10354087073	Lead	59	15	ppb
049-38A Room 29 - Sink Faucet	6/27/2016 19:59	7/7/2016 22:29	10354087075	Copper	1.2	1.3	ppm
049-38A Room 29 - Sink Faucet	6/27/2016 19:59	7/7/2016 19:51	10354087075	Lead	17	15	ppb
049-39A Room 29 - Drinking Fountain	6/27/2016 19:59	7/7/2016 22:33	10354087077	Copper	1.2	1.3	ppm
049-39A Room 29 - Drinking Fountain	6/27/2016 19:59	7/7/2016 19:53	10354087077	Lead	12	15	ppb
049-40A Hall - Drinking Fountain #1	6/27/2016 20:01	7/7/2016 19:54	10354087079	Copper	0.0	1.3	ppm
049-40A Hall - Drinking Fountain #1	6/27/2016 20:01	7/7/2016 19:54	10354087079	Lead	8	15	ppb
049-41A Hall - Drinking Fountain #2	6/27/2016 20:01	7/7/2016 04:31	10354087081	Copper	0.0	1.3	ppm
049-41A Hall - Drinking Fountain #2	6/27/2016 20:01	7/7/2016 04:31	10354087081	Lead	5	15	ppb
049-42A Boys Bathroom - Sink Faucet (1)	6/27/2016 20:05	7/7/2016 04:37	10354087083	Copper	0.0	1.3	ppm
049-42A Boys Bathroom - Sink Faucet (1)	6/27/2016 20:05	7/7/2016 04:37	10354087083	Lead	9	15	ppb
049-43A Boys Bathroom - Sink Faucet (2)	6/27/2016 20:05	7/7/2016 04:38	10354087085	Copper	0.1	1.3	ppm
049-43A Boys Bathroom - Sink Faucet (2)	6/27/2016 20:05	7/7/2016 04:38	10354087085	Lead	12	15	ppb
049-44A Girls Bathroom - Sink Faucet (1)	6/27/2016 20:08	7/7/2016 04:42	10354087087	Copper	0.1	1.3	ppm
049-44A Girls Bathroom - Sink Faucet (1)	6/27/2016 20:08	7/7/2016 04:42	10354087087	Lead	8	15	ppb
049-45A Girls Bathroom - Sink Faucet (2)	6/27/2016 20:08	7/7/2016 04:44	10354087089	Copper	0.2	1.3	ppm
049-45A Girls Bathroom - Sink Faucet (2)	6/27/2016 20:08	7/7/2016 04:44	10354087089	Lead	5	15	ppb

Analysis by: Grant's Pass

Reviewed by: TRC Environmental Corp

3 of 8

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample data
James John Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
049-46A Girls Bathroom - Water Spigot	6/27/2016 20:10	7/7/2016 16:50	10354087091	Copper	0.0	1.3	ppm
049-46A Girls Bathroom - Water Spigot	6/27/2016 20:10	7/7/2016 16:50	10354087091	Lead	69	15	ppb
049-47A Room 30 - Sink Faucet	6/27/2016 20:15	7/7/2016 20:25	10354087093	Copper	0.5	1.3	ppm
049-47A Room 30 - Sink Faucet	6/27/2016 20:15	7/7/2016 04:45	10354087093	Lead	5	15	ppb
049-48A Room 30 - Drinking Fountain	6/27/2016 20:15	7/7/2016 04:46	10354087095	Copper	0.5	1.3	ppm
049-48A Room 30 - Drinking Fountain	6/27/2016 20:15	7/7/2016 04:46	10354087095	Lead	9	15	ppb
049-49A Room 31 - Sink Faucet	6/27/2016 20:17	7/7/2016 04:48	10354087097	Copper	0.0	1.3	ppm
049-49A Room 31 - Sink Faucet	6/27/2016 20:17	7/7/2016 04:48	10354087097	Lead	6	15	ppb
049-50A Library - Sink Faucet	6/27/2016 20:21	7/7/2016 04:49	10354087099	Copper	0.4	1.3	ppm
049-50A Library - Sink Faucet	6/27/2016 20:21	7/7/2016 04:49	10354087099	Lead	14.6	15	ppb
049-51A Gymnasium - Drinking Fountain	6/27/2016 20:25	7/7/2016 04:50	10354087101	Copper	0.0	1.3	ppm
049-51A Gymnasium - Drinking Fountain	6/27/2016 20:25	7/7/2016 04:50	10354087101	Lead	14	15	ppb
049-52A Gymnasium - Small room Sink Faucet	6/27/2016 20:28	7/7/2016 16:51	10354087103	Copper	0.1	1.3	ppm
049-52A Gymnasium - Small room Sink Faucet	6/27/2016 20:28	7/7/2016 16:51	10354087103	Lead	29	15	ppb
049-53A Hall by Gymnasium - Drinking Fountain	6/27/2016 20:31	7/7/2016 04:53	10354087105	Copper	0.0	1.3	ppm
049-53A Hall by Gymnasium - Drinking Fountain	6/27/2016 20:31	7/7/2016 04:53	10354087105	Lead	14	15	ppb
049-54A Storeroom by Gymnasium - Sink Faucet	6/27/2016 20:35	7/7/2016 04:55	10354087107	Copper	0.0	1.3	ppm
049-54A Storeroom by Gymnasium - Sink Faucet	6/27/2016 20:35	7/7/2016 04:55	10354087107	Lead	22	15	ppb
049-55A Custodial Closet - Sink Faucet	6/27/2016 20:37	7/7/2016 04:59	10354087109	Copper	0.0	1.3	ppm
049-55A Custodial Closet - Sink Faucet	6/27/2016 20:37	7/7/2016 04:59	10354087109	Lead	17	15	ppb
049-56A Room 34 - Sink Faucet	6/27/2016 20:58	7/7/2016 05:00	10354087111	Copper	0.1	1.3	ppm
049-56A Room 34 - Sink Faucet	6/27/2016 20:58	7/7/2016 05:00	10354087111	Lead	22	15	ppb
049-57A Room 19 - Drinking Fountain	6/27/2016 21:01	7/7/2016 05:02	10354087113	Copper	0.0	1.3	ppm
049-57A Room 19 - Drinking Fountain	6/27/2016 21:01	7/7/2016 05:02	10354087113	Lead	2	15	ppb
049-58A Room 19 Bathroom - Sink Faucet	6/27/2016 21:03	7/7/2016 05:03	10354087115	Copper	0.0	1.3	ppm
049-58A Room 19 Bathroom - Sink Faucet	6/27/2016 21:03	7/7/2016 05:03	10354087115	Lead	39	15	ppb
049-59A Boys Bathroom by Room 13 - Sink Faucet (1)	6/27/2016 21:09	7/7/2016 05:04	10354087117	Copper	0.0	1.3	ppm
049-59A Boys Bathroom by Room 13 - Sink Faucet (1)	6/27/2016 21:09	7/7/2016 05:04	10354087117	Lead	10	15	ppb
049-60A Boys Bathroom by Room 13 - Sink Faucet (2)	6/27/2016 21:09	7/7/2016 05:06	10354087119	Copper	0.0	1.3	ppm
049-60A Boys Bathroom by Room 13 - Sink Faucet (2)	6/27/2016 21:09	7/7/2016 05:06	10354087119	Lead	7	15	ppb

Analysis by: Grant's Pass

Reviewed by: TRC Environmental Corp

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample data
James John Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
049-61A Boys Bathroom by Room 13 - Water Spigot	6/27/2016 21:11	7/7/2016 09:28	10354087121	Copper	0.0	1.3	ppm
049-61A Boys Bathroom by Room 13 - Water Spigot	6/27/2016 21:11	7/7/2016 09:28	10354087121	Lead	15.4	15	ppb
049-62A Girls Bathroom - Sink Faucet (1)	6/27/2016 21:15	7/7/2016 02:00	10354087123	Copper	0.2	1.3	ppm
049-62A Girls Bathroom - Sink Faucet (1)	6/27/2016 21:15	7/7/2016 02:00	10354087123	Lead	14	15	ppb
049-63A Girls Bathroom - Sink Faucet (2)	6/27/2016 21:15	7/7/2016 02:01	10354087125	Copper	0.0	1.3	ppm
049-63A Girls Bathroom - Sink Faucet (2)	6/27/2016 21:15	7/7/2016 02:01	10354087125	Lead	21	15	ppb
049-64A Girls Bathroom - Water Spigot	6/27/2016 21:17	7/7/2016 02:03	10354087127	Copper	0.1	1.3	ppm
049-64A Girls Bathroom - Water Spigot	6/27/2016 21:17	7/7/2016 02:03	10354087127	Lead	165	15	ppb
049-65A Teachers Room - Sink Faucet	6/27/2016 21:21	7/7/2016 02:04	10354087129	Copper	0.0	1.3	ppm
049-65A Teachers Room - Sink Faucet	6/27/2016 21:21	7/7/2016 02:04	10354087129	Lead	4	15	ppb
049-66A Teachers Room Bathroom - Sink Faucet	6/27/2016 21:22	7/7/2016 02:05	10354087131	Copper	0.1	1.3	ppm
049-66A Teachers Room Bathroom - Sink Faucet	6/27/2016 21:22	7/7/2016 02:05	10354087131	Lead	16	15	ppb
049-67A Custodial Closet by Room 8 - Sink Faucet	6/27/2016 21:24	7/7/2016 02:07	10354087133	Copper	0.0	1.3	ppm
049-67A Custodial Closet by Room 8 - Sink Faucet	6/27/2016 21:24	7/7/2016 02:07	10354087133	Lead	4	15	ppb
049-68A Hall - Drinking Fountain by Room 8 (1)	6/27/2016 21:27	7/7/2016 02:08	10354087135	Copper	0.0	1.3	ppm
049-68A Hall - Drinking Fountain by Room 8 (1)	6/27/2016 21:27	7/7/2016 02:08	10354087135	Lead	3	15	ppb
049-69A Hall - Drinking Fountain by Room 8 (2)	6/27/2016 21:28	7/7/2016 02:10	10354087137	Copper	0.0	1.3	ppm
049-69A Hall - Drinking Fountain by Room 8 (2)	6/27/2016 21:28	7/7/2016 02:10	10354087137	Lead	7	15	ppb
049-70A Hall - Drinking Fountain by Room 15 (1)	6/27/2016 21:31	7/7/2016 02:11	10354087139	Copper	0.0	1.3	ppm
049-70A Hall - Drinking Fountain by Room 15 (1)	6/27/2016 21:31	7/7/2016 02:11	10354087139	Lead	14	15	ppb
049-71A Hall - Drinking Fountain by Room 15 (2)	6/27/2016 21:33	7/7/2016 02:15	10354087141	Copper	0.0	1.3	ppm
049-71A Hall - Drinking Fountain by Room 15 (2)	6/27/2016 21:33	7/7/2016 02:15	10354087141	Lead	4	15	ppb
049-72A Custodial by Room 7 - Sink Faucet	6/27/2016 21:35	7/7/2016 02:18	10354087143	Copper	0.1	1.3	ppm
049-72A Custodial by Room 7 - Sink Faucet	6/27/2016 21:35	7/7/2016 02:18	10354087143	Lead	4	15	ppb
049-73A Boys Bathroom - Sink Faucet (1)	6/27/2016 21:38	7/7/2016 02:19	10354087145	Copper	0.1	1.3	ppm
049-73A Boys Bathroom - Sink Faucet (1)	6/27/2016 21:38	7/7/2016 02:19	10354087145	Lead	14.5	15	ppb
049-74A Boys Bathroom - Sink Faucet (2)	6/27/2016 21:38	7/7/2016 02:21	10354087147	Copper	0.1	1.3	ppm
049-74A Boys Bathroom - Sink Faucet (2)	6/27/2016 21:38	7/7/2016 02:21	10354087147	Lead	13	15	ppb
049-75A Boys Bathroom - Water Spigot	6/27/2016 21:40	7/7/2016 02:22	10354087149	Copper	0.0	1.3	ppm
049-75A Boys Bathroom - Water Spigot	6/27/2016 21:40	7/7/2016 02:22	10354087149	Lead	21	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample data
James John Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
049-76A Hall - Drinking Fountain	6/27/2016 21:43	7/7/2016 02:23	10354087151	Copper	0.0	1.3	ppm
049-76A Hall - Drinking Fountain	6/27/2016 21:43	7/7/2016 02:23	10354087151	Lead	3	15	ppb
049-77A Girls Bathroom - Sink Faucet (1)	6/27/2016 21:46	7/7/2016 02:25	10354087153	Copper	0.1	1.3	ppm
049-77A Girls Bathroom - Sink Faucet (1)	6/27/2016 21:46	7/7/2016 02:25	10354087153	Lead	24	15	ppb
049-78A Girls Bathroom - Sink Faucet (2)	6/27/2016 21:46	7/7/2016 02:26	10354087155	Copper	0.1	1.3	ppm
049-78A Girls Bathroom - Sink Faucet (2)	6/27/2016 21:46	7/7/2016 02:26	10354087155	Lead	13	15	ppb
049-79A Girls Bathroom - Sink Faucet (1) - Portable	6/27/2016 22:04	7/7/2016 02:27	10354087157	Copper	0.1	1.3	ppm
049-79A Girls Bathroom - Sink Faucet (1) - Portable	6/27/2016 22:04	7/7/2016 02:27	10354087157	Lead	30	15	ppb
049-80A Girls Bathroom - Sink Faucet (2)	6/27/2016 22:04	7/7/2016 02:32	10354087159	Copper	0.1	1.3	ppm
049-80A Girls Bathroom - Sink Faucet (2)	6/27/2016 22:04	7/7/2016 02:32	10354087159	Lead	30	15	ppb
049-81A Hall (Nema) Drinking Fountain (1)	6/27/2016 22:06	7/7/2016 19:46	10354087161	Copper	0.0	1.3	ppm
049-81A Hall (Nema) Drinking Fountain (1)	6/27/2016 22:06	7/7/2016 19:46	10354087161	Lead	19	15	ppb
049-82A Hall - Drinking Fountain (2)	6/27/2016 22:08	7/7/2016 19:52	10354087163	Copper	0.0	1.3	ppm
049-82A Hall - Drinking Fountain (2)	6/27/2016 22:08	7/7/2016 19:52	10354087163	Lead	5	15	ppb
049-83A Room 39 - Sink Faucet	6/27/2016 22:11	7/8/2016 09:02	10354087165	Copper	0.8	1.3	ppm
049-83A Room 39 - Sink Faucet	6/27/2016 22:11	7/7/2016 19:53	10354087165	Lead	7	15	ppb
049-84A Room 39 - Drinking Fountain	6/27/2016 22:11	7/8/2016 09:04	10354087167	Copper	1.1	1.3	ppm
049-84A Room 39 - Drinking Fountain	6/27/2016 22:11	7/7/2016 19:55	10354087167	Lead	6	15	ppb
049-85A Room 38 - Sink Faucet	6/27/2016 22:14	7/7/2016 19:56	10354087169	Copper	0.2	1.3	ppm
049-85A Room 38 - Sink Faucet	6/27/2016 22:14	7/7/2016 19:56	10354087169	Lead	17	15	ppb
049-86A Room 40 - Sink Faucet	6/27/2016 22:16	7/7/2016 19:57	10354087171	Copper	0.3	1.3	ppm
049-86A Room 40 - Sink Faucet	6/27/2016 22:16	7/7/2016 19:57	10354087171	Lead	7	15	ppb
049-87A Room 40 - Drinking Fountain	6/27/2016 22:16	7/7/2016 19:59	10354087173	Copper	0.0	1.3	ppm
049-87A Room 40 - Drinking Fountain	6/27/2016 22:16	7/7/2016 19:59	10354087173	Lead	1	15	ppb
049-88A Room 37 - Sink Faucet	6/27/2016 22:18	7/8/2016 09:05	10354087175	Copper	0.7	1.3	ppm
049-88A Room 37 - Sink Faucet	6/27/2016 22:18	7/7/2016 20:03	10354087175	Lead	17	15	ppb
049-89A Room 37 - Drinking Fountain	6/27/2016 22:18	7/7/2016 20:04	10354087177	Copper	0.0	1.3	ppm
049-89A Room 37 - Drinking Fountain	6/27/2016 22:18	7/7/2016 20:04	10354087177	Lead	4	15	ppb
049-90A Hall by Boys Bathroom - Drinking Fountain (1)	6/27/2016 22:20	7/7/2016 20:06	10354087179	Copper	0.0	1.3	ppm
049-90A Hall by Boys Bathroom - Drinking Fountain (1)	6/27/2016 22:20	7/7/2016 20:06	10354087179	Lead	3	15	ppb

Analysis by: Grant's Pass

Reviewed by: TRC Environmental Corp

6 of 8

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample data
James John Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
049-91A Hall by Boys Bathroom - Drinking Fountain (2)	6/27/2016 22:22	7/7/2016 20:07	10354087181	Copper	0.0	1.3	ppm
049-91A Hall by Boys Bathroom - Drinking Fountain (2)	6/27/2016 22:22	7/7/2016 20:07	10354087181	Lead	5	15	ppb
049-92A Boys Bathroom - Sink Faucet (1)	6/27/2016 22:25	7/7/2016 20:10	10354087183	Copper	0.0	1.3	ppm
049-92A Boys Bathroom - Sink Faucet (1)	6/27/2016 22:25	7/7/2016 20:10	10354087183	Lead	6	15	ppb
049-93A Boys Bathroom - Sink Faucet (2)	6/27/2016 22:25	7/7/2016 20:11	10354087185	Copper	0.1	1.3	ppm
049-93A Boys Bathroom - Sink Faucet (2)	6/27/2016 22:25	7/7/2016 20:11	10354087185	Lead	11	15	ppb
049-94A Small Bathroom Sink Faucet	6/27/2016 22:28	7/7/2016 20:13	10354087187	Copper	0.0	1.3	ppm
049-94A Small Bathroom Sink Faucet	6/27/2016 22:28	7/7/2016 20:13	10354087187	Lead	6	15	ppb
049-95A Room 36 - Sink Faucet	6/27/2016 22:30	7/7/2016 20:14	10354087189	Copper	0.0	1.3	ppm
049-95A Room 36 - Sink Faucet	6/27/2016 22:30	7/7/2016 20:14	10354087189	Lead	5	15	ppb
049-96A Custodial Closet - Sink Faucet	6/27/2016 22:31	7/7/2016 20:15	10354087191	Copper	0.0	1.3	ppm
049-96A Custodial Closet - Sink Faucet	6/27/2016 22:31	7/7/2016 20:15	10354087191	Lead	15.2	15	ppb
049-97A Room 42 - Sink Faucet	6/27/2016 22:33	7/7/2016 20:19	10354087193	Copper	0.0	1.3	ppm
049-97A Room 42 - Sink Faucet	6/27/2016 22:33	7/7/2016 20:19	10354087193	Lead	10	15	ppb
049-98A Portable outside Water Spigot (1)	6/27/2016 22:38	7/7/2016 20:21	10354087195	Copper	0.1	1.3	ppm
049-98A Portable outside Water Spigot (1)	6/27/2016 22:38	7/7/2016 20:21	10354087195	Lead	65	15	ppb
049-99A Outside Water Spigot (2)	6/27/2016 22:42	7/7/2016 05:48	10354087197	Copper	0.0	1.3	ppm
049-99A Outside Water Spigot (2)	6/27/2016 22:42	7/7/2016 05:48	10354087197	Lead	45	15	ppb
049-100A Outside Water Spigot (3)	6/27/2016 22:46	7/7/2016 05:50	10354087199	Copper	0.0	1.3	ppm
049-100A Outside Water Spigot (3)	6/27/2016 22:46	7/7/2016 05:50	10354087199	Lead	5	15	ppb
049-101A Outside Water Spigot (4)	6/27/2016 22:50	7/7/2016 07:26	10354087201	Copper	0.0	1.3	ppm
049-101A Outside Water Spigot (4)	6/27/2016 22:50	7/7/2016 07:26	10354087201	Lead	16	15	ppb
049-102A Outside Water Spigot (5)	6/27/2016 22:54	7/7/2016 07:29	10354087203	Copper	0.2	1.3	ppm
049-102A Outside Water Spigot (5)	6/27/2016 22:54	7/7/2016 07:29	10354087203	Lead	91	15	ppb
049-103A Outside Water Spigot (6)	6/27/2016 22:56	7/7/2016 07:30	10354087205	Copper	0.0	1.3	ppm
049-103A Outside Water Spigot (6)	6/27/2016 22:56	7/7/2016 07:30	10354087205	Lead	25	15	ppb
049-104A Outside Water Spigot (7)	6/27/2016 23:00	7/7/2016 12:44	10354087207	Copper	0.2	1.3	ppm
049-104A Outside Water Spigot (7)	6/27/2016 23:00	7/7/2016 12:44	10354087207	Lead	126	15	ppb
049-105A Outside Water Spigot (8)	6/27/2016 23:03	7/7/2016 12:46	10354087209	Copper	0.1	1.3	ppm
049-105A Outside Water Spigot (8)	6/27/2016 23:03	7/7/2016 12:46	10354087209	Lead	93	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample data
James John Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
049-106A Outside Water Spigot (9)	6/27/2016 23:07	7/7/2016 07:31	10354087211	Copper	0.2	1.3	ppm
049-106A Outside Water Spigot (9)	6/27/2016 23:07	7/7/2016 07:31	10354087211	Lead	40	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.