

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Kelly Elementary School

Sample Identification # and Location		Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
051-01A	Room 127 Sink Faucet	6/25/2016 8:52:00 AM	7/5/2016 11:12:00 AM	BB66899	Copper	0.6	1.3	ppm
051-01A	Room 127 Sink Faucet	6/25/2016 8:52:00 AM	7/5/2016 11:12:00 AM	BB66899	Lead	6	15	ppb
051-02A	Room 100 Sink Faucet	6/25/2016 8:56:00 AM	7/5/2016 11:20:00 AM	BB66900	Copper	0.4	1.3	ppm
051-02A	Room 100 Sink Faucet	6/25/2016 8:56:00 AM	7/5/2016 11:20:00 AM	BB66900	Lead	2	15	ppb
051-03A	Boiler Room Slop Sink	6/25/2016 9:00:00 AM	7/5/2016 11:22:00 AM	BB66901	Copper	0.2	1.3	ppm
051-03A	Boiler Room Slop Sink	6/25/2016 9:00:00 AM	7/5/2016 11:22:00 AM	BB66901	Lead	2	15	ppb
051-04A	Boiler Room Bathroom Sink	6/25/2016 9:01:00 AM	7/5/2016 11:25:00 AM	BB66902	Copper	0.1	1.3	ppm
051-04A	Boiler Room Bathroom Sink	6/25/2016 9:01:00 AM	7/5/2016 11:25:00 AM	BB66902	Lead	10	15	ppb
051-05A	Room 117 Sink Faucet	6/25/2016 9:03:00 AM	7/5/2016 11:27:00 AM	BB66903	Copper	0.4	1.3	ppm
051-05A	Room 117 Sink Faucet	6/25/2016 9:03:00 AM	7/5/2016 11:27:00 AM	BB66903	Lead	2	15	ppb
051-06A	Room 116 Sink Faucet	6/25/2016 9:05:00 AM	7/5/2016 11:30:00 AM	BB66904	Copper	0.5	1.3	ppm
051-06A	Room 116 Sink Faucet	6/25/2016 9:05:00 AM	7/5/2016 11:30:00 AM	BB66904	Lead	4	15	ppb
051-07A	Room 116 Drinking Fountain	6/25/2016 9:05:00 AM	7/5/2016 11:37:00 AM	BB66905	Copper	0.8	1.3	ppm
051-07A	Room 116 Drinking Fountain	6/25/2016 9:05:00 AM	7/5/2016 11:37:00 AM	BB66905	Lead	4	15	ppb
051-08A	Room 115 Sink Faucet	6/25/2016 9:10:00 AM	7/7/2016 6:07:00 PM	BB66906	Copper	0.7	1.3	ppm
051-08A	Room 115 Sink Faucet	6/25/2016 9:10:00 AM	7/7/2016 6:07:00 PM	BB66906	Lead	4	15	ppb
051-09A	Room 114 Sink Faucet	6/25/2016 9:11:00 AM	7/5/2016 11:40:00 AM	BB66907	Copper	0.5	1.3	ppm
051-09A	Room 114 Sink Faucet	6/25/2016 9:11:00 AM	7/5/2016 11:40:00 AM	BB66907	Lead	5	15	ppb
051-10A	Room 114 Drinking Fountain	6/25/2016 9:12:00 AM	7/5/2016 11:48:00 AM	BB66908	Copper	0.7	1.3	ppm
051-10A	Room 114 Drinking Fountain	6/25/2016 9:12:00 AM	7/5/2016 11:48:00 AM	BB66908	Lead	2	15	ppb
051-11A	Room 113 Sink Faucet	6/25/2016 9:13:00 AM	7/5/2016 11:50:00 AM	BB66909	Copper	0.7	1.3	ppm
051-11A	Room 113 Sink Faucet	6/25/2016 9:13:00 AM	7/5/2016 11:50:00 AM	BB66909	Lead	6	15	ppb
051-12A	Room 113 Drinking Fountain	6/25/2016 9:13:00 AM	7/5/2016 12:38:00 PM	BB66910	Copper	0.0	1.3	ppm
051-12A	Room 113 Drinking Fountain	6/25/2016 9:13:00 AM	7/5/2016 12:38:00 PM	BB66910	Lead	4	15	ppb
051-13A	Room 112 Sink Faucet	6/25/2016 9:16:00 AM	7/5/2016 12:01:00 PM	BB66911	Copper	0.7	1.3	ppm
051-13A	Room 112 Sink Faucet	6/25/2016 9:16:00 AM	7/5/2016 12:01:00 PM	BB66911	Lead	3	15	ppb
051-14A	Room 112 Drinking Fountain	6/25/2016 9:16:00 AM	7/5/2016 12:03:00 PM	BB66912	Copper	0.8	1.3	ppm
051-14A	Room 112 Drinking Fountain	6/25/2016 9:16:00 AM	7/5/2016 12:03:00 PM	BB66912	Lead	1	15	ppb
051-15A	Room 118 Sink Faucet	6/25/2016 9:19:00 AM	7/5/2016 12:06:00 PM	BB66913	Copper	0.8	1.3	ppm
051-15A	Room 118 Sink Faucet	6/25/2016 9:19:00 AM	7/5/2016 12:06:00 PM	BB66913	Lead	7	15	ppb
051-16A	Hallway Drinking Fountain Near Room 118	6/25/2016 9:19:00 AM	7/5/2016 12:18:00 PM	BB66914	Copper	0.7	1.3	ppm
051-16A	Hallway Drinking Fountain Near Room 118	6/25/2016 9:19:00 AM	7/5/2016 12:18:00 PM	BB66914	Lead	2	15	ppb
051-17A	Room 119 Sink Faucet	6/25/2016 9:21:00 AM	7/5/2016 12:21:00 PM	BB66915	Copper	0.7	1.3	ppm
051-17A	Room 119 Sink Faucet	6/25/2016 9:21:00 AM	7/5/2016 12:21:00 PM	BB66915	Lead	6	15	ppb
051-18A	Room 119 Spray Hose	6/25/2016 9:21:00 AM	7/10/2016 8:40:00 PM	BB66916	Copper	0.9	1.3	ppm
051-18A	Room 119 Spray Hose	6/25/2016 9:21:00 AM	7/10/2016 8:40:00 PM	BB66916	Lead	8	15	ppb
051-19A	Room 120 Sink Faucet	6/25/2016 9:24:00 AM	7/5/2016 12:24:00 PM	BB66917	Copper	0.5	1.3	ppm
051-19A	Room 120 Sink Faucet	6/25/2016 9:24:00 AM	7/5/2016 12:24:00 PM	BB66917	Lead	12	15	ppb
051-20A	Girls Bathroom Sink Faucet Left	6/25/2016 9:27:00 AM	7/5/2016 12:28:00 PM	BB66918	Copper	0.5	1.3	ppm
051-20A	Girls Bathroom Sink Faucet Left	6/25/2016 9:27:00 AM	7/5/2016 12:28:00 PM	BB66918	Lead	1	15	ppb
051-21A	Girls Bathroom Sink Faucet Middle	6/25/2016 9:27:00 AM	7/10/2016 8:37:00 PM	BB66919	Copper	1.1	1.3	ppm
051-21A	Girls Bathroom Sink Faucet Middle	6/25/2016 9:27:00 AM	7/10/2016 8:37:00 PM	BB66919	Lead	5	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Kelly Elementary School

Sample Identification # and Location		Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
051-22A	Girls Bathroom Sink Faucet Right	6/25/2016 9:27:00 AM	7/5/2016 12:30:00 PM	BB66920	Copper	0.7	1.3	ppm
051-22A	Girls Bathroom Sink Faucet Right	6/25/2016 9:27:00 AM	7/5/2016 12:30:00 PM	BB66920	Lead	3	15	ppb
051-23A	Girls Bathroom Spigot	6/25/2016 9:29:00 AM	7/10/2016 8:44:00 PM	BB66921	Copper	0.9	1.3	ppm
051-23A	Girls Bathroom Spigot	6/25/2016 9:29:00 AM	7/10/2016 8:44:00 PM	BB66921	Lead	16	15	ppb
051-24A	Hallway Drinking Fountain Near Girls Bathroom	6/25/2016 9:32:00 AM	7/5/2016 12:33:00 PM	BB66922	Copper	0.5	1.3	ppm
051-24A	Hallway Drinking Fountain Near Girls Bathroom	6/25/2016 9:32:00 AM	7/5/2016 12:33:00 PM	BB66922	Lead	3	15	ppb
051-25A	Custodian Sink Between Bathrooms	6/25/2016 9:34:00 AM	7/10/2016 8:47:00 PM	BB66923	Copper	0.6	1.3	ppm
051-25A	Custodian Sink Between Bathrooms	6/25/2016 9:34:00 AM	7/10/2016 8:47:00 PM	BB66923	Lead	5	15	ppb
051-26A	Boys Bathroom Sink Faucet Left	6/25/2016 9:36:00 AM	7/5/2016 1:57:00 PM	BB66924	Copper	0.6	1.3	ppm
051-26A	Boys Bathroom Sink Faucet Left	6/25/2016 9:36:00 AM	7/5/2016 1:57:00 PM	BB66924	Lead	4	15	ppb
051-27A	Boys Bathroom Sink Faucet Middle	6/25/2016 9:36:00 AM	7/6/2016 1:33:00 PM	BB66925	Copper	0.4	1.3	ppm
051-27A	Boys Bathroom Sink Faucet Middle	6/25/2016 9:36:00 AM	7/6/2016 1:33:00 PM	BB66925	Lead	3	15	ppb
051-28A	Boys Bathroom Sink Faucet Right	6/25/2016 9:37:00 AM	7/5/2016 2:07:00 PM	BB66926	Copper	0.4	1.3	ppm
051-28A	Boys Bathroom Sink Faucet Right	6/25/2016 9:37:00 AM	7/5/2016 2:07:00 PM	BB66926	Lead	2	15	ppb
051-29A	Boys Bathroom Spigot	6/25/2016 9:39:00 AM	7/10/2016 8:50:00 PM	BB66927	Copper	1.2	1.3	ppm
051-29A	Boys Bathroom Spigot	6/25/2016 9:39:00 AM	7/10/2016 8:50:00 PM	BB66927	Lead	11	15	ppb
051-30A	Gym Office Sink Faucet	6/25/2016 9:42:00 AM	7/5/2016 2:15:00 PM	BB66928	Copper	0.2	1.3	ppm
051-30A	Gym Office Sink Faucet	6/25/2016 9:42:00 AM	7/5/2016 2:15:00 PM	BB66928	Lead	36	15	ppb
051-31A	Gym Office Shower	6/25/2016 9:43:00 AM	7/10/2016 8:54:00 PM	BB66929	Copper	0.3	1.3	ppm
051-31A	Gym Office Shower	6/25/2016 9:43:00 AM	7/10/2016 8:54:00 PM	BB66929	Lead	93	15	ppb
051-32A	Boys Locker Room Sink Faucet	6/25/2016 9:45:00 AM	7/6/2016 2:27:00 PM	BB66930	Copper	0.0	1.3	ppm
051-32A	Boys Locker Room Sink Faucet	6/25/2016 9:45:00 AM	7/6/2016 2:27:00 PM	BB66930	Lead	17	15	ppb
051-33A	Gym Drinking Fountain	6/25/2016 9:48:00 AM	7/6/2016 2:29:00 PM	BB66931	Copper	0.8	1.3	ppm
051-33A	Gym Drinking Fountain	6/25/2016 9:48:00 AM	7/6/2016 2:29:00 PM	BB66931	Lead	1	15	ppb
051-34A	Girls Locker Room Sink Faucet	6/25/2016 9:50:00 AM	7/5/2016 2:22:00 PM	BB66932	Copper	0.1	1.3	ppm
051-34A	Girls Locker Room Sink Faucet	6/25/2016 9:50:00 AM	7/5/2016 2:22:00 PM	BB66932	Lead	44	15	ppb
051-35A	Girls Locker Room Drinking Fountain	6/25/2016 9:51:00 AM	7/5/2016 2:25:00 PM	BB66933	Copper	0.1	1.3	ppm
051-35A	Girls Locker Room Drinking Fountain	6/25/2016 9:51:00 AM	7/5/2016 2:25:00 PM	BB66933	Lead	26	15	ppb
051-36A	Hallway Drinking Fountain outside of Gym	6/25/2016 9:54:00 AM	7/6/2016 2:32:00 PM	BB66934	Copper	0.6	1.3	ppm
051-36A	Hallway Drinking Fountain outside of Gym	6/25/2016 9:54:00 AM	7/6/2016 2:32:00 PM	BB66934	Lead	0	15	ppb
051-37A	Room 122 Sink Faucet	6/25/2016 9:56:00 AM	7/5/2016 2:30:00 PM	BB66935	Copper	0.5	1.3	ppm
051-37A	Room 122 Sink Faucet	6/25/2016 9:56:00 AM	7/5/2016 2:30:00 PM	BB66935	Lead	2	15	ppb
051-38A	Room 122 Drinking Fountain	6/25/2016 9:57:00 AM	7/6/2016 2:34:00 PM	BB66936	Copper	0.5	1.3	ppm
051-38A	Room 122 Drinking Fountain	6/25/2016 9:57:00 AM	7/6/2016 2:34:00 PM	BB66936	Lead	4	15	ppb
051-39A	Room 123 Sink Faucet	6/25/2016 10:00:00 AM	7/6/2016 1:41:00 PM	BB66937	Copper	0.5	1.3	ppm
051-39A	Room 123 Sink Faucet	6/25/2016 10:00:00 AM	7/6/2016 1:41:00 PM	BB66937	Lead	3	15	ppb
051-40A	Room 123 Drinking Fountain	6/25/2016 11:00:00 AM	7/5/2016 3:27:00 PM	BB66938	Copper	0.1	1.3	ppm
051-40A	Room 123 Drinking Fountain	6/25/2016 11:00:00 AM	7/5/2016 3:27:00 PM	BB66938	Lead	2	15	ppb
051-41A	Room 124 Sink Faucet	6/25/2016 10:01:00 AM	7/5/2016 3:30:00 PM	BB66939	Copper	0.6	1.3	ppm
051-41A	Room 124 Sink Faucet	6/25/2016 10:01:00 AM	7/5/2016 3:30:00 PM	BB66939	Lead	2	15	ppb
051-42A	Room 124 Drinking Fountain	6/25/2016 10:02:00 AM	7/5/2016 3:33:00 PM	BB66940	Copper	0.8	1.3	ppm
051-42A	Room 124 Drinking Fountain	6/25/2016 10:02:00 AM	7/5/2016 3:33:00 PM	BB66940	Lead	40	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Kelly Elementary School

Sample Identification # and Location		Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
051-43A	Custodial Closet inside Boys Bathroom	6/25/2016 10:03:00 AM	7/6/2016 11:45:00 AM	BB66941	Copper	1.5	1.3	ppm
051-43A	Custodial Closet inside Boys Bathroom	6/25/2016 10:03:00 AM	7/5/2016 3:01:00 PM	BB66941	Lead	19	15	ppb
051-44A	Boys Bathroom Sink Faucet Left	6/25/2016 10:04:00 AM	7/6/2016 2:37:00 PM	BB66942	Copper	0.7	1.3	ppm
051-44A	Boys Bathroom Sink Faucet Left	6/25/2016 10:04:00 AM	7/6/2016 2:37:00 PM	BB66942	Lead	3	15	ppb
051-45A	Boys Bathroom Sink Faucet Middle	6/25/2016 10:04:00 AM	7/6/2016 2:39:00 PM	BB66943	Copper	0.6	1.3	ppm
051-45A	Boys Bathroom Sink Faucet Middle	6/25/2016 10:04:00 AM	7/6/2016 2:39:00 PM	BB66943	Lead	4	15	ppb
051-46A	Boys Bathroom Sink Faucet Right	6/25/2016 10:04:00 AM	7/5/2016 3:08:00 PM	BB66944	Copper	0.6	1.3	ppm
051-46A	Boys Bathroom Sink Faucet Right	6/25/2016 10:04:00 AM	7/5/2016 3:08:00 PM	BB66944	Lead	5	15	ppb
051-47A	Boys Bathroom Spigot	6/25/2016 10:06:00 AM	7/5/2016 3:11:00 PM	BB66945	Copper	0.4	1.3	ppm
051-47A	Boys Bathroom Spigot	6/25/2016 10:06:00 AM	7/5/2016 3:11:00 PM	BB66945	Lead	29	15	ppb
051-48A	Girls Bathroom Sink Faucet Left	6/25/2016 10:10:00 AM	7/6/2016 10:02:00 AM	BB66946	Copper	0.3	1.3	ppm
051-48A	Girls Bathroom Sink Faucet Left	6/25/2016 10:10:00 AM	7/6/2016 10:02:00 AM	BB66946	Lead	25	15	ppb
051-49A	Girls Bathroom Sink Faucet Right	6/25/2016 10:10:00 AM	7/6/2016 10:05:00 AM	BB66947	Copper	0.3	1.3	ppm
051-49A	Girls Bathroom Sink Faucet Right	6/25/2016 10:10:00 AM	7/6/2016 10:05:00 AM	BB66947	Lead	5	15	ppb
051-50A	Girls Bathroom Spigot	6/25/2016 10:13:00 AM	7/6/2016 10:07:00 AM	BB66948	Copper	0.3	1.3	ppm
051-50A	Girls Bathroom Spigot	6/25/2016 10:13:00 AM	7/6/2016 10:07:00 AM	BB66948	Lead	13	15	ppb
051-51A	Room 125 Sink Faucet	6/25/2016 10:15:00 AM	7/6/2016 10:15:00 AM	BB66949	Copper	0.4	1.3	ppm
051-51A	Room 125 Sink Faucet	6/25/2016 10:15:00 AM	7/6/2016 10:15:00 AM	BB66949	Lead	5	15	ppb
051-52A	Room 125 Drinking Fountain	6/25/2016 10:15:00 AM	7/6/2016 10:18:00 AM	BB66950	Copper	0.0	1.3	ppm
051-52A	Room 125 Drinking Fountain	6/25/2016 10:15:00 AM	7/6/2016 10:18:00 AM	BB66950	Lead	1	15	ppb
051-53A	Room 126 Sink Faucet	6/25/2016 10:17:00 AM	7/6/2016 10:20:00 AM	BB66951	Copper	0.6	1.3	ppm
051-53A	Room 126 Sink Faucet	6/25/2016 10:17:00 AM	7/6/2016 10:20:00 AM	BB66951	Lead	5	15	ppb
051-54A	Room 126 Drinking Fountain	6/25/2016 10:17:00 AM	7/6/2016 10:28:00 AM	BB66952	Copper	0.1	1.3	ppm
051-54A	Room 126 Drinking Fountain	6/25/2016 10:17:00 AM	7/6/2016 10:28:00 AM	BB66952	Lead	2	15	ppb
051-55A	Room 127 Drinking Fountain	6/25/2016 10:19:00 AM	7/6/2016 10:30:00 AM	BB66953	Copper	0.4	1.3	ppm
051-55A	Room 127 Drinking Fountain	6/25/2016 10:19:00 AM	7/6/2016 10:30:00 AM	BB66953	Lead	1	15	ppb
051-56A	Room 106 Sink Faucet	6/25/2016 10:29:00 AM	7/6/2016 10:33:00 AM	BB66954	Copper	0.7	1.3	ppm
051-56A	Room 106 Sink Faucet	6/25/2016 10:29:00 AM	7/6/2016 10:33:00 AM	BB66954	Lead	3	15	ppb
051-57A	Room 106 Drinking Fountain	6/25/2016 10:29:00 AM	7/6/2016 10:35:00 AM	BB66955	Copper	0.0	1.3	ppm
051-57A	Room 106 Drinking Fountain	6/25/2016 10:29:00 AM	7/6/2016 10:35:00 AM	BB66955	Lead	1	15	ppb
051-58A	Room 100 Drinking Fountain	6/25/2016 10:31:00 AM	7/6/2016 10:38:00 AM	BB66956	Copper	0.9	1.3	ppm
051-58A	Room 100 Drinking Fountain	6/25/2016 10:31:00 AM	7/6/2016 10:38:00 AM	BB66956	Lead	1	15	ppb
051-59A	Room 100 Bathroom Faucet Left	6/25/2016 10:33:00 AM	7/6/2016 10:41:00 AM	BB66957	Copper	0.5	1.3	ppm
051-59A	Room 100 Bathroom Faucet Left	6/25/2016 10:33:00 AM	7/6/2016 10:41:00 AM	BB66957	Lead	4	15	ppb
051-60A	Room 100 Bathroom Faucet Right	6/25/2016 10:33:00 AM	7/6/2016 11:07:00 AM	BB66958	Copper	0.4	1.3	ppm
051-60A	Room 100 Bathroom Faucet Right	6/25/2016 10:33:00 AM	7/6/2016 11:07:00 AM	BB66958	Lead	10	15	ppb
051-61A	Room 101 Drinking Fountain	6/25/2016 10:35:00 AM	7/6/2016 11:10:00 AM	BB66959	Copper	0.3	1.3	ppm
051-61A	Room 101 Drinking Fountain	6/25/2016 10:35:00 AM	7/6/2016 11:10:00 AM	BB66959	Lead	2	15	ppb
051-62A	Room 101 Sink Faucet	6/25/2016 10:36:00 AM	7/6/2016 11:12:00 AM	BB66960	Copper	0.6	1.3	ppm
051-62A	Room 101 Sink Faucet	6/25/2016 10:36:00 AM	7/6/2016 11:12:00 AM	BB66960	Lead	3	15	ppb
051-63A	Room 107 Sink Faucet	6/25/2016 10:37:00 AM	7/6/2016 11:01:00 AM	BB66961	Copper	0.5	1.3	ppm
051-63A	Room 107 Sink Faucet	6/25/2016 10:37:00 AM	7/6/2016 11:01:00 AM	BB66961	Lead	2	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Kelly Elementary School

Sample Identification # and Location		Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
051-64A	Room 107 Drinking Fountain	6/25/2016 10:37:00 AM	7/6/2016 11:23:00 AM	BB66962	Copper	0.1	1.3	ppm
051-64A	Room 107 Drinking Fountain	6/25/2016 10:37:00 AM	7/6/2016 11:23:00 AM	BB66962	Lead	1	15	ppb
051-65A	Boys Bathroom Sink Faucet Left	6/25/2016 10:40:00 AM	7/6/2016 11:32:00 AM	BB66963	Copper	0.2	1.3	ppm
051-65A	Boys Bathroom Sink Faucet Left	6/25/2016 10:40:00 AM	7/6/2016 11:32:00 AM	BB66963	Lead	2	15	ppb
051-66A	Boys Bathroom Sink Faucet Right	6/25/2016 10:40:00 AM	7/6/2016 11:35:00 AM	BB66964	Copper	0.6	1.3	ppm
051-66A	Boys Bathroom Sink Faucet Right	6/25/2016 10:40:00 AM	7/6/2016 11:35:00 AM	BB66964	Lead	2	15	ppb
051-67A	Hallway Drinking Fountain Btwn Bathrooms	6/25/2016 10:43:00 AM	7/6/2016 11:42:00 AM	BB66965	Copper	0.7	1.3	ppm
051-67A	Hallway Drinking Fountain Btwn Bathrooms	6/25/2016 10:43:00 AM	7/6/2016 11:42:00 AM	BB66965	Lead	1	15	ppb
051-68A	Girls Bathroom Sink Faucet Left	6/25/2016 10:45:00 AM	7/6/2016 11:53:00 AM	BB66966	Copper	0.6	1.3	ppm
051-68A	Girls Bathroom Sink Faucet Left	6/25/2016 10:45:00 AM	7/6/2016 11:53:00 AM	BB66966	Lead	3	15	ppb
051-69A	Girls Bathroom Sink Faucet Right	6/25/2016 10:45:00 AM	7/6/2016 11:55:00 AM	BB66967	Copper	0.6	1.3	ppm
051-69A	Girls Bathroom Sink Faucet Right	6/25/2016 10:45:00 AM	7/6/2016 11:55:00 AM	BB66967	Lead	1	15	ppb
051-70A	Room 108 Sink Faucet	6/25/2016 10:47:00 AM	7/6/2016 11:58:00 AM	BB66968	Copper	0.5	1.3	ppm
051-70A	Room 108 Sink Faucet	6/25/2016 10:47:00 AM	7/6/2016 11:58:00 AM	BB66968	Lead	3	15	ppb
051-71A	Room 108 Drinking Fountain	6/25/2016 10:47:00 AM	7/6/2016 12:00:00 PM	BB66969	Copper	0.0	1.3	ppm
051-71A	Room 108 Drinking Fountain	6/25/2016 10:47:00 AM	7/6/2016 12:00:00 PM	BB66969	Lead	9	15	ppb
051-72A	Room 102 Sink Faucet	6/25/2016 10:49:00 AM	7/6/2016 12:03:00 PM	BB66970	Copper	0.6	1.3	ppm
051-72A	Room 102 Sink Faucet	6/25/2016 10:49:00 AM	7/6/2016 12:03:00 PM	BB66970	Lead	1	15	ppb
051-73A	Room 102 Drinking Fountain	6/25/2016 10:49:00 AM	7/6/2016 12:16:00 PM	BB66971	Copper	0.0	1.3	ppm
051-73A	Room 102 Drinking Fountain	6/25/2016 10:49:00 AM	7/6/2016 12:16:00 PM	BB66971	Lead	6	15	ppb
051-74A	Room 109 Sink Faucet	6/25/2016 10:53:00 AM	7/6/2016 12:18:00 PM	BB66972	Copper	0.7	1.3	ppm
051-74A	Room 109 Sink Faucet	6/25/2016 10:53:00 AM	7/6/2016 12:18:00 PM	BB66972	Lead	2	15	ppb
051-75A	Room 109 Drinking Fountain	6/25/2016 10:54:00 AM	7/6/2016 12:21:00 PM	BB66973	Copper	0.0	1.3	ppm
051-75A	Room 109 Drinking Fountain	6/25/2016 10:54:00 AM	7/6/2016 12:21:00 PM	BB66973	Lead	2	15	ppb
051-76A	Room 103 Sink Faucet	6/25/2016 10:55:00 AM	7/6/2016 12:23:00 PM	BB66974	Copper	0.6	1.3	ppm
051-76A	Room 103 Sink Faucet	6/25/2016 10:55:00 AM	7/6/2016 12:23:00 PM	BB66974	Lead	4	15	ppb
051-77A	Room 103 Drinking Fountain	6/25/2016 10:55:00 AM	7/1/2016 6:10:00 PM	BB66975	Copper	0.0	1.3	ppm
051-77A	Room 103 Drinking Fountain	6/25/2016 10:55:00 AM	7/1/2016 6:10:00 PM	BB66975	Lead	5	15	ppb
051-78A	Room 110 Sink Faucet	6/25/2016 11:00:00 AM	7/1/2016 6:13:00 PM	BB66976	Copper	0.6	1.3	ppm
051-78A	Room 110 Sink Faucet	6/25/2016 11:00:00 AM	7/1/2016 6:13:00 PM	BB66976	Lead	5	15	ppb
051-79A	Room 110 Drinking Faucet	6/25/2016 11:00:00 AM	7/1/2016 6:16:00 PM	BB66977	Copper	0.0	1.3	ppm
051-79A	Room 110 Drinking Faucet	6/25/2016 11:00:00 AM	7/1/2016 6:16:00 PM	BB66977	Lead	4	15	ppb
051-80A	Room 104 Sink Faucet	6/25/2016 11:01:00 AM	7/1/2016 6:19:00 PM	BB66978	Copper	0.5	1.3	ppm
051-80A	Room 104 Sink Faucet	6/25/2016 11:01:00 AM	7/1/2016 6:19:00 PM	BB66978	Lead	5	15	ppb
051-81A	Room 104 Drinking Fountain	6/25/2016 11:01:00 AM	7/10/2016 8:57:00 PM	BB66979	Copper	0.6	1.3	ppm
051-81A	Room 104 Drinking Fountain	6/25/2016 11:01:00 AM	7/10/2016 8:57:00 PM	BB66979	Lead	1	15	ppb
051-82A	Room 111 Sink Faucet	6/25/2016 11:06:00 AM	7/1/2016 6:22:00 PM	BB66980	Copper	0.6	1.3	ppm
051-82A	Room 111 Sink Faucet	6/25/2016 11:06:00 AM	7/1/2016 6:22:00 PM	BB66980	Lead	7	15	ppb
051-83A	Room 111 Drinking Fountain	6/25/2016 11:06:00 AM	7/1/2016 6:25:00 PM	BB66981	Copper	0.0	1.3	ppm
051-83A	Room 111 Drinking Fountain	6/25/2016 11:06:00 AM	7/1/2016 6:25:00 PM	BB66981	Lead	4	15	ppb
051-84A	Room 105 Sink Faucet	6/25/2016 11:09:00 AM	7/1/2016 6:28:00 PM	BB66982	Copper	0.7	1.3	ppm
051-84A	Room 105 Sink Faucet	6/25/2016 11:09:00 AM	7/1/2016 6:28:00 PM	BB66982	Lead	3	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Kelly Elementary School

Sample Identification # and Location		Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
051-85A	Room 105 Drinking Fountain	6/25/2016 11:09:00 AM	7/1/2016 6:31:00 PM	BB66983	Copper	0.0	1.3	ppm
051-85A	Room 105 Drinking Fountain	6/25/2016 11:09:00 AM	7/1/2016 6:31:00 PM	BB66983	Lead	1	15	ppb
051-86A	Girls Bathroom Sink Faucet Left	6/25/2016 11:12:00 AM	7/1/2016 6:34:00 PM	BB66984	Copper	0.6	1.3	ppm
051-86A	Girls Bathroom Sink Faucet Left	6/25/2016 11:12:00 AM	7/1/2016 6:34:00 PM	BB66984	Lead	2	15	ppb
051-87A	Girls Bathroom Sink Faucet Middle	6/25/2016 11:12:00 AM	7/1/2016 6:37:00 PM	BB66985	Copper	0.6	1.3	ppm
051-87A	Girls Bathroom Sink Faucet Middle	6/25/2016 11:12:00 AM	7/1/2016 6:37:00 PM	BB66985	Lead	2	15	ppb
051-88A	Girls Bathroom Sink Faucet Right	6/25/2016 11:13:00 AM	7/1/2016 6:59:00 PM	BB66986	Copper	0.3	1.3	ppm
051-88A	Girls Bathroom Sink Faucet Right	6/25/2016 11:13:00 AM	7/1/2016 6:59:00 PM	BB66986	Lead	4	15	ppb
051-89A	Handicap Bathroom Sink Faucet	6/25/2016 11:16:00 AM	7/1/2016 7:02:00 PM	BB66987	Copper	0.8	1.3	ppm
051-89A	Handicap Bathroom Sink Faucet	6/25/2016 11:16:00 AM	7/1/2016 7:02:00 PM	BB66987	Lead	1	15	ppb
051-90A	Bathroom Sink Faucet (next to Custodian Rm)	6/25/2016 11:17:00 AM	7/1/2016 7:05:00 PM	BB66988	Copper	0.1	1.3	ppm
051-90A	Bathroom Sink Faucet (next to Custodian Rm)	6/25/2016 11:17:00 AM	7/1/2016 7:05:00 PM	BB66988	Lead	3	15	ppb
051-91A	Custodian Slop Sink	6/25/2016 11:19:00 AM	7/1/2016 7:08:00 PM	BB66989	Copper	0.3	1.3	ppm
051-91A	Custodian Slop Sink	6/25/2016 11:19:00 AM	7/1/2016 7:08:00 PM	BB66989	Lead	1	15	ppb
051-92A	Boys Bathroom Sink Faucet Left	6/25/2016 11:20:00 AM	7/1/2016 7:11:00 PM	BB66990	Copper	0.2	1.3	ppm
051-92A	Boys Bathroom Sink Faucet Left	6/25/2016 11:20:00 AM	7/1/2016 7:11:00 PM	BB66990	Lead	5	15	ppb
051-93A	Boys Bathroom Sink Faucet Middle	6/25/2016 11:20:00 AM	7/1/2016 7:14:00 PM	BB66991	Copper	0.3	1.3	ppm
051-93A	Boys Bathroom Sink Faucet Middle	6/25/2016 11:20:00 AM	7/1/2016 7:14:00 PM	BB66991	Lead	6	15	ppb
051-94A	Boys Bathroom Sink Faucet Right	6/25/2016 11:31:00 AM	7/1/2016 7:17:00 PM	BB66992	Copper	0.3	1.3	ppm
051-94A	Boys Bathroom Sink Faucet Right	6/25/2016 11:31:00 AM	7/1/2016 7:17:00 PM	BB66992	Lead	5	15	ppb
051-96A	Cafeteria Drinking Fountain Left	6/25/2016 11:35:00 AM	7/1/2016 8:36:00 PM	BB66993	Copper	1.2	1.3	ppm
051-96A	Cafeteria Drinking Fountain Left	6/25/2016 11:35:00 AM	7/1/2016 7:20:00 PM	BB66993	Lead	2	15	ppb
051-97A	Cafeteria Drinking Fountain Right	6/25/2016 11:36:00 AM	7/1/2016 8:39:00 PM	BB66994	Copper	0.9	1.3	ppm
051-97A	Cafeteria Drinking Fountain Right	6/25/2016 11:36:00 AM	7/1/2016 7:23:00 PM	BB66994	Lead	1	15	ppb
051-98A	Kitchen Sink Faucet	6/25/2016 11:39:00 AM	7/1/2016 7:26:00 PM	BB66995	Copper	0.0	1.3	ppm
051-98A	Kitchen Sink Faucet	6/25/2016 11:39:00 AM	7/1/2016 7:26:00 PM	BB66995	Lead	4	15	ppb
051-99A	Kitchen Sprayer Front	6/25/2016 11:40:00 AM	7/1/2016 7:44:00 PM	BB66996	Copper	0.0	1.3	ppm
051-99A	Kitchen Sprayer Front	6/25/2016 11:40:00 AM	7/1/2016 7:44:00 PM	BB66996	Lead	5	15	ppb
051-100A	Kitchen Sink Left Side	6/25/2016 11:41:00 AM	7/1/2016 7:47:00 PM	BB66997	Copper	0.0	1.3	ppm
051-100A	Kitchen Sink Left Side	6/25/2016 11:41:00 AM	7/1/2016 7:47:00 PM	BB66997	Lead	17	15	ppb
051-101A	Kitchen Hand Wash Sink	6/25/2016 11:42:00 AM	7/10/2016 9:01:00 PM	BB66998	Copper	0.2	1.3	ppm
051-101A	Kitchen Hand Wash Sink	6/25/2016 11:42:00 AM	7/10/2016 9:01:00 PM	BB66998	Lead	9	15	ppb
051-102A	Kitchen Sprayer Left Side	6/25/2016 11:44:00 AM	7/1/2016 8:12:00 PM	BB66999	Copper	0.1	1.3	ppm
051-102A	Kitchen Sprayer Left Side	6/25/2016 11:44:00 AM	7/1/2016 8:12:00 PM	BB66999	Lead	10	15	ppb
051-103A	Kitchen Bathroom Back Left Corner	6/25/2016 11:45:00 AM	7/10/2016 9:04:00 PM	BB67000	Copper	0.2	1.3	ppm
051-103A	Kitchen Bathroom Back Left Corner	6/25/2016 11:45:00 AM	7/10/2016 9:04:00 PM	BB67000	Lead	8	15	ppb
051-104A	Kitchen Slop Sink next to Bathroom	6/25/2016 11:46:00 AM	7/10/2016 9:08:00 PM	BB67001	Copper	0.1	1.3	ppm
051-104A	Kitchen Slop Sink next to Bathroom	6/25/2016 11:46:00 AM	7/10/2016 9:08:00 PM	BB67001	Lead	12	15	ppb
051-105A	Drinking Fountain outside Main Office	6/25/2016 11:49:00 AM	7/1/2016 8:42:00 PM	BB67002	Copper	1.1	1.3	ppm
051-105A	Drinking Fountain outside Main Office	6/25/2016 11:49:00 AM	7/1/2016 7:50:00 PM	BB67002	Lead	16	15	ppb
051-106A	Nurses Office Sink Faucet	6/25/2016 11:51:00 AM	7/1/2016 7:53:00 PM	BB67003	Copper	0.8	1.3	ppm
051-106A	Nurses Office Sink Faucet	6/25/2016 11:51:00 AM	7/1/2016 7:53:00 PM	BB67003	Lead	2	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Kelly Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA	Units
						Action Level	
051-107A Office next to Nurse Bathroom Sink Faucet	6/25/2016 11:52:00 AM	7/1/2016 7:57:00 PM	BB67004	Copper	0.1	1.3	ppm
051-107A Office next to Nurse Bathroom Sink Faucet	6/25/2016 11:52:00 AM	7/1/2016 7:57:00 PM	BB67004	Lead	1	15	ppb
051-108A Office next to Nurse Sink Faucet	6/25/2016 11:53:00 AM	7/1/2016 7:59:00 PM	BB67005	Copper	0.6	1.3	ppm
051-108A Office next to Nurse Sink Faucet	6/25/2016 11:53:00 AM	7/1/2016 7:59:00 PM	BB67005	Lead	7	15	ppb
051-109A Music Building Sink Faucet	6/25/2016 12:00:00 PM	7/1/2016 8:03:00 PM	BB67006	Copper	0.2	1.3	ppm
051-109A Music Building Sink Faucet	6/25/2016 12:00:00 PM	7/1/2016 8:03:00 PM	BB67006	Lead	9	15	ppb
051-110A Music Building Drinking Fountain	6/25/2016 12:00:00 PM	7/1/2016 8:06:00 PM	BB67007	Copper	0.0	1.3	ppm
051-110A Music Building Drinking Fountain	6/25/2016 12:00:00 PM	7/1/2016 8:06:00 PM	BB67007	Lead	11	15	ppb
051-111A Music Building Bathroom Sink Faucet	6/25/2016 12:00:00 PM	7/1/2016 8:09:00 PM	BB67008	Copper	0.2	1.3	ppm
051-111A Music Building Bathroom Sink Faucet	6/25/2016 12:00:00 PM	7/1/2016 8:09:00 PM	BB67008	Lead	10	15	ppb
051-112A Music Building Bathroom Spigot	6/25/2016 12:00:00 PM	7/10/2016 9:39:00 PM	BB67009	Copper	0.2	1.3	ppm
051-112A Music Building Bathroom Spigot	6/25/2016 12:00:00 PM	7/10/2016 9:39:00 PM	BB67009	Lead	28	15	ppb
051-113A Water Spigot in Music Room	6/25/2016 12:03:00 PM	7/2/2016 9:16:00 AM	BB67010	Copper	0.1	1.3	ppm
051-113A Water Spigot in Music Room	6/25/2016 12:03:00 PM	7/2/2016 9:16:00 AM	BB67010	Lead	17	15	ppb
051-114A Exterior Water Spigot 2	6/25/2016 12:06:00 PM	7/2/2016 9:19:00 AM	BB67011	Copper	0.1	1.3	ppm
051-114A Exterior Water Spigot 2	6/25/2016 12:06:00 PM	7/2/2016 9:19:00 AM	BB67011	Lead	122	15	ppb
051-115A Exterior Water Spigot 3	6/25/2016 12:15:00 PM	7/10/2016 9:42:00 PM	BB67012	Copper	0.0	1.3	ppm
051-115A Exterior Water Spigot 3	6/25/2016 12:15:00 PM	7/10/2016 9:42:00 PM	BB67012	Lead	16	15	ppb
051-116A Exterior Water Spigot 4	6/25/2016 12:20:00 PM	7/10/2016 9:46:00 PM	BB67013	Copper	0.0	1.3	ppm
051-116A Exterior Water Spigot 4	6/25/2016 12:20:00 PM	7/10/2016 9:46:00 PM	BB67013	Lead	22	15	ppb
051-117A Exterior Water Spigot 5	6/25/2016 12:27:00 PM	7/2/2016 9:22:00 AM	BB67014	Copper	0.0	1.3	ppm
051-117A Exterior Water Spigot 5	6/25/2016 12:27:00 PM	7/2/2016 9:22:00 AM	BB67014	Lead	63	15	ppb
051-118A Exterior Water Spigot 6	6/25/2016 12:31:00 PM	7/2/2016 9:25:00 AM	BB67015	Copper	0.1	1.3	ppm
051-118A Exterior Water Spigot 6	6/25/2016 12:31:00 PM	7/2/2016 9:25:00 AM	BB67015	Lead	29	15	ppb
051-119A Exterior Water Spigot 7	6/25/2016 12:33:00 PM	7/2/2016 9:28:00 AM	BB67016	Copper	0.1	1.3	ppm
051-119A Exterior Water Spigot 7	6/25/2016 12:33:00 PM	7/2/2016 9:28:00 AM	BB67016	Lead	29	15	ppb
051-120A Exterior Water Spigot 8	6/25/2016 12:35:00 PM	7/10/2016 9:49:00 PM	BB67017	Copper	0.8	1.3	ppm
051-120A Exterior Water Spigot 8	6/25/2016 12:35:00 PM	7/10/2016 9:49:00 PM	BB67017	Lead	397	15	ppb
051-121A Exterior Water Spigot 9 on Annex	6/25/2016 12:40:00 PM	7/6/2016 8:57:00 PM	BB67018	Copper	0.2	1.3	ppm
051-121A Exterior Water Spigot 9 on Annex	6/25/2016 12:40:00 PM	7/6/2016 8:57:00 PM	BB67018	Lead	59	15	ppb
051-122A Exterior Water Spigot 10 on Annex	6/25/2016 12:43:00 PM	7/6/2016 9:18:00 PM	BB67019	Copper	0.0	1.3	ppm
051-122A Exterior Water Spigot 10 on Annex	6/25/2016 12:43:00 PM	7/6/2016 9:18:00 PM	BB67019	Lead	68	15	ppb
051-123A Exterior Water Spigot 11 on Annex	6/25/2016 12:45:00 PM	7/6/2016 9:22:00 PM	BB67020	Copper	0.0	1.3	ppm
051-123A Exterior Water Spigot 11 on Annex	6/25/2016 12:45:00 PM	7/6/2016 9:22:00 PM	BB67020	Lead	21	15	ppb
051-124A Room 1 Sink Faucet in Annex	6/25/2016 12:48:00 PM	7/6/2016 9:25:00 PM	BB67021	Copper	0.2	1.3	ppm
051-124A Room 1 Sink Faucet in Annex	6/25/2016 12:48:00 PM	7/6/2016 9:25:00 PM	BB67021	Lead	26	15	ppb
051-125A Sink Faucet Adult Bathroom of Annex	6/25/2016 12:50:00 PM	7/6/2016 9:28:00 PM	BB67022	Copper	0.2	1.3	ppm
051-125A Sink Faucet Adult Bathroom of Annex	6/25/2016 12:50:00 PM	7/6/2016 9:28:00 PM	BB67022	Lead	55	15	ppb
051-126A Sink Faucet in Bathroom of Annex	6/25/2016 12:50:00 PM	7/6/2016 9:31:00 PM	BB67023	Copper	0.1	1.3	ppm
051-126A Sink Faucet in Bathroom of Annex	6/25/2016 12:50:00 PM	7/6/2016 9:31:00 PM	BB67023	Lead	16	15	ppb
051-127A Room 2 Sink Faucet in Annex	6/25/2016 12:52:00 PM	7/6/2016 9:34:00 PM	BB67024	Copper	0.1	1.3	ppm
051-127A Room 2 Sink Faucet in Annex	6/25/2016 12:52:00 PM	7/6/2016 9:34:00 PM	BB67024	Lead	6	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Kelly Elementary School

Sample Identification # and Location		Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
051-128A	Room 2 Bathroom Sink Faucet	6/25/2016 12:52:00 PM	7/6/2016 9:37:00 PM	BB67025	Copper	0.1	1.3	ppm
051-128A	Room 2 Bathroom Sink Faucet	6/25/2016 12:52:00 PM	7/6/2016 9:37:00 PM	BB67025	Lead	56	15	ppb
051-129A	Room 6 Sink Faucet in Annex	6/25/2016 12:54:00 PM	7/6/2016 9:40:00 PM	BB67026	Copper	0.1	1.3	ppm
051-129A	Room 6 Sink Faucet in Annex	6/25/2016 12:54:00 PM	7/6/2016 9:40:00 PM	BB67026	Lead	27	15	ppb
051-130A	Room 6 Bathroom Sink Faucet in Annex	6/25/2016 12:54:00 PM	7/6/2016 9:43:00 PM	BB67027	Copper	0.0	1.3	ppm
051-130A	Room 6 Bathroom Sink Faucet in Annex	6/25/2016 12:54:00 PM	7/6/2016 9:43:00 PM	BB67027	Lead	5	15	ppb
051-131A	Room 7 Sink Faucet in Annex	6/25/2016 12:56:00 PM	7/6/2016 9:46:00 PM	BB67028	Copper	0.1	1.3	ppm
051-131A	Room 7 Sink Faucet in Annex	6/25/2016 12:56:00 PM	7/6/2016 9:46:00 PM	BB67028	Lead	7	15	ppb
051-132A	Room 10 Sink Faucet in Annex	6/25/2016 12:58:00 PM	7/7/2016 9:03:00 AM	BB67029	Copper	0.6	1.3	ppm
051-132A	Room 10 Sink Faucet in Annex	6/25/2016 12:58:00 PM	7/7/2016 9:03:00 AM	BB67029	Lead	22	15	ppb
051-133A	Room 10 Drinking Fountain	6/25/2016 12:58:00 PM	7/7/2016 9:06:00 AM	BB67030	Copper	0.1	1.3	ppm
051-133A	Room 10 Drinking Fountain	6/25/2016 12:58:00 PM	7/7/2016 9:06:00 AM	BB67030	Lead	36	15	ppb
051-134A	Room 10 Bathroom Sink Faucet	6/25/2016 12:58:00 PM	7/7/2016 9:09:00 AM	BB67031	Copper	0.1	1.3	ppm
051-134A	Room 10 Bathroom Sink Faucet	6/25/2016 12:58:00 PM	7/7/2016 9:09:00 AM	BB67031	Lead	8	15	ppb
051-135A	Room 9 Custodian Slop Sink	6/25/2016 1:00:00 PM	7/7/2016 9:12:00 AM	BB67032	Copper	0.1	1.3	ppm
051-135A	Room 9 Custodian Slop Sink	6/25/2016 1:00:00 PM	7/7/2016 9:12:00 AM	BB67032	Lead	24	15	ppb
051-136A	Main Office Room 12C Sink Faucet	6/25/2016 1:01:00 PM	7/7/2016 9:15:00 AM	BB67033	Copper	0.1	1.3	ppm
051-136A	Main Office Room 12C Sink Faucet	6/25/2016 1:01:00 PM	7/7/2016 9:15:00 AM	BB67033	Lead	50	15	ppb
051-137A	Room 19 Sink Faucet	6/25/2016 1:01:00 PM	7/7/2016 9:18:00 AM	BB67034	Copper	0.4	1.3	ppm
051-137A	Room 19 Sink Faucet	6/25/2016 1:01:00 PM	7/7/2016 9:18:00 AM	BB67034	Lead	33	15	ppb
051-138A	Room 23 Sink Faucet	6/25/2016 1:02:00 PM	7/7/2016 9:21:00 AM	BB67035	Copper	0.2	1.3	ppm
051-138A	Room 23 Sink Faucet	6/25/2016 1:02:00 PM	7/7/2016 9:21:00 AM	BB67035	Lead	12	15	ppb
051-139A	Hallway Drinking Fountain outside Room 120 1	6/25/2016 1:02:00 PM	7/7/2016 9:24:00 AM	BB67036	Copper	0.4	1.3	ppm
051-139A	Hallway Drinking Fountain outside Room 120 1	6/25/2016 1:02:00 PM	7/7/2016 9:24:00 AM	BB67036	Lead	20	15	ppb
051-140A	Hallway Drinking Fountain outside Room 120 2	6/25/2016 1:02:00 PM	7/7/2016 9:27:00 AM	BB67037	Copper	0.5	1.3	ppm
051-140A	Hallway Drinking Fountain outside Room 120 2	6/25/2016 1:02:00 PM	7/7/2016 9:27:00 AM	BB67037	Lead	18	15	ppb
051-141A	Girls Bathroom (Room 18) Sink Faucet 1	6/25/2016 1:04:00 PM	7/7/2016 9:30:00 AM	BB67038	Copper	0.3	1.3	ppm
051-141A	Girls Bathroom (Room 18) Sink Faucet 1	6/25/2016 1:04:00 PM	7/7/2016 9:30:00 AM	BB67038	Lead	21	15	ppb
051-142A	Girls Bathroom (Room 18) Sink Faucet 2	6/25/2016 1:04:00 PM	7/10/2016 9:53:00 PM	BB67039	Copper	0.4	1.3	ppm
051-142A	Girls Bathroom (Room 18) Sink Faucet 2	6/25/2016 1:04:00 PM	7/10/2016 9:53:00 PM	BB67039	Lead	31	15	ppb
051-143A	Girls Bathroom (Room 18) Water Spigot	6/25/2016 1:05:00 PM	7/10/2016 9:36:00 PM	BB67040	Copper	0.6	1.3	ppm
051-143A	Girls Bathroom (Room 18) Water Spigot	6/25/2016 1:05:00 PM	7/10/2016 9:36:00 PM	BB67040	Lead	140	15	ppb
051-144A	Room 20 Custodian Sink	6/25/2016 1:06:00 PM	7/7/2016 9:51:00 AM	BB67041	Copper	0.2	1.3	ppm
051-144A	Room 20 Custodian Sink	6/25/2016 1:06:00 PM	7/7/2016 9:51:00 AM	BB67041	Lead	80	15	ppb
051-145A	Boys Bathroom Sink Faucet 1	6/25/2016 1:06:00 PM	7/7/2016 9:54:00 AM	BB67042	Copper	0.3	1.3	ppm
051-145A	Boys Bathroom Sink Faucet 1	6/25/2016 1:06:00 PM	7/7/2016 9:54:00 AM	BB67042	Lead	21	15	ppb
051-146A	Boys Bathroom Sink Faucet 2	6/25/2016 1:06:00 PM	7/7/2016 9:57:00 AM	BB67043	Copper	0.3	1.3	ppm
051-146A	Boys Bathroom Sink Faucet 2	6/25/2016 1:06:00 PM	7/7/2016 9:57:00 AM	BB67043	Lead	18	15	ppb
051-147A	Boys Bathroom Water Spigot	6/25/2016 1:07:00 PM	7/10/2016 9:56:00 PM	BB67044	Copper	0.8	1.3	ppm
051-147A	Boys Bathroom Water Spigot	6/25/2016 1:07:00 PM	7/10/2016 9:56:00 PM	BB67044	Lead	854	15	ppb
051-148A	Room 24 Sink Faucet	6/25/2016 1:08:00 PM	7/7/2016 10:00:00 AM	BB67045	Copper	0.1	1.3	ppm
051-148A	Room 24 Sink Faucet	6/25/2016 1:08:00 PM	7/7/2016 10:00:00 AM	BB67045	Lead	42	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Kelly Elementary School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA	Units
						Action Level	
051-149A Room 28 Sink Faucet	6/25/2016 1:08:00 PM	7/7/2016 10:03:00 AM	BB67046	Copper	0.5	1.3	ppm
051-149A Room 28 Sink Faucet	6/25/2016 1:08:00 PM	7/7/2016 10:03:00 AM	BB67046	Lead	25	15	ppb
051-150A Room 25 Sink Faucet	6/25/2016 1:10:00 PM	7/10/2016 10:01:00 PM	BB67047	Copper	0.4	1.3	ppm
051-150A Room 25 Sink Faucet	6/25/2016 1:10:00 PM	7/10/2016 10:01:00 PM	BB67047	Lead	65	15	ppb
051-151A Room 29 Sink Faucet	6/25/2016 1:10:00 PM	7/10/2016 10:04:00 PM	BB67048	Copper	0.6	1.3	ppm
051-151A Room 29 Sink Faucet	6/25/2016 1:10:00 PM	7/10/2016 10:04:00 PM	BB67048	Lead	88	15	ppb
051-152A Room 29 Drinking Fountain	6/25/2016 1:12:00 PM	7/7/2016 10:06:00 AM	BB67049	Copper	0.2	1.3	ppm
051-152A Room 29 Drinking Fountain	6/25/2016 1:12:00 PM	7/7/2016 10:06:00 AM	BB67049	Lead	2	15	ppb
051-153A Room 117 Drinking Fountain	6/25/2016 9:05:00 AM	7/7/2016 10:09:00 AM	BB67050	Copper	0.7	1.3	ppm
051-153A Room 117 Drinking Fountain	6/25/2016 9:05:00 AM	7/7/2016 10:09:00 AM	BB67050	Lead	34	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.