

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Kenton Elementary School

| Sample Identification # and Location |                                                         | Date/Time Collected  | Date/Time Analyzed    | Container ID | Analyte | Results | EPA Action Level | Units |
|--------------------------------------|---------------------------------------------------------|----------------------|-----------------------|--------------|---------|---------|------------------|-------|
| 096 - 01A                            | Custodial Slop Sink Between Room 101 and Girls Bathroom | 6/25/2016 8:04:00 AM | 6/30/2016             | BB66826      | Copper  | 0.1     | 1.3              | ppm   |
| 096 - 01A                            | Custodial Slop Sink Between Room 101 and Girls Bathroom | 6/25/2016 8:04:00 AM | 6/30/2016             | BB66826      | Lead    | 4       | 15               | ppb   |
| 096 - 02A                            | Portable 1 Sink Faucet                                  | 6/25/2016 8:09:00 AM | 6/30/2016             | BB66827      | Copper  | 0.1     | 1.3              | ppm   |
| 096 - 02A                            | Portable 1 Sink Faucet                                  | 6/25/2016 8:09:00 AM | 6/30/2016             | BB66827      | Lead    | 5       | 15               | ppb   |
| 096 - 03A                            | Boiler Room Can Wash                                    | 6/25/2016 8:14:00 AM | 6/30/2016             | BB66828      | Copper  | 0.1     | 1.3              | ppm   |
| 096 - 03A                            | Boiler Room Can Wash                                    | 6/25/2016 8:14:00 AM | 6/30/2016             | BB66828      | Lead    | 0       | 15               | ppb   |
| 096 - 04A                            | Boiler Room Sink Facuet                                 | 6/25/2016 8:16:00 AM | 6/30/2016             | BB66829      | Copper  | 0.3     | 1.3              | ppm   |
| 096 - 04A                            | Boiler Room Sink Facuet                                 | 6/25/2016 8:16:00 AM | 6/30/2016             | BB66829      | Lead    | 4       | 15               | ppb   |
| 096 - 05A                            | Development Office Sink Faucet                          | 6/25/2016 8:20:00 AM | 7/11/2016 9:37:00 AM  | BB66830      | Copper  | 0.9     | 1.3              | ppm   |
| 096 - 05A                            | Development Office Sink Faucet                          | 6/25/2016 8:20:00 AM | 7/11/2016 9:37:00 AM  | BB66830      | Lead    | 51      | 15               | ppb   |
| 096 - 06A                            | Mens Bathroom Sink Faucet (left)                        | 6/25/2016 8:24:00 AM | 6/30/2016             | BB66831      | Copper  | 0.7     | 1.3              | ppm   |
| 096 - 06A                            | Mens Bathroom Sink Faucet (left)                        | 6/25/2016 8:24:00 AM | 6/30/2016             | BB66831      | Lead    | 3       | 15               | ppb   |
| 096 - 07A                            | Mens Bathroom Sink Faucet (middle)                      | 6/25/2016 8:24:00 AM | 6/30/2016             | BB66832      | Copper  | 0.7     | 1.3              | ppm   |
| 096 - 07A                            | Mens Bathroom Sink Faucet (middle)                      | 6/25/2016 8:24:00 AM | 6/30/2016             | BB66832      | Lead    | 5       | 15               | ppb   |
| 096 - 08A                            | Mens Bathroom Sink Faucet (right)                       | 6/25/2016 8:27:00 AM | 6/30/2016             | BB66833      | Copper  | 0.3     | 1.3              | ppm   |
| 096 - 08A                            | Mens Bathroom Sink Faucet (right)                       | 6/25/2016 8:27:00 AM | 6/30/2016             | BB66833      | Lead    | 2       | 15               | ppb   |
| 096 - 09A                            | Mens Bathroom Sink Faucet (front left)                  | 6/25/2016 8:27:00 AM | 6/30/2016             | BB66834      | Copper  | 0.5     | 1.3              | ppm   |
| 096 - 09A                            | Mens Bathroom Sink Faucet (front left)                  | 6/25/2016 8:27:00 AM | 6/30/2016             | BB66834      | Lead    | 5       | 15               | ppb   |
| 096 - 10A                            | Mens Bathroom Sink Faucet (front right)                 | 6/25/2016 8:29:00 AM | 7/11/2016 9:40:00 AM  | BB66835      | Copper  | 0.7     | 1.3              | ppm   |
| 096 - 10A                            | Mens Bathroom Sink Faucet (front right)                 | 6/25/2016 8:29:00 AM | 7/11/2016 9:40:00 AM  | BB66835      | Lead    | 10      | 15               | ppb   |
| 096 - 11A                            | Womens Bathroom Sink Faucet (front left)                | 6/25/2016 8:32:00 AM | 7/8/2016 11:01:00 AM  | BB66836      | Copper  | 1.0     | 1.3              | ppm   |
| 096 - 11A                            | Womens Bathroom Sink Faucet (front left)                | 6/25/2016 8:32:00 AM | 7/8/2016 11:01:00 AM  | BB66836      | Lead    | 6       | 15               | ppb   |
| 096 - 12A                            | Womens Bathroom Sink Faucet (front right)               | 6/25/2016 8:33:00 AM | 7/10/2016 4:44:00 PM  | BB66837      | Copper  | 0.9     | 1.3              | ppm   |
| 096 - 12A                            | Womens Bathroom Sink Faucet (front right)               | 6/25/2016 8:33:00 AM | 7/10/2016 4:44:00 PM  | BB66837      | Lead    | 6       | 15               | ppb   |
| 096 - 13A                            | Womens Bathroom Sink Faucet (left)                      | 6/25/2016 8:33:00 AM | 6/30/2016             | BB66838      | Copper  | 0.5     | 1.3              | ppm   |
| 096 - 13A                            | Womens Bathroom Sink Faucet (left)                      | 6/25/2016 8:33:00 AM | 6/30/2016             | BB66838      | Lead    | 8       | 15               | ppb   |
| 096 - 14A                            | Womens Bathroom Sink Faucet (middle)                    | 6/25/2016 8:33:00 AM | 6/30/2016             | BB66839      | Copper  | 0.6     | 1.3              | ppm   |
| 096 - 14A                            | Womens Bathroom Sink Faucet (middle)                    | 6/25/2016 8:33:00 AM | 6/30/2016             | BB66839      | Lead    | 12      | 15               | ppb   |
| 096 - 15A                            | Womens Bathroom Sink Faucet (right)                     | 6/25/2016 8:35:00 AM | 6/30/2016 8:47:00 AM  | BB66840      | Copper  | 0.2     | 1.3              | ppm   |
| 096 - 15A                            | Womens Bathroom Sink Faucet (right)                     | 6/25/2016 8:35:00 AM | 6/30/2016 8:47:00 AM  | BB66840      | Lead    | 3       | 15               | ppb   |
| 096 - 16A                            | Hallway Sink Faucet next to Boiler Room (left)          | 6/25/2016 8:41:00 AM | 6/30/2016 8:50:00 AM  | BB66841      | Copper  | 0.0     | 1.3              | ppm   |
| 096 - 16A                            | Hallway Sink Faucet next to Boiler Room (left)          | 6/25/2016 8:41:00 AM | 6/30/2016 8:50:00 AM  | BB66841      | Lead    | 6       | 15               | ppb   |
| 096 - 17A                            | Hallway Sink Faucet next to Boiler Room (right)         | 6/25/2016 8:42:00 AM | 6/30/2016 8:53:00 AM  | BB66842      | Copper  | 0.0     | 1.3              | ppm   |
| 096 - 17A                            | Hallway Sink Faucet next to Boiler Room (right)         | 6/25/2016 8:42:00 AM | 6/30/2016 8:53:00 AM  | BB66842      | Lead    | 5       | 15               | ppb   |
| 096 - 18A                            | Faculty Lounge Sink Faucet                              | 6/25/2016 8:44:00 AM | 6/30/2016 8:56:00 AM  | BB66843      | Copper  | 0.2     | 1.3              | ppm   |
| 096 - 18A                            | Faculty Lounge Sink Faucet                              | 6/25/2016 8:44:00 AM | 6/30/2016 8:56:00 AM  | BB66843      | Lead    | 1       | 15               | ppb   |
| 096 - 19A                            | Room 202 Sink Faucet                                    | 6/25/2016 8:46:00 AM | 6/30/2016 8:59:00 AM  | BB66844      | Copper  | 0.3     | 1.3              | ppm   |
| 096 - 19A                            | Room 202 Sink Faucet                                    | 6/25/2016 8:46:00 AM | 6/30/2016 8:59:00 AM  | BB66844      | Lead    | 1       | 15               | ppb   |
| 096 - 20A                            | Room 201 Lab Sink Faucet 1                              | 6/25/2016 8:53:00 AM | 7/10/2016 4:47:00 PM  | BB66845      | Copper  | 0.6     | 1.3              | ppm   |
| 096 - 20A                            | Room 201 Lab Sink Faucet 1                              | 6/25/2016 8:53:00 AM | 7/10/2016 4:47:00 PM  | BB66845      | Lead    | 44      | 15               | ppb   |
| 096 - 21A                            | Room 201 Lab Sink Faucet 2                              | 6/25/2016 8:54:00 AM | 7/8/2016 10:54:00 AM  | BB66846      | Copper  | 0.8     | 1.3              | ppm   |
| 096 - 21A                            | Room 201 Lab Sink Faucet 2                              | 6/25/2016 8:54:00 AM | 7/8/2016 10:54:00 AM  | BB66846      | Lead    | 48      | 15               | ppb   |
| 096 - 22A                            | Room 201 Lab Sink Faucet 3                              | 6/25/2016 8:56:00 AM | 7/8/2016 11:12:00 AM  | BB66847      | Copper  | 0.5     | 1.3              | ppm   |
| 096 - 22A                            | Room 201 Lab Sink Faucet 3                              | 6/25/2016 8:56:00 AM | 7/8/2016 11:12:00 AM  | BB66847      | Lead    | 35      | 15               | ppb   |
| 096 - 23A                            | Room 201 Lab Sink Faucet 4                              | 6/25/2016 8:56:00 AM | 7/10/2016 4:54:00 PM  | BB66848      | Copper  | 0.3     | 1.3              | ppm   |
| 096 - 23A                            | Room 201 Lab Sink Faucet 4                              | 6/25/2016 8:56:00 AM | 7/10/2016 4:54:00 PM  | BB66848      | Lead    | 49      | 15               | ppb   |
| 096 - 24A                            | Room 201 Lab Sink Faucet 5                              | 6/25/2016 8:57:00 AM | 6/30/2016 9:02:00 AM  | BB66849      | Copper  | 0.2     | 1.3              | ppm   |
| 096 - 24A                            | Room 201 Lab Sink Faucet 5                              | 6/25/2016 8:57:00 AM | 6/30/2016 9:02:00 AM  | BB66849      | Lead    | 21      | 15               | ppb   |
| 096 - 25A                            | Room 201 Lab Sink Faucet 6                              | 6/25/2016 8:57:00 AM | 6/30/2016 9:05:00 AM  | BB66850      | Copper  | 0.4     | 1.3              | ppm   |
| 096 - 25A                            | Room 201 Lab Sink Faucet 6                              | 6/25/2016 8:57:00 AM | 6/30/2016 9:05:00 AM  | BB66850      | Lead    | 34      | 15               | ppb   |
| 096 - 26A                            | Room 201 Lab Sink Faucet 7                              | 6/25/2016 9:00:00 AM | 7/10/2016 5:05:00 PM  | BB66851      | Copper  | 17.6    | 1.3              | ppm   |
| 096 - 26A                            | Room 201 Lab Sink Faucet 7                              | 6/25/2016 9:00:00 AM | 7/8/2016 11:18:00 AM  | BB66851      | Lead    | 588     | 15               | ppb   |
| 096 - 27A                            | Room 201 Lab Sink Faucet 8                              | 6/25/2016 9:01:00 AM | 6/30/2016 12:13:00 PM | BB66852      | Copper  | 1.8     | 1.3              | ppm   |
| 096 - 27A                            | Room 201 Lab Sink Faucet 8                              | 6/25/2016 9:01:00 AM | 6/30/2016 9:08:00 AM  | BB66852      | Lead    | 110     | 15               | ppb   |
| 096 - 28A                            | Room 201 Lab Sink Faucet 9                              | 6/25/2016 9:03:00 AM | 7/8/2016 11:22:00 AM  | BB66853      | Copper  | 0.5     | 1.3              | ppm   |
| 096 - 28A                            | Room 201 Lab Sink Faucet 9                              | 6/25/2016 9:03:00 AM | 7/8/2016 11:22:00 AM  | BB66853      | Lead    | 30      | 15               | ppb   |
| 096 - 29A                            | Room 201 Lab Sink Faucet 10                             | 6/25/2016 9:03:00 AM | 7/8/2016 11:25:00 AM  | BB66854      | Copper  | 0.4     | 1.3              | ppm   |
| 096 - 29A                            | Room 201 Lab Sink Faucet 10                             | 6/25/2016 9:03:00 AM | 7/8/2016 11:25:00 AM  | BB66854      | Lead    | 21      | 15               | ppb   |
| 096 - 30A                            | Room 201 Lab Sink Faucet 11                             | 6/25/2016 9:05:00 AM | 7/10/2016 3:52:00 PM  | BB66855      | Copper  | 0.4     | 1.3              | ppm   |
| 096 - 30A                            | Room 201 Lab Sink Faucet 11                             | 6/25/2016 9:05:00 AM | 7/10/2016 3:52:00 PM  | BB66855      | Lead    | 18      | 15               | ppb   |
| 096 - 31A                            | Room 201 Lab Sink Faucet 12                             | 6/25/2016 9:05:00 AM | 6/30/2016 9:27:00 AM  | BB66856      | Copper  | 0.2     | 1.3              | ppm   |
| 096 - 31A                            | Room 201 Lab Sink Faucet 12                             | 6/25/2016 9:05:00 AM | 6/30/2016 9:27:00 AM  | BB66856      | Lead    | 15.2    | 15               | ppb   |
| 096 - 32A                            | Room 201 Lab Sink Faucet 13                             | 6/25/2016 9:07:00 AM | 6/30/2016 9:30:00 AM  | BB66857      | Copper  | 0.2     | 1.3              | ppm   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Kenton Elementary School

| Sample Identification # and Location |                                                     | Date/Time Collected   | Date/Time Analyzed    | Container ID | Analyte | Results | EPA Action Level | Units |
|--------------------------------------|-----------------------------------------------------|-----------------------|-----------------------|--------------|---------|---------|------------------|-------|
| 096 - 32A                            | Room 201 Lab Sink Faucet 13                         | 6/25/2016 9:07:00 AM  | 6/30/2016 9:30:00 AM  | BB66857      | Lead    | 12      | 15               | ppb   |
| 096 - 33A                            | Room 201 Lab Sink Faucet 14                         | 6/25/2016 9:07:00 AM  | 6/30/2016 9:33:00 AM  | BB66858      | Copper  | 0.4     | 1.3              | ppm   |
| 096 - 33A                            | Room 201 Lab Sink Faucet 14                         | 6/25/2016 9:07:00 AM  | 6/30/2016 9:33:00 AM  | BB66858      | Lead    | 17      | 15               | ppb   |
| 096 - 34A                            | Room 201 Lab Sink Faucet 15 (main desk)             | 6/25/2016 9:00:00 AM  | 6/30/2016 9:36:00 AM  | BB66859      | Copper  | 0.2     | 1.3              | ppm   |
| 096 - 34A                            | Room 201 Lab Sink Faucet 15 (main desk)             | 6/25/2016 9:00:00 AM  | 6/30/2016 9:36:00 AM  | BB66859      | Lead    | 14.7    | 15               | ppb   |
| 096 - 35A                            | Room 201, Back Room Sink Faucet                     | 6/25/2016 8:58:00 AM  | 6/30/2016 9:39:00 AM  | BB66860      | Copper  | 0.5     | 1.3              | ppm   |
| 096 - 35A                            | Room 201, Back Room Sink Faucet                     | 6/25/2016 8:58:00 AM  | 6/30/2016 9:39:00 AM  | BB66860      | Lead    | 11      | 15               | ppb   |
| 096 - 36A                            | Room 201, Eye Wash                                  | 6/25/2016 9:11:00 AM  | 7/10/2016 3:55:00 PM  | BB66861      | Copper  | 1.7     | 1.3              | ppm   |
| 096 - 36A                            | Room 201, Eye Wash                                  | 6/25/2016 9:11:00 AM  | 7/10/2016 3:55:00 PM  | BB66861      | Lead    | 199     | 15               | ppb   |
| 096 - 37A                            | Main Floor, Womens Bathroom Sink Faucet 1           | 6/25/2016 9:20:00 AM  | 6/30/2016 9:42:00 AM  | BB66862      | Copper  | 0.2     | 1.3              | ppm   |
| 096 - 37A                            | Main Floor, Womens Bathroom Sink Faucet 1           | 6/25/2016 9:20:00 AM  | 6/30/2016 9:42:00 AM  | BB66862      | Lead    | 1       | 15               | ppb   |
| 096 - 38A                            | Main Floor, Womens Bathroom Sink Faucet 2           | 6/25/2016 9:22:00 AM  | 6/30/2016 9:45:00 AM  | BB66863      | Copper  | 0.3     | 1.3              | ppm   |
| 096 - 38A                            | Main Floor, Womens Bathroom Sink Faucet 2           | 6/25/2016 9:22:00 AM  | 6/30/2016 9:45:00 AM  | BB66863      | Lead    | 9       | 15               | ppb   |
| 096 - 39A                            | Main Floor, Womens Bathroom Sink Faucet 3           | 6/25/2016 9:23:00 AM  | 6/30/2016 9:48:00 AM  | BB66864      | Copper  | 0.3     | 1.3              | ppm   |
| 096 - 39A                            | Main Floor, Womens Bathroom Sink Faucet 3           | 6/25/2016 9:23:00 AM  | 6/30/2016 9:48:00 AM  | BB66864      | Lead    | 8       | 15               | ppb   |
| 096 - 40A                            | Main Floor, Womens Bathroom Sink Faucet 4           | 6/25/2016 9:25:00 AM  | 6/30/2016 9:51:00 AM  | BB66865      | Copper  | 0.2     | 1.3              | ppm   |
| 096 - 40A                            | Main Floor, Womens Bathroom Sink Faucet 4           | 6/25/2016 9:25:00 AM  | 6/30/2016 9:51:00 AM  | BB66865      | Lead    | 5       | 15               | ppb   |
| 096 - 41A                            | Main Floor, Mens Bathroom Sink Faucet 1             | 6/25/2016 9:27:00 AM  | 6/30/2016 9:54:00 AM  | BB66866      | Copper  | 0.2     | 1.3              | ppm   |
| 096 - 41A                            | Main Floor, Mens Bathroom Sink Faucet 1             | 6/25/2016 9:27:00 AM  | 6/30/2016 9:54:00 AM  | BB66866      | Lead    | 1       | 15               | ppb   |
| 096 - 42A                            | Main Floor, Mens Bathroom Sink Faucet 2             | 6/25/2016 9:28:00 AM  | 6/30/2016 10:15:00 AM | BB66867      | Copper  | 0.3     | 1.3              | ppm   |
| 096 - 42A                            | Main Floor, Mens Bathroom Sink Faucet 2             | 6/25/2016 9:28:00 AM  | 6/30/2016 10:15:00 AM | BB66867      | Lead    | 7       | 15               | ppb   |
| 096 - 43A                            | Main Floor, Mens Bathroom Sink Faucet 3             | 6/25/2016 9:30:00 AM  | 6/30/2016 10:18:00 AM | BB66868      | Copper  | 0.3     | 1.3              | ppm   |
| 096 - 43A                            | Main Floor, Mens Bathroom Sink Faucet 3             | 6/25/2016 9:30:00 AM  | 6/30/2016 10:18:00 AM | BB66868      | Lead    | 5       | 15               | ppb   |
| 096 - 44A                            | Main Floor, Mens Bathroom Sink Faucet 4             | 6/25/2016 9:31:00 AM  | 6/30/2016 10:21:00 AM | BB66869      | Copper  | 0.3     | 1.3              | ppm   |
| 096 - 44A                            | Main Floor, Mens Bathroom Sink Faucet 4             | 6/25/2016 9:31:00 AM  | 6/30/2016 10:21:00 AM | BB66869      | Lead    | 9       | 15               | ppb   |
| 096 - 45A                            | Hallway Drinking Fountain in front of Mens Bathroom | 6/25/2016 9:34:00 AM  | 6/30/2016 10:24:00 AM | BB66870      | Copper  | 0.4     | 1.3              | ppm   |
| 096 - 45A                            | Hallway Drinking Fountain in front of Mens Bathroom | 6/25/2016 9:34:00 AM  | 6/30/2016 10:24:00 AM | BB66870      | Lead    | 0       | 15               | ppb   |
| 096 - 46A                            | Hallway Drinking Fountain Bottle Refill             | 6/25/2016 9:35:00 AM  | 6/30/2016 10:27:00 AM | BB66871      | Copper  | 0.3     | 1.3              | ppm   |
| 096 - 46A                            | Hallway Drinking Fountain Bottle Refill             | 6/25/2016 9:35:00 AM  | 6/30/2016 10:27:00 AM | BB66871      | Lead    | 0       | 15               | ppb   |
| 096 - 47A                            | Facility 6 Sink Faucet (across from main entrance)  | 6/25/2016 9:41:00 AM  | 6/30/2016 10:30:00 AM | BB66872      | Copper  | 0.0     | 1.3              | ppm   |
| 096 - 47A                            | Facility 6 Sink Faucet (across from main entrance)  | 6/25/2016 9:41:00 AM  | 6/30/2016 10:30:00 AM | BB66872      | Lead    | 0       | 15               | ppb   |
| 096 - 48A                            | Hallway Drinking Fountain (across from staircase)   | 6/25/2016 9:43:00 AM  | 6/30/2016 10:33:00 AM | BB66873      | Copper  | 0.7     | 1.3              | ppm   |
| 096 - 48A                            | Hallway Drinking Fountain (across from staircase)   | 6/25/2016 9:43:00 AM  | 6/30/2016 10:33:00 AM | BB66873      | Lead    | 2       | 15               | ppb   |
| 096 - 49A                            | Accessible Bathroom, Sink Faucet (left)             | 6/25/2016 9:47:00 AM  | 6/30/2016 10:36:00 AM | BB66874      | Copper  | 0.1     | 1.3              | ppm   |
| 096 - 49A                            | Accessible Bathroom, Sink Faucet (left)             | 6/25/2016 9:47:00 AM  | 6/30/2016 10:36:00 AM | BB66874      | Lead    | 12      | 15               | ppb   |
| 096 - 50A                            | Accessible Bathroom, Sink Faucet (right)            | 6/25/2016 9:47:00 AM  | 6/30/2016 10:39:00 AM | BB66875      | Copper  | 0.0     | 1.3              | ppm   |
| 096 - 50A                            | Accessible Bathroom, Sink Faucet (right)            | 6/25/2016 9:47:00 AM  | 6/30/2016 10:39:00 AM | BB66875      | Lead    | 17      | 15               | ppb   |
| 096 - 51A                            | Accessible Bathroom, Showerhead (left)              | 6/25/2016 9:50:00 AM  | 6/30/2016 10:42:00 AM | BB66876      | Copper  | 0.0     | 1.3              | ppm   |
| 096 - 51A                            | Accessible Bathroom, Sink Faucet (left)             | 6/25/2016 9:50:00 AM  | 6/30/2016 10:42:00 AM | BB66876      | Lead    | 2       | 15               | ppb   |
| 096 - 52A                            | Kitchen Sink Faucet (front left)                    | 6/25/2016 9:54:00 AM  | 7/10/2016 3:48:00 PM  | BB66877      | Copper  | 0.7     | 1.3              | ppm   |
| 096 - 52A                            | Kitchen Sink Faucet (front left)                    | 6/25/2016 9:54:00 AM  | 7/10/2016 3:48:00 PM  | BB66877      | Lead    | 59      | 15               | ppb   |
| 096 - 53A                            | Kitchen Sink Faucet (front middle)                  | 6/25/2016 9:55:00 AM  | 6/30/2016 10:58:00 AM | BB66878      | Copper  | 0.2     | 1.3              | ppm   |
| 096 - 53A                            | Kitchen Sink Faucet (front middle)                  | 6/25/2016 9:55:00 AM  | 6/30/2016 10:58:00 AM | BB66878      | Lead    | 3       | 15               | ppb   |
| 096 - 54A                            | Kitchen Sink Faucet (right)                         | 6/25/2016 9:55:00 AM  | 6/30/2016 11:01:00 AM | BB66879      | Copper  | 0.1     | 1.3              | ppm   |
| 096 - 54A                            | Kitchen Sink Faucet (right)                         | 6/25/2016 9:55:00 AM  | 6/30/2016 11:01:00 AM | BB66879      | Lead    | 2       | 15               | ppb   |
| 096 - 55A                            | Kitchen Ice Machine - Ice                           | 6/25/2016 9:56:00 AM  | 6/30/2016 11:04:00 AM | BB66880      | Copper  | 0.0     | 1.3              | ppm   |
| 096 - 55A                            | Kitchen Ice Machine - Ice                           | 6/25/2016 9:56:00 AM  | 6/30/2016 11:04:00 AM | BB66880      | Lead    | 0       | 15               | ppb   |
| 096 - 56A                            | Kitchen Sink Faucet (next to ice machine)           | 6/25/2016 9:58:00 AM  | 6/30/2016 11:07:00 AM | BB66881      | Copper  | 0.2     | 1.3              | ppm   |
| 096 - 56A                            | Kitchen Sink Faucet (next to ice machine)           | 6/25/2016 9:58:00 AM  | 6/30/2016 11:07:00 AM | BB66881      | Lead    | 2       | 15               | ppb   |
| 096 - 57A                            | Kitchen Side Room Slop Sink                         | 6/25/2016 10:00:00 AM | 6/30/2016 11:10:00 AM | BB66882      | Copper  | 0.2     | 1.3              | ppm   |
| 096 - 57A                            | Kitchen Side Room Slop Sink                         | 6/25/2016 10:00:00 AM | 6/30/2016 11:10:00 AM | BB66882      | Lead    | 8       | 15               | ppb   |
| 096 - 58A                            | Kitchen Back Room Sink Faucet                       | 6/25/2016 10:02:00 AM | 6/30/2016 11:13:00 AM | BB66883      | Copper  | 0.1     | 1.3              | ppm   |
| 096 - 58A                            | Kitchen Back Room Sink Faucet                       | 6/25/2016 10:02:00 AM | 6/30/2016 11:13:00 AM | BB66883      | Lead    | 1       | 15               | ppb   |
| 096 - 59A                            | Kitchen Bathroom Sink Faucet                        | 6/25/2016 10:04:00 AM | 6/30/2016 11:16:00 AM | BB66884      | Copper  | 0.2     | 1.3              | ppm   |
| 096 - 59A                            | Kitchen Bathroom Sink Faucet                        | 6/25/2016 10:04:00 AM | 6/30/2016 11:16:00 AM | BB66884      | Lead    | 5       | 15               | ppb   |
| 096 - 60A                            | Auditorium Front Entrance Bathroom (Mens)           | 6/25/2016 10:09:00 AM | 6/30/2016 11:19:00 AM | BB66885      | Copper  | 0.7     | 1.3              | ppm   |
| 096 - 60A                            | Auditorium Front Entrance Bathroom (Mens)           | 6/25/2016 10:09:00 AM | 6/30/2016 11:19:00 AM | BB66885      | Lead    | 93      | 15               | ppb   |
| 096 - 61A                            | Portable 3 Bathroom Sink Faucet (Womens)            | 6/25/2016 10:12:00 AM | 7/10/2016 3:59:00 PM  | BB66886      | Copper  | 0.2     | 1.3              | ppm   |
| 096 - 61A                            | Portable 3 Bathroom Sink Faucet (Womens)            | 6/25/2016 10:12:00 AM | 7/10/2016 3:59:00 PM  | BB66886      | Lead    | 61      | 15               | ppb   |
| 096 - 62A                            | Portable 3 Bathroom Sink Faucet (Mens)              | 6/25/2016 10:14:00 AM | 6/30/2016 11:22:00 AM | BB66887      | Copper  | 0.1     | 1.3              | ppm   |
| 096 - 62A                            | Portable 3 Bathroom Sink Faucet (Mens)              | 6/25/2016 10:14:00 AM | 6/30/2016 11:22:00 AM | BB66887      | Lead    | 14.5    | 15               | ppb   |
| 096 - 63A                            | Portable 1 Drinking Fountain                        | 6/25/2016 10:17:00 AM | 7/10/2016 4:02:00 PM  | BB66888      | Copper  | 0.3     | 1.3              | ppm   |
| 096 - 63A                            | Portable 1 Drinking Fountain                        | 6/25/2016 10:17:00 AM | 7/10/2016 4:02:00 PM  | BB66888      | Lead    | 20      | 15               | ppb   |

Portland Public Schools  
Lead and Copper Water Sampling Results  
A (First Draw) Sample Data  
Kenton Elementary School

| Sample Identification # and Location |                                                | Date/Time Collected   | Date/Time Analyzed    | Container ID | Analyte | Results | EPA Action Level | Units |
|--------------------------------------|------------------------------------------------|-----------------------|-----------------------|--------------|---------|---------|------------------|-------|
| 096 - 64A                            | Portable 1 Sink Faucet                         | 6/25/2016 10:18:00 AM | 7/10/2016 4:06:00 PM  | BB66889      | Copper  | 0.5     | 1.3              | ppm   |
| 096 - 64A                            | Portable 1 Sink Faucet                         | 6/25/2016 10:18:00 AM | 7/10/2016 4:06:00 PM  | BB66889      | Lead    | 26      | 15               | ppb   |
| 096 - 65A                            | Auditorium Side Hall Drinking Fountain (left)  | 6/25/2016 10:24:00 AM | 6/30/2016 11:25:00 AM | BB66890      | Copper  | 0.0     | 1.3              | ppm   |
| 096 - 65A                            | Auditorium Side Hall Drinking Fountain (left)  | 6/25/2016 10:24:00 AM | 6/30/2016 11:25:00 AM | BB66890      | Lead    | 3       | 15               | ppb   |
| 096 - 66A                            | Auditorium Side Hall Drinking Fountain (right) | 6/25/2016 10:25:00 AM | 6/30/2016 11:46:00 AM | BB66891      | Copper  | 0.0     | 1.3              | ppm   |
| 096 - 66A                            | Auditorium Side Hall Drinking Fountain (right) | 6/25/2016 10:25:00 AM | 6/30/2016 11:46:00 AM | BB66891      | Lead    | 1       | 15               | ppb   |
| 096 - 67A                            | Roon 210 Bathroom Sink Faucet                  | 6/25/2016 10:29:00 AM | 6/30/2016 11:49:00 AM | BB66892      | Copper  | 0.6     | 1.3              | ppm   |
| 096 - 67A                            | Room 210 Bathroom Sink Faucet                  | 6/25/2016 10:29:00 AM | 6/30/2016 11:49:00 AM | BB66892      | Lead    | 2       | 15               | ppb   |
| 096 - 68A                            | Second Floor Hallway Drinking Fountain         | 6/25/2016 10:32:00 AM | 6/30/2016 11:52:00 AM | BB66893      | Copper  | 0.4     | 1.3              | ppm   |
| 096 - 68A                            | Second Floor Hallway Drinking Fountain         | 6/25/2016 10:32:00 AM | 6/30/2016 11:52:00 AM | BB66893      | Lead    | 2       | 15               | ppb   |
| 096 - 69A                            | Exterior Spigot #1 (outside of auditorium)     | 6/25/2016 10:23:00 AM | 6/30/2016 11:58:00 AM | BB66894      | Copper  | 0.0     | 1.3              | ppm   |
| 096 - 69A                            | Exterior Spigot #1 (outside of auditorium)     | 6/25/2016 10:23:00 AM | 6/30/2016 11:58:00 AM | BB66894      | Lead    | 109     | 15               | ppb   |
| 096 - 70A                            | Exterior Spigot #2 (outside of gymnasium)      | 6/25/2016 10:28:00 AM | 6/30/2016 12:01:00 PM | BB66895      | Copper  | 0.1     | 1.3              | ppm   |
| 096 - 70A                            | Exterior Spigot #2 (outside of gymnasium)      | 6/25/2016 10:28:00 AM | 6/30/2016 12:01:00 PM | BB66895      | Lead    | 14      | 15               | ppb   |
| 096 - 71A                            | Exterior Spigot #3 (outside of kitchen south)  | 6/25/2016 10:37:00 AM | 6/30/2016 12:04:00 PM | BB66896      | Copper  | 0.0     | 1.3              | ppm   |
| 096 - 71A                            | Exterior Spigot #3 (outside of kitchen south)  | 6/25/2016 10:37:00 AM | 6/30/2016 12:04:00 PM | BB66896      | Lead    | 52      | 15               | ppb   |
| 096 - 72A                            | Exterior Spigot #4 (outside of kitchen)        | 6/25/2016 10:38:00 AM | 6/30/2016 12:07:00 PM | BB66897      | Copper  | 0.0     | 1.3              | ppm   |
| 096 - 72A                            | Exterior Spigot #4 (outside of kitchen)        | 6/25/2016 10:38:00 AM | 6/30/2016 12:07:00 PM | BB66897      | Lead    | 6       | 15               | ppb   |
| 096 - 73A                            | Exterior Spigot #5 (outside facility north)    | 6/25/2016 10:40:00 AM | 6/30/2016 12:10:00 PM | BB66898      | Copper  | 0.1     | 1.3              | ppm   |
| 096 - 73A                            | Exterior Spigot #5 (outside facility north)    | 6/25/2016 10:40:00 AM | 6/30/2016 12:10:00 PM | BB66898      | Lead    | 14.9    | 15               | ppb   |

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.