Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Lane Middle School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
053-01A Sink Faucet in Boiler Room	6/30/2016 20:05	7/6/2016	36690	Copper	ND	1.3	ppm
053-01A Sink Faucet in Boiler Room	6/30/2016 20:05	7/6/2016	36690	Lead	7	15	ppb
053-02A Spigot in Boiler Room	6/30/2016 20:11	7/6/2016	36692	Copper	ND	1.3	ppm
053-02A Spigot in Boiler Room	6/30/2016 20:11	7/6/2016	36692	Lead	17	15	ppb
053-03A Sink Faucet in Janitor Closet by Boiler	6/30/2016 20:14	7/6/2016	36694	Copper	0.1	1.3	ppm
053-03A Sink Faucet in Janitor Closet by Boiler	6/30/2016 20:14	7/6/2016	36694	Lead	1	15	ppb
053-04A Sink Faucet in Kitchen	6/30/2016 20:15	7/6/2016	36696	Copper	0.1	1.3	ppm
053-04A Sink Faucet in Kitchen	6/30/2016 20:15	7/6/2016	36696	Lead	5	15	ppb
053-05A Sink Faucet in Kitchen	6/30/2016 20:16	7/6/2016	36698	Copper	0.1	1.3	ppm
053-05A Sink Faucet in Kitchen	6/30/2016 20:16	7/6/2016	36698	Lead	2	15	ppb
053-06A Sink Faucet in Kitchen	6/30/2016 20:17	7/6/2016	36700	Copper	0.3	1.3	ppm
053-06A Sink Faucet in Kitchen	6/30/2016 20:17	7/6/2016	36700	Lead	3	15	ppb
053-07A Sink Faucet in Kitchen	6/30/2016 20:18	7/6/2016	36702	Copper	0.1	1.3	ppm
053-07A Sink Faucet in Kitchen	6/30/2016 20:18	7/6/2016	36702	Lead	ND	15	ppb
053-08A Sink Faucet in Bathroom of Kitchen	6/30/2016 20:20	7/6/2016	36704	Copper	0.3	1.3	ppm
053-08A Sink Faucet in Bathroom of Kitchen	6/30/2016 20:20	7/6/2016	36704	Lead	1	15	ppb
053-09A Kitchen Sink Faucet	6/30/2016 20:17	7/6/2016	36706	Copper	ND	1.3	ppm
053-09A Kitchen Sink Faucet	6/30/2016 20:17	7/6/2016	36706	Lead	2	15	ppb
053-10A Sink Faucet in Room 147	6/30/2016 20:22	7/6/2016	36708	Copper	0.4	1.3	ppm
053-10A Sink Faucet in Room 147	6/30/2016 20:22	7/6/2016	36708	Lead	11	15	ppb
053-11A Drinking Fountain in Room 147	6/30/2016 20:22	7/6/2016	36710	Copper	ND	1.3	ppm
053-11A Drinking Fountain in Room 147	6/30/2016 20:22	7/6/2016	36710	Lead	6	15	ppb
053-12A Drinking Fountain in Gym	6/30/2016 20:24	7/6/2016	36712	Copper	0.4	1.3	ppm
053-12A Drinking Fountain in Gym	6/30/2016 20:24	7/6/2016	36712	Lead	ND	15	ppb
053-13A Drinking Fountain in Gym	6/30/2016 20:27	7/6/2016	36714	Copper	0.2	1.3	ppm
053-13A Drinking Fountain in Gym	6/30/2016 20:27	7/6/2016	36714	Lead	ND	15	ppb
053-14A Sink Faucet in Girls Restroom by Gym	6/30/2016 20:30	7/6/2016	36716	Copper	0.1	1.3	ppm
053-14A Sink Faucet in Girls Restroom by Gym	6/30/2016 20:30	7/6/2016	36716	Lead	1	15	ppb
053-15A Spigot in Girls Restroom by Gym	6/30/2016 20:31	7/8/2016	36718	Copper	0.4	1.3	ppm
053-15A Spigot in Girls Restroom by Gym	6/30/2016 20:31	7/8/2016	36718	Lead	260	15	ppb
053-16A Drinking Fountain in Closet in Girls Restroom	6/30/2016 20:38	7/6/2016	36720	Copper	0.3	1.3	ppm
053-16A Drinking Fountain in Closet in Girls Restroom	6/30/2016 20:38	7/6/2016	36720	Lead	59	15	ppb
053-17A Sink Faucet in Custodian Room	6/30/2016 20:40	7/6/2016	36722	Copper	0.2	1.3	ppm
053-17A Sink Faucet in Custodian Room	6/30/2016 20:40	7/6/2016	36722	Lead	5	15	ppb
053-18A Sink Faucet in Boys Restroom of Gym	6/30/2016 20:42	7/6/2016	36724	Copper	0.2	1.3	ppm
053-18A Sink Faucet in Boys Restroom of Gym	6/30/2016 20:42	7/6/2016	36724	Lead	3	15	ppb
053-19A Spigot in Boys Restroom	6/30/2016 20:44	7/8/2016	36726	Copper	1.30	1.3	ppm
053-19A Spigot in Boys Restroom	6/30/2016 20:44	7/8/2016	36726	Lead	2023	15	ppb
053-20A Sink Faucet in Room 130	6/30/2016 20:50	7/6/2016	36728	Copper	0.2	1.3	ppm
053-20A Sink Faucet in Room 130	6/30/2016 20:50	7/6/2016	36728	Lead	11	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Lane Middle School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
053-21A Drinking Fountain in Room 130	6/30/2016 20:50	7/6/2016	36730	Copper	ND	1.3	ppm
053-21A Drinking Fountain in Room 130	6/30/2016 20:50	7/6/2016	36730	Lead	ND	15	ppb
053-22A Drinking Fountain in Room 131	6/30/2016 20:52	7/6/2016	36732	Copper	ND	1.3	ppm
053-22A Drinking Fountain in Room 131	6/30/2016 20:52	7/6/2016	36732	Lead	ND	15	ppb
053-23A Sink Faucet in Room 131 Purse Pt	6/30/2016 20:52	7/6/2016	36734	Copper	0.1	1.3	ppm
053-23A Sink Faucet in Room 131 Purse Pt	6/30/2016 20:52	7/6/2016	36734	Lead	4	15	ppb
053-24A Sink Faucet in Room 128	6/30/2016 20:54	7/6/2016	36736	Copper	ND	1.3	ppm
053-24A Sink Faucet in Room 128	6/30/2016 20:54	7/6/2016	36736	Lead	ND	15	ppb
053-25A Drinking Fountain in Room 128	6/30/2016 20:54	7/6/2016	36738	Copper	ND	1.3	ppm
053-25A Drinking Fountain in Room 128	6/30/2016 20:54	7/6/2016	36738	Lead	2	15	ppb
053-26A Sink Faucet in Room 129	6/30/2016 20:56	7/6/2016	36740	Copper	ND	1.3	ppm
053-26A Sink Faucet in Room 129	6/30/2016 20:56	7/6/2016	36740	Lead	2	15	ppb
053-27A Drinking Fountain in Room 129	6/30/2016 20:56	7/6/2016	36742	Copper	ND	1.3	ppm
053-27A Drinking Fountain in Room 129	6/30/2016 20:56	7/6/2016	36742	Lead	ND	15	ppb
053-28A Sink Faucet in Room 126	6/30/2016 20:58	7/6/2016	36744	Copper	ND	1.3	ppm
053-28A Sink Faucet in Room 126	6/30/2016 20:58	7/6/2016	36744	Lead	ND	15	ppb
053-29A Sink Faucet in Room 127	6/30/2016 20:58	7/8/2016	36746	Copper	0.2	1.3	ppm
053-29A Sink Faucet in Room 127	6/30/2016 20:58	7/8/2016	36746	Lead	52	15	ppb
053-30A Sink Faucet in Room 127	6/30/2016 20:58	7/8/2016	36748	Copper	0.4	1.3	ppm
053-30A Sink Faucet in Room 127	6/30/2016 20:58	7/8/2016	36748	Lead	61	15	ppb
053-31A Eye Wash Station in Room 127	6/30/2016 20:59	7/6/2016	36750	Copper	0.1	1.3	ppm
053-31A Eye Wash Station in Room 127	6/30/2016 20:59	7/6/2016	36750	Lead	2	15	ppb
053-32A Sink Faucet in Room 123	6/30/2016 21:01	7/6/2016	36752	Copper	ND	1.3	ppm
053-32A Sink Faucet in Room 123	6/30/2016 21:01	7/6/2016	36752	Lead	14	15	ppb
053-33A Drinking Fountain in Room 123	6/30/2016 21:01	7/6/2016	36754	Copper	ND	1.3	ppm
053-33A Drinking Fountain in Room 123	6/30/2016 21:01	7/6/2016	36754	Lead	41	15	ppb
053-34A Sink Faucet in Boys Restroom by Room 123	6/30/2016 21:03	7/6/2016	36756	Copper	ND	1.3	ppm
053-34A Sink Faucet in Boys Restroom by Room 123	6/30/2016 21:03	7/6/2016	36756	Lead	12	15	ppb
053-35A Sink Faucet in Boys Restroom by Room 123	6/30/2016 21:03	7/6/2016	36758	Copper	ND	1.3	ppm
053-35A Sink Faucet in Boys Restroom by Room 123	6/30/2016 21:03	7/6/2016	36758	Lead	1	15	ppb
053-36A Sink Faucet in Janitor Closet	6/30/2016 21:05	7/6/2016	36760	Copper	0.1	1.3	ppm
053-36A Sink Faucet in Janitor Closet	6/30/2016 21:05	7/6/2016	36760	Lead	7	15	ppb
053-37A Sink Faucet in Girls Restroom	6/30/2016 21:06	7/6/2016	36762	Copper	ND	1.3	ppm
053-37A Sink Faucet in Girls Restroom	6/30/2016 21:06	7/6/2016	36762	Lead	ND	15	ppb
053-38A Sink Faucet in Girls Restroom	6/30/2016 21:06	7/6/2016	36764	Copper	0.1	1.3	ppm
053-38A Sink Faucet in Girls Restroom	6/30/2016 21:06	7/6/2016	36764	Lead	6	15	ppb
053-39A Drinking Fountain in 1st Floor Hall	6/30/2016 21:08	7/6/2016	36766	Copper	0.7	1.3	ppm
053-39A Drinking Fountain in 1st Floor Hall	6/30/2016 21:08	7/6/2016	36766	Lead	1	15	ppb
053-40A Sink Faucet in Room 107 Bathroom	6/30/2016 21:10	7/6/2016	36768	Copper	0.4	1.3	ppm
053-40A Sink Faucet in Room 107 Bathroom	6/30/2016 21:10	7/6/2016	36768	Lead	3	15	ppb
053-41A Spigot in Room 107 Bathroom	6/30/2016 21:12	7/8/2016	36770	Copper	3.7	1.3	ppm
053-41A Spigot in Room 107 Bathroom	6/30/2016 21:12	7/8/2016	36770	Lead	595	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Lane Middle School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
053-42A Sink Faucet in Bathroom of Room 103	6/30/2016 21:15	7/6/2016	36772	Copper	0.3	1.3	ppm
053-42A Sink Faucet in Bathroom of Room 103	6/30/2016 21:15	7/6/2016	36772	Lead	7	15	ppb
053-43A Sink Faucet in Bathroom of Room 103	6/30/2016 21:14	7/6/2016	36774	Copper	0.5	1.3	ppm
053-43A Sink Faucet in Bathroom of Room 103	6/30/2016 21:14	7/6/2016	36774	Lead	3	15	ppb
053-44A Spigot in Room 103	6/30/2016 21:16	7/8/2016	36776	Copper	18.6	1.3	ppm
053-44A Spigot in Room 103	6/30/2016 21:16	7/8/2016	36776	Lead	2849	15	ppb
053-45A Sink Faucet in Room 102	6/30/2016 21:18	7/6/2016	36778	Copper	0.4	1.3	ppm
053-45A Sink Faucet in Room 102	6/30/2016 21:18	7/6/2016	36778	Lead	10	15	ppb
053-46A Sink Faucet in Room 168 Bathroom	6/30/2016 21:20	7/6/2016	36780	Copper	0.1	1.3	ppm
053-46A Sink Faucet in Room 168 Bathroom	6/30/2016 21:20	7/6/2016	36780	Lead	13	15	ppb
053-47A Drinking Fountain Next to Room 169	6/30/2016 21:22	7/6/2016	36782	Copper	0.1	1.3	ppm
053-47A Drinking Fountain Next to Room 169	6/30/2016 21:22	7/6/2016	36782	Lead	ND	15	ppb
053-48A Sink Faucet in Room 170	6/30/2016 21:22	7/6/2016	36784	Copper	0.2	1.3	ppm
053-48A Sink Faucet in Room 170	6/30/2016 21:22	7/6/2016	36784	Lead	9	15	ppb
053-49A Spigot Outside Room 169	6/30/2016 21:24	7/6/2016	36786	Copper	0.1	1.3	ppm
053-49A Spigot Outside Room 169	6/30/2016 21:24	7/6/2016	36786	Lead	15.0	15	ppb
053-50A Sink Faucet in Boys Restroom 1st Floor	6/30/2016 21:28	7/6/2016	36788	Copper	0.3	1.3	ppm
053-50A Sink Faucet in Boys Restroom 1st Floor	6/30/2016 21:28	7/6/2016	36788	Lead	5	15	ppb
053-51A Sink Faucet in Boys Restroom 1st Floor	6/30/2016 21:28	7/6/2016	36790	Copper	0.2	1.3	ppm
053-51A Sink Faucet in Boys Restroom 1st Floor	6/30/2016 21:28	7/6/2016	36790	Lead	6	15	ppb
053-52A Spigot in Boys Restroom	6/30/2016 21:29	7/7/2016	36792	Copper	1.8	1.3	ppm
053-52A Spigot in Boys Restroom	6/30/2016 21:29	7/6/2016	36792	Lead	64	15	ppb
053-53A Sink Faucet in Girls Restroom	6/30/2016 21:31	7/6/2016	36794	Copper	0.2	1.3	ppm
053-53A Sink Faucet in Girls Restroom	6/30/2016 21:31	7/6/2016	36794	Lead	1	15	ppb
053-54A Sink Faucet in Girls Restroom	6/30/2016 21:31	7/6/2016	36796	Copper	0.3	1.3	ppm
053-54A Sink Faucet in Girls Restroom	6/30/2016 21:31	7/6/2016	36796	Lead	3	15	ppb
053-55A Spigot in Girls Restroom	6/30/2016 21:32	7/6/2016	36798	Copper	0.2	1.3	ppm
053-55A Spigot in Girls Restroom	6/30/2016 21:32	7/6/2016	36798	Lead	9	15	ppb
053-56A Janitor Closet by Restroom	6/30/2016 21:34	7/6/2016	36800	Copper	0.3	1.3	ppm
053-56A Janitor Closet by Restroom	6/30/2016 21:34	7/6/2016	36800	Lead	12	15	ppb
053-57A Sink Faucet in Room 184	6/30/2016 21:36	7/8/2016	36802	Copper	3.3	1.3	ppm
053-57A Sink Faucet in Room 184	6/30/2016 21:36	7/8/2016	36802	Lead	270	15	ppb
053-58A Sink Faucet in Room 184	6/30/2016 21:36	7/8/2016	36804	Copper	1.4	1.3	ppm
053-58A Sink Faucet in Room 184	6/30/2016 21:36	7/8/2016	36804	Lead	75	15	ppb
053-59A Sink Faucet in Room 184	6/30/2016 21:36	7/8/2016	36806	Copper	2	1.3	ppm
053-59A Sink Faucet in Room 184	6/30/2016 21:36	7/8/2016	36806	Lead	149	15	ppb
053-60A Sink Faucet in Room 184	6/30/2016 21:37	7/6/2016	36808	Copper	ND	1.3	ppm
053-60A Sink Faucet in Room 184	6/30/2016 21:37	7/6/2016	36808	Lead	3	15	ppb
053-61A Sink Faucet in Room 183	6/30/2016 21:43	7/6/2016	36810	Copper	0.5	1.3	ppm
053-61A Sink Faucet in Room 183	6/30/2016 21:43	7/6/2016	36810	Lead	8	15	ppb
053-62A Sink Faucet in Room 183	6/30/2016 21:43	7/6/2016	36812	Copper	0.8	1.3	ppm
053-62A Sink Faucet in Room 183	6/30/2016 21:43	7/6/2016	36812	Lead	16	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Lane Middle School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
053-63A Sink Faucet in Room 183	6/30/2016 21:44	7/6/2016	36814	Copper	0.4	1.3	ppm
053-63A Sink Faucet in Room 183	6/30/2016 21:44	7/6/2016	36814	Lead	8	15	ppb
053-64A Sink Faucet in Room 183	6/30/2016 21:44	7/6/2016	36816	Copper	0.5	1.3	ppm
053-64A Sink Faucet in Room 183	6/30/2016 21:44	7/6/2016	36816	Lead	7	15	ppb
053-65A Sink Faucet in Room 186	6/30/2016 21:48	7/6/2016	36818	Copper	0.3	1.3	ppm
053-65A Sink Faucet in Room 186	6/30/2016 21:48	7/6/2016	36818	Lead	7	15	ppb
053-66A Sink Faucet in Room School Nurse Office	6/30/2016 21:50	7/6/2016	36820	Copper	0.3	1.3	ppm
053-66A Sink Faucet in Room School Nurse Office	6/30/2016 21:50	7/6/2016	36820	Lead	8	15	ppb
053-67A Restroom Sink Faucet Inside Nurse Office	6/30/2016 21:52	7/6/2016	36822	Copper	0.5	1.3	ppm
053-67A Restroom Sink Faucet Inside Nurse Office	6/30/2016 21:52	7/6/2016	36822	Lead	1	15	ppb
053-68A Sink Faucet Inside School Nurse Office	6/30/2016 21:54	7/8/2016	36824	Copper	0.8	1.3	ppm
053-68A Sink Faucet Inside School Nurse Office	6/30/2016 21:54	7/8/2016	36824	Lead	22	15	ppb
053-69A Sink Faucet Inside School Nurse Office	6/30/2016 21:54	7/6/2016	36826	Copper	0.3	1.3	ppm
053-69A Sink Faucet Inside School Nurse Office	6/30/2016 21:54	7/6/2016	36826	Lead	25	15	ppb
053-70A Eye Wash Station	6/30/2016 21:55	7/6/2016	36828	Copper	0.2	1.3	ppm
053-70A Eye Wash Station	6/30/2016 21:55	7/6/2016	36828	Lead	3	15	ppb
053-71A Sink Faucet in Nurse Area	6/30/2016 21:57	7/6/2016	36830	Copper	0.3	1.3	ppm
053-71A Sink Faucet in Nurse Area	6/30/2016 21:57	7/6/2016	36830	Lead	13	15	ppb
053-72A Sink Faucet in Nurse Area	6/30/2016 21:58	7/6/2016	36832	Copper	0.1	1.3	ppm
053-72A Sink Faucet in Nurse Area	6/30/2016 21:58	7/6/2016	36832	Lead	8	15	ppb
053-73A Janitor Sink	6/30/2016 21:59	7/6/2016	36834	Copper	ND	1.3	ppm
053-73A Janitor Sink	6/30/2016 21:59	7/6/2016	36834	Lead	2	15	ppb
053-74A Spigot in Janitor Closet	6/30/2016 22:00	7/8/2016	36836	Copper	27.9	1.3	ppm
053-74A Spigot in Janitor Closet	6/30/2016 22:00	7/8/2016	36836	Lead	1333	15	ppb
053-75A Sink Faucet in Room 160A	6/30/2016 22:09	7/6/2016	36838	Copper	0.3	1.3	ppm
053-75A Sink Faucet in Room 160A	6/30/2016 22:09	7/6/2016	36838	Lead	6	15	ppb
053-76A Sink Faucet in Janitor Room 187	6/30/2016 22:12	7/6/2016	36840	Copper	0.2	1.3	ppm
053-76A Sink Faucet in Janitor Room 187	6/30/2016 22:12	7/6/2016	36840	Lead	ND	15	ppb
053-77A Sink Faucet in Staff Restroom by Room 192	6/30/2016 22:14	7/6/2016	36842	Copper	0.3	1.3	ppm
053-77A Sink Faucet in Staff Restroom by Room 192	6/30/2016 22:14	7/6/2016	36842	Lead	3	15	ppb
053-78A Spigot in staff Restroom by Room 192	6/30/2016 22:16	7/8/2016	36844	Copper	0.9	1.3	ppm
053-78A Spigot in staff Restroom by Room 192	6/30/2016 22:16	7/8/2016	36844	Lead	134	15	ppb
053-79A Sink Faucet in Room 192	6/30/2016 22:15	7/6/2016	36846	Copper	0.3	1.3	ppm
053-79A Sink Faucet in Room 192	6/30/2016 22:15	7/6/2016	36846	Lead	2	15	ppb
053-80A Sink Faucet in Girls Restroom 191	6/30/2016 22:18	7/6/2016	36848	Copper	ND	1.3	ppm
053-80A Sink Faucet in Girls Restroom 191	6/30/2016 22:18	7/6/2016	36848	Lead	20	15	ppb
053-81A Sink Faucet in Girls Restroom 191	6/30/2016 22:18	7/6/2016	36850	Copper	ND	1.3	ppm
053-81A Sink Faucet in Girls Restroom 191	6/30/2016 22:18	7/6/2016	36850	Lead	31	15	ppb
053-82A Sink Faucet in Boys Restroom 194	6/30/2016 22:20	7/6/2016	36852	Copper	ND	1.3	ppm
053-82A Sink Faucet in Boys Restroom 194	6/30/2016 22:20	7/6/2016	36852	Lead	20	15	ppb
053-83A Sink Faucet in Boys Restroom 194	6/30/2016 22:20	7/6/2016	36854	Copper	ND	1.3	ppm
053-83A Sink Faucet in Boys Restroom 194	6/30/2016 22:20	7/6/2016	36854	Lead	8	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Lane Middle School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
053-84A Spigot in Boys Restroom 194	6/30/2016 22:22	7/6/2016	36856	Copper	0.2	1.3	ppm
053-84A Spigot in Boys Restroom 194	6/30/2016 22:22	7/6/2016	36856	Lead	70	15	ppb
053-85A Sink Faucet in Room 196	6/30/2016 22:25	7/6/2016	36858	Copper	0.1	1.3	ppm
053-85A Sink Faucet in Room 196	6/30/2016 22:25	7/6/2016	36858	Lead	2	15	ppb
053-86A Drinking Fountain in Room 196	6/30/2016 22:27	7/6/2016	36860	Copper	ND	1.3	ppm
053-86A Drinking Fountain in Room 196	6/30/2016 22:27	7/6/2016	36860	Lead	ND	15	ppb
053-87A Sink Faucet in Room 193	6/30/2016 22:28	7/8/2016	36862	Copper	3.9	1.3	ppm
053-87A Sink Faucet in Room 193	6/30/2016 22:28	7/8/2016	36862	Lead	39	15	ppb
053-88A Sink Faucet in Room 193	6/30/2016 22:28	7/7/2016	36864	Copper	1.4	1.3	ppm
053-88A Sink Faucet in Room 193	6/30/2016 22:28	7/6/2016	36864	Lead	19	15	ppb
053-89A Sink Faucet in Room 193	6/30/2016 22:28	7/7/2016	36866	Copper	1.30	1.3	ppm
053-89A Sink Faucet in Room 193	6/30/2016 22:28	7/6/2016	36866	Lead	13	15	ppb
053-90A Sink Faucet in Room 193	6/30/2016 22:28	7/6/2016	36868	Copper	0.7	1.3	ppm
053-90A Sink Faucet in Room 193	6/30/2016 22:28	7/6/2016	36868	Lead	7	15	ppb
053-91A Eye Wash in Room 193	6/30/2016 22:29	7/6/2016	36870	Copper	0.3	1.3	ppm
053-91A Eye Wash in Room 193	6/30/2016 22:29	7/6/2016	36870	Lead	1	15	ppb
053-92A Drinking Fountain Outside Room 195	6/30/2016 22:32	7/6/2016	36872	Copper	ND	1.3	ppm
053-92A Drinking Fountain Outside Room 195	6/30/2016 22:32	7/6/2016	36872	Lead	13	15	ppb
053-93A Sink Faucet in Room 195	6/30/2016 22:33	7/7/2016	36874	Copper	1.6	1.3	ppm
053-93A Sink Faucet in Room 195	6/30/2016 22:33	7/6/2016	36874	Lead	35	15	ppb
053-94A Sink Faucet in Room 195 Purse Pt	6/30/2016 22:33	7/6/2016	36876	Copper	0.4	1.3	ppm
053-94A Sink Faucet in Room 195 Purse Pt	6/30/2016 22:33	7/6/2016	36876	Lead	7	15	ppb
053-95A Sink Faucet in Room 195	6/30/2016 22:34	7/7/2016	36878	Copper	1.7	1.3	ppm
053-95A Sink Faucet in Room 195	6/30/2016 22:34	7/6/2016	36878	Lead	16	15	ppb
053-96A Sink Faucet in Room 195	6/30/2016 22:34	7/6/2016	36880	Copper	0.6	1.3	ppm
053-96A Sink Faucet in Room 195	6/30/2016 22:34	7/6/2016	36880	Lead	3	15	ppb
053-97A Sink Faucet in Room 195	6/30/2016 22:34	7/6/2016	36882	Copper	0.5	1.3	ppm
053-97A Sink Faucet in Room 195	6/30/2016 22:34	7/6/2016	36882	Lead	1	15	ppb
053-98A Sink Faucet in Storage Room #197	6/30/2016 22:36	7/8/2016	36884	Copper	37.3	1.3	ppm
053-98A Sink Faucet in Storage Room #197	6/30/2016 22:36	7/8/2016	36884	Lead	150	15	ppb
053-99A Eye Wash Station in Room 197	6/30/2016 22:37	7/8/2016	36886	Copper	13	1.3	ppm
053-99A Eye Wash Station in Room 197	6/30/2016 22:37	7/8/2016	36886	Lead	219	15	ppb
053-100A Drinking Fountain in Hall Across Restroom	6/30/2016 22:43	7/7/2016	36888	Copper	3	1.3	ppm
053-100A Drinking Fountain in Hall Across Restroom	6/30/2016 22:43	7/6/2016	36888	Lead	ND	15	ppb
053-101A Bbottle Refill Across Restroom	6/30/2016 22:43	7/7/2016	36890	Copper	2.3	1.3	ppm
053-101A Bbottle Refill Across Restroom	6/30/2016 22:43	7/6/2016	36890	Lead	ND	15	ppb
053-102A Sink Faucet in Girls Restroom	6/30/2016 22:43	7/6/2016	36892	Copper	0.3	1.3	ppm
053-102A Sink Faucet in Girls Restroom	6/30/2016 22:43	7/6/2016	36892	Lead	4	15	ppb
053-103A Sink Faucet in Girls Restroom	6/30/2016 22:44	7/6/2016	36894	Copper	0.6	1.3	ppm
053-103A Sink Faucet in Girls Restroom	6/30/2016 22:44	7/6/2016	36894	Lead	4	15	ppb
053-104A Spigot in Girls Restroom	6/30/2016 22:44	7/8/2016	36896	Copper	1.1	1.3	ppm
053-104A Spigot in Girls Restroom	6/30/2016 22:44	7/8/2016	36896	Lead	444	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Lane Middle School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
053-105A Sink Faucet in Janitors Closet by Restroom	6/30/2016 22:48	7/6/2016	36898	Copper	ND	1.3	ppm
053-105A Sink Faucet in Janitors Closet by Restroom	6/30/2016 22:48	7/6/2016	36898	Lead	ND	15	ppb
053-106A Sink Faucet in Boys Restroom	6/30/2016 22:49	7/6/2016	36900	Copper	0.3	1.3	ppm
053-106A Sink Faucet in Boys Restroom	6/30/2016 22:49	7/6/2016	36900	Lead	4	15	ppb
053-107A Sink Faucet in Boys Restroom	6/30/2016 22:49	7/6/2016	36902	Copper	0.4	1.3	ppm
053-107A Sink Faucet in Boys Restroom	6/30/2016 22:49	7/6/2016	36902	Lead	4	15	ppb
053-108A Spigot in Boys Restroom	6/30/2016 22:50	7/8/2016	36904	Copper	0.9	1.3	ppm
053-108A Spigot in Boys Restroom	6/30/2016 22:50	7/8/2016	36904	Lead	481	15	ppb
053-109A Sink Faucet in Room 216	6/30/2016 22:48	7/6/2016	36906	Copper	0.2	1.3	ppm
053-109A Sink Faucet in Room 216	6/30/2016 22:48	7/6/2016	36906	Lead	22	15	ppb
053-110A Drinking Fountain in Hall by Room 204	6/30/2016 22:25	7/7/2016	36908	Copper	1.2	1.3	ppm
053-110A Drinking Fountain in Hall by Room 204	6/30/2016 22:25	7/6/2016	36908	Lead	ND	15	ppb
053-111A Botte Refill by Room 204	6/30/2016 22:51	7/6/2016	36910	Copper	0.7	1.3	ppm
053-111A Botte Refill by Room 204	6/30/2016 22:51	7/6/2016	36910	Lead	1	15	ppb
053-112A Sink Faucet in Bathroom of Room 204	6/30/2016 22:51	7/8/2016	36912	Copper	0.1	1.3	ppm
053-112A Sink Faucet in Bathroom of Room 204	6/30/2016 22:51	7/8/2016	36912	Lead	29	15	ppb
053-113A Spigot by North Exit	6/30/2016 23:01	7/6/2016	36914	Copper	ND	1.3	ppm
053-113A Spigot by North Exit	6/30/2016 23:01	7/6/2016	36914	Lead	14	15	ppb
053-114A Spigot by North Wall of Gym	6/30/2016 23:05	7/6/2016	36916	Copper	0.2	1.3	ppm
053-114A Spigot by North Wall of Gym	6/30/2016 23:05	7/6/2016	36916	Lead	7	15	ppb
053-115A Spigot by North Eastern Wall by Room 193	6/30/2016 23:09	7/8/2016	36918	Copper	0.2	1.3	ppm
053-115A Spigot by North Eastern Wall by Room 193	6/30/2016 23:09	7/8/2016	36918	Lead	144	15	ppb
053-116A Spigot by Room 196	6/30/2016 23:14	7/6/2016	36920	Copper	ND	1.3	ppm
053-116A Spigot by Room 196	6/30/2016 23:14	7/6/2016	36920	Lead	3	15	ppb
053-117A Spigot by Room 192	6/30/2016 23:27	7/6/2016	36922	Copper	ND	1.3	ppm
053-117A Spigot by Room 192	6/30/2016 23:27	7/6/2016	36922	Lead	36	15	ppb
053-118A Spigot by Room 186	6/30/2016 23:31	7/6/2016	36924	Copper	0.2	1.3	ppm
053-118A Spigot by Room 186	6/30/2016 23:31	7/6/2016	36924	Lead	99	15	ppb
053-119A Spigot by West Wall Room 119	6/30/2016 23:34	7/6/2016	36926	Copper	ND	1.3	ppm
053-119A Spigot by West Wall Room 119	6/30/2016 23:34	7/6/2016	36926	Lead	21	15	ppb

EPA Action Level for Lead of 15 ppb
EPA Action Level for Copper of 1.3 ppm

ND = Non detect

Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.