

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Laurelhurst Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
054-01A Boiler Room Sink Faucet	6/27/2016 21:36	7/6/2016 13:35	10354048001	Copper	0.0	1.3	ppm
054-01A Boiler Room Sink Faucet	6/27/2016 21:36	7/6/2016 13:35	10354048001	Lead	4	15	ppb
054-02A Boiler Room Water Spigot	6/27/2016 21:38	7/8/2016 00:12	10354048003	Copper	0.0	1.3	ppm
054-02A Boiler Room Water Spigot	6/27/2016 21:38	7/8/2016 00:12	10354048003	Lead	2	15	ppb
054-03A Generator Room Water Spigot	6/27/2016 21:44	7/8/2016 00:17	10354048005	Copper	0.0	1.3	ppm
054-03A Generator Room Water Spigot	6/27/2016 21:44	7/8/2016 00:17	10354048005	Lead	5	15	ppb
054-04A Media Center Library Sink Faucet	6/27/2016 21:49	7/8/2016 09:00	10354048007	Copper	0.6	1.3	ppm
054-04A Media Center Library Sink Faucet	6/27/2016 21:49	7/8/2016 00:18	10354048007	Lead	4	15	ppb
054-05A Faculty Bathroom Sink Faucet	6/27/2016 21:54	7/8/2016 00:20	10354048009	Copper	0.0	1.3	ppm
054-05A Faculty Bathroom Sink Faucet	6/27/2016 21:54	7/8/2016 00:20	10354048009	Lead	51	15	ppb
054-06A Music Room Sink Faucet	6/27/2016 21:58	7/8/2016 00:21	10354048011	Copper	0.4	1.3	ppm
054-06A Music Room Sink Faucet	6/27/2016 21:58	7/8/2016 00:21	10354048011	Lead	9	15	ppb
054-07A Math Room Sink Faucet (Faculty Room)	6/27/2016 22:00	7/8/2016 00:23	10354048013	Copper	0.2	1.3	ppm
054-07A Math Room Sink Faucet (Faculty Room)	6/27/2016 22:00	7/8/2016 00:23	10354048013	Lead	4	15	ppb
054-08A Math Room Drinking Fountain (Faculty Room)	6/27/2016 22:02	7/6/2016 13:37	10354048015	Copper	0.0	1.3	ppm
054-08A Math Room Drinking Fountain (Faculty Room)	6/27/2016 22:02	7/6/2016 13:37	10354048015	Lead	18	15	ppb
054-09A Classroom 4 Sink Faucet	6/27/2016 22:05	7/8/2016 00:24	10354048017	Copper	0.1	1.3	ppm
054-09A Classroom 4 Sink Faucet	6/27/2016 22:05	7/8/2016 00:24	10354048017	Lead	3	15	ppb
054-10A Nurses Office Sink Faucet	6/27/2016 22:07	7/6/2016 13:39	10354048019	Copper	0.1	1.3	ppm
054-10A Nurses Office Sink Faucet	6/27/2016 22:07	7/6/2016 13:39	10354048019	Lead	3	15	ppb
054-11A Workroom (Office) Sink Faucet	6/27/2016 22:12	7/8/2016 00:28	10354048021	Copper	0.2	1.3	ppm
054-11A Workroom (Office) Sink Faucet	6/27/2016 22:12	7/8/2016 00:28	10354048021	Lead	19	15	ppb
054-12A Cafe/ Auditorium Drinking Fountain	6/27/2016 22:14	7/8/2016 09:01	10354048023	Copper	0.6	1.3	ppm
054-12A Cafe/ Auditorium Drinking Fountain	6/27/2016 22:14	7/8/2016 00:29	10354048023	Lead	1	15	ppb
054-13A Kitchen Dishwash Sink Faucet	6/27/2016 22:16	7/6/2016 13:41	10354048025	Copper	0.3	1.3	ppm
054-13A Kitchen Dishwash Sink Faucet	6/27/2016 22:16	7/6/2016 13:41	10354048025	Lead	3	15	ppb
054-14A Kitchen Food Preparation Sink Faucet	6/27/2016 22:19	7/8/2016 00:31	10354048027	Copper	0.2	1.3	ppm
054-14A Kitchen Food Preparation Sink Faucet	6/27/2016 22:19	7/8/2016 00:31	10354048027	Lead	1	15	ppb
054-15A Kitchen Handwash Sink Faucet	6/27/2016 22:21	7/8/2016 00:32	10354048029	Copper	0.2	1.3	ppm
054-15A Kitchen Handwash Sink Faucet	6/27/2016 22:21	7/8/2016 00:32	10354048029	Lead	12	15	ppb

Analysis by: Grant's Pass

Reviewed by: TRC Environmental Corp

1 of 6

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Laurelhurst Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
054-16A Faculty Bathroom Sink Faucet	6/27/2016 22:23	7/8/2016 00:35	10354048031	Copper	0.1	1.3	ppm
054-16A Faculty Bathroom Sink Faucet	6/27/2016 22:23	7/8/2016 00:35	10354048031	Lead	1	15	ppb
054-17A Boys Bathroom Sink Faucet #1	6/27/2016 22:26	7/8/2016 00:36	10354048033	Copper	0.1	1.3	ppm
054-17A Boys Bathroom Sink Faucet #1	6/27/2016 22:26	7/8/2016 00:36	10354048033	Lead	5	15	ppb
054-18A Boys Bathroom Sink Faucet #2	6/27/2016 22:27	7/8/2016 00:38	10354048035	Copper	0.0	1.3	ppm
054-18A Boys Bathroom Sink Faucet #2	6/27/2016 22:27	7/8/2016 00:38	10354048035	Lead	2	15	ppb
054-19A Boys Bathroom Sink Faucet #3	6/27/2016 22:29	7/8/2016 00:39	10354048037	Copper	0.2	1.3	ppm
054-19A Boys Bathroom Sink Faucet #3	6/27/2016 22:29	7/8/2016 00:39	10354048037	Lead	7	15	ppb
054-20A Boys Bathroom Sink Faucet #4	6/27/2016 22:30	7/8/2016 00:40	10354048039	Copper	0.0	1.3	ppm
054-20A Boys Bathroom Sink Faucet #4	6/27/2016 22:30	7/8/2016 00:40	10354048039	Lead	7	15	ppb
054-21A Boys Bathroom Water Spigot	6/27/2016 22:32	7/6/2016 14:15	10354048041	Copper	3.6	1.3	ppm
054-21A Boys Bathroom Water Spigot	6/27/2016 22:32	7/6/2016 14:15	10354048041	Lead	629	15	ppb
054-22A Custodial Mop Sink	6/27/2016 22:34	7/7/2016 03:19	10354048043	Copper	0.1	1.3	ppm
054-22A Custodial Mop Sink	6/27/2016 22:34	7/7/2016 03:19	10354048043	Lead	3	15	ppb
054-23A Drinking Fountain #1	6/27/2016 22:39	7/7/2016 03:27	10354048045	Copper	0.1	1.3	ppm
054-23A Drinking Fountain #1	6/27/2016 22:39	7/7/2016 03:27	10354048045	Lead	3	15	ppb
054-24A Drinking Fountain #2	6/27/2016 22:40	7/7/2016 03:28	10354048047	Copper	0.2	1.3	ppm
054-24A Drinking Fountain #2	6/27/2016 22:40	7/7/2016 03:28	10354048047	Lead	1	15	ppb
054-25A Drinking Fountain #3	6/27/2016 22:41	7/7/2016 03:30	10354048049	Copper	0.4	1.3	ppm
054-25A Drinking Fountain #3	6/27/2016 22:41	7/7/2016 03:30	10354048049	Lead	2	15	ppb
054-26A Faculty Bathroom Sink Faucet	6/27/2016 22:43	7/7/2016 20:23	10354048051	Copper	0.5	1.3	ppm
054-26A Faculty Bathroom Sink Faucet	6/27/2016 22:43	7/7/2016 03:31	10354048051	Lead	8	15	ppb
054-27A Storage/ Fire Alarm Room Sink Faucet	6/27/2016 22:45	7/7/2016 03:33	10354048053	Copper	0.2	1.3	ppm
054-27A Storage/ Fire Alarm Room Sink Faucet	6/27/2016 22:45	7/7/2016 03:33	10354048053	Lead	18	15	ppb
054-28A Drinking Fountain #4	6/27/2016 22:50	7/7/2016 03:34	10354048055	Copper	0.0	1.3	ppm
054-28A Drinking Fountain #4	6/27/2016 22:50	7/7/2016 03:34	10354048055	Lead	5	15	ppb
054-29A Drinking Fountain #5	6/27/2016 22:52	7/7/2016 03:35	10354048057	Copper	0.1	1.3	ppm
054-29A Drinking Fountain #5	6/27/2016 22:52	7/7/2016 03:35	10354048057	Lead	5	15	ppb
054-30A Drinking Fountain #6	6/27/2016 22:55	7/7/2016 03:37	10354048059	Copper	0.0	1.3	ppm
054-30A Drinking Fountain #6	6/27/2016 22:55	7/7/2016 03:37	10354048059	Lead	5	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Laurelhurst Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
054-31A Drinking Fountain #7	6/27/2016 22:56	7/7/2016 03:38	10354048061	Copper	0.0	1.3	ppm
054-31A Drinking Fountain #7	6/27/2016 22:56	7/7/2016 03:38	10354048061	Lead	7	15	ppb
054-32A Drinking Fountain #8	6/27/2016 22:53	7/7/2016 03:42	10354048063	Copper	0.0	1.3	ppm
054-32A Drinking Fountain #8	6/27/2016 22:53	7/7/2016 03:42	10354048063	Lead	6	15	ppb
054-33A Drinking Fountain #9	6/27/2016 22:52	7/7/2016 03:45	10354048065	Copper	0.0	1.3	ppm
054-33A Drinking Fountain #9	6/27/2016 22:52	7/7/2016 03:45	10354048065	Lead	5	15	ppb
054-34A Girls Bathroom Sink Faucet #1	6/27/2016 23:02	7/7/2016 15:00	10354048067	Copper	1.5	1.3	ppm
054-34A Girls Bathroom Sink Faucet #1	6/27/2016 23:02	7/7/2016 12:13	10354048067	Lead	16	15	ppb
054-35A Girls Bathroom Sink Faucet #2	6/27/2016 23:04	7/6/2016 14:17	10354048069	Copper	1.1	1.3	ppm
054-35A Girls Bathroom Sink Faucet #2	6/27/2016 23:04	7/6/2016 13:44	10354048069	Lead	11	15	ppb
054-36A Girls Bathroom Sink Faucet #3	6/27/2016 23:03	7/7/2016 03:46	10354048071	Copper	0.2	1.3	ppm
054-36A Girls Bathroom Sink Faucet #3	6/27/2016 23:03	7/7/2016 03:46	10354048071	Lead	13	15	ppb
054-37A Girls Bathroom Sink Faucet #4	6/27/2016 23:02	7/6/2016 14:18	10354048073	Copper	2.3	1.3	ppm
054-37A Girls Bathroom Sink Faucet #4	6/27/2016 23:02	7/6/2016 13:46	10354048073	Lead	26	15	ppb
054-38A Girls Bathroom Water Spigot	6/27/2016 23:05	7/6/2016 14:20	10354048075	Copper	1.7	1.3	ppm
054-38A Girls Bathroom Water Spigot	6/27/2016 23:05	7/6/2016 13:48	10354048075	Lead	59	15	ppb
054-39A Classroom 7 Sink Faucet #1	6/27/2016 23:10	7/7/2016 03:48	10354048077	Copper	0.0	1.3	ppm
054-39A Classroom 7 Sink Faucet #1	6/27/2016 23:10	7/7/2016 03:48	10354048077	Lead	19	15	ppb
054-40A Classroom 7 Sink Faucet #2	6/27/2016 23:11	7/7/2016 03:49	10354048079	Copper	0.2	1.3	ppm
054-40A Classroom 7 Sink Faucet #2	6/27/2016 23:11	7/7/2016 03:49	10354048079	Lead	10	15	ppb
054-41A Classroom 7 Eyewash	6/27/2016 23:11	7/6/2016 14:21	10354048081	Copper	1.5	1.3	ppm
054-41A Classroom 7 Eyewash	6/27/2016 23:11	7/6/2016 13:56	10354048081	Lead	196	15	ppb
054-42A Classroom 7 Sink Faucet #3	6/27/2016 23:09	7/7/2016 22:50	10354048083	Copper	0.3	1.3	ppm
054-42A Classroom 7 Sink Faucet #3	6/27/2016 23:09	7/7/2016 22:50	10354048083	Lead	2	15	ppb
054-43A Gymnasium Drinking Fountain	6/27/2016 23:16	7/7/2016 22:55	10354048085	Copper	0.0	1.3	ppm
054-43A Gymnasium Drinking Fountain	6/27/2016 23:16	7/7/2016 22:55	10354048085	Lead	7	15	ppb
054-44A Gymnasium Office Drinking Fountain	6/27/2016 23:17	7/7/2016 22:57	10354048087	Copper	0.0	1.3	ppm
054-44A Gymnasium Office Drinking Fountain	6/27/2016 23:17	7/7/2016 22:57	10354048087	Lead	5	15	ppb
054-45A Classroom 10 Sink Faucet	6/27/2016 23:21	7/7/2016 22:58	10354048089	Copper	0.0	1.3	ppm
054-45A Classroom 10 Sink Faucet	6/27/2016 23:21	7/7/2016 22:58	10354048089	Lead	12	15	ppb

Analysis by: Grant's Pass

Reviewed by: TRC Environmental Corp

3 of 6

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Laurelhurst Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
054-46A Classroom 21 Sink Faucet	6/27/2016 23:25	7/7/2016 22:59	10354048091	Copper	0.0	1.3	ppm
054-46A Classroom 21 Sink Faucet	6/27/2016 23:25	7/7/2016 22:59	10354048091	Lead	12	15	ppb
054-47A Drinking Fountain #10	6/27/2016 23:29	7/7/2016 23:01	10354048093	Copper	0.1	1.3	ppm
054-47A Drinking Fountain #10	6/27/2016 23:29	7/7/2016 23:01	10354048093	Lead	10	15	ppb
054-48A Drinking Fountain #11	6/27/2016 23:30	7/7/2016 23:05	10354048095	Copper	0.2	1.3	ppm
054-48A Drinking Fountain #11	6/27/2016 23:30	7/7/2016 23:05	10354048095	Lead	8	15	ppb
054-49A Womens Bathroom Sink Faucet #1	6/27/2016 23:34	7/7/2016 23:06	10354048097	Copper	0.0	1.3	ppm
054-49A Womens Bathroom Sink Faucet #1	6/27/2016 23:34	7/7/2016 23:06	10354048097	Lead	4	15	ppb
054-50A Womens Bathroom Sink Faucet #2	6/27/2016 23:35	7/7/2016 23:08	10354048099	Copper	0.0	1.3	ppm
054-50A Womens Bathroom Sink Faucet #2	6/27/2016 23:35	7/7/2016 23:08	10354048099	Lead	5	15	ppb
054-51A Classroom 215 Sink Faucet #1	6/27/2016 23:51	7/7/2016 23:09	10354048101	Copper	0.1	1.3	ppm
054-51A Classroom 215 Sink Faucet #1	6/27/2016 23:51	7/7/2016 23:09	10354048101	Lead	34	15	ppb
054-52A Classroom 215 Sink Faucet #2	6/27/2016 22:48	7/7/2016 23:10	10354048103	Copper	0.3	1.3	ppm
054-52A Classroom 215 Sink Faucet #2	6/27/2016 22:48	7/7/2016 23:10	10354048103	Lead	7	15	ppb
054-53A Classroom 215 Eyewash	6/27/2016 23:50	7/6/2016 13:57	10354048105	Copper	0.4	1.3	ppm
054-53A Classroom 215 Eyewash	6/27/2016 23:50	7/6/2016 13:57	10354048105	Lead	68	15	ppb
054-54A Classroom 215 Sink Faucet #3	6/27/2016 23:47	7/7/2016 23:13	10354048107	Copper	0.3	1.3	ppm
054-54A Classroom 215 Sink Faucet #3	6/27/2016 23:47	7/7/2016 23:13	10354048107	Lead	2	15	ppb
054-55A Classroom 215 Sink Faucet #4	6/27/2016 23:46	7/7/2016 23:15	10354048109	Copper	0.1	1.3	ppm
054-55A Classroom 215 Sink Faucet #4	6/27/2016 23:46	7/7/2016 23:15	10354048109	Lead	12	15	ppb
054-56A Custodial 209 Sink Faucet	6/27/2016 23:56	7/7/2016 23:16	10354048111	Copper	0.3	1.3	ppm
054-56A Custodial 209 Sink Faucet	6/27/2016 23:56	7/7/2016 23:16	10354048111	Lead	8	15	ppb
054-57A Boys Bathroom 210 Sink Faucet #1	6/27/2016 23:39	7/7/2016 23:17	10354048113	Copper	0.0	1.3	ppm
054-57A Boys Bathroom 210 Sink Faucet #1	6/27/2016 23:39	7/7/2016 23:17	10354048113	Lead	4	15	ppb
054-58A Boys Bathroom 210 Sink Faucet #2	6/27/2016 23:40	7/7/2016 23:22	10354048115	Copper	0.0	1.3	ppm
054-58A Boys Bathroom 210 Sink Faucet #2	6/27/2016 23:40	7/7/2016 23:22	10354048115	Lead	8	15	ppb
054-59A Area 1 / Northwing Sink Faucet	6/27/2016 23:38	7/7/2016 23:23	10354048117	Copper	0.1	1.3	ppm
054-59A Area 1 / Northwing Sink Faucet	6/27/2016 23:38	7/7/2016 23:23	10354048117	Lead	5	15	ppb
054-60A Area 1 / Northwing Drinking Fountain	6/27/2016 23:35	7/7/2016 23:24	10354048119	Copper	0.0	1.3	ppm
054-60A Area 1 / Northwing Drinking Fountain	6/27/2016 23:35	7/7/2016 23:24	10354048119	Lead	4	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Laurelhurst Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
054-61A Classroom 111 Sink Faucet	6/27/2016 00:10	7/7/2016 03:56	10354048121	Copper	0.1	1.3	ppm
054-61A Classroom 111 Sink Faucet	6/27/2016 00:10	7/7/2016 03:56	10354048121	Lead	20	15	ppb
054-62A Classroom 111 Drinking Fountain	6/27/2016 00:12	7/7/2016 04:01	10354048123	Copper	0.0	1.3	ppm
054-62A Classroom 111 Drinking Fountain	6/27/2016 00:12	7/7/2016 04:01	10354048123	Lead	7	15	ppb
054-63A Classroom 112 Sink Faucet	6/27/2016 00:15	7/7/2016 18:16	10354048125	Copper	0.2	1.3	ppm
054-63A Classroom 112 Sink Faucet	6/27/2016 00:15	7/7/2016 18:16	10354048125	Lead	37	15	ppb
054-64A Classroom 112 Drinking Fountain	6/27/2016 00:17	7/7/2016 04:03	10354048127	Copper	0.0	1.3	ppm
054-64A Classroom 112 Drinking Fountain	6/27/2016 00:17	7/7/2016 04:03	10354048127	Lead	29	15	ppb
054-65A Girls Bathroom Sink Faucet #1	6/27/2016 00:19	7/8/2016 08:02	10354048129	Copper	1.2	1.3	ppm
054-65A Girls Bathroom Sink Faucet #1	6/27/2016 00:19	7/7/2016 18:17	10354048129	Lead	12	15	ppb
054-66A Girls Bathroom Sink Faucet #2	6/27/2016 00:21	7/7/2016 04:04	10354048131	Copper	0.3	1.3	ppm
054-66A Girls Bathroom Sink Faucet #2	6/27/2016 00:21	7/7/2016 04:04	10354048131	Lead	5	15	ppb
054-67A Girls Bathroom Water Spigot	6/27/2016 00:22	7/7/2016 04:06	10354048133	Copper	0.2	1.3	ppm
054-67A Girls Bathroom Water Spigot	6/27/2016 00:22	7/7/2016 04:06	10354048133	Lead	95	15	ppb
054-68A Teachers Bathroom Sink Faucet	6/27/2016 00:24	7/7/2016 15:02	10354048135	Copper	2.5	1.3	ppm
054-68A Teachers Bathroom Sink Faucet	6/27/2016 00:24	7/7/2016 12:16	10354048135	Lead	18	15	ppb
054-69A Custodial Closet Mop Sink Faucet	6/27/2016 00:27	7/7/2016 04:10	10354048137	Copper	0.1	1.3	ppm
054-69A Custodial Closet Mop Sink Faucet	6/27/2016 00:27	7/7/2016 04:10	10354048137	Lead	14.5	15	ppb
054-70A Boys Bathroom Sink Faucet #1	6/27/2016 00:29	7/7/2016 04:11	10354048139	Copper	0.2	1.3	ppm
054-70A Boys Bathroom Sink Faucet #1	6/27/2016 00:29	7/7/2016 04:11	10354048139	Lead	5	15	ppb
054-71A Boys Bathroom Sink Faucet #2	6/27/2016 00:30	7/7/2016 15:03	10354048141	Copper	1.6	1.3	ppm
054-71A Boys Bathroom Sink Faucet #2	6/27/2016 00:30	7/7/2016 12:17	10354048141	Lead	35	15	ppb
054-72A Boys Bathroom Water Spigot	6/27/2016 00:32	7/7/2016 04:12	10354048143	Copper	0.1	1.3	ppm
054-72A Boys Bathroom Water Spigot	6/27/2016 00:32	7/7/2016 04:12	10354048143	Lead	58	15	ppb
054-73A Classroom 113 Sink Faucet #1	6/27/2016 00:34	7/7/2016 04:14	10354048145	Copper	0.1	1.3	ppm
054-73A Classroom 113 Sink Faucet #1	6/27/2016 00:34	7/7/2016 04:14	10354048145	Lead	19	15	ppb
054-74A Classroom 113 Drinking Fountain	6/27/2016 00:36	7/7/2016 04:15	10354048147	Copper	0.0	1.3	ppm
054-74A Classroom 113 Drinking Fountain	6/27/2016 00:36	7/7/2016 04:15	10354048147	Lead	38	15	ppb
054-75A Classroom 113 Sink Faucet #2	6/27/2016 00:40	7/7/2016 04:16	10354048149	Copper	0.2	1.3	ppm
054-75A Classroom 113 Sink Faucet #2	6/27/2016 00:40	7/7/2016 04:16	10354048149	Lead	9	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Laurelhurst Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
054-76A Classroom 114 Drinking Fountain	6/27/2016 00:40	7/7/2016 04:19	10354048151	Copper	0.0	1.3	ppm
054-76A Classroom 114 Drinking Fountain	6/27/2016 00:40	7/7/2016 04:19	10354048151	Lead	8	15	ppb
054-77A Classroom 114 Sink Faucet	6/27/2016 00:45	7/7/2016 04:21	10354048153	Copper	0.2	1.3	ppm
054-77A Classroom 114 Sink Faucet	6/27/2016 00:45	7/7/2016 04:21	10354048153	Lead	37	15	ppb
054-78A Classroom A5 Drinking Fountain	6/27/2016 00:47	7/7/2016 04:22	10354048155	Copper	0.1	1.3	ppm
054-78A Classroom A5 Drinking Fountain	6/27/2016 00:47	7/7/2016 04:22	10354048155	Lead	11	15	ppb
054-79A Classroom A6 Sink Faucet	6/27/2016 00:46	7/7/2016 04:26	10354048157	Copper	0.1	1.3	ppm
054-79A Classroom A6 Sink Faucet	6/27/2016 00:46	7/7/2016 04:26	10354048157	Lead	27	15	ppb
054-80A Classroom A6 Drinking Fountain	6/27/2016 00:48	7/7/2016 04:27	10354048159	Copper	0.1	1.3	ppm
054-80A Classroom A6 Drinking Fountain	6/27/2016 00:48	7/7/2016 04:27	10354048159	Lead	10	15	ppb
054-81A Outside Water Spigot #1	6/27/2016 00:53	7/7/2016 07:21	10354048161	Copper	0.1	1.3	ppm
054-81A Outside Water Spigot #1	6/27/2016 00:53	7/7/2016 07:21	10354048161	Lead	73	15	ppb
054-82A Outside Water Spigot #2	6/27/2016 00:56	7/7/2016 07:23	10354048163	Copper	0.1	1.3	ppm
054-82A Outside Water Spigot #2	6/27/2016 00:56	7/7/2016 07:23	10354048163	Lead	244	15	ppb
054-83A Outside Water Spigot #3	6/27/2016 01:00	7/7/2016 07:24	10354048165	Copper	0.1	1.3	ppm
054-83A Outside Water Spigot #3	6/27/2016 01:00	7/7/2016 07:24	10354048165	Lead	14	15	ppb
054-84A Outside Water Spigot #4	6/27/2016 01:04	7/7/2016 12:18	10354048167	Copper	0.4	1.3	ppm
054-84A Outside Water Spigot #4	6/27/2016 01:04	7/7/2016 12:18	10354048167	Lead	220	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.