

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Lee Elementary School

Sample Identification # and Location		Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
055-01A	Boiler Room Sink Faucet	6/22/16 8:46	7/1/2016	1606C51-01A	Copper	0.1	1.3	ppm
055-01A	Boiler Room Sink Faucet	6/22/16 8:46	7/1/2016	1606C51-01A	Lead	1	15	ppb
055-02A	Boiler Room Bathroom Sink Faucet	6/22/16 8:46	7/1/2016	1606C51-02A	Copper	0.6	1.3	ppm
055-02A	Boiler Room Bathroom Sink Faucet	6/22/16 8:46	7/1/2016	1606C51-02A	Lead	15.0	15	ppb
055-03A	Drinking Fountain Outside Boiler Room	6/22/16 8:46	7/1/2016	1606C51-03A	Copper	0.5	1.3	ppm
055-03A	Drinking Fountain Outside Boiler Room	6/22/16 8:46	7/1/2016	1606C51-03A	Lead	ND	15	ppb
055-04A	Gymnasiumnasium Bottle Fill	6/22/16 9:07	7/2/2016	1606C51-04A	Copper	1.0	1.3	ppm
055-04A	Gymnasiumnasium Bottle Fill	6/22/16 9:07	7/1/2016	1606C51-04A	Lead	3	15	ppb
055-05A	Gymnasium Office Bathroom	6/22/16 9:06	7/1/2016	1606C51-05A	Copper	0.6	1.3	ppm
055-05A	Gymnasium Office Bathroom	6/22/16 9:06	7/1/2016	1606C51-05A	Lead	7	15	ppb
055-06A	Boys Locker Room Bath Sink Faucet	6/22/16 9:19	7/1/2016	1606C51-06A	Copper	0.6	1.3	ppm
055-06A	Boys Locker Room Bath Sink Faucet	6/22/16 9:19	7/1/2016	1606C51-06A	Lead	13	15	ppb
055-07A	Boys Bathroom Sink Faucet 1 (left)	6/22/16 8:52	7/1/2016	1606C51-07A	Copper	0.5	1.3	ppm
055-07A	Boys Bathroom Sink Faucet 1 (left)	6/22/16 8:52	7/1/2016	1606C51-07A	Lead	3	15	ppb
055-08A	Boys Bathroom Sink Faucet 2 (right)	6/22/16 8:52	7/1/2016	1606C51-08A	Copper	0.5	1.3	ppm
055-08A	Boys Bathroom Sink Faucet 2 (right)	6/22/16 8:52	7/1/2016	1606C51-08A	Lead	3	15	ppb
055-09A	Boys Bathroom Water Spigot	6/22/16 8:55	7/1/2016	1606C51-09A	Copper	0.5	1.3	ppm
055-09A	Boys Bathroom Water Spigot	6/22/16 8:55	7/1/2016	1606C51-09A	Lead	8	15	ppb
055-100A	Room 100A Drinking Fountain	6/22/16 11:35	7/3/2016	1606C52-45A	Copper	0.5	1.3	ppm
055-100A	Room 100A Drinking Fountain	6/22/16 11:35	7/3/2016	1606C52-45A	Lead	2	15	ppb
055-101A	Room 100 Drinking Fountain	6/22/16 11:40	7/4/2016	1606C52-46A	Copper	ND	1.3	ppm
055-101A	Room 100 Drinking Fountain	6/22/16 11:40	7/4/2016	1606C52-46A	Lead	2	15	ppb
055-102A	Room 100 Sink Faucet	6/22/16 11:45	7/3/2016	1606C52-47A	Copper	0.3	1.3	ppm
055-102A	Room 100 Sink Faucet	6/22/16 11:45	7/3/2016	1606C52-47A	Lead	45	15	ppb
055-103A	Room 100 Drinking Fountain	6/22/16 11:45	7/3/2016	1606C52-48A	Copper	0.4	1.3	ppm
055-103A	Room 100 Drinking Fountain	6/22/16 11:45	7/3/2016	1606C52-48A	Lead	32	15	ppb
055-104A	Outdoor Water Spigot 1	6/22/16 12:01	7/4/2016	1606C52-49A	Copper	0.2	1.3	ppm
055-104A	Outdoor Water Spigot 1	6/22/16 12:01	7/4/2016	1606C52-49A	Lead	14	15	ppb
055-105A	Outdoor Water Spigot 2	6/22/16 11:01	7/4/2016	1606C52-50A	Copper	0.3	1.3	ppm
055-105A	Outdoor Water Spigot 2	6/22/16 11:01	7/4/2016	1606C52-50A	Lead	9	15	ppb
055-106A	Outdoor Water Spigot 3	6/22/16 11:09	7/4/2016	1606C52-51A	Copper	0.2	1.3	ppm
055-106A	Outdoor Water Spigot 3	6/22/16 11:09	7/4/2016	1606C52-51A	Lead	18	15	ppb
055-107A	Outdoor Water Spigot 4	6/22/16 11:10	7/4/2016	1606C52-52A	Copper	0.6	1.3	ppm
055-107A	Outdoor Water Spigot 4	6/22/16 11:10	7/4/2016	1606C52-52A	Lead	8	15	ppb
055-10A	Custodial Closet Sink Faucet	6/22/16 8:52	7/1/2016	1606C51-10A	Copper	0.3	1.3	ppm
055-10A	Custodial Closet Sink Faucet	6/22/16 8:52	7/1/2016	1606C51-10A	Lead	4	15	ppb
055-11A	Girls Bathroom Sink Faucet 1 (left)	6/22/16 8:57	7/1/2016	1606C51-11A	Copper	0.3	1.3	ppm
055-11A	Girls Bathroom Sink Faucet 1 (left)	6/22/16 8:57	7/1/2016	1606C51-11A	Lead	3	15	ppb
055-12A	Girls Bathroom Sink Faucet 2 (right)	6/22/16 8:57	7/1/2016	1606C51-12A	Copper	0.3	1.3	ppm
055-12A	Girls Bathroom Sink Faucet 2 (right)	6/22/16 8:57	7/1/2016	1606C51-12A	Lead	2	15	ppb
055-13A	Girls Bathroom Water Spigot	6/22/16 9:02	7/1/2016	1606C51-13A	Copper	0.4	1.3	ppm
055-13A	Girls Bathroom Water Spigot	6/22/16 9:02	7/1/2016	1606C51-13A	Lead	15.0	15	ppb
055-14A	Drinking Fountain Near Boys Locker Room	6/22/16 9:25	7/1/2016	1606C51-14A	Copper	0.6	1.3	ppm
055-14A	Drinking Fountain Near Boys Locker Room	6/22/16 9:25	7/1/2016	1606C51-14A	Lead	14	15	ppb
055-15A	Room 115 Sink Faucet	6/22/16 9:27	7/1/2016	1606C51-15A	Copper	0.8	1.3	ppm
055-15A	Room 115 Sink Faucet	6/22/16 9:27	7/1/2016	1606C51-15A	Lead	10	15	ppb
055-16A	Room 110 Sink Faucet (left)	6/22/16 9:18	7/1/2016	1606C51-16A	Copper	0.5	1.3	ppm
055-16A	Room 110 Sink Faucet (left)	6/22/16 9:18	7/1/2016	1606C51-16A	Lead	6	15	ppb
055-17A	Room 110 Drinking Fountain (left)	6/22/16 9:18	7/2/2016	1606C51-17A	Copper	0.9	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Lee Elementary School

055-17A	Room 110 Drinking Fountain (left)	6/22/16 9:18	7/1/2016	1606C51-17A	Lead	18	15	ppb
055-18A	Room 110 Sink Faucet (right)	6/22/16 9:19	7/2/2016	1606C51-18A	Copper	0.7	1.3	ppm
055-18A	Room 110 Sink Faucet (right)	6/22/16 9:19	7/2/2016	1606C51-18A	Lead	10	15	ppb
055-19A	Room 110 Drinking Fountain (right)	6/22/16 9:19	7/2/2016	1606C51-19A	Copper	0.7	1.3	ppm
055-19A	Room 110 Drinking Fountain (right)	6/22/16 9:19	7/2/2016	1606C51-19A	Lead	15.0	15	ppb
055-20A	Room 112 Sink Faucet 1 (left)	6/22/16 9:26	7/2/2016	1606C51-20A	Copper	0.5	1.3	ppm
055-20A	Room 112 Sink Faucet 1 (left)	6/22/16 9:26	7/2/2016	1606C51-20A	Lead	17	15	ppb
055-21A	Room 112 Sink Faucet 2 (left)	6/22/16 9:26	7/2/2016	1606C51-21A	Copper	0.4	1.3	ppm
055-21A	Room 112 Sink Faucet 2 (left)	6/22/16 9:26	7/2/2016	1606C51-21A	Lead	15.0	15	ppb
055-22A	Room 112 Sink Faucet 3 (right)	6/22/16 9:26	7/2/2016	1606C51-22A	Copper	0.5	1.3	ppm
055-22A	Room 112 Sink Faucet 3 (right)	6/22/16 9:26	7/2/2016	1606C51-22A	Lead	16	15	ppb
055-23A	Room 114 Sink Faucet	6/22/16 9:30	7/2/2016	1606C51-23A	Copper	0.4	1.3	ppm
055-23A	Room 114 Sink Faucet	6/22/16 9:30	7/2/2016	1606C51-23A	Lead	15.0	15	ppb
055-24A	Room 114 Drinking Fountain	6/22/16 9:30	7/2/2016	1606C51-24A	Copper	0.8	1.3	ppm
055-24A	Room 114 Drinking Fountain	6/22/16 9:30	7/2/2016	1606C51-24A	Lead	24	15	ppb
055-25A	Room 117 Sink Faucet	6/22/16 9:32	7/2/2016	1606C51-25A	Copper	0.7	1.3	ppm
055-25A	Room 117 Sink Faucet	6/22/16 9:32	7/2/2016	1606C51-25A	Lead	14	15	ppb
055-26A	Room 117 Drinking Fountain	6/22/16 9:32	7/3/2016	1606C51-26A	Copper	0.9	1.3	ppm
055-26A	Room 117 Drinking Fountain	6/22/16 9:32	7/2/2016	1606C51-26A	Lead	15.0	15	ppb
055-27A	Room 116 Sink Faucet	6/22/16 9:34	7/2/2016	1606C51-27A	Copper	0.4	1.3	ppm
055-27A	Room 116 Sink Faucet	6/22/16 9:34	7/2/2016	1606C51-27A	Lead	24	15	ppb
055-28A	Room 116 Drinking Fountain	6/22/16 9:34	7/2/2016	1606C51-28A	Copper	ND	1.3	ppm
055-28A	Room 116 Drinking Fountain	6/22/16 9:34	7/2/2016	1606C51-28A	Lead	4	15	ppb
055-29A	Room 119 Sink Faucet #1	6/22/16 9:36	7/2/2016	1606C51-29A	Copper	0.4	1.3	ppm
055-29A	Room 119 Sink Faucet #1	6/22/16 9:36	7/2/2016	1606C51-29A	Lead	2	15	ppb
055-30A	Room 119 Sink Faucet #2	6/22/16 9:36	7/2/2016	1606C51-30A	Copper	0.4	1.3	ppm
055-30A	Room 119 Sink Faucet #2	6/22/16 9:36	7/2/2016	1606C51-30A	Lead	5	15	ppb
055-32A	Room 118 Sink Faucet	6/22/16 9:39	7/2/2016	1606C51-31A	Copper	0.4	1.3	ppm
055-32A	Room 118 Sink Faucet	6/22/16 9:39	7/2/2016	1606C51-31A	Lead	24	15	ppb
055-33A	Room 118 Drinking Fountain	6/22/16 9:39	7/2/2016	1606C51-32A	Copper	0.8	1.3	ppm
055-33A	Room 118 Drinking Fountain	6/22/16 9:39	7/2/2016	1606C51-32A	Lead	29	15	ppb
055-34A	Drinking Fountain Outside Room 121	6/22/16 9:41	7/3/2016	1606C51-33A	Copper	0.9	1.3	ppm
055-34A	Drinking Fountain Outside Room 121	6/22/16 9:41	7/2/2016	1606C51-33A	Lead	7	15	ppb
055-35A	Room 121 Sink Faucet 1 (left)	6/22/16 9:45	7/2/2016	1606C51-34A	Copper	0.3	1.3	ppm
055-35A	Room 121 Sink Faucet 1 (left)	6/22/16 9:45	7/2/2016	1606C51-34A	Lead	5	15	ppb
055-36A	Room 121 Drinking Fountain	6/22/16 9:46	7/3/2016	1606C51-35A	Copper	0.9	1.3	ppm
055-36A	Room 121 Drinking Fountain	6/22/16 9:46	7/2/2016	1606C51-35A	Lead	52	15	ppb
055-37A	Room 121 Sink Faucet Eyewash	6/22/16 9:46	7/2/2016	1606C51-36A	Copper	0.3	1.3	ppm
055-37A	Room 121 Sink Faucet Eyewash	6/22/16 9:46	7/2/2016	1606C51-36A	Lead	3	15	ppb
055-39A	Room 120 Sink Faucet	6/22/16 9:45	7/2/2016	1606C51-37A	Copper	0.5	1.3	ppm
055-39A	Room 120 Sink Faucet	6/22/16 9:45	7/2/2016	1606C51-37A	Lead	13	15	ppb
055-40A	Room 120 Drinking Fountain	6/22/16 9:45	7/2/2016	1606C51-38A	Copper	ND	1.3	ppm
055-40A	Room 120 Drinking Fountain	6/22/16 9:45	7/2/2016	1606C51-38A	Lead	3	15	ppb
055-41A	Custodial No. 3 Sink Faucet	6/22/16 9:51	7/2/2016	1606C51-39A	Copper	0.1	1.3	ppm
055-41A	Custodial No. 3 Sink Faucet	6/22/16 9:51	7/2/2016	1606C51-39A	Lead	7	15	ppb
055-42A	Girls Bathroom by 120 Sink Faucet 1 (left)	6/22/16 9:54	7/2/2016	1606C51-40A	Copper	0.1	1.3	ppm
055-42A	Girls Bathroom by 120 Sink Faucet 1 (left)	6/22/16 9:54	7/2/2016	1606C51-40A	Lead	3	15	ppb
055-43A	Girls Bathroom by 120 Sink Faucet 2 (left)	6/22/16 9:54	7/2/2016	1606C51-41A	Copper	0.1	1.3	ppm
055-43A	Girls Bathroom by 120 Sink Faucet 2 (left)	6/22/16 9:54	7/2/2016	1606C51-41A	Lead	4	15	ppb
055-44A	Girls Bathroom by 120 Sink Faucet 3 (right)	6/22/16 9:54	7/2/2016	1606C51-42A	Copper	0.1	1.3	ppm
055-44A	Girls Bathroom by 120 Sink Faucet 3 (right)	6/22/16 9:54	7/2/2016	1606C51-42A	Lead	9	15	ppb
055-45A	Girls Bathroom Water Spigot	6/22/16 10:00	7/2/2016	1606C51-43A	Copper	ND	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Lee Elementary School

055-45A	Girls Bathroom Water Spigot	6/22/16 10:00	7/2/2016	1606C51-43A	Lead	12	15	ppb
055-46A	Womens Teacher Bathroom Sink Faucet	6/22/16 10:09	7/2/2016	1606C51-44A	Copper	ND	1.3	ppm
055-46A	Womens Teacher Bathroom Sink Faucet	6/22/16 10:09	7/2/2016	1606C51-44A	Lead	10	15	ppb
055-47A	Boys Bathroom Sink Faucet 1 (left)	6/22/16 9:56	7/2/2016	1606C51-45A	Copper	ND	1.3	ppm
055-47A	Boys Bathroom Sink Faucet 1 (left)	6/22/16 9:56	7/2/2016	1606C51-45A	Lead	2	15	ppb
055-48A	Boys Bathroom Sink Faucet 2 (left)	6/22/16 9:57	7/2/2016	1606C51-46A	Copper	0.1	1.3	ppm
055-48A	Boys Bathroom Sink Faucet 2 (left)	6/22/16 9:57	7/2/2016	1606C51-46A	Lead	4	15	ppb
055-49A	Boys Bathroom Sink Faucet 3 (right)	6/22/16 9:58	7/2/2016	1606C51-47A	Copper	ND	1.3	ppm
055-49A	Boys Bathroom Sink Faucet 3 (right)	6/22/16 9:58	7/2/2016	1606C51-47A	Lead	6	15	ppb
055-50A	Boys Bathroom Water Spigot	6/22/16 10:04	7/2/2016	1606C51-48A	Copper	ND	1.3	ppm
055-50A	Boys Bathroom Water Spigot	6/22/16 10:04	7/2/2016	1606C51-48A	Lead	4	15	ppb
055-51A	Room 123 Sink Faucet	6/22/16 10:05	7/2/2016	1606C51-49A	Copper	0.2	1.3	ppm
055-51A	Room 123 Sink Faucet	6/22/16 10:05	7/2/2016	1606C51-49A	Lead	13	15	ppb
055-52A	Room 123 Drinking Fountain	6/22/16 10:05	7/2/2016	1606C51-50A	Copper	0.2	1.3	ppm
055-52A	Room 123 Drinking Fountain	6/22/16 10:05	7/2/2016	1606C51-50A	Lead	8	15	ppb
055-53A	Room 122 Sink Faucet	6/22/16 10:08	7/2/2016	1606C51-51A	Copper	ND	1.3	ppm
055-53A	Room 122 Sink Faucet	6/22/16 10:08	7/2/2016	1606C51-51A	Lead	7	15	ppb
055-54A	Room 122 Drinking Fountain	6/22/16 10:08	7/2/2016	1606C51-52A	Copper	ND	1.3	ppm
055-54A	Room 122 Drinking Fountain	6/22/16 10:08	7/2/2016	1606C51-52A	Lead	4	15	ppb
055-55A	Kitchen Food Prep Handheld	6/22/16 10:20	7/2/2016	1606C51-53A	Copper	0.1	1.3	ppm
055-55A	Kitchen Food Prep Handheld	6/22/16 10:20	7/2/2016	1606C51-53A	Lead	4	15	ppb
055-56A	Kitchen Food Prep Sink Faucet	6/22/16 10:20	7/2/2016	1606C52-01A	Copper	0.2	1.3	ppm
055-56A	Kitchen Food Prep Sink Faucet	6/22/16 10:20	7/2/2016	1606C52-01A	Lead	1	15	ppb
055-57A	Kitchen Food Prep Sink Faucet	6/22/16 10:29	7/2/2016	1606C52-02A	Copper	0.2	1.3	ppm
055-57A	Kitchen Food Prep Sink Faucet	6/22/16 10:29	7/2/2016	1606C52-02A	Lead	3	15	ppb
055-58A	Kitchen Custodial Sink Faucet	6/22/16 10:45	7/2/2016	1606C52-03A	Copper	0.2	1.3	ppm
055-58A	Kitchen Custodial Sink Faucet	6/22/16 10:45	7/2/2016	1606C52-03A	Lead	13	15	ppb
055-59A	Faculty Room Sink Faucet	6/22/16 10:47	7/2/2016	1606C52-04A	Copper	0.4	1.3	ppm
055-59A	Faculty Room Sink Faucet	6/22/16 10:47	7/2/2016	1606C52-04A	Lead	5	15	ppb
055-60A	Cafeteria Drinking Fountain (left)	6/22/16 10:36	7/2/2016	1606C52-05A	Copper	ND	1.3	ppm
055-60A	Cafeteria Drinking Fountain (left)	6/22/16 10:36	7/2/2016	1606C52-05A	Lead	3	15	ppb
055-61A	Cafeteria Drinking Fountain (right)	6/22/16 10:36	7/2/2016	1606C52-06A	Copper	ND	1.3	ppm
055-61A	Cafeteria Drinking Fountain (right)	6/22/16 10:36	7/2/2016	1606C52-06A	Lead	2	15	ppb
055-62A	Boys Bath Near Café Sink Faucet (left)	6/22/16 10:32	7/2/2016	1606C52-07A	Copper	ND	1.3	ppm
055-62A	Boys Bath Near Café Sink Faucet (left)	6/22/16 10:32	7/2/2016	1606C52-07A	Lead	2	15	ppb
055-63A	Boys Bath Near Café Sink Faucet (right)	6/22/16 10:32	7/2/2016	1606C52-08A	Copper	0.2	1.3	ppm
055-63A	Boys Bath Near Café Sink Faucet (right)	6/22/16 10:32	7/2/2016	1606C52-08A	Lead	8	15	ppb
055-64A	Boys Bath Near Café Water Spigot	6/22/16 10:42	7/2/2016	1606C52-09A	Copper	0.3	1.3	ppm
055-64A	Boys Bath Near Café Water Spigot	6/22/16 10:42	7/2/2016	1606C52-09A	Lead	17	15	ppb
055-65A	Custodial No 1 Sink Faucet	6/22/16 10:26	7/2/2016	1606C52-10A	Copper	0.1	1.3	ppm
055-65A	Custodial No 1 Sink Faucet	6/22/16 10:26	7/2/2016	1606C52-10A	Lead	9	15	ppb
055-66A	Faculty Mens Room Sink Faucet	6/22/16 10:40	7/2/2016	1606C52-11A	Copper	ND	1.3	ppm
055-66A	Faculty Mens Room Sink Faucet	6/22/16 10:40	7/2/2016	1606C52-11A	Lead	8	15	ppb
055-67A	Office Sink Faucet Room 3	6/22/16 10:46	7/2/2016	1606C52-12A	Copper	0.3	1.3	ppm
055-67A	Office Sink Faucet Room 3	6/22/16 10:46	7/2/2016	1606C52-12A	Lead	4	15	ppb
055-68A	Nurse Office Bathroom Sink Faucet Room 4	6/22/16 10:46	7/2/2016	1606C52-13A	Copper	0.3	1.3	ppm
055-68A	Nurse Office Bathroom Sink Faucet Room 4	6/22/16 10:46	7/2/2016	1606C52-13A	Lead	1	15	ppb
055-69A	Girls Bathroom by Office Sink Faucet 1 (left)	6/22/16 10:54	7/2/2016	1606C52-14A	Copper	ND	1.3	ppm
055-69A	Girls Bathroom by Office Sink Faucet 1 (left)	6/22/16 10:54	7/2/2016	1606C52-14A	Lead	2	15	ppb
055-70A	Girls Bathroom by Office Sink Faucet 2 (right)	6/22/16 10:55	7/2/2016	1606C52-15A	Copper	ND	1.3	ppm
055-70A	Girls Bathroom by Office Sink Faucet 2 (right)	6/22/16 10:55	7/2/2016	1606C52-15A	Lead	3	15	ppb
055-71A	Girls Bathroom by Office Water Spigot	6/22/16 10:56	7/3/2016	1606C52-16A	Copper	1.0	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Lee Elementary School

055-71A	Girls Bathroom by Office Water Spigot	6/22/16 10:56	7/3/2016	1606C52-16A	Lead	24	15	ppb
055-72A	Staff Bathroom Near Room 5 Sink Faucet	6/22/16 10:55	7/2/2016	1606C52-17A	Copper	0.2	1.3	ppm
055-72A	Staff Bathroom Near Room 5 Sink Faucet	6/22/16 10:55	7/2/2016	1606C52-17A	Lead	8	15	ppb
055-73A	Room 109 Sink Faucet	6/22/16 10:56	7/2/2016	1606C52-18A	Copper	0.4	1.3	ppm
055-73A	Room 109 Sink Faucet	6/22/16 10:56	7/2/2016	1606C52-18A	Lead	13	15	ppb
055-74A	Room 109 Drinking Fountain	6/22/16 10:56	7/2/2016	1606C52-19A	Copper	0.6	1.3	ppm
055-74A	Room 109 Drinking Fountain	6/22/16 10:56	7/2/2016	1606C52-19A	Lead	10	15	ppb
055-75A	Hallway Near Office Drinking Fountain	6/22/16 11:02	7/3/2016	1606C52-20A	Copper	1.4	1.3	ppm
055-75A	Hallway Near Office Drinking Fountain	6/22/16 11:02	7/2/2016	1606C52-20A	Lead	3	15	ppb
055-76A	Room 108 Sink Faucet	6/22/16 11:07	7/2/2016	1606C52-21A	Copper	0.4	1.3	ppm
055-76A	Room 108 Sink Faucet	6/22/16 11:07	7/2/2016	1606C52-21A	Lead	17	15	ppb
055-77A	Room 108 Drinking Fountain	6/22/16 11:07	7/2/2016	1606C52-22A	Copper	0.6	1.3	ppm
055-77A	Room 108 Drinking Fountain	6/22/16 11:07	7/2/2016	1606C52-22A	Lead	5	15	ppb
055-78A	Room 107 Drinking Fountain	6/22/16 11:12	7/2/2016	1606C52-23A	Copper	0.8	1.3	ppm
055-78A	Room 107 Drinking Fountain	6/22/16 11:12	7/2/2016	1606C52-23A	Lead	5	15	ppb
055-79A	Room 106 Sink Faucet	6/22/16 11:17	7/2/2016	1606C52-24A	Copper	0.4	1.3	ppm
055-79A	Room 106 Sink Faucet	6/22/16 11:17	7/2/2016	1606C52-24A	Lead	5	15	ppb
055-80A	Room 106 Drinking Fountain	6/22/16 11:17	7/2/2016	1606C52-25A	Copper	0.7	1.3	ppm
055-80A	Room 106 Drinking Fountain	6/22/16 11:17	7/2/2016	1606C52-25A	Lead	3	15	ppb
055-81A	Room 105 Drinking Fountain	6/22/16 11:18	7/3/2016	1606C52-26A	Copper	0.5	1.3	ppm
055-81A	Room 105 Drinking Fountain	6/22/16 11:18	7/3/2016	1606C52-26A	Lead	27	15	ppb
055-82A	Room 104 Sink Faucet	6/22/16 11:22	7/3/2016	1606C52-27A	Copper	0.4	1.3	ppm
055-82A	Room 104 Sink Faucet	6/22/16 11:22	7/3/2016	1606C52-27A	Lead	7	15	ppb
055-83A	Room 104 Drinking Fountain	6/22/16 11:22	7/3/2016	1606C52-28A	Copper	ND	1.3	ppm
055-83A	Room 104 Drinking Fountain	6/22/16 11:22	7/3/2016	1606C52-28A	Lead	2	15	ppb
055-84A	Room 103 Sink Faucet	6/22/16 11:24	7/3/2016	1606C52-29A	Copper	0.3	1.3	ppm
055-84A	Room 103 Sink Faucet	6/22/16 11:24	7/3/2016	1606C52-29A	Lead	47	15	ppb
055-85A	Room 103 Drinking Fountain	6/22/16 11:24	7/3/2016	1606C52-30A	Copper	0.2	1.3	ppm
055-85A	Room 103 Drinking Fountain	6/22/16 11:24	7/3/2016	1606C52-30A	Lead	15.0	15	ppb
055-86A	Room 102 Sink Faucet	6/22/16 11:30	7/3/2016	1606C52-31A	Copper	0.4	1.3	ppm
055-86A	Room 102 Sink Faucet	6/22/16 11:30	7/3/2016	1606C52-31A	Lead	6	15	ppb
055-87A	Room 102 Drinking Fountain	6/22/16 11:30	7/3/2016	1606C52-32A	Copper	0.6	1.3	ppm
055-87A	Room 102 Drinking Fountain	6/22/16 11:30	7/3/2016	1606C52-32A	Lead	3	15	ppb
055-88A	Girls Bathroom Near 102 Sink Faucet	6/22/16 11:29	7/3/2016	1606C52-33A	Copper	0.2	1.3	ppm
055-88A	Girls Bathroom Near 102 Sink Faucet	6/22/16 11:29	7/3/2016	1606C52-33A	Lead	9	15	ppb
055-89A	Room 101A Sink Faucet	6/22/16 11:33	7/3/2016	1606C52-34A	Copper	0.1	1.3	ppm
055-89A	Room 101A Sink Faucet	6/22/16 11:33	7/3/2016	1606C52-34A	Lead	2	15	ppb
055-90A	Room 101A Drinking Fountain	6/22/16 11:33	7/3/2016	1606C52-35A	Copper	0.4	1.3	ppm
055-90A	Room 101A Drinking Fountain	6/22/16 11:33	7/3/2016	1606C52-35A	Lead	5	15	ppb
055-91A	Hall Drinking Fountain Near Room 102	6/22/16 11:26	7/4/2016	1606C52-36A	Copper	0.9	1.3	ppm
055-91A	Hall Drinking Fountain Near Room 102	6/22/16 11:26	7/3/2016	1606C52-36A	Lead	4	15	ppb
055-92A	Boy Bathroom by Room 101 Sink Faucet 1 (left)	6/22/16 11:48	7/3/2016	1606C52-37A	Copper	0.3	1.3	ppm
055-92A	Boy Bathroom by Room 101 Sink Faucet 1 (left)	6/22/16 11:48	7/3/2016	1606C52-37A	Lead	6	15	ppb
055-93A	Boy Bathroom by Room 101 Sink Faucet 2 (right)	6/22/16 11:48	7/3/2016	1606C52-38A	Copper	0.3	1.3	ppm
055-93A	Boy Bathroom by Room 101 Sink Faucet 2 (right)	6/22/16 11:48	7/3/2016	1606C52-38A	Lead	4	15	ppb
055-94A	Boy Bathroom by Room 101 Water Spigot	6/22/16 11:48	7/3/2016	1606C52-39A	Copper	0.8	1.3	ppm
055-94A	Boy Bathroom by Room 101 Water Spigot	6/22/16 11:48	7/3/2016	1606C52-39A	Lead	37	15	ppb
055-95A	Room 101 Sink Faucet	6/22/16 11:38	7/3/2016	1606C52-40A	Copper	0.3	1.3	ppm
055-95A	Room 101 Sink Faucet	6/22/16 11:38	7/3/2016	1606C52-40A	Lead	12	15	ppb
055-96A	Room 101 Drinking Fountain	6/22/16 11:38	7/3/2016	1606C52-41A	Copper	0.4	1.3	ppm
055-96A	Room 101 Drinking Fountain	6/22/16 11:38	7/3/2016	1606C52-41A	Lead	9	15	ppb
055-97A	Room 101 Bathroom Sink Faucet 1	6/22/16 11:41	7/3/2016	1606C52-42A	Copper	0.6	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Lee Elementary School

055-97A	Room 101 Bathroom Sink Faucet 1	6/22/16 11:41	7/3/2016	1606C52-42A	Lead	12	15	ppb
055-98A	Room 101 Bathroom Sink Faucet 2	6/22/16 11:41	7/3/2016	1606C52-43A	Copper	0.3	1.3	ppm
055-98A	Room 101 Bathroom Sink Faucet 2	6/22/16 11:41	7/3/2016	1606C52-43A	Lead	8	15	ppb
055-99A	Room 100A Sink Faucet	6/22/16 11:34	7/3/2016	1606C52-44A	Copper	0.4	1.3	ppm
055-99A	Room 100A Sink Faucet	6/22/16 11:34	7/3/2016	1606C52-44A	Lead	10	15	ppb

EPA Action Level for Lead of 15 ppb

ND = Non detect

EPA Action Level for Copper of 1.3 ppm

Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.