

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Lent Elementary School

Sample Identification # and Location		Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
056-01A	Boiler Room Slop Sink	6/23/16 8:29	7/8/2016	1606C80-01A	Copper	ND	1.3	ppm
056-01A	Boiler Room Slop Sink	6/23/16 8:29	7/8/2016	1606C80-01A	Lead	8	15	ppb
056-02A	Boiler Room Water Hose Faucet	6/23/16 8:32	7/8/2016	1606C80-02A	Copper	0.3	1.3	ppm
056-02A	Boiler Room Water Hose Faucet	6/23/16 8:32	7/8/2016	1606C80-02A	Lead	5	15	ppb
056-03A	Custodian Restroom Wash	6/23/16 8:25	7/8/2016	1606C80-03A	Copper	0.2	1.3	ppm
056-03A	Custodian Restroom Wash	6/23/16 8:25	7/8/2016	1606C80-03A	Lead	11	15	ppb
056-04A	Custodian Restroom Shower	6/23/16 8:27	7/8/2016	1606C80-04A	Copper	0.1	1.3	ppm
056-04A	Custodian Restroom Shower	6/23/16 8:27	7/8/2016	1606C80-04A	Lead	2	15	ppb
056-05A	Drinking Fountain near Custodian	6/23/16 8:40	7/8/2016	1606C80-05A	Copper	0.2	1.3	ppm
056-05A	Drinking Fountain near Custodian	6/23/16 8:40	7/8/2016	1606C80-05A	Lead	ND	15	ppb
056-06A	Room 136 Sink Faucet	6/23/16 8:46	7/8/2016	1606C80-06A	Copper	0.4	1.3	ppm
056-06A	Room 136 Sink Faucet	6/23/16 8:46	7/8/2016	1606C80-06A	Lead	3	15	ppb
056-07A	Room 136 Drinking Fountain	6/23/16 8:49	7/8/2016	1606C80-07A	Copper	0.3	1.3	ppm
056-07A	Room 136 Drinking Fountain	6/23/16 8:49	7/8/2016	1606C80-07A	Lead	4	15	ppb
056-08A	Room 134 Boys Bathroom Sink	6/23/16 8:52	7/8/2016	1606C80-08A	Copper	0.2	1.3	ppm
056-08A	Room 134 Boys Bathroom Sink	6/23/16 8:52	7/8/2016	1606C80-08A	Lead	6	15	ppb
056-09A	Room 132 Girls Bathroom Sink	6/23/16 8:55	7/8/2016	1606C80-09A	Copper	0.2	1.3	ppm
056-09A	Room 132 Girls Bathroom Sink	6/23/16 8:55	7/8/2016	1606C80-09A	Lead	6	15	ppb
056-100A	Room 111 Girls Bathroom Sink 1	6/23/16 9:46	7/8/2016	1606C81-02A	Copper	ND	1.3	ppm
056-100A	Room 111 Girls Bathroom Sink 1	6/23/16 9:46	7/8/2016	1606C81-02A	Lead	14	15	ppb
056-101A	Room 111 Girls Bathroom Sink 2	6/23/16 9:48	7/8/2016	1606C81-03A	Copper	0.2	1.3	ppm
056-101A	Room 111 Girls Bathroom Sink 2	6/23/16 9:48	7/8/2016	1606C81-03A	Lead	11	15	ppb
056-102A	Room 111 Girls Bathroom Spigot	6/23/16 9:50	7/10/2016	1606C81-04A	Copper	0.2	1.3	ppm
056-102A	Room 111 Girls Bathroom Spigot	6/23/16 9:50	7/10/2016	1606C81-04A	Lead	61	15	ppb
056-103A	Room 109 Sink Faucet	6/23/16 9:30	7/8/2016	1606C81-05A	Copper	ND	1.3	ppm
056-103A	Room 109 Sink Faucet	6/23/16 9:30	7/8/2016	1606C81-05A	Lead	4	15	ppb
056-104A	Room 109 Drinking Fountain	6/23/16 9:32	7/8/2016	1606C81-06A	Copper	ND	1.3	ppm
056-104A	Room 109 Drinking Fountain	6/23/16 9:32	7/8/2016	1606C81-06A	Lead	8	15	ppb
056-105A	Gymnasium Room Bathroom Sink	6/23/16 10:56	7/8/2016	1606C81-07A	Copper	ND	1.3	ppm
056-105A	Gymnasium Room Bathroom Sink	6/23/16 10:56	7/8/2016	1606C81-07A	Lead	33	15	ppb
056-106A	Gymnasium Room Drinking Fountain	6/23/16 10:54	7/8/2016	1606C81-08A	Copper	ND	1.3	ppm
056-106A	Gymnasium Room Drinking Fountain	6/23/16 10:54	7/8/2016	1606C81-08A	Lead	14	15	ppb
056-107A	Gymnasium Office Bathroom Shower	6/23/16 10:47	7/8/2016	1606C81-09A	Copper	ND	1.3	ppm
056-107A	Gymnasium Office Bathroom Shower	6/23/16 10:47	7/8/2016	1606C81-09A	Lead	21	15	ppb
056-108A	Gymnasium Office Bathroom Sink	6/23/16 10:49	7/8/2016	1606C81-10A	Copper	ND	1.3	ppm
056-108A	Gymnasium Office Bathroom Sink	6/23/16 10:49	7/8/2016	1606C81-10A	Lead	12	15	ppb
056-109A	Shop Building Music Room Sink	6/23/16 13:05	7/8/2016	1606C81-11A	Copper	ND	1.3	ppm
056-109A	Shop Building Music Room Sink	6/23/16 13:05	7/8/2016	1606C81-11A	Lead	79	15	ppb
056-10A	Room 130 Sink Faucet	6/23/16 8:59	7/8/2016	1606C80-10A	Copper	0.3	1.3	ppm
056-10A	Room 130 Sink Faucet	6/23/16 8:59	7/8/2016	1606C80-10A	Lead	2	15	ppb
056-110A	Shop Building Music Room Bathroom Sink	6/23/16 13:08	7/9/2016	1606C81-12A	Copper	0.1	1.3	ppm
056-110A	Shop Building Music Room Bathroom Sink	6/23/16 13:08	7/9/2016	1606C81-12A	Lead	5	15	ppb
056-111A	Shop Building Bathroom Spigot	6/23/16 13:10	7/9/2016	1606C81-13A	Copper	ND	1.3	ppm
056-111A	Shop Building Bathroom Spigot	6/23/16 13:10	7/9/2016	1606C81-13A	Lead	7	15	ppb
056-112A	Shop Building Drinking Fountain	6/23/16 13:12	7/9/2016	1606C81-14A	Copper	ND	1.3	ppm
056-112A	Shop Building Drinking Fountain	6/23/16 13:12	7/9/2016	1606C81-14A	Lead	5	15	ppb
056-113A	Northwest Building 202 Sink Faucet	6/23/16 13:17	7/9/2016	1606C81-15A	Copper	ND	1.3	ppm
056-113A	Northwest Building 202 Sink Faucet	6/23/16 13:17	7/9/2016	1606C81-15A	Lead	16	15	ppb
056-114A	Northwest Building 202 Drinking Fountain	6/23/16 13:19	7/9/2016	1606C81-16A	Copper	ND	1.3	ppm
056-114A	Northwest Building 202 Drinking Fountain	6/23/16 13:19	7/9/2016	1606C81-16A	Lead	1	15	ppb
056-115A	Northwest Building 202 Boys Bathroom Sink Faucet	6/23/16 13:28	7/9/2016	1606C81-17A	Copper	0.2	1.3	ppm
056-115A	Northwest Building 202 Boys Bathroom Sink Faucet	6/23/16 13:28	7/9/2016	1606C81-17A	Lead	4	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Lent Elementary School

056-116A	Northwest Building 202 Girls Bathroom Sink Faucet	6/23/16 13:22	7/9/2016	1606C81-18A	Copper	0.1	1.3	ppm
056-116A	Northwest Building 202 Girls Bathroom Sink Faucet	6/23/16 13:22	7/9/2016	1606C81-18A	Lead	3	15	ppb
056-117A	Northwest Building 202 Drinking Fountain	6/23/16 13:25	7/9/2016	1606C81-19A	Copper	0.4	1.3	ppm
056-117A	Northwest Building 202 Drinking Fountain	6/23/16 13:25	7/9/2016	1606C81-19A	Lead	4	15	ppb
056-118A	Northwest Building 201 Sink Faucet	6/23/16 13:31	7/9/2016	1606C81-20A	Copper	ND	1.3	ppm
056-118A	Northwest Building 201 Sink Faucet	6/23/16 13:31	7/9/2016	1606C81-20A	Lead	15.0	15	ppb
056-119A	Northwest Building 201 Drinking Fountain	6/23/16 13:33	7/9/2016	1606C81-21A	Copper	ND	1.3	ppm
056-119A	Northwest Building 201 Drinking Fountain	6/23/16 13:33	7/9/2016	1606C81-21A	Lead	3	15	ppb
056-11A	Room 130 Drinking Fountain	6/23/16 9:01	7/8/2016	1606C80-11A	Copper	0.2	1.3	ppm
056-11A	Room 130 Drinking Fountain	6/23/16 9:01	7/8/2016	1606C80-11A	Lead	8	15	ppb
056-120A	Northwest Building 202 Right Side Water Spigot	6/23/16 13:45	7/9/2016	1606C81-22A	Copper	ND	1.3	ppm
056-120A	Northwest Building 202 Right Side Water Spigot	6/23/16 13:45	7/9/2016	1606C81-22A	Lead	5	15	ppb
056-121A	Room 36 Annex Building Sink Faucet	6/23/16 13:14	7/9/2016	1606C81-23A	Copper	0.2	1.3	ppm
056-121A	Room 36 Annex Building Sink Faucet	6/23/16 13:14	7/9/2016	1606C81-23A	Lead	59	15	ppb
056-122A	Room 36 Annex Building Drinking Fountain	6/23/16 13:16	7/9/2016	1606C81-24A	Copper	ND	1.3	ppm
056-122A	Room 36 Annex Building Drinking Fountain	6/23/16 13:16	7/9/2016	1606C81-24A	Lead	41	15	ppb
056-123A	Room 35 Annex Building Sink Faucet	6/23/16 13:09	7/9/2016	1606C81-25A	Copper	ND	1.3	ppm
056-123A	Room 35 Annex Building Sink Faucet	6/23/16 13:09	7/9/2016	1606C81-25A	Lead	57	15	ppb
056-124A	Room 35 Annex Building Drinking Fountain	6/23/16 13:11	7/9/2016	1606C81-26A	Copper	ND	1.3	ppm
056-124A	Room 35 Annex Building Drinking Fountain	6/23/16 13:11	7/9/2016	1606C81-26A	Lead	6	15	ppb
056-125A	Room 34 Annex Building Sink Faucet	6/23/16 13:22	7/9/2016	1606C81-27A	Copper	0.2	1.3	ppm
056-125A	Room 34 Annex Building Sink Faucet	6/23/16 13:22	7/9/2016	1606C81-27A	Lead	24	15	ppb
056-126A	Room 34 Annex Building Drinking Fountain	6/23/16 13:24	7/9/2016	1606C81-28A	Copper	ND	1.3	ppm
056-126A	Room 34 Annex Building Drinking Fountain	6/23/16 13:24	7/9/2016	1606C81-28A	Lead	14	15	ppb
056-127A	Girls Bathroom Annex Building Sink 1	6/23/16 13:28	7/9/2016	1606C81-29A	Copper	ND	1.3	ppm
056-127A	Girls Bathroom Annex Building Sink 1	6/23/16 13:28	7/9/2016	1606C81-29A	Lead	7	15	ppb
056-128A	Girls Bathroom Annex Building Sink 2	6/23/16 13:30	7/9/2016	1606C81-30A	Copper	0.2	1.3	ppm
056-128A	Girls Bathroom Annex Building Sink 2	6/23/16 13:30	7/9/2016	1606C81-30A	Lead	18	15	ppb
056-129A	Girls Bathroom Annex Building Sink 3	6/23/16 13:32	7/9/2016	1606C81-31A	Copper	ND	1.3	ppm
056-129A	Girls Bathroom Annex Building Sink 3	6/23/16 13:32	7/9/2016	1606C81-31A	Lead	3	15	ppb
056-12A	Room 128 Book Room Sink Faucet	6/23/16 9:04	7/8/2016	1606C80-12A	Copper	ND	1.3	ppm
056-12A	Room 128 Book Room Sink Faucet	6/23/16 9:04	7/8/2016	1606C80-12A	Lead	4	15	ppb
056-130A	Girls Bathroom Annex Building Sink Water Spigot	6/23/16 13:34	7/9/2016	1606C81-32A	Copper	ND	1.3	ppm
056-130A	Girls Bathroom Annex Building Sink Water Spigot	6/23/16 13:34	7/9/2016	1606C81-32A	Lead	16	15	ppb
056-131A	Staff Restroom Annex Building Sink	6/23/16 13:37	7/9/2016	1606C81-33A	Copper	ND	1.3	ppm
056-131A	Staff Restroom Annex Building Sink	6/23/16 13:37	7/9/2016	1606C81-33A	Lead	31	15	ppb
056-132A	Drinking Fountain Near Custodial Room Annex	6/23/16 13:35	7/9/2016	1606C81-34A	Copper	ND	1.3	ppm
056-132A	Drinking Fountain Near Custodial Room Annex	6/23/16 13:35	7/9/2016	1606C81-34A	Lead	5	15	ppb
056-133A	Custodial Room Slop Sink Annex	6/23/16 13:51	7/9/2016	1606C81-35A	Copper	ND	1.3	ppm
056-133A	Custodial Room Slop Sink Annex	6/23/16 13:51	7/9/2016	1606C81-35A	Lead	10	15	ppb
056-134A	Boys Bathroom Sink 1	6/23/16 13:46	7/9/2016	1606C81-36A	Copper	ND	1.3	ppm
056-134A	Boys Bathroom Sink 1	6/23/16 13:46	7/9/2016	1606C81-36A	Lead	11	15	ppb
056-135A	Boys Bathroom Sink 2	6/23/16 13:48	7/9/2016	1606C81-37A	Copper	ND	1.3	ppm
056-135A	Boys Bathroom Sink 2	6/23/16 13:48	7/9/2016	1606C81-37A	Lead	14	15	ppb
056-136A	Boys Bathroom Sink 3	6/23/16 13:50	7/9/2016	1606C81-38A	Copper	ND	1.3	ppm
056-136A	Boys Bathroom Sink 3	6/23/16 13:50	7/9/2016	1606C81-38A	Lead	5	15	ppb
056-137A	Boys Bathroom Spigot	6/23/16 13:53	7/9/2016	1606C81-39A	Copper	ND	1.3	ppm
056-137A	Boys Bathroom Spigot	6/23/16 13:53	7/9/2016	1606C81-39A	Lead	3	15	ppb
056-138A	Room 33 Sink Faucet Annex Building	6/23/16 13:50	7/9/2016	1606C81-40A	Copper	ND	1.3	ppm
056-138A	Room 33 Sink Faucet Annex Building	6/23/16 13:50	7/9/2016	1606C81-40A	Lead	9	15	ppb
056-139A	Room 33 Drinking Fountain Annex Building	6/23/16 13:52	7/9/2016	1606C81-41A	Copper	ND	1.3	ppm
056-139A	Room 33 Drinking Fountain Annex Building	6/23/16 13:52	7/9/2016	1606C81-41A	Lead	10	15	ppb
056-13A	Room 128 Book Room Drinking Fountain	6/23/16 9:06	7/8/2016	1606C80-13A	Copper	ND	1.3	ppm
056-13A	Room 128 Book Room Drinking Fountain	6/23/16 9:06	7/8/2016	1606C80-13A	Lead	12	15	ppb
056-140A	Room 32 Sink Faucet Annex Building	6/23/16 13:58	7/9/2016	1606C81-42A	Copper	ND	1.3	ppm
056-140A	Room 32 Sink Faucet Annex Building	6/23/16 13:58	7/9/2016	1606C81-42A	Lead	7	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Lent Elementary School

056-141A	Room 32 Drinking Fountain Annex Building	6/23/16 14:00	7/9/2016	1606C81-43A	Copper	ND	1.3	ppm
056-141A	Room 32 Drinking Fountain Annex Building	6/23/16 14:00	7/9/2016	1606C81-43A	Lead	3	15	ppb
056-142A	Behind Annex Water Spigot South	6/23/16 14:12	7/8/2016	1606C81-44A	Copper	0.2	1.3	ppm
056-142A	Behind Annex Water Spigot South	6/23/16 14:12	7/8/2016	1606C81-44A	Lead	120	15	ppb
056-143A	Behind Building West Side Water Spigot	6/23/16 14:08	7/9/2016	1606C81-45A	Copper	ND	1.3	ppm
056-143A	Behind Building West Side Water Spigot	6/23/16 14:08	7/9/2016	1606C81-45A	Lead	25	15	ppb
056-144A	Water Spigot Left Side Main Entrance	6/23/16 14:27	7/8/2016	1606C81-46A	Copper	ND	1.3	ppm
056-144A	Water Spigot Left Side Main Entrance	6/23/16 14:27	7/8/2016	1606C81-46A	Lead	2	15	ppb
056-145A	Water Spigot Right Side Main Entrance 10 ft	6/23/16 14:24	7/8/2016	1606C81-47A	Copper	0.1	1.3	ppm
056-145A	Water Spigot Right Side Main Entrance 10 ft	6/23/16 14:24	7/8/2016	1606C81-47A	Lead	67	15	ppb
056-146A	Water Spigot Right Side Main Entrance Frnt	6/23/16 14:20	7/9/2016	1606C81-48A	Copper	ND	1.3	ppm
056-146A	Water Spigot Right Side Main Entrance Frnt	6/23/16 14:20	7/9/2016	1606C81-48A	Lead	4	15	ppb
056-147A	Water Spigot Behind Building Basketball Court	6/23/16 14:18	7/9/2016	1606C81-49A	Copper	ND	1.3	ppm
056-147A	Water Spigot Behind Building Basketball Court	6/23/16 14:18	7/9/2016	1606C81-49A	Lead	3	15	ppb
056-148A	Water Spigot Behind Building Horse Cage	6/23/16 14:16	7/9/2016	1606C81-50A	Copper	ND	1.3	ppm
056-148A	Water Spigot Behind Building Horse Cage	6/23/16 14:16	7/9/2016	1606C81-50A	Lead	12	15	ppb
056-14A	Room 131 Multi Purpose Sink Faucet	6/23/16 11:44	7/8/2016	1606C80-14A	Copper	0.6	1.3	ppm
056-14A	Room 131 Multi Purpose Sink Faucet	6/23/16 11:44	7/8/2016	1606C80-14A	Lead	4	15	ppb
056-15A	Room 164 Multi Purpose Sink Faucet	6/23/16 10:26	7/10/2016	1606C80-15A	Copper	1.1	1.3	ppm
056-15A	Room 164 Multi Purpose Sink Faucet	6/23/16 10:26	7/8/2016	1606C80-15A	Lead	6	15	ppb
056-16A	Drinking Fountain Near Storage 168	6/23/16 10:20	7/8/2016	1606C80-16A	Copper	ND	1.3	ppm
056-16A	Drinking Fountain Near Storage 168	6/23/16 10:20	7/8/2016	1606C80-16A	Lead	28	15	ppb
056-17A	Room 169 Sink Faucet	6/23/16 10:16	7/8/2016	1606C80-17A	Copper	0.1	1.3	ppm
056-17A	Room 169 Sink Faucet	6/23/16 10:16	7/8/2016	1606C80-17A	Lead	7	15	ppb
056-18A	Room 169 Drinking Fountain	6/23/16 10:18	7/8/2016	1606C80-18A	Copper	ND	1.3	ppm
056-18A	Room 169 Drinking Fountain	6/23/16 10:18	7/8/2016	1606C80-18A	Lead	7	15	ppb
056-19A	Boiler Room Water Hose Faucet	6/23/16 10:11	7/8/2016	1606C80-19A	Copper	0.2	1.3	ppm
056-19A	Boiler Room Water Hose Faucet	6/23/16 10:11	7/8/2016	1606C80-19A	Lead	29	15	ppb
056-20A	Room 165 Girls Bathroom Sink	6/23/16 10:06	7/8/2016	1606C80-20A	Copper	0.2	1.3	ppm
056-20A	Room 165 Girls Bathroom Sink	6/23/16 10:06	7/8/2016	1606C80-20A	Lead	20	15	ppb
056-21A	Room 163 Sink Faucet	6/23/16 10:03	7/8/2016	1606C80-21A	Copper	ND	1.3	ppm
056-21A	Room 163 Sink Faucet	6/23/16 10:03	7/8/2016	1606C80-21A	Lead	6	15	ppb
056-22A	Room 163 Drinking Fountain	6/23/16 10:03	7/8/2016	1606C80-22A	Copper	ND	1.3	ppm
056-22A	Room 163 Drinking Fountain	6/23/16 10:03	7/8/2016	1606C80-22A	Lead	6	15	ppb
056-23A	Room 158 Unisex Restroom Sink	6/23/16 9:57	7/8/2016	1606C80-23A	Copper	0.3	1.3	ppm
056-23A	Room 158 Unisex Restroom Sink	6/23/16 9:57	7/8/2016	1606C80-23A	Lead	9	15	ppb
056-24A	Room 159 Unisex Restroom Sink	6/23/16 10:31	7/8/2016	1606C80-24A	Copper	0.2	1.3	ppm
056-24A	Room 159 Unisex Restroom Sink	6/23/16 10:31	7/8/2016	1606C80-24A	Lead	5	15	ppb
056-25A	Room 145 Drinking Fountain	6/23/16 10:55	7/8/2016	1606C80-25A	Copper	ND	1.3	ppm
056-25A	Room 145 Drinking Fountain	6/23/16 10:55	7/8/2016	1606C80-25A	Lead	25	15	ppb
056-26A	Room 145 Sink Faucet	6/23/16 10:51	7/8/2016	1606C80-26A	Copper	0.2	1.3	ppm
056-26A	Room 145 Sink Faucet	6/23/16 10:51	7/8/2016	1606C80-26A	Lead	54	15	ppb
056-27A	Room 147 Wash Sink 1	6/23/16 12:06	7/8/2016	1606C80-27A	Copper	0.2	1.3	ppm
056-27A	Room 147 Wash Sink 1	6/23/16 12:06	7/8/2016	1606C80-27A	Lead	25	15	ppb
056-28A	Room 147 Wash Sink 2	6/23/16 12:13	7/8/2016	1606C80-28A	Copper	ND	1.3	ppm
056-28A	Room 147 Wash Sink 2	6/23/16 12:13	7/8/2016	1606C80-28A	Lead	17	15	ppb
056-29A	Room 149 Sink Faucet	6/23/16 12:26	7/8/2016	1606C80-29A	Copper	0.3	1.3	ppm
056-29A	Room 149 Sink Faucet	6/23/16 12:26	7/8/2016	1606C80-29A	Lead	27	15	ppb
056-30A	Room 149 Drinking Fountain	6/23/16 12:25	7/8/2016	1606C80-30A	Copper	ND	1.3	ppm
056-30A	Room 149 Drinking Fountain	6/23/16 12:25	7/8/2016	1606C80-30A	Lead	9	15	ppb
056-31A	Room 151 Restroom Left Sink Faucet	6/23/16 12:48	7/8/2016	1606C80-31A	Copper	0.2	1.3	ppm
056-31A	Room 151 Restroom Left Sink Faucet	6/23/16 12:48	7/8/2016	1606C80-31A	Lead	36	15	ppb
056-32A	Drinking Fountain Near Room 151	6/23/16 12:33	7/8/2016	1606C80-32A	Copper	ND	1.3	ppm
056-32A	Drinking Fountain Near Room 151	6/23/16 12:33	7/8/2016	1606C80-32A	Lead	46	15	ppb
056-33A	Room 153 Slop Sink	6/23/16 12:38	7/8/2016	1606C80-33A	Copper	ND	1.3	ppm
056-33A	Room 153 Slop Sink	6/23/16 12:38	7/8/2016	1606C80-33A	Lead	43	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Lent Elementary School

056-34A	Kitchen Spray Sink #1	6/23/16 12:40	7/8/2016	1606C80-34A	Copper	0.1	1.3	ppm
056-34A	Kitchen Spray Sink #1	6/23/16 12:40	7/8/2016	1606C80-34A	Lead	12	15	ppb
056-35A	Kitchen Wash Sink #1	6/23/16 12:44	7/8/2016	1606C80-35A	Copper	ND	1.3	ppm
056-35A	Kitchen Wash Sink #1	6/23/16 12:44	7/8/2016	1606C80-35A	Lead	21	15	ppb
056-36A	Kitchen Sink Faucet	6/23/16 12:40	7/8/2016	1606C80-36A	Copper	ND	1.3	ppm
056-36A	Kitchen Sink Faucet	6/23/16 12:40	7/8/2016	1606C80-36A	Lead	21	15	ppb
056-37A	Kitchen Spray Sink #2	6/23/16 12:38	7/8/2016	1606C80-37A	Copper	ND	1.3	ppm
056-37A	Kitchen Spray Sink #2	6/23/16 12:38	7/8/2016	1606C80-37A	Lead	53	15	ppb
056-38A	Kitchen Bathroom Sink Faucet	6/23/16 12:35	7/8/2016	1606C80-38A	Copper	0.1	1.3	ppm
056-38A	Kitchen Bathroom Sink Faucet	6/23/16 12:35	7/8/2016	1606C80-38A	Lead	25	15	ppb
056-39A	Kitchen Wash Sink #2	6/23/16 12:37	7/8/2016	1606C80-39A	Copper	0.2	1.3	ppm
056-39A	Kitchen Wash Sink #2	6/23/16 12:37	7/8/2016	1606C80-39A	Lead	22	15	ppb
056-40A	Room 152 Drinking Fountain	6/23/16 12:39	7/8/2016	1606C80-40A	Copper	ND	1.3	ppm
056-40A	Room 152 Drinking Fountain	6/23/16 12:39	7/8/2016	1606C80-40A	Lead	8	15	ppb
056-41A	Room 152 Wash Sink	6/23/16 12:36	7/8/2016	1606C80-41A	Copper	ND	1.3	ppm
056-41A	Room 152 Wash Sink	6/23/16 12:36	7/8/2016	1606C80-41A	Lead	15.0	15	ppb
056-42A	Room 150 Girls Bathroom Sink 1	6/23/16 12:28	7/8/2016	1606C80-42A	Copper	ND	1.3	ppm
056-42A	Room 150 Girls Bathroom Sink 1	6/23/16 12:28	7/8/2016	1606C80-42A	Lead	10	15	ppb
056-43A	Room 150 Girls Bathroom Sink 2	6/23/16 12:30	7/8/2016	1606C80-43A	Copper	ND	1.3	ppm
056-43A	Room 150 Girls Bathroom Sink 2	6/23/16 12:30	7/8/2016	1606C80-43A	Lead	13	15	ppb
056-44A	Room 148 Wash Sink	6/23/16 12:20	7/8/2016	1606C80-44A	Copper	ND	1.3	ppm
056-44A	Room 148 Wash Sink	6/23/16 12:20	7/8/2016	1606C80-44A	Lead	14	15	ppb
056-45A	Room 146 Drinking Fountain	6/23/16 11:53	7/8/2016	1606C80-45A	Copper	ND	1.3	ppm
056-45A	Room 146 Drinking Fountain	6/23/16 11:53	7/8/2016	1606C80-45A	Lead	18	15	ppb
056-46A	Room 146 Wash Sink	6/23/16 11:56	7/8/2016	1606C80-46A	Copper	ND	1.3	ppm
056-46A	Room 146 Wash Sink	6/23/16 11:56	7/8/2016	1606C80-46A	Lead	17	15	ppb
056-47A	Room 146 Bathroom Wash Sink	6/23/16 12:06	7/8/2016	1606C80-47A	Copper	0.4	1.3	ppm
056-47A	Room 146 Bathroom Wash Sink	6/23/16 12:06	7/8/2016	1606C80-47A	Lead	65	15	ppb
056-48A	Room 146 Back Room Sink 1	6/23/16 11:59	7/8/2016	1606C80-48A	Copper	0.2	1.3	ppm
056-48A	Room 146 Back Room Sink 1	6/23/16 11:59	7/8/2016	1606C80-48A	Lead	27	15	ppb
056-49A	Room 146 Back Room Sink 2	6/23/16 12:02	7/8/2016	1606C80-49A	Copper	ND	1.3	ppm
056-49A	Room 146 Back Room Sink 2	6/23/16 12:02	7/8/2016	1606C80-49A	Lead	33	15	ppb
056-50A	Room 144 Slop Sink	6/23/16 10:47	7/8/2016	1606C80-50A	Copper	ND	1.3	ppm
056-50A	Room 144 Slop Sink	6/23/16 10:47	7/8/2016	1606C80-50A	Lead	5	15	ppb
056-51A	Room 142 Women Teacher Restroom Sink	6/23/16 10:32	7/8/2016	1606C80-51A	Copper	ND	1.3	ppm
056-51A	Room 142 Women Teacher Restroom Sink	6/23/16 10:32	7/8/2016	1606C80-51A	Lead	4	15	ppb
056-52A	Room 142 Women Teacher Drinking Fountain	6/23/16 10:37	7/8/2016	1606C80-52A	Copper	ND	1.3	ppm
056-52A	Room 142 Women Teacher Drinking Fountain	6/23/16 10:37	7/8/2016	1606C80-52A	Lead	23	15	ppb
056-53A	Blw Sun Com Ctr Sign WD	6/23/16 10:41	7/10/2016	1606C80-53A	Copper	1.9	1.3	ppm
056-53A	Blw Sun Com Ctr Sign WD	6/23/16 10:41	7/8/2016	1606C80-53A	Lead	ND	15	ppb
056-54A	Blw Sun Com Ctr Sign Drinking Fountain	6/23/16 10:44	7/10/2016	1606C80-54A	Copper	1.0	1.3	ppm
056-54A	Blw Sun Com Ctr Sign Drinking Fountain	6/23/16 10:44	7/8/2016	1606C80-54A	Lead	ND	15	ppb
056-55A	Room 140 Wash Sink	6/23/16 10:28	7/8/2016	1606C80-55A	Copper	0.1	1.3	ppm
056-55A	Room 140 Wash Sink	6/23/16 10:28	7/8/2016	1606C80-55A	Lead	6	15	ppb
056-56A	Room 102 Sink Faucet	6/23/16 9:11	7/8/2016	1606C80-56A	Copper	ND	1.3	ppm
056-56A	Room 102 Sink Faucet	6/23/16 9:11	7/8/2016	1606C80-56A	Lead	6	15	ppb
056-57A	Water Dispenser near Main Office	6/23/16 9:19	7/10/2016	1606C80-57A	Copper	1.9	1.3	ppm
056-57A	Water Dispenser near Main Office	6/23/16 9:19	7/8/2016	1606C80-57A	Lead	ND	15	ppb
056-58A	Drinking Fountain near Main Office	6/23/16 9:21	7/10/2016	1606C80-58A	Copper	1.26	1.3	ppm
056-58A	Drinking Fountain near Main Office	6/23/16 9:21	7/8/2016	1606C80-58A	Lead	ND	15	ppb
056-59A	Room 104 Slop Sink	6/23/16 9:24	7/8/2016	1606C80-59A	Copper	ND	1.3	ppm
056-59A	Room 104 Slop Sink	6/23/16 9:24	7/8/2016	1606C80-59A	Lead	11	15	ppb
056-60A	Room 106 Bathroom Sink Faucet	6/23/16 9:13	7/8/2016	1606C80-60A	Copper	ND	1.3	ppm
056-60A	Room 106 Bathroom Sink Faucet	6/23/16 9:13	7/8/2016	1606C80-60A	Lead	64	15	ppb
056-61A	Room 108 (Office 274) Sink Faucet	6/23/16 13:42	7/8/2016	1606C80-61A	Copper	ND	1.3	ppm
056-61A	Room 108 (Office 274) Sink Faucet	6/23/16 13:42	7/8/2016	1606C80-61A	Lead	32	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Lent Elementary School

056-62A	Room 108 (Office 271) Sink Faucet	6/23/16 13:45	7/8/2016	1606C80-62A	Copper	ND	1.3	ppm
056-62A	Room 108 (Office 271) Sink Faucet	6/23/16 13:45	7/8/2016	1606C80-62A	Lead	33	15	ppb
056-63A	Room 110 (Library) Sink Faucet	6/23/16 9:54	7/8/2016	1606C80-63A	Copper	ND	1.3	ppm
056-63A	Room 110 (Library) Sink Faucet	6/23/16 9:54	7/8/2016	1606C80-63A	Lead	10	15	ppb
056-64A	Room 110 Drinking Fountain	6/23/16 9:56	7/8/2016	1606C80-64A	Copper	ND	1.3	ppm
056-64A	Room 110 Drinking Fountain	6/23/16 9:56	7/8/2016	1606C80-64A	Lead	6	15	ppb
056-65A	Room 114 Drinking Fountain	6/23/16 10:10	7/8/2016	1606C80-65A	Copper	ND	1.3	ppm
056-65A	Room 114 Drinking Fountain	6/23/16 10:10	7/8/2016	1606C80-65A	Lead	12	15	ppb
056-66A	Room 114 Sink Faucet	6/23/16 10:12	7/8/2016	1606C80-66A	Copper	ND	1.3	ppm
056-66A	Room 114 Sink Faucet	6/23/16 10:12	7/8/2016	1606C80-66A	Lead	12	15	ppb
056-67A	Room 116 Girls Bathroom Sink 1	6/23/16 10:31	7/8/2016	1606C80-67A	Copper	ND	1.3	ppm
056-67A	Room 116 Girls Bathroom Sink 1	6/23/16 10:31	7/8/2016	1606C80-67A	Lead	9	15	ppb
056-68A	Room 116 Girls Bathroom Sink 2	6/23/16 10:23	7/8/2016	1606C80-68A	Copper	ND	1.3	ppm
056-68A	Room 116 Girls Bathroom Sink 2	6/23/16 10:23	7/8/2016	1606C80-68A	Lead	7	15	ppb
056-69A	Room 116 Water Spigot	6/23/16 10:25	7/8/2016	1606C80-69A	Copper	ND	1.3	ppm
056-69A	Room 116 Water Spigot	6/23/16 10:25	7/8/2016	1606C80-69A	Lead	30	15	ppb
056-70A	Room 118 Sink Faucet	6/23/16 12:08	7/8/2016	1606C80-70A	Copper	ND	1.3	ppm
056-70A	Room 118 Sink Faucet	6/23/16 12:08	7/8/2016	1606C80-70A	Lead	21	15	ppb
056-71A	Room 118 Drinking Fountain	6/23/16 12:10	7/8/2016	1606C80-71A	Copper	ND	1.3	ppm
056-71A	Room 118 Drinking Fountain	6/23/16 12:10	7/8/2016	1606C80-71A	Lead	30	15	ppb
056-72A	Room 120 Sink Faucet	6/23/16 11:51	7/8/2016	1606C80-72A	Copper	0.3	1.3	ppm
056-72A	Room 120 Sink Faucet	6/23/16 11:51	7/8/2016	1606C80-72A	Lead	ND	15	ppb
056-73A	Room 120 Eye Wash	6/23/16 11:53	7/8/2016	1606C80-73A	Copper	0.3	1.3	ppm
056-73A	Room 120 Eye Wash	6/23/16 11:53	7/8/2016	1606C80-73A	Lead	58	15	ppb
056-74A	Room 120 Sink Faucet	6/23/16 11:55	7/8/2016	1606C80-74A	Copper	0.3	1.3	ppm
056-74A	Room 120 Sink Faucet	6/23/16 11:55	7/8/2016	1606C80-74A	Lead	ND	15	ppb
056-75A	Room 120 Drinking Fountain	6/23/16 11:56	7/8/2016	1606C80-75A	Copper	ND	1.3	ppm
056-75A	Room 120 Drinking Fountain	6/23/16 11:56	7/8/2016	1606C80-75A	Lead	11	15	ppb
056-76A	Water Dispenser Near Room 122	6/23/16 11:28	7/10/2016	1606C80-76A	Copper	2.0	1.3	ppm
056-76A	Water Dispenser Near Room 122	6/23/16 11:28	7/8/2016	1606C80-76A	Lead	ND	15	ppb
056-77A	Drinking Fountain Near Room 122	6/23/16 11:30	7/10/2016	1606C80-77A	Copper	1.0	1.3	ppm
056-77A	Drinking Fountain Near Room 122	6/23/16 11:30	7/9/2016	1606C80-77A	Lead	3	15	ppb
056-78A	Room 122 Sink Faucet #1	6/23/16 11:16	7/9/2016	1606C80-78A	Copper	0.3	1.3	ppm
056-78A	Room 122 Sink Faucet #1	6/23/16 11:16	7/9/2016	1606C80-78A	Lead	ND	15	ppb
056-79A	Room 122 Eye Wash	6/23/16 11:18	7/9/2016	1606C80-79A	Copper	0.4	1.3	ppm
056-79A	Room 122 Eye Wash	6/23/16 11:18	7/9/2016	1606C80-79A	Lead	46	15	ppb
056-80A	Room 122 Sink Faucet #2	6/23/16 11:20	7/9/2016	1606C80-80A	Copper	ND	1.3	ppm
056-80A	Room 122 Sink Faucet #2	6/23/16 11:20	7/9/2016	1606C80-80A	Lead	2	15	ppb
056-81A	Room 122 Drinking Fountain	6/23/16 11:22	7/9/2016	1606C80-81A	Copper	ND	1.3	ppm
056-81A	Room 122 Drinking Fountain	6/23/16 11:22	7/9/2016	1606C80-81A	Lead	8	15	ppb
056-82A	Room 124 Slop Sink	6/23/16 11:00	7/9/2016	1606C80-82A	Copper	ND	1.3	ppm
056-82A	Room 124 Slop Sink	6/23/16 11:00	7/9/2016	1606C80-82A	Lead	2	15	ppb
056-83A	Room 125 Drinking Fountain	6/23/16 11:04	7/9/2016	1606C80-83A	Copper	ND	1.3	ppm
056-83A	Room 125 Drinking Fountain	6/23/16 11:04	7/9/2016	1606C80-83A	Lead	16	15	ppb
056-84A	Room 125 Sink Metallic	6/23/16 11:06	7/9/2016	1606C80-84A	Copper	0.2	1.3	ppm
056-84A	Room 125 Sink Metallic	6/23/16 11:06	7/9/2016	1606C80-84A	Lead	37	15	ppb
056-85A	Room 123 Boys Restroom Sink 1	6/23/16 11:33	7/9/2016	1606C80-85A	Copper	ND	1.3	ppm
056-85A	Room 123 Boys Restroom Sink 1	6/23/16 11:33	7/9/2016	1606C80-85A	Lead	5	15	ppb
056-86A	Room 123 Boys Restroom Sink 2	6/23/16 11:35	7/9/2016	1606C80-86A	Copper	ND	1.3	ppm
056-86A	Room 123 Boys Restroom Sink 2	6/23/16 11:35	7/9/2016	1606C80-86A	Lead	8	15	ppb
056-87A	Room 123 Boys Restroom Spigot	6/23/16 11:37	7/9/2016	1606C80-87A	Copper	ND	1.3	ppm
056-87A	Room 123 Boys Restroom Spigot	6/23/16 11:37	7/9/2016	1606C80-87A	Lead	ND	15	ppb
056-88A	Room 121 Sink Faucet	6/23/16 11:42	7/9/2016	1606C80-88A	Copper	ND	1.3	ppm
056-88A	Room 121 Sink Faucet	6/23/16 11:42	7/9/2016	1606C80-88A	Lead	6	15	ppb
056-89A	Room 121 Drinking Fountain	6/23/16 11:44	7/9/2016	1606C80-89A	Copper	ND	1.3	ppm
056-89A	Room 121 Drinking Fountain	6/23/16 11:44	7/9/2016	1606C80-89A	Lead	13	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Lent Elementary School

056-90A	Room 119 Drinking Fountain	6/23/16 12:00	7/9/2016	1606C80-90A	Copper	ND	1.3	ppm
056-90A	Room 119 Drinking Fountain	6/23/16 12:00	7/9/2016	1606C80-90A	Lead	43	15	ppb
056-91A	Room 119 Sink Faucet	6/23/16 12:02	7/9/2016	1606C80-91A	Copper	ND	1.3	ppm
056-91A	Room 119 Sink Faucet	6/23/16 12:02	7/9/2016	1606C80-91A	Lead	32	15	ppb
056-92A	Room 117 Boys Restroom Sink 1	6/23/16 10:24	7/9/2016	1606C80-92A	Copper	0.2	1.3	ppm
056-92A	Room 117 Boys Restroom Sink 1	6/23/16 10:24	7/9/2016	1606C80-92A	Lead	14	15	ppb
056-93A	Room 117 Boys Restroom Sink 2	6/23/16 10:28	7/9/2016	1606C80-93A	Copper	ND	1.3	ppm
056-93A	Room 117 Boys Restroom Sink 2	6/23/16 10:28	7/9/2016	1606C80-93A	Lead	24	15	ppb
056-94A	Room 117 Boys Restroom Spigot	6/23/16 10:26	7/9/2016	1606C80-94A	Copper	0.1	1.3	ppm
056-94A	Room 117 Boys Restroom Spigot	6/23/16 10:26	7/9/2016	1606C80-94A	Lead	17	15	ppb
056-95A	Room 115 Sink Faucet	6/23/16 10:15	7/9/2016	1606C80-95A	Copper	ND	1.3	ppm
056-95A	Room 115 Sink Faucet	6/23/16 10:15	7/9/2016	1606C80-95A	Lead	7	15	ppb
056-96A	Room 115 Drinking Fountain	6/23/16 10:17	7/9/2016	1606C80-96A	Copper	ND	1.3	ppm
056-96A	Room 115 Drinking Fountain	6/23/16 10:17	7/9/2016	1606C80-96A	Lead	6	15	ppb
056-97A	Water Dispenser Near Portables Exit	6/23/16 10:03	7/8/2016	1606C80-97A	Copper	0.7	1.3	ppm
056-97A	Water Dispenser Near Portables Exit	6/23/16 10:03	7/8/2016	1606C80-97A	Lead	8	15	ppb
056-98A	Drinking Fountain Near Portables Exit	6/23/16 10:05	7/8/2016	1606C80-98A	Copper	0.3	1.3	ppm
056-98A	Drinking Fountain Near Portables Exit	6/23/16 10:05	7/8/2016	1606C80-98A	Lead	4	15	ppb
056-99A	Room 113 Sink Faucet	6/23/16 10:00	7/8/2016	1606C81-01A	Copper	ND	1.3	ppm
056-99A	Room 113 Sink Faucet	6/23/16 10:00	7/8/2016	1606C81-01A	Lead	53	15	ppb

EPA Action Level for Lead of 15 ppb

ND = Non detect

EPA Action Level for Copper of 1.3 ppm

Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.