

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Lincoln High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
058-01A Boiler Room #1 Sink Faucet	6/28/16 18:16	7/9/16 16:18	606300001	Copper	4.1	1.3	ppm
058-01A Boiler Room #1 Sink Faucet	6/28/16 18:16	7/9/16 16:18	606300001	Lead	383	15	ppb
058-02A Boiler Room #2 Sink Faucet	6/28/16 18:18	7/8/16 11:05	606300002	Copper	0.2	1.3	ppm
058-02A Boiler Room #2 Sink Faucet	6/28/16 18:18	7/8/16 11:05	606300002	Lead	303	15	ppb
058-03A Boiler Room #3 Sink Faucet	6/28/16 18:20	7/9/16 16:11	606300003	Copper	6.7	1.3	ppm
058-03A Boiler Room #3 Sink Faucet	6/28/16 18:20	7/9/16 16:11	606300003	Lead	1430	15	ppb
058-04A Boiler Room #4 Sink Faucet	6/28/16 18:20	7/9/16 16:11	606300004	Copper	2.7	1.3	ppm
058-04A Boiler Room #4 Sink Faucet	6/28/16 18:20	7/9/16 16:11	606300004	Lead	256	15	ppb
058-05A Boiler Room #5 Sink Faucet	6/28/16 18:25	7/9/16 16:11	606300005	Copper	5.6	1.3	ppm
058-05A Boiler Room #5 Sink Faucet	6/28/16 18:25	7/9/16 16:11	606300005	Lead	404	15	ppb
058-06A Boiler Room #6 Sink Faucet	6/28/16 18:30	7/9/16 16:11	606300006	Copper	2.2	1.3	ppm
058-06A Boiler Room #6 Sink Faucet	6/28/16 18:30	7/9/16 16:11	606300006	Lead	926	15	ppb
058-07A Boiler Room #7 Sink Faucet	6/28/16 18:34	7/8/16 11:05	606300007	Copper	0.1	1.3	ppm
058-07A Boiler Room #7 Sink Faucet	6/28/16 18:34	7/8/16 11:05	606300007	Lead	4	15	ppb
058-08A Boiler Room #8 Sink Faucet	6/28/16 18:37	7/8/16 11:05	606300008	Copper	0.0	1.3	ppm
058-08A Boiler Room #8 Sink Faucet	6/28/16 18:37	7/8/16 11:05	606300008	Lead	9	15	ppb
058-09A Boiler Room #9 Sink Faucet	6/28/16 18:40	7/9/16 16:11	606300009	Copper	5.7	1.3	ppm
058-09A Boiler Room #9 Sink Faucet	6/28/16 18:40	7/9/16 16:11	606300009	Lead	89	15	ppb
058-10A Office above Boiler Room #1 Sink Faucet	6/28/16 18:47	7/8/16 11:05	606300010	Copper	0.2	1.3	ppm
058-10A Office above Boiler Room #1 Sink Faucet	6/28/16 18:47	7/8/16 11:05	606300010	Lead	3	15	ppb
058-11A Office above Boiler Room #2 Sink Faucet	6/28/16 18:50	7/8/16 11:05	606300011	Copper	0.0	1.3	ppm
058-11A Office above Boiler Room #2 Sink Faucet	6/28/16 18:50	7/8/16 11:05	606300011	Lead	9	15	ppb
058-12A Sink Faucet outside Boiler Room Office	6/28/16 18:52	7/8/16 11:05	606300012	Copper	0.2	1.3	ppm
058-12A Sink Faucet outside Boiler Room Office	6/28/16 18:52	7/8/16 11:05	606300012	Lead	1	15	ppb
058-13A Sink Faucet at end of Ceramics Hallway	6/28/16 19:16	7/8/16 11:05	606300013	Copper	0.6	1.3	ppm
058-13A Sink Faucet at end of Ceramics Hallway	6/28/16 19:16	7/8/16 11:05	606300013	Lead	3	15	ppb
058-14A Sink Faucet in Room across Ceramic Classroom	6/28/16 19:18	7/8/16 11:06	606300014	Copper	0.1	1.3	ppm
058-14A Sink Faucet in Room across Ceramic Classroom	6/28/16 19:18	7/8/16 11:06	606300014	Lead	6	15	ppb
058-15A Drinking Fountain in Ceramics Hallway	6/28/16 19:20	7/8/16 11:06	606300015	Copper	0.4	1.3	ppm
058-15A Drinking Fountain in Ceramics Hallway	6/28/16 19:20	7/8/16 11:06	606300015	Lead	4	15	ppb
058-16A Sink Faucet in Faculty Restroom in Ceramics	6/28/16 19:18	7/8/16 11:06	606300016	Copper	0.1	1.3	ppm
058-16A Sink Faucet in Faculty Restroom in Ceramics	6/28/16 19:18	7/8/16 11:06	606300016	Lead	2	15	ppb
058-17A Sink Faucet in Ceramics next to Pottery Area #1	6/28/16 19:22	7/8/16 11:06	606300017	Copper	0.1	1.3	ppm
058-17A Sink Faucet in Ceramics next to Pottery Area #1	6/28/16 19:22	7/8/16 11:06	606300017	Lead	3	15	ppb
058-18A Sink Faucet in Ceramics next to Pottery Area #2	6/28/16 19:23	7/8/16 11:06	606300018	Copper	0.1	1.3	ppm
058-18A Sink Faucet in Ceramics next to Pottery Area #2	6/28/16 19:23	7/8/16 11:06	606300018	Lead	2	15	ppb
058-19A Janitor Sink Faucet	6/28/16 19:21	7/8/16 11:06	606300019	Copper	0.3	1.3	ppm
058-19A Janitor Sink Faucet	6/28/16 19:21	7/8/16 11:06	606300019	Lead	2	15	ppb
058-20A Sink Faucet in Janitor Break Area	6/28/16 19:27	7/8/16 11:06	606300020	Copper	0.1	1.3	ppm
058-20A Sink Faucet in Janitor Break Area	6/28/16 19:27	7/8/16 11:06	606300020	Lead	3	15	ppb
058-21A Sink Faucet in Mens Dressing Room	6/28/16 19:44	7/8/16 11:07	606300021	Copper	0.2	1.3	ppm
058-21A Sink Faucet in Mens Dressing Room	6/28/16 19:44	7/8/16 11:07	606300021	Lead	7	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Lincoln High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
058-22A Sink Faucet in Womens Dressing Room	6/28/16 19:42	7/8/16 11:07	606300022	Copper	0.3	1.3	ppm
058-22A Sink Faucet in Womens Dressing Room	6/28/16 19:42	7/8/16 11:07	606300022	Lead	4	15	ppb
058-23A Shower Head in Womens Dressing Room	6/28/16 18:34	7/8/16 11:07	606300023	Copper	0.4	1.3	ppm
058-23A Shower Head in Womens Dressing Room	6/28/16 18:34	7/8/16 11:07	606300023	Lead	128	15	ppb
058-24A Sink Faucet in Janitor Room	6/28/16 18:36	7/8/16 11:07	606300024	Copper	0.3	1.3	ppm
058-24A Sink Faucet in Janitor Room	6/28/16 18:36	7/8/16 11:07	606300024	Lead	17	15	ppb
058-25A Sink Faucet in Diversity Room	6/28/16 18:39	7/8/16 11:07	606300025	Copper	0.3	1.3	ppm
058-25A Sink Faucet in Diversity Room	6/28/16 18:39	7/8/16 11:07	606300025	Lead	5	15	ppb
058-26A Drinking Fountain in Cafe	6/28/16 18:41	7/8/16 11:07	606300026	Copper	1.4	1.3	ppm
058-26A Drinking Fountain in Cafe	6/28/16 18:41	7/8/16 11:07	606300026	Lead	ND	15	ppb
058-27A Bottle Refill in Cafe	6/28/16 18:43	7/8/16 11:09	606300027	Copper	0.1	1.3	ppm
058-27A Bottle Refill in Cafe	6/28/16 18:43	7/8/16 11:09	606300027	Lead	ND	15	ppb
058-28A Drinking Fountain next to 26	6/28/16 18:45	7/8/16 11:09	606300028	Copper	0.0	1.3	ppm
058-28A Drinking Fountain next to 26	6/28/16 18:45	7/8/16 11:09	606300028	Lead	ND	15	ppb
058-29A Sink Faucet in Kitchen	6/28/16 18:48	7/8/16 11:09	606300029	Copper	1.1	1.3	ppm
058-29A Sink Faucet in Kitchen	6/28/16 18:48	7/8/16 11:09	606300029	Lead	77	15	ppb
058-30A Hand Wash along Back Wall	6/28/16 18:50	7/8/16 11:09	606300030	Copper	0.1	1.3	ppm
058-30A Hand Wash along Back Wall	6/28/16 18:50	7/8/16 11:09	606300030	Lead	3	15	ppb
058-31A Dish Washing Sink Faucet #1	6/28/16 18:52	7/8/16 11:09	606300031	Copper	0.1	1.3	ppm
058-31A Dish Washing Sink Faucet #1	6/28/16 18:52	7/8/16 11:09	606300031	Lead	5	15	ppb
058-32A Dish Washing Sink Faucet #2	6/28/16 18:54	7/8/16 11:09	606300032	Copper	0.1	1.3	ppm
058-32A Dish Washing Sink Faucet #2	6/28/16 18:54	7/8/16 11:09	606300032	Lead	3	15	ppb
058-33A Faucet in Central Area	6/28/16 18:56	7/8/16 11:09	606300033	Copper	0.3	1.3	ppm
058-33A Faucet in Central Area	6/28/16 18:56	7/8/16 11:09	606300033	Lead	29	15	ppb
058-36A Sink Faucet in Library/Book Room	6/28/16 19:03	7/8/16 11:09	606300036	Copper	0.1	1.3	ppm
058-36A Sink Faucet in Library/Book Room	6/28/16 19:03	7/8/16 11:09	606300036	Lead	11	15	ppb
058-37A Sink Faucet in Girls Restroom	6/28/16 19:05	7/8/16 11:09	606300037	Copper	0.4	1.3	ppm
058-37A Sink Faucet in Girls Restroom	6/28/16 19:05	7/8/16 11:09	606300037	Lead	4	15	ppb
058-38A Sink Faucet in Boys Restroom	6/28/16 19:08	7/8/16 11:09	606300038	Copper	0.4	1.3	ppm
058-38A Sink Faucet in Boys Restroom	6/28/16 19:08	7/8/16 11:09	606300038	Lead	2	15	ppb
058-39A Sink Faucet in Boys Locker Room	6/28/16 19:35	7/8/16 11:09	606300039	Copper	0.7	1.3	ppm
058-39A Sink Faucet in Boys Locker Room	6/28/16 19:35	7/8/16 11:09	606300039	Lead	4	15	ppb
058-40A Drinking Fountain in Boys Locker Room #1	6/28/16 19:37	7/8/16 11:09	606300040	Copper	0.4	1.3	ppm
058-40A Drinking Fountain in Boys Locker Room #1	6/28/16 19:37	7/8/16 11:09	606300040	Lead	2	15	ppb
058-41A Drinking Fountain in Boys Locker Room #2	6/28/16 19:39	7/8/16 11:09	606300041	Copper	0.1	1.3	ppm
058-41A Drinking Fountain in Boys Locker Room #2	6/28/16 19:39	7/8/16 11:09	606300041	Lead	1	15	ppb
058-42A Sink Faucet in Boys Locker Room	6/28/16 19:41	7/9/16 16:12	606300042	Copper	3.7	1.3	ppm
058-42A Sink Faucet in Boys Locker Room	6/28/16 19:41	7/9/16 16:12	606300042	Lead	1950	15	ppb
058-43A Boys Locker Room Shower #1	6/28/16 19:45	7/8/16 11:09	606300043	Copper	0.6	1.3	ppm
058-43A Boys Locker Room Shower #1	6/28/16 19:45	7/8/16 11:09	606300043	Lead	1	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Lincoln High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
058-44A Boys Locker Room Shower #2	6/28/16 19:47	7/8/16 11:09	606300044	Copper	0.6	1.3	ppm
058-44A Boys Locker Room Shower #2	6/28/16 19:47	7/8/16 11:09	606300044	Lead	10	15	ppb
058-45A Boys Locker Room Shower #3	6/28/16 19:49	7/8/16 11:09	606300045	Copper	0.8	1.3	ppm
058-45A Boys Locker Room Shower #3	6/28/16 19:49	7/8/16 11:09	606300045	Lead	18	15	ppb
058-46A Boys Locker Room Shower #4	6/28/16 19:51	7/8/16 11:09	606300046	Copper	0.3	1.3	ppm
058-46A Boys Locker Room Shower #4	6/28/16 19:51	7/8/16 11:09	606300046	Lead	2	15	ppb
058-47A Boys Locker Room Shower #5	6/28/16 19:53	7/8/16 11:09	606300047	Copper	0.7	1.3	ppm
058-47A Boys Locker Room Shower #5	6/28/16 19:53	7/8/16 11:09	606300047	Lead	13	15	ppb
058-48A Boys Locker Room Shower #6	6/28/16 19:55	7/8/16 11:09	606300048	Copper	0.5	1.3	ppm
058-48A Boys Locker Room Shower #6	6/28/16 19:55	7/8/16 11:09	606300048	Lead	9	15	ppb
058-49A Boys Locker Room Shower #7	6/28/16 19:57	7/8/16 11:09	606300049	Copper	0.5	1.3	ppm
058-49A Boys Locker Room Shower #7	6/28/16 19:57	7/8/16 11:09	606300049	Lead	12	15	ppb
058-50A Boys Locker Room Shower #8	6/28/16 19:59	7/8/16 11:10	606300050	Copper	0.4	1.3	ppm
058-50A Boys Locker Room Shower #8	6/28/16 19:59	7/8/16 11:10	606300050	Lead	8	15	ppb
058-52A Boys Locker Room Shower #9	6/28/16 20:03	7/8/16 11:10	606300052	Copper	0.5	1.3	ppm
058-52A Boys Locker Room Shower #9	6/28/16 20:03	7/8/16 11:10	606300052	Lead	14.8	15	ppb
058-53A Boys Locker Room Shower #10	6/28/16 20:05	7/8/16 11:10	606300053	Copper	0.6	1.3	ppm
058-53A Boys Locker Room Shower #10	6/28/16 20:05	7/8/16 11:10	606300053	Lead	19	15	ppb
058-54A Boys Locker Room Shower #11	6/28/16 20:07	7/8/16 11:10	606300054	Copper	0.4	1.3	ppm
058-54A Boys Locker Room Shower #11	6/28/16 20:07	7/8/16 11:10	606300054	Lead	12	15	ppb
058-55A Boys Locker Room Shower #12	6/28/16 20:09	7/8/16 11:10	606300055	Copper	0.4	1.3	ppm
058-55A Boys Locker Room Shower #12	6/28/16 20:09	7/8/16 11:10	606300055	Lead	12	15	ppb
058-56A Boys Locker Room Shower #13	6/28/16 20:11	7/8/16 11:10	606300056	Copper	0.5	1.3	ppm
058-56A Boys Locker Room Shower #13	6/28/16 20:11	7/8/16 11:10	606300056	Lead	8	15	ppb
058-57A Boys Locker Room Shower #14	6/28/16 20:13	7/8/16 11:10	606300057	Copper	0.5	1.3	ppm
058-57A Boys Locker Room Shower #14	6/28/16 20:13	7/8/16 11:10	606300057	Lead	9	15	ppb
058-58A Boys Locker Room Shower #15	6/28/16 20:15	7/8/16 11:10	606300058	Copper	0.1	1.3	ppm
058-58A Boys Locker Room Shower #15	6/28/16 20:15	7/8/16 11:10	606300058	Lead	2	15	ppb
058-59A Boys Locker Room Shower #16	6/28/16 20:17	7/8/16 11:10	606300059	Copper	0.4	1.3	ppm
058-59A Boys Locker Room Shower #16	6/28/16 20:17	7/8/16 11:10	606300059	Lead	9	15	ppb
058-60A Boys Locker Room Shower #17	6/28/16 20:19	7/8/16 11:10	606300060	Copper	0.5	1.3	ppm
058-60A Boys Locker Room Shower #17	6/28/16 20:19	7/8/16 11:10	606300060	Lead	6	15	ppb
058-61A Boys Locker Room Shower #18	6/28/16 20:21	7/8/16 11:10	606300061	Copper	0.6	1.3	ppm
058-61A Boys Locker Room Shower #18	6/28/16 20:21	7/8/16 11:10	606300061	Lead	13	15	ppb
058-62A Showerhead in Coaches Office Boys Locker Room	6/28/16 20:23	7/8/16 11:10	606300062	Copper	0.3	1.3	ppm
058-62A Showerhead in Coaches Office Boys Locker Room	6/28/16 20:23	7/8/16 11:10	606300062	Lead	2	15	ppb
058-63A Sink Faucet in Coaches Office of Boys Locker Room #1	6/28/16 20:25	7/8/16 11:10	606300063	Copper	0.4	1.3	ppm
058-63A Sink Faucet in Coaches Office of Boys Locker Room #1	6/28/16 20:25	7/8/16 11:10	606300063	Lead	10	15	ppb
058-64A Sink Faucet in Coaches Office of Boys Locker Room #2	6/28/16 20:28	7/8/16 11:10	606300064	Copper	0.2	1.3	ppm
058-64A Sink Faucet in Coaches Office of Boys Locker Room #2	6/28/16 20:28	7/8/16 11:10	606300064	Lead	3	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Lincoln High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
058-65A Sink Faucet in Boys Locker Room New Showers	6/28/16 20:31	7/8/16 11:10	606300065	Copper	0.4	1.3	ppm
058-65A Sink Faucet in Boys Locker Room New Showers	6/28/16 20:31	7/8/16 11:10	606300065	Lead	41	15	ppb
058-66A Ice Machine in Training Room	6/28/16 20:34	7/8/16 11:11	606300066	Copper	0.0	1.3	ppm
058-66A Ice Machine in Training Room	6/28/16 20:34	7/8/16 11:11	606300066	Lead	ND	15	ppb
058-67A Ice Bath Sink Faucet in Training Room #1	6/28/16 20:20	7/9/16 16:11	606300067	Copper	2.9	1.3	ppm
058-67A Ice Bath Sink Faucet in Training Room #1	6/28/16 20:20	7/9/16 16:11	606300067	Lead	173	15	ppb
058-68A Ice Bath Sink Faucet in Training Room #2	6/28/16 20:15	7/8/16 11:11	606300068	Copper	0.3	1.3	ppm
058-68A Ice Bath Sink Faucet in Training Room #2	6/28/16 20:15	7/8/16 11:11	606300068	Lead	10	15	ppb
058-69A Spigot in Team Room F	6/28/16 20:20	7/8/16 11:11	606300069	Copper	0.4	1.3	ppm
058-69A Spigot in Team Room F	6/28/16 20:20	7/8/16 11:11	606300069	Lead	156	15	ppb
058-70A Spigot in Team Room E	6/28/16 20:26	7/8/16 11:11	606300070	Copper	0.6	1.3	ppm
058-70A Spigot in Team Room E	6/28/16 20:26	7/8/16 11:11	606300070	Lead	152	15	ppb
058-71A Sink Faucet in Team Room D	6/28/16 20:27	7/8/16 11:11	606300071	Copper	0.3	1.3	ppm
058-71A Sink Faucet in Team Room D	6/28/16 20:27	7/8/16 11:11	606300071	Lead	4	15	ppb
058-72A Spigot in Team Room D Bathroom	6/28/16 20:29	7/8/16 11:12	606300072	Copper	0.5	1.3	ppm
058-72A Spigot in Team Room D Bathroom	6/28/16 20:29	7/8/16 11:12	606300072	Lead	50	15	ppb
058-73A Sink Faucet in Coach Locker Room Girls Locker Room	6/28/16 20:39	7/8/16 11:12	606300073	Copper	0.4	1.3	ppm
058-73A Sink Faucet in Coach Locker Room Girls Locker Room	6/28/16 20:39	7/8/16 11:12	606300073	Lead	5	15	ppb
058-74A Shower in Coach Locker Room of Girls Locker Room	6/28/16 20:42	7/8/16 11:12	606300074	Copper	0.1	1.3	ppm
058-74A Shower in Coach Locker Room of Girls Locker Room	6/28/16 20:42	7/8/16 11:12	606300074	Lead	40	15	ppb
058-75A Drinking Fountain in Girls Locker Room #1	6/28/16 20:45	7/8/16 11:12	606300075	Copper	0.0	1.3	ppm
058-75A Drinking Fountain in Girls Locker Room #1	6/28/16 20:45	7/8/16 11:12	606300075	Lead	0	15	ppb
058-76A Drinking Fountain in Girls Locker Room #2	6/28/16 20:48	7/8/16 11:12	606300076	Copper	0.1	1.3	ppm
058-76A Drinking Fountain in Girls Locker Room #2	6/28/16 20:48	7/8/16 11:12	606300076	Lead	ND	15	ppb
058-77A Sink Faucet in Girls Locker Room by Showers	6/28/16 21:00	7/8/16 11:12	606300077	Copper	0.1	1.3	ppm
058-77A Sink Faucet in Girls Locker Room by Showers	6/28/16 21:00	7/8/16 11:12	606300077	Lead	2	15	ppb
058-78A Girls Locker Room Shower #1	6/28/16 21:04	7/8/16 11:12	606300078	Copper	0.5	1.3	ppm
058-78A Girls Locker Room Shower #1	6/28/16 21:04	7/8/16 11:12	606300078	Lead	36	15	ppb
058-79A Girls Locker Room Shower #2	6/28/16 21:07	7/8/16 11:12	606300079	Copper	0.1	1.3	ppm
058-79A Girls Locker Room Shower #2	6/28/16 21:07	7/8/16 11:12	606300079	Lead	3	15	ppb
058-80A Girls Locker Room Shower #3	6/28/16 21:10	7/8/16 11:12	606300080	Copper	0.3	1.3	ppm
058-80A Girls Locker Room Shower #3	6/28/16 21:10	7/8/16 11:12	606300080	Lead	63	15	ppb
058-81A Girls Locker Room Shower #4	6/28/16 21:12	7/8/16 11:12	606300081	Copper	0.4	1.3	ppm
058-81A Girls Locker Room Shower #4	6/28/16 21:12	7/8/16 11:12	606300081	Lead	61	15	ppb
058-82A Girls Locker Room Shower #5	6/28/16 21:15	7/8/16 11:13	606300082	Copper	0.3	1.3	ppm
058-82A Girls Locker Room Shower #5	6/28/16 21:15	7/8/16 11:13	606300082	Lead	71	15	ppb
058-83A Girls Locker Room Shower #6	6/28/16 21:19	7/8/16 11:13	606300083	Copper	0.3	1.3	ppm
058-83A Girls Locker Room Shower #6	6/28/16 21:19	7/8/16 11:13	606300083	Lead	49	15	ppb
058-84A Girls Locker Room Shower #7	6/28/16 21:22	7/8/16 11:13	606300084	Copper	0.1	1.3	ppm
058-84A Girls Locker Room Shower #7	6/28/16 21:22	7/8/16 11:13	606300084	Lead	9	15	ppb
058-85A Girls Locker Room Shower #8	6/28/16 21:24	7/8/16 11:13	606300085	Copper	0.4	1.3	ppm
058-85A Girls Locker Room Shower #8	6/28/16 21:24	7/8/16 11:13	606300085	Lead	73	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Lincoln High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
058-86A Girls Locker Room Shower #9	6/28/16 21:25	7/8/16 11:13	606300086	Copper	0.3	1.3	ppm
058-86A Girls Locker Room Shower #9	6/28/16 21:25	7/8/16 11:13	606300086	Lead	38	15	ppb
058-87A Girls Locker Room Shower #10	6/28/16 21:26	7/8/16 11:13	606300087	Copper	0.4	1.3	ppm
058-87A Girls Locker Room Shower #10	6/28/16 21:26	7/8/16 11:13	606300087	Lead	55	15	ppb
058-88A Girls Locker Room Shower #11	6/28/16 21:28	7/8/16 11:13	606300088	Copper	0.6	1.3	ppm
058-88A Girls Locker Room Shower #11	6/28/16 21:28	7/8/16 11:13	606300088	Lead	19	15	ppb
058-89A Girls Locker Room Shower #12	6/28/16 21:30	7/8/16 11:13	606300089	Copper	0.6	1.3	ppm
058-89A Girls Locker Room Shower #12	6/28/16 21:30	7/8/16 11:13	606300089	Lead	5	15	ppb
058-90A Girls Locker Room Shower #13	6/28/16 21:32	7/8/16 11:13	606300090	Copper	0.7	1.3	ppm
058-90A Girls Locker Room Shower #13	6/28/16 21:32	7/8/16 11:13	606300090	Lead	127	15	ppb
058-91A Girls Locker Room Shower #14	6/28/16 21:34	7/8/16 11:13	606300091	Copper	0.8	1.3	ppm
058-91A Girls Locker Room Shower #14	6/28/16 21:34	7/8/16 11:13	606300091	Lead	70	15	ppb
058-92A Girls Locker Room Shower #15	6/28/16 21:26	7/8/16 11:13	606300092	Copper	0.8	1.3	ppm
058-92A Girls Locker Room Shower #15	6/28/16 21:26	7/8/16 11:13	606300092	Lead	68	15	ppb
058-93A Girls Locker Room Shower #16	6/28/16 21:27	7/8/16 11:14	606300093	Copper	1.0	1.3	ppm
058-93A Girls Locker Room Shower #16	6/28/16 21:27	7/8/16 11:14	606300093	Lead	8	15	ppb
058-94A Custodial Closet Sink Faucet	6/28/16 22:03	7/8/16 11:14	606300094	Copper	0.5	1.3	ppm
058-94A Custodial Closet Sink Faucet	6/28/16 22:03	7/8/16 11:14	606300094	Lead	9	15	ppb
058-95A Drinking Fountain in Weight Room #1	6/28/16 21:49	7/8/16 11:14	606300095	Copper	1.2	1.3	ppm
058-95A Drinking Fountain in Weight Room #1	6/28/16 21:49	7/8/16 11:14	606300095	Lead	6	15	ppb
058-96A Drinking Fountain in Weight Room #2	6/28/16 21:44	7/8/16 11:14	606300096	Copper	0.5	1.3	ppm
058-96A Drinking Fountain in Weight Room #2	6/28/16 21:44	7/8/16 11:14	606300096	Lead	2	15	ppb
058-97A Spigot in Janitor Closet in Room 701 Basement	6/28/16 22:04	7/8/16 11:14	606300097	Copper	0.2	1.3	ppm
058-97A Spigot in Janitor Closet in Room 701 Basement	6/28/16 22:04	7/8/16 11:14	606300097	Lead	21	15	ppb
058-98A Drinking Fountain in Gym #1	6/28/16 22:17	7/8/16 11:14	606300098	Copper	1.2	1.3	ppm
058-98A Drinking Fountain in Gym #1	6/28/16 22:17	7/8/16 11:14	606300098	Lead	2	15	ppb
058-99A Drinking Fountain in Gym #2	6/28/16 22:20	7/8/16 11:14	606300099	Copper	0.4	1.3	ppm
058-99A Drinking Fountain in Gym #2	6/28/16 22:20	7/8/16 11:14	606300099	Lead	2	15	ppb
058-100A Sink Faucet inside Room 107	6/28/16 21:11	7/8/16 11:14	6063000100	Copper	0.5	1.3	ppm
058-100A Sink Faucet inside Room 107	6/28/16 21:11	7/8/16 11:14	6063000100	Lead	3	15	ppb
058-101A Dishwash Sink Faucet inside Room 107	6/28/16 21:13	7/8/16 11:14	6063000101	Copper	0.7	1.3	ppm
058-101A Dishwash Sink Faucet inside Room 107	6/28/16 21:13	7/8/16 11:14	6063000101	Lead	0	15	ppb
058-102A Bottle Refill in Hall outside Gym	6/28/16 21:15	7/8/16 11:15	6063000102	Copper	1.25	1.3	ppm
058-102A Bottle Refill in Hall outside Gym	6/28/16 21:15	7/8/16 11:15	6063000102	Lead	ND	15	ppb
058-103A Drinking Fountain in Hall outside Gym #1	6/28/16 21:17	7/8/16 11:15	6063000103	Copper	0.7	1.3	ppm
058-103A Drinking Fountain in Hall outside Gym #1	6/28/16 21:17	7/8/16 11:15	6063000103	Lead	ND	15	ppb
058-104A Drinking Fountain in Hall outside Gym #2	6/28/16 21:19	7/8/16 11:16	6063000104	Copper	0.3	1.3	ppm
058-104A Drinking Fountain in Hall outside Gym #2	6/28/16 21:19	7/8/16 11:16	6063000104	Lead	3	15	ppb
058-105A Drinking Fountain in Hall outside Gym #3	6/28/16 21:21	7/8/16 11:16	6063000105	Copper	0.1	1.3	ppm
058-105A Drinking Fountain in Hall outside Gym #3	6/28/16 21:21	7/8/16 11:16	6063000105	Lead	2	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Lincoln High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
058-106A Sink Faucet in Boys Restroom outside Gym #1	6/28/16 21:24	7/8/16 11:16	6063000106	Copper	0.3	1.3	ppm
058-106A Sink Faucet in Boys Restroom outside Gym #1	6/28/16 21:24	7/8/16 11:16	6063000106	Lead	4	15	ppb
058-107A Sink Faucet in Boys Restroom outside Gym #2	6/28/16 21:26	7/8/16 11:16	6063000107	Copper	0.2	1.3	ppm
058-107A Sink Faucet in Boys Restroom outside Gym #2	6/28/16 21:26	7/8/16 11:16	6063000107	Lead	4	15	ppb
058-108A Sink Faucet in Boys Restroom outside Gym #3	6/28/16 21:28	7/8/16 11:16	6063000108	Copper	0.1	1.3	ppm
058-108A Sink Faucet in Boys Restroom outside Gym #3	6/28/16 21:28	7/8/16 11:16	6063000108	Lead	2	15	ppb
058-109A Sink Faucet in Boys Restroom outside Gym #4	6/28/16 21:30	7/8/16 11:16	6063000109	Copper	0.1	1.3	ppm
058-109A Sink Faucet in Boys Restroom outside Gym #4	6/28/16 21:30	7/8/16 11:16	6063000109	Lead	5	15	ppb
058-110A Sink Faucet in Boys Restroom outside Gym #5	6/28/16 21:32	7/8/16 11:16	6063000110	Copper	0.1	1.3	ppm
058-110A Sink Faucet in Boys Restroom outside Gym #5	6/28/16 21:32	7/8/16 11:16	6063000110	Lead	2	15	ppb
058-111A Spigot inside Boys Restroom	6/28/16 21:34	7/8/16 11:16	6063000111	Copper	0.5	1.3	ppm
058-111A Spigot inside Boys Restroom	6/28/16 21:34	7/8/16 11:16	6063000111	Lead	17	15	ppb
058-112A Sink Faucet in office, Back Room	6/28/16 21:44	7/9/16 16:24	6063000112	Copper	0.5	1.3	ppm
058-112A Sink Faucet in office, Back Room	6/28/16 21:44	7/9/16 16:24	6063000112	Lead	3	15	ppb
058-113A Sink Faucet in Boys Restroom far left near Office	6/28/16 21:46	7/9/16 16:24	6063000113	Copper	0.1	1.3	ppm
058-113A Sink Faucet in Boys Restroom far left near Office	6/28/16 21:46	7/9/16 16:24	6063000113	Lead	6	15	ppb
058-114A Spigot in Boys Restroom near Office #1	6/28/16 21:48	7/9/16 16:24	6063000114	Copper	0.3	1.3	ppm
058-114A Spigot in Boys Restroom near Office #1	6/28/16 21:48	7/9/16 16:24	6063000114	Lead	10	15	ppb
058-115A Spigot in Boys Restroom near Office #2	6/28/16 21:50	7/9/16 16:25	6063000115	Copper	0.2	1.3	ppm
058-115A Spigot in Boys Restroom near Office #2	6/28/16 21:50	7/9/16 16:25	6063000115	Lead	6	15	ppb
058-116A Drinking Fountain in Hallway outside Boys Restroom #1	6/28/16 21:58	7/9/16 16:25	6063000116	Copper	0.2	1.3	ppm
058-116A Drinking Fountain in Hallway outside Boys Restroom #1	6/28/16 21:58	7/9/16 16:25	6063000116	Lead	4	15	ppb
058-117A Drinking Fountain in Hallway outside Boys Restroom #2	6/28/16 22:00	7/9/16 16:25	6063000117	Copper	0.2	1.3	ppm
058-117A Drinking Fountain in Hallway outside Boys Restroom #2	6/28/16 22:00	7/9/16 16:25	6063000117	Lead	2	15	ppb
058-118A Drinking Fountain in Hallway outside Boys Restroom #3	6/28/16 22:02	7/9/16 16:25	6063000118	Copper	0.2	1.3	ppm
058-118A Drinking Fountain in Hallway outside Boys Restroom #3	6/28/16 22:02	7/9/16 16:25	6063000118	Lead	2	15	ppb
058-119A Sink Faucet in Room 167 #1	6/28/16 22:05	7/9/16 16:25	6063000119	Copper	1.0	1.3	ppm
058-119A Sink Faucet in Room 167 #1	6/28/16 22:05	7/9/16 16:25	6063000119	Lead	7	15	ppb
058-120A Sink Faucet in Room 167 #2	6/28/16 22:07	7/9/16 16:25	6063000120	Copper	0.7	1.3	ppm
058-120A Sink Faucet in Room 167 #2	6/28/16 22:07	7/9/16 16:25	6063000120	Lead	6	15	ppb
058-121A Sink Faucet inside Boys Changing Room 167 #1	6/28/16 22:07	7/9/16 16:25	6063000121	Copper	0.7	1.3	ppm
058-121A Sink Faucet inside Boys Changing Room 167 #1	6/28/16 22:07	7/9/16 16:25	6063000121	Lead	4	15	ppb
058-122A Sink Faucet inside Boys Changing Room 167 #2	6/28/16 22:09	7/9/16 16:25	6063000122	Copper	1.0	1.3	ppm
058-122A Sink Faucet inside Boys Changing Room 167 #2	6/28/16 22:09	7/9/16 16:25	6063000122	Lead	14	15	ppb
058-123A Janitor Closet Spigot Room 138	6/28/16 22:12	7/9/16 16:25	6063000123	Copper	0.2	1.3	ppm
058-123A Janitor Closet Spigot Room 138	6/28/16 22:12	7/9/16 16:25	6063000123	Lead	5	15	ppb
058-124A Sink Faucet Faculty Womens Restroom across from Room 140 #1	6/28/16 22:14	7/9/16 16:25	6063000124	Copper	0.2	1.3	ppm
058-124A Sink Faucet Faculty Womens Restroom across from Room 140 #1	6/28/16 22:14	7/9/16 16:25	6063000124	Lead	7	15	ppb
058-125A Sink Faucet Faculty Womens Restroom across from Room 140 #2	6/28/16 22:16	7/9/16 16:25	6063000125	Copper	0.3	1.3	ppm
058-125A Sink Faucet Faculty Womens Restroom across from Room 140 #2	6/28/16 22:16	7/9/16 16:25	6063000125	Lead	3	15	ppb
058-126A Sink Faucet Girls Restroom next to Room 140 #1	6/28/16 22:19	7/9/16 16:26	6063000126	Copper	0.4	1.3	ppm
058-126A Sink Faucet Girls Restroom next to Room 140 #1	6/28/16 22:19	7/9/16 16:26	6063000126	Lead	25	15	ppb
058-127A Sink Faucet Girls Restroom next to Room 140 #2	6/28/16 22:21	7/9/16 16:26	6063000127	Copper	0.0	1.3	ppm
058-127A Sink Faucet Girls Restroom next to Room 140 #2	6/28/16 22:21	7/9/16 16:26	6063000127	Lead	1	15	ppb
058-128A Sink Faucet Girls Restroom next to Room 140 #3	6/28/16 22:23	7/9/16 16:27	6063000128	Copper	0.2	1.3	ppm
058-128A Sink Faucet Girls Restroom next to Room 140 #3	6/28/16 22:23	7/9/16 16:27	6063000128	Lead	4	15	ppb
058-129A Sink Faucet Girls Restroom next to Room 140 #4	6/28/16 22:25	7/9/16 16:27	6063000129	Copper	0.1	1.3	ppm
058-129A Sink Faucet Girls Restroom next to Room 140 #4	6/28/16 22:25	7/9/16 16:27	6063000129	Lead	2	15	ppb
058-130A Sink Faucet Girls Restroom next to Room 140 #5	6/28/16 22:27	7/9/16 16:27	6063000130	Copper	0.1	1.3	ppm
058-130A Sink Faucet Girls Restroom next to Room 140 #5	6/28/16 22:27	7/9/16 16:27	6063000130	Lead	4	15	ppb
058-131A Spigot in Womens Restroom next to Room 140 #1	6/28/16 22:30	7/9/16 16:27	6063000131	Copper	0.4	1.3	ppm
058-131A Spigot in Womens Restroom next to Room 140 #1	6/28/16 22:30	7/9/16 16:27	6063000131	Lead	19	15	ppb
058-132A Spigot in Womens Restroom next to Room 140 #2	6/28/16 22:32	7/9/16 16:27	6063000132	Copper	0.6	1.3	ppm
058-132A Spigot in Womens Restroom next to Room 140 #2	6/28/16 22:32	7/9/16 16:27	6063000132	Lead	31	15	ppb
058-133A Drinking Fountain at end of Hallway in between 145 & 144 #1	6/28/16 22:40	7/9/16 16:27	6063000133	Copper	1.2	1.3	ppm
058-133A Drinking Fountain at end of Hallway in between 145 & 144 #1	6/28/16 22:40	7/9/16 16:27	6063000133	Lead	2	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Lincoln High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
058-134A Drinking Fountain at end of Hallway in between 145 & 144 #2	6/28/16 22:42	7/9/16 16:27	6063000134	Copper	1.0	1.3	ppm
058-134A Drinking Fountain at end of Hallway in between 145 & 144 #2	6/28/16 22:42	7/9/16 16:27	6063000134	Lead	2	15	ppb
058-135A Drinking Fountain at end of Hallway in between 145 & 144 #3	6/28/16 22:44	7/9/16 16:27	6063000135	Copper	1.0	1.3	ppm
058-135A Drinking Fountain at end of Hallway in between 145 & 144 #3	6/28/16 22:44	7/9/16 16:27	6063000135	Lead	1	15	ppb
058-136A Janitor Sink across Gym	6/28/16 22:50	7/9/16 16:39	6063000136	Copper	0.1	1.3	ppm
058-136A Janitor Sink across Gym	6/28/16 22:50	7/9/16 16:39	6063000136	Lead	9	15	ppb
058-137A Sink Faucet in Womens Restroom outside Gym #1	6/28/16 22:53	7/9/16 16:39	6063000137	Copper	0.2	1.3	ppm
058-137A Sink Faucet in Womens Restroom outside Gym #1	6/28/16 22:53	7/9/16 16:39	6063000137	Lead	1	15	ppb
058-138A Sink Faucet in Womens Restroom outside Gym #2	6/28/16 22:55	7/9/16 16:39	6063000138	Copper	0.2	1.3	ppm
058-138A Sink Faucet in Womens Restroom outside Gym #2	6/28/16 22:55	7/9/16 16:39	6063000138	Lead	3	15	ppb
058-139A Sink Faucet in Womens Restroom outside Gym #3	6/28/16 22:57	7/9/16 16:39	6063000139	Copper	0.2	1.3	ppm
058-139A Sink Faucet in Womens Restroom outside Gym #3	6/28/16 22:57	7/9/16 16:39	6063000139	Lead	5	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Lincoln High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
058-140A Sink Faucet in Womens Restroom outside Gym #4	6/28/16 22:59	7/9/16 16:39	6063000140	Copper	0.3	1.3	ppm
058-140A Sink Faucet in Womens Restroom outside Gym #4	6/28/16 22:59	7/9/16 16:39	6063000140	Lead	5	15	ppb
058-141A Sink Faucet in Womens Restroom outside Gym #5	6/28/16 23:01	7/9/16 16:39	6063000141	Copper	0.3	1.3	ppm
058-141A Sink Faucet in Womens Restroom outside Gym #5	6/28/16 23:01	7/9/16 16:39	6063000141	Lead	4	15	ppb
058-142A Sink Faucet in Nurses Office Room 126	6/28/16 23:04	7/9/16 16:39	6063000142	Copper	0.3	1.3	ppm
058-142A Sink Faucet in Nurses Office Room 126	6/28/16 23:04	7/9/16 16:39	6063000142	Lead	6	15	ppb
058-143A Sink Faucet in Police Office Room 126	6/28/16 23:06	7/9/16 16:39	6063000143	Copper	0.6	1.3	ppm
058-143A Sink Faucet in Police Office Room 126	6/28/16 23:06	7/9/16 16:39	6063000143	Lead	26	15	ppb
058-144A Sink Faucet in Mens Staff Room next to 117	6/28/16 22:37	7/9/16 16:39	6063000144	Copper	0.1	1.3	ppm
058-144A Sink Faucet in Mens Staff Room next to 117	6/28/16 22:37	7/9/16 16:39	6063000144	Lead	3	15	ppb
058-145A Sink Faucet in Room 117	6/28/16 22:35	7/9/16 16:39	6063000145	Copper	0.1	1.3	ppm
058-145A Sink Faucet in Room 117	6/28/16 22:35	7/9/16 16:39	6063000145	Lead	5	15	ppb
058-146A Sink Faucet in Room 125	6/28/16 22:42	7/9/16 16:44	6063000146	Copper	0.3	1.3	ppm
058-146A Sink Faucet in Room 125	6/28/16 22:42	7/9/16 16:44	6063000146	Lead	60	15	ppb
058-147A Sink Faucet in Room 120	6/28/16 22:47	7/9/16 16:44	6063000147	Copper	0.1	1.3	ppm
058-147A Sink Faucet in Room 120	6/28/16 22:47	7/9/16 16:44	6063000147	Lead	3	15	ppb
058-148A Sink Faucet in Room 124 #1	6/28/16 22:47	7/9/16 16:44	6063000148	Copper	0.4	1.3	ppm
058-148A Sink Faucet in Room 124 #1	6/28/16 22:47	7/9/16 16:44	6063000148	Lead	6	15	ppb
058-149A Sink Faucet in Room 124 #2	6/28/16 22:47	7/9/16 16:44	6063000149	Copper	0.5	1.3	ppm
058-149A Sink Faucet in Room 124 #2	6/28/16 22:47	7/9/16 16:44	6063000149	Lead	7	15	ppb
058-150A Sink Faucet in Room 124 #3	6/28/16 22:52	7/9/16 16:44	6063000150	Copper	0.7	1.3	ppm
058-150A Sink Faucet in Room 124 #3	6/28/16 22:52	7/9/16 16:44	6063000150	Lead	21	15	ppb
058-151A Drinking Fountain in between Room 124 & 123 #1	6/28/16 22:27	7/9/16 16:44	6063000151	Copper	1.0	1.3	ppm
058-151A Drinking Fountain in between Room 124 & 123 #1	6/28/16 22:27	7/9/16 16:44	6063000151	Lead	2	15	ppb
058-152A Drinking Fountain in between Room 124 & 123 #2	6/28/16 22:28	7/9/16 16:44	6063000152	Copper	0.8	1.3	ppm
058-152A Drinking Fountain in between Room 124 & 123 #2	6/28/16 22:28	7/9/16 16:44	6063000152	Lead	2	15	ppb
058-153A Drinking Fountain in between Room 124 & 123 #3	6/28/16 23:00	7/9/16 16:44	6063000153	Copper	0.8	1.3	ppm
058-153A Drinking Fountain in between Room 124 & 123 #3	6/28/16 23:00	7/9/16 16:44	6063000153	Lead	1	15	ppb
058-154A Sink Faucet in Room 123	6/28/16 23:01	7/9/16 16:44	6063000154	Copper	0.6	1.3	ppm
058-154A Sink Faucet in Room 123	6/28/16 23:01	7/9/16 16:44	6063000154	Lead	5	15	ppb
058-155A Sink Faucet inside Room 123 #1	6/28/16 23:01	7/9/16 16:44	6063000155	Copper	0.4	1.3	ppm
058-155A Sink Faucet inside Room 123 #1	6/28/16 23:01	7/9/16 16:44	6063000155	Lead	5	15	ppb
058-156A Sink Faucet inside Room 123 #2	6/28/16 23:04	7/9/16 16:45	6063000156	Copper	0.7	1.3	ppm
058-156A Sink Faucet inside Room 123 #2	6/28/16 23:04	7/9/16 16:45	6063000156	Lead	9	15	ppb
058-157A Sink Faucet inside Room 123 #3	6/28/16 23:04	7/9/16 16:45	6063000157	Copper	0.6	1.3	ppm
058-157A Sink Faucet inside Room 123 #3	6/28/16 23:04	7/9/16 16:45	6063000157	Lead	12	15	ppb
058-158A Sink Faucet inside Room 123 #4	6/28/16 23:03	7/9/16 16:45	6063000158	Copper	0.8	1.3	ppm
058-158A Sink Faucet inside Room 123 #4	6/28/16 23:03	7/9/16 16:45	6063000158	Lead	9	15	ppb
058-159A Sink Faucet inside Room 215 #1	6/29/16 2:27	7/9/16 16:45	6063000159	Copper	0.9	1.3	ppm
058-159A Sink Faucet inside Room 215 #1	6/29/16 2:27	7/9/16 16:45	6063000159	Lead	22	15	ppb
058-160A Sink Faucet inside Room 215 #2	6/29/16 2:27	7/9/16 16:45	6063000160	Copper	0.7	1.3	ppm
058-160A Sink Faucet inside Room 215 #2	6/29/16 2:27	7/9/16 16:45	6063000160	Lead	12	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Lincoln High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
058-161A Sink Faucet inside Room 215 #3	6/29/16 2:29	7/9/16 16:45	6063000161	Copper	0.7	1.3	ppm
058-161A Sink Faucet inside Room 215 #3	6/29/16 2:29	7/9/16 16:45	6063000161	Lead	23	15	ppb
058-162A Sink Faucet inside Room 215 #4	6/29/16 2:21	7/9/16 16:45	6063000162	Copper	0.8	1.3	ppm
058-162A Sink Faucet inside Room 215 #4	6/29/16 2:21	7/9/16 16:45	6063000162	Lead	17	15	ppb
058-163A Sink Faucet inside Room 215 #5	6/29/16 2:24	7/9/16 16:45	6063000163	Copper	1.2	1.3	ppm
058-163A Sink Faucet inside Room 215 #5	6/29/16 2:24	7/9/16 16:45	6063000163	Lead	9	15	ppb
058-164A Sink Faucet inside Room 215 #6	6/29/16 2:34	7/9/16 16:45	6063000164	Copper	0.5	1.3	ppm
058-164A Sink Faucet inside Room 215 #6	6/29/16 2:34	7/9/16 16:45	6063000164	Lead	6	15	ppb
058-165A Sink Faucet inside Room 215 #7	6/29/16 2:33	7/9/16 16:45	6063000165	Copper	0.6	1.3	ppm
058-165A Sink Faucet inside Room 215 #7	6/29/16 2:33	7/9/16 16:45	6063000165	Lead	6	15	ppb
058-166A Sink Faucet inside Room 215 #8	6/29/16 2:31	7/9/16 16:46	6063000166	Copper	0.8	1.3	ppm
058-166A Sink Faucet inside Room 215 #8	6/29/16 2:31	7/9/16 16:46	6063000166	Lead	7	15	ppb
058-167A Sink Faucet inside Room 215 #9	6/29/16 2:26	7/9/16 16:46	6063000167	Copper	1.2	1.3	ppm
058-167A Sink Faucet inside Room 215 #9	6/29/16 2:26	7/9/16 16:46	6063000167	Lead	10	15	ppb
058-168A Sink Faucet inside Room 215 #10	6/29/16 2:28	7/9/16 16:46	6063000168	Copper	0.8	1.3	ppm
058-168A Sink Faucet inside Room 215 #10	6/29/16 2:28	7/9/16 16:46	6063000168	Lead	16	15	ppb
058-169A Sink Faucet inside Room 215 #11	6/29/16 2:31	7/9/16 16:46	6063000169	Copper	0.4	1.3	ppm
058-169A Sink Faucet inside Room 215 #11	6/29/16 2:31	7/9/16 16:46	6063000169	Lead	13	15	ppb
058-170A Sink Faucet inside Room 215 #12	6/29/16 2:39	7/9/16 16:46	6063000170	Copper	0.8	1.3	ppm
058-170A Sink Faucet inside Room 215 #12	6/29/16 2:39	7/9/16 16:46	6063000170	Lead	8	15	ppb
058-171A Sink Faucet inside Room 215 #13	6/29/16 2:41	7/9/16 16:46	6063000171	Copper	0.7	1.3	ppm
058-171A Sink Faucet inside Room 215 #13	6/29/16 2:41	7/9/16 16:46	6063000171	Lead	9	15	ppb
058-172A Sink Faucet inside Room 215 #14	6/29/16 2:30	7/9/16 16:46	6063000172	Copper	0.7	1.3	ppm
058-172A Sink Faucet inside Room 215 #14	6/29/16 2:30	7/9/16 16:46	6063000172	Lead	4	15	ppb
058-173A Sink Faucet inside Room 215 #15	6/29/16 2:37	7/9/16 16:46	6063000173	Copper	0.7	1.3	ppm
058-173A Sink Faucet inside Room 215 #15	6/29/16 2:37	7/9/16 16:46	6063000173	Lead	4	15	ppb
058-174A Sink Faucet inside Room 215 #16	6/29/16 2:33	7/9/16 16:46	6063000174	Copper	0.4	1.3	ppm
058-174A Sink Faucet inside Room 215 #16	6/29/16 2:33	7/9/16 16:46	6063000174	Lead	73	15	ppb
058-175A Eye Wash Station Room 215 #1	6/29/16 2:34	7/9/16 16:46	6063000175	Copper	0.3	1.3	ppm
058-175A Eye Wash Station Room 215 #1	6/29/16 2:34	7/9/16 16:46	6063000175	Lead	4	15	ppb
058-176A Eye Wash Station Room 215 #2	6/29/16 2:36	7/9/16 16:47	6063000176	Copper	0.4	1.3	ppm
058-176A Eye Wash Station Room 215 #2	6/29/16 2:36	7/9/16 16:47	6063000176	Lead	109	15	ppb
058-177A Sink Faucet in Room 214	6/28/16 23:40	7/9/16 16:47	6063000177	Copper	0.4	1.3	ppm
058-177A Sink Faucet in Room 214	6/28/16 23:40	7/9/16 16:47	6063000177	Lead	9	15	ppb
058-178A Sink Faucet in Room 214 #1	6/28/16 23:41	7/9/16 16:47	6063000178	Copper	0.7	1.3	ppm
058-178A Sink Faucet in Room 214 #1	6/28/16 23:41	7/9/16 16:47	6063000178	Lead	19	15	ppb
058-179A Sink Faucet in Room 214 #2	6/28/16 23:43	7/9/16 16:47	6063000179	Copper	0.2	1.3	ppm
058-179A Sink Faucet in Room 214 #2	6/28/16 23:43	7/9/16 16:47	6063000179	Lead	144	15	ppb
058-180A Sink Faucet in Room 214 #3	6/28/16 23:44	7/9/16 16:47	6063000180	Copper	0.3	1.3	ppm
058-180A Sink Faucet in Room 214 #3	6/28/16 23:44	7/9/16 16:47	6063000180	Lead	78	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Lincoln High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
058-181A Sink Faucet in Room 214 Chemical Storage Closet	6/28/16 23:55	7/9/16 16:47	6063000181	Copper	0.3	1.3	ppm
058-181A Sink Faucet in Room 214 Chemical Storage Closet	6/28/16 23:55	7/9/16 16:47	6063000181	Lead	3	15	ppb
058-182A Sink Faucet in Room 216	6/29/16 0:14	7/9/16 16:47	6063000182	Copper	0.7	1.3	ppm
058-182A Sink Faucet in Room 216	6/29/16 0:14	7/9/16 16:47	6063000182	Lead	12	15	ppb
058-183A Drinking Fountain outside Room 213 #1	6/29/16 0:01	7/9/16 16:47	6063000183	Copper	0.1	1.3	ppm
058-183A Drinking Fountain outside Room 213 #1	6/29/16 0:01	7/9/16 16:47	6063000183	Lead	7	15	ppb
058-184A Drinking Fountain outside Room 213 #2	6/29/16 0:03	7/9/16 16:47	6063000184	Copper	0.1	1.3	ppm
058-184A Drinking Fountain outside Room 213 #2	6/29/16 0:03	7/9/16 16:47	6063000184	Lead	5	15	ppb
058-185A Sink Faucet in Room 213 #1	6/29/16 0:00	7/9/16 16:47	6063000185	Copper	0.4	1.3	ppm
058-185A Sink Faucet in Room 213 #1	6/29/16 0:00	7/9/16 16:47	6063000185	Lead	11	15	ppb
058-186A Sink Faucet in Room 213 #2	6/29/16 0:02	7/9/16 16:12	6063000186	Copper	2.8	1.3	ppm
058-186A Sink Faucet in Room 213 #2	6/29/16 0:02	7/9/16 16:12	6063000186	Lead	266	15	ppb
058-187A Sink Faucet in Room 213 #3	6/29/16 0:04	7/9/16 16:48	6063000187	Copper	0.4	1.3	ppm
058-187A Sink Faucet in Room 213 #3	6/29/16 0:04	7/9/16 16:48	6063000187	Lead	10	15	ppb
058-188A Sink Faucet in Room 213 #4	6/29/16 0:06	7/9/16 16:49	6063000188	Copper	0.4	1.3	ppm
058-188A Sink Faucet in Room 213 #4	6/29/16 0:06	7/9/16 16:49	6063000188	Lead	51	15	ppb
058-189A Sink Faucet in Room 217 #1	6/29/16 0:37	7/9/16 16:49	6063000189	Copper	0.6	1.3	ppm
058-189A Sink Faucet in Room 217 #1	6/29/16 0:37	7/9/16 16:49	6063000189	Lead	65	15	ppb
058-190A Sink Faucet in Room 217 #2	6/29/16 0:38	7/9/16 16:49	6063000190	Copper	0.5	1.3	ppm
058-190A Sink Faucet in Room 217 #2	6/29/16 0:38	7/9/16 16:49	6063000190	Lead	202	15	ppb
058-191A Sink Faucet in Room 217 #3	6/29/16 0:42	7/9/16 16:49	6063000191	Copper	0.6	1.3	ppm
058-191A Sink Faucet in Room 217 #3	6/29/16 0:42	7/9/16 16:49	6063000191	Lead	35	15	ppb
058-192A Sink Faucet in Room 217 #4	6/29/16 0:45	7/9/16 16:49	6063000192	Copper	0.3	1.3	ppm
058-192A Sink Faucet in Room 217 #4	6/29/16 0:45	7/9/16 16:49	6063000192	Lead	9	15	ppb
058-193A Sink Faucet in Room 217 #5	6/29/16 0:39	7/9/16 16:49	6063000193	Copper	0.5	1.3	ppm
058-193A Sink Faucet in Room 217 #5	6/29/16 0:39	7/9/16 16:49	6063000193	Lead	15.4	15	ppb
058-194A Sink Faucet in Room 217 #6	6/29/16 0:39	7/9/16 16:49	6063000194	Copper	0.4	1.3	ppm
058-194A Sink Faucet in Room 217 #6	6/29/16 0:39	7/9/16 16:49	6063000194	Lead	14	15	ppb
058-195A Sink Faucet in Room 217 #7	6/29/16 0:24	7/9/16 16:49	6063000195	Copper	0.4	1.3	ppm
058-195A Sink Faucet in Room 217 #7	6/29/16 0:24	7/9/16 16:49	6063000195	Lead	23	15	ppb
058-196A Sink Faucet in Room 217 #8	6/29/16 0:28	7/9/16 16:49	6063000196	Copper	1.1	1.3	ppm
058-196A Sink Faucet in Room 217 #8	6/29/16 0:28	7/9/16 16:49	6063000196	Lead	32	15	ppb
058-197A Sink Faucet in Room 217 #9	6/29/16 0:26	7/9/16 16:50	6063000197	Copper	0.4	1.3	ppm
058-197A Sink Faucet in Room 217 #9	6/29/16 0:26	7/9/16 16:50	6063000197	Lead	6	15	ppb
058-198A Sink Faucet in Room 217 #10	6/29/16 0:30	7/9/16 16:50	6063000198	Copper	0.7	1.3	ppm
058-198A Sink Faucet in Room 217 #10	6/29/16 0:30	7/9/16 16:50	6063000198	Lead	66	15	ppb
058-199A Sink Faucet in Room 217 #11	6/29/16 0:30	7/9/16 16:50	6063000199	Copper	0.5	1.3	ppm
058-199A Sink Faucet in Room 217 #11	6/29/16 0:30	7/9/16 16:50	6063000199	Lead	6	15	ppb
058-200A Sink Faucet in Room 217 #12	6/29/16 0:34	7/9/16 16:50	6063000200	Copper	0.6	1.3	ppm
058-200A Sink Faucet in Room 217 #12	6/29/16 0:34	7/9/16 16:50	6063000200	Lead	12	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Lincoln High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
058-201A Sink Faucet in Room 217 #13	6/29/16 0:34	7/9/16 16:50	6063000201	Copper	0.5	1.3	ppm
058-201A Sink Faucet in Room 217 #13	6/29/16 0:34	7/9/16 16:50	6063000201	Lead	6	15	ppb
058-202A Sink Faucet in Room 217 #14	6/29/16 0:35	7/9/16 16:50	6063000202	Copper	0.7	1.3	ppm
058-202A Sink Faucet in Room 217 #14	6/29/16 0:35	7/9/16 16:50	6063000202	Lead	12	15	ppb
058-203A Eyewash in Room 217	6/29/16 0:33	7/9/16 16:50	6063000203	Copper	0.3	1.3	ppm
058-203A Eyewash in Room 217	6/29/16 0:33	7/9/16 16:50	6063000203	Lead	25	15	ppb
058-204A Sink Faucet inside Room 212 #1	6/29/16 0:51	7/9/16 16:50	6063000204	Copper	0.8	1.3	ppm
058-204A Sink Faucet inside Room 212 #1	6/29/16 0:51	7/9/16 16:50	6063000204	Lead	10	15	ppb
058-205A Sink Faucet inside Room 212 #2	6/29/16 0:48	7/9/16 16:50	6063000205	Copper	0.7	1.3	ppm
058-205A Sink Faucet inside Room 212 #2	6/29/16 0:48	7/9/16 16:50	6063000205	Lead	16	15	ppb
058-206A Sink Faucet inside Room 212 #3	6/29/16 0:48	7/9/16 16:50	6063000206	Copper	0.7	1.3	ppm
058-206A Sink Faucet inside Room 212 #3	6/29/16 0:48	7/9/16 16:50	6063000206	Lead	9	15	ppb
058-207A Sink Faucet inside Room 212 #4	6/29/16 0:48	7/9/16 16:50	6063000207	Copper	0.9	1.3	ppm
058-207A Sink Faucet inside Room 212 #4	6/29/16 0:48	7/9/16 16:50	6063000207	Lead	7	15	ppb
058-208A Sink Faucet inside Room 212 #5	6/29/16 0:51	7/9/16 16:50	6063000208	Copper	0.7	1.3	ppm
058-208A Sink Faucet inside Room 212 #5	6/29/16 0:51	7/9/16 16:50	6063000208	Lead	134	15	ppb
058-209A Sink Faucet in Room 218 #1	6/29/16 0:58	7/9/16 16:50	6063000209	Copper	1.5	1.3	ppm
058-209A Sink Faucet in Room 218 #1	6/29/16 0:58	7/9/16 16:50	6063000209	Lead	8	15	ppb
058-210A Sink Faucet in Room 218 #2	6/29/16 0:01	7/9/16 16:50	6063000210	Copper	0.5	1.3	ppm
058-210A Sink Faucet in Room 218 #2	6/29/16 0:01	7/9/16 16:50	6063000210	Lead	9	15	ppb
058-211A Sink Faucet in Room 218 #3	6/29/16 0:03	7/9/16 16:50	6063000211	Copper	0.7	1.3	ppm
058-211A Sink Faucet in Room 218 #3	6/29/16 0:03	7/9/16 16:50	6063000211	Lead	11	15	ppb
058-212A Sink Faucet in Room 218 #4	6/29/16 0:05	7/9/16 16:50	6063000212	Copper	0.3	1.3	ppm
058-212A Sink Faucet in Room 218 #4	6/29/16 0:05	7/9/16 16:50	6063000212	Lead	13	15	ppb
058-213A Sink Faucet in Room 218 #5	6/29/16 0:07	7/13/16 11:57	6063000213	Copper	0.4	1.3	ppm
058-213A Sink Faucet in Room 218 #5	6/29/16 0:07	7/13/16 11:57	6063000213	Lead	13	15	ppb
058-214A Sink Faucet in Room 218 #6	6/29/16 0:09	7/13/16 11:57	6063000214	Copper	0.9	1.3	ppm
058-214A Sink Faucet in Room 218 #6	6/29/16 0:09	7/13/16 11:57	6063000214	Lead	15.4	15	ppb
058-215A Sink Faucet in Room 218 #7	6/29/16 0:11	7/13/16 11:57	6063000215	Copper	0.4	1.3	ppm
058-215A Sink Faucet in Room 218 #7	6/29/16 0:11	7/13/16 11:57	6063000215	Lead	14.7	15	ppb
058-216A Sink Faucet in Room 218 #8	6/29/16 0:13	7/13/16 11:57	6063000216	Copper	0.9	1.3	ppm
058-216A Sink Faucet in Room 218 #8	6/29/16 0:13	7/13/16 11:57	6063000216	Lead	26	15	ppb
058-217A Sink Faucet in Room 218 #9	6/29/16 0:15	7/13/16 11:58	6063000217	Copper	1.0	1.3	ppm
058-217A Sink Faucet in Room 218 #9	6/29/16 0:15	7/13/16 11:58	6063000217	Lead	17	15	ppb
058-218A Sink Faucet in Room 218 #10	6/29/16 0:17	7/13/16 11:58	6063000218	Copper	0.9	1.3	ppm
058-218A Sink Faucet in Room 218 #10	6/29/16 0:17	7/13/16 11:58	6063000218	Lead	13	15	ppb
058-219A Sink Faucet in Room 218 #11	6/29/16 0:19	7/13/16 11:58	6063000219	Copper	1.6	1.3	ppm
058-219A Sink Faucet in Room 218 #11	6/29/16 0:19	7/13/16 11:58	6063000219	Lead	21	15	ppb
058-220A Sink Faucet in Room 218 #12	6/29/16 0:21	7/13/16 11:58	6063000220	Copper	0.5	1.3	ppm
058-220A Sink Faucet in Room 218 #12	6/29/16 0:21	7/13/16 11:58	6063000220	Lead	18	15	ppb
058-221A Sink Faucet in Room 218 #13	6/29/16 0:23	7/13/16 11:58	6063000221	Copper	0.5	1.3	ppm
058-221A Sink Faucet in Room 218 #13	6/29/16 0:23	7/13/16 11:58	6063000221	Lead	5	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Lincoln High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
058-222A Sink Faucet in Room 218 #14	6/29/16 0:25	7/13/16 11:58	6063000222	Copper	0.7	1.3	ppm
058-222A Sink Faucet in Room 218 #14	6/29/16 0:25	7/13/16 11:58	6063000222	Lead	10	15	ppb
058-223A Sink Faucet in Room 218 #15	6/29/16 0:27	7/13/16 11:58	6063000223	Copper	0.7	1.3	ppm
058-223A Sink Faucet in Room 218 #15	6/29/16 0:27	7/13/16 11:58	6063000223	Lead	40	15	ppb
058-224A Eyewash in Room 218	6/29/16 0:29	7/13/16 11:58	6063000224	Copper	0.5	1.3	ppm
058-224A Eyewash in Room 218	6/29/16 0:29	7/13/16 11:58	6063000224	Lead	22	15	ppb
058-225A Sink Faucet in Dark Room 210 #1	6/29/16 0:37	7/13/16 11:58	6063000225	Copper	0.2	1.3	ppm
058-225A Sink Faucet in Dark Room 210 #1	6/29/16 0:37	7/13/16 11:58	6063000225	Lead	6	15	ppb
058-226A Sink Faucet in Dark Room 210 #2	6/29/16 0:39	7/13/16 11:58	6063000226	Copper	0.1	1.3	ppm
058-226A Sink Faucet in Dark Room 210 #2	6/29/16 0:39	7/13/16 11:58	6063000226	Lead	1	15	ppb
058-227A Sink Faucet in Dark Room 210 #3	6/29/16 0:41	7/13/16 11:58	6063000227	Copper	0.1	1.3	ppm
058-227A Sink Faucet in Dark Room 210 #3	6/29/16 0:41	7/13/16 11:58	6063000227	Lead	4	15	ppb
058-228A Sink Faucet in Dark Room 210 #4	6/29/16 0:43	7/13/16 11:58	6063000228	Copper	0.2	1.3	ppm
058-228A Sink Faucet in Dark Room 210 #4	6/29/16 0:43	7/13/16 11:58	6063000228	Lead	505	15	ppb
058-229A Sink Faucet in Girls Restroom outside Room 209 #1	6/29/16 0:46	7/13/16 11:58	6063000229	Copper	0.3	1.3	ppm
058-229A Sink Faucet in Girls Restroom outside Room 209 #1	6/29/16 0:46	7/13/16 11:58	6063000229	Lead	3	15	ppb
058-230A Sink Faucet in Girls Restroom outside Room 209 #2	6/29/16 0:48	7/13/16 11:58	6063000230	Copper	0.3	1.3	ppm
058-230A Sink Faucet in Girls Restroom outside Room 209 #2	6/29/16 0:48	7/13/16 11:58	6063000230	Lead	3	15	ppb
058-231A Sink Faucet in Girls Restroom outside Room 209 #3	6/29/16 0:50	7/13/16 11:58	6063000231	Copper	0.9	1.3	ppm
058-231A Sink Faucet in Girls Restroom outside Room 209 #3	6/29/16 0:50	7/13/16 11:58	6063000231	Lead	39	15	ppb
058-232A Sink Faucet in Girls Restroom outside Room 209 #4	6/29/16 0:52	7/14/16 9:35	6063000232	Copper	2.2	1.3	ppm
058-232A Sink Faucet in Girls Restroom outside Room 209 #4	6/29/16 0:52	7/13/16 11:58	6063000232	Lead	64	15	ppb
058-233A Sink Faucet in Girls Restroom outside Room 209 #5	6/29/16 0:54	7/13/16 11:58	6063000233	Copper	1.0	1.3	ppm
058-233A Sink Faucet in Girls Restroom outside Room 209 #5	6/29/16 0:54	7/13/16 11:58	6063000233	Lead	28	15	ppb
058-234A Spigot in Girls Restroom outside Room 209	6/29/16 0:56	7/13/16 11:58	6063000234	Copper	0.2	1.3	ppm
058-234A Spigot in Girls Restroom outside Room 209	6/29/16 0:56	7/13/16 11:58	6063000234	Lead	7	15	ppb
058-235A Janitor Closet Sink	6/29/16 0:59	7/13/16 11:58	6063000235	Copper	0.3	1.3	ppm
058-235A Janitor Closet Sink	6/29/16 0:59	7/13/16 11:58	6063000235	Lead	1	15	ppb
058-236A Drinking Fountain in Hallway #1	6/29/16 1:01	7/13/16 11:58	6063000236	Copper	0.1	1.3	ppm
058-236A Drinking Fountain in Hallway #1	6/29/16 1:01	7/13/16 11:58	6063000236	Lead	4	15	ppb
058-237A Drinking Fountain in Hallway #2	6/29/16 1:03	7/13/16 13:10	6063000237	Copper	0.1	1.3	ppm
058-237A Drinking Fountain in Hallway #2	6/29/16 1:03	7/13/16 13:10	6063000237	Lead	5	15	ppb
058-238A Drinking Fountain in Hallway #3	6/29/16 1:05	7/13/16 13:10	6063000238	Copper	0.1	1.3	ppm
058-238A Drinking Fountain in Hallway #3	6/29/16 1:05	7/13/16 13:10	6063000238	Lead	2	15	ppb
058-239A Sink Faucet in Boys Restroom across Room 237 #1	6/29/16 1:08	7/13/16 13:10	6063000239	Copper	0.3	1.3	ppm
058-239A Sink Faucet in Boys Restroom across Room 237 #1	6/29/16 1:08	7/13/16 13:10	6063000239	Lead	7	15	ppb
058-240A Sink Faucet in Boys Restroom across Room 237 #2	6/29/16 1:10	7/13/16 13:10	6063000240	Copper	0.2	1.3	ppm
058-240A Sink Faucet in Boys Restroom across Room 237 #2	6/29/16 1:10	7/13/16 13:10	6063000240	Lead	5	15	ppb
058-241A Sink Faucet in Boys Restroom across Room 237 #3	6/29/16 1:12	7/13/16 13:10	6063000241	Copper	0.3	1.3	ppm
058-241A Sink Faucet in Boys Restroom across Room 237 #3	6/29/16 1:12	7/13/16 13:10	6063000241	Lead	5	15	ppb
058-242A Sink Faucet in Boys Restroom across Room 237 #4	6/29/16 1:14	7/13/16 13:10	6063000242	Copper	0.2	1.3	ppm
058-242A Sink Faucet in Boys Restroom across Room 237 #4	6/29/16 1:14	7/13/16 13:10	6063000242	Lead	6	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Lincoln High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
058-243A Sink Faucet in Boys Restroom across Room 237 #5	6/29/16 1:16	7/13/16 13:10	6063000243	Copper	0.2	1.3	ppm
058-243A Sink Faucet in Boys Restroom across Room 237 #5	6/29/16 1:16	7/13/16 13:10	6063000243	Lead	10	15	ppb
058-244A Spigot in Boys Restroom across Room 237 #1	6/29/16 1:18	7/13/16 13:10	6063000244	Copper	0.2	1.3	ppm
058-244A Spigot in Boys Restroom across Room 237 #1	6/29/16 1:18	7/13/16 13:10	6063000244	Lead	5	15	ppb
058-245A Spigot in Boys Restroom across Room 237 #2	6/29/16 1:20	7/13/16 13:10	6063000245	Copper	0.2	1.3	ppm
058-245A Spigot in Boys Restroom across Room 237 #2	6/29/16 1:20	7/13/16 13:10	6063000245	Lead	9	15	ppb
058-246A Sink Faucet in Staff Restroom next Room 223	6/29/16 1:23	7/13/16 13:10	6063000246	Copper	0.1	1.3	ppm
058-246A Sink Faucet in Staff Restroom next Room 223	6/29/16 1:23	7/13/16 13:10	6063000246	Lead	2	15	ppb
058-247A Sink Faucet in Staff Restroom across Room 223	6/29/16 1:25	7/13/16 13:10	6063000247	Copper	0.2	1.3	ppm
058-247A Sink Faucet in Staff Restroom across Room 223	6/29/16 1:25	7/13/16 13:10	6063000247	Lead	5	15	ppb
058-248A Sink Faucet in Attic, Room across from Library	6/29/16 1:35	7/13/16 13:10	6063000248	Copper	0.2	1.3	ppm
058-248A Sink Faucet in Attic, Room across from Library	6/29/16 1:35	7/13/16 13:10	6063000248	Lead	18	15	ppb
058-249A Sink Faucet inside Library	6/29/16 1:37	7/13/16 13:10	6063000249	Copper	0.3	1.3	ppm
058-249A Sink Faucet inside Library	6/29/16 1:37	7/13/16 13:10	6063000249	Lead	67	15	ppb
058-250A Sink Faucet in Faculty Room 225	6/29/16 1:30	7/13/16 13:10	6063000250	Copper	0.2	1.3	ppm
058-250A Sink Faucet in Faculty Room 225	6/29/16 1:30	7/13/16 13:10	6063000250	Lead	2	15	ppb
058-251A Sink Faucet in Boys Restroom outside Library #1	6/29/16 1:39	7/13/16 13:10	6063000251	Copper	0.2	1.3	ppm
058-251A Sink Faucet in Boys Restroom outside Library #1	6/29/16 1:39	7/13/16 13:10	6063000251	Lead	2	15	ppb
058-252A Sink Faucet in Boys Restroom outside Library #2	6/29/16 1:41	7/13/16 13:10	6063000252	Copper	0.2	1.3	ppm
058-252A Sink Faucet in Boys Restroom outside Library #2	6/29/16 1:41	7/13/16 13:10	6063000252	Lead	4	15	ppb
058-253A Sink Faucet in Boys Restroom outside Library #3	6/29/16 1:43	7/13/16 13:10	6063000253	Copper	0.7	1.3	ppm
058-253A Sink Faucet in Boys Restroom outside Library #3	6/29/16 1:43	7/13/16 13:10	6063000253	Lead	33	15	ppb
058-254A Sink Faucet in Boys Restroom outside Library #4	6/29/16 1:45	7/13/16 13:10	6063000254	Copper	0.3	1.3	ppm
058-254A Sink Faucet in Boys Restroom outside Library #4	6/29/16 1:45	7/13/16 13:10	6063000254	Lead	7	15	ppb
058-255A Sink Faucet in Boys Restroom outside Library #5	6/29/16 1:47	7/13/16 13:10	6063000255	Copper	0.3	1.3	ppm
058-255A Sink Faucet in Boys Restroom outside Library #5	6/29/16 1:47	7/13/16 13:10	6063000255	Lead	4	15	ppb
058-256A Spigot in Boys Restroom outside Library #1	6/29/16 1:49	7/13/16 13:11	6063000256	Copper	0.3	1.3	ppm
058-256A Spigot in Boys Restroom outside Library #1	6/29/16 1:49	7/13/16 13:11	6063000256	Lead	13	15	ppb
058-257A Spigot in Boys Restroom outside Library #2	6/29/16 1:51	7/13/16 13:11	6063000257	Copper	0.1	1.3	ppm
058-257A Spigot in Boys Restroom outside Library #2	6/29/16 1:51	7/13/16 13:11	6063000257	Lead	6	15	ppb
058-258A Drinking Fountain in Hallway by Library	6/29/16 1:54	7/13/16 13:11	6063000258	Copper	0.0	1.3	ppm
058-258A Drinking Fountain in Hallway by Library	6/29/16 1:54	7/13/16 13:11	6063000258	Lead	6	15	ppb
058-259A Sink Faucet in Custodian Closet 227	6/29/16 1:57	7/13/16 13:11	6063000259	Copper	0.3	1.3	ppm
058-259A Sink Faucet in Custodian Closet 227	6/29/16 1:57	7/13/16 13:11	6063000259	Lead	1	15	ppb
058-260A Sink Faucet in Girls Restroom across Room 236 #1	6/29/16 2:12	7/13/16 13:11	6063000260	Copper	0.1	1.3	ppm
058-260A Sink Faucet in Girls Restroom across Room 236 #1	6/29/16 2:12	7/13/16 13:11	6063000260	Lead	1	15	ppb
058-261A Sink Faucet in Girls Restroom across Room 236 #2	6/29/16 2:14	7/13/16 13:11	6063000261	Copper	0.2	1.3	ppm
058-261A Sink Faucet in Girls Restroom across Room 236 #2	6/29/16 2:14	7/13/16 13:11	6063000261	Lead	2	15	ppb
058-262A Sink Faucet in Girls Restroom across Room 236 #3	6/29/16 2:16	7/13/16 13:11	6063000262	Copper	0.2	1.3	ppm
058-262A Sink Faucet in Girls Restroom across Room 236 #3	6/29/16 2:16	7/13/16 13:11	6063000262	Lead	4	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Lincoln High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
058-263A Sink Faucet in Girls Restroom across Room 236 #4	6/29/16 2:18	7/13/16 13:11	6063000263	Copper	0.2	1.3	ppm
058-263A Sink Faucet in Girls Restroom across Room 236 #4	6/29/16 2:18	7/13/16 13:11	6063000263	Lead	3	15	ppb
058-264A Sink Faucet in Girls Restroom across Room 236 #5	6/29/16 2:20	7/13/16 13:11	6063000264	Copper	0.2	1.3	ppm
058-264A Sink Faucet in Girls Restroom across Room 236 #5	6/29/16 2:20	7/13/16 13:11	6063000264	Lead	3	15	ppb
058-265A Spigot in Girls Restroom across Room 236 #1	6/29/16 2:16	7/13/16 13:11	6063000265	Copper	0.4	1.3	ppm
058-265A Spigot in Girls Restroom across Room 236 #1	6/29/16 2:16	7/13/16 13:11	6063000265	Lead	33	15	ppb
058-266A Spigot in Girls Restroom across Room 236 #2	6/29/16 2:24	7/13/16 13:11	6063000266	Copper	0.3	1.3	ppm
058-266A Spigot in Girls Restroom across Room 236 #2	6/29/16 2:24	7/13/16 13:11	6063000266	Lead	14	15	ppb
058-267A Sink Faucet in Room 230 #1	6/29/16 2:27	7/13/16 13:12	6063000267	Copper	0.5	1.3	ppm
058-267A Sink Faucet in Room 230 #1	6/29/16 2:27	7/13/16 13:12	6063000267	Lead	27	15	ppb
058-268A Sink Faucet in Room 230 #2	6/29/16 2:29	7/13/16 13:12	6063000268	Copper	0.7	1.3	ppm
058-268A Sink Faucet in Room 230 #2	6/29/16 2:29	7/13/16 13:12	6063000268	Lead	10	15	ppb
058-269A Sink Faucet in Room 230 #3	6/29/16 2:31	7/13/16 13:12	6063000269	Copper	0.4	1.3	ppm
058-269A Sink Faucet in Room 230 #3	6/29/16 2:31	7/13/16 13:12	6063000269	Lead	3	15	ppb
058-270A Sink Faucet in Room 231 #1	6/29/16 2:34	7/13/16 13:12	6063000270	Copper	0.4	1.3	ppm
058-270A Sink Faucet in Room 231 #1	6/29/16 2:34	7/13/16 13:12	6063000270	Lead	3	15	ppb
058-271A Sink Faucet in Room 231 #2	6/29/16 2:36	7/13/16 13:12	6063000271	Copper	0.3	1.3	ppm
058-271A Sink Faucet in Room 231 #2	6/29/16 2:36	7/13/16 13:12	6063000271	Lead	3	15	ppb
058-272A Drinking Fountain outside of Room 231 #1	6/29/16 2:39	7/13/16 13:12	6063000272	Copper	1.0	1.3	ppm
058-272A Drinking Fountain outside of Room 231 #1	6/29/16 2:39	7/13/16 13:12	6063000272	Lead	2	15	ppb
058-273A Drinking Fountain outside of Room 231 #2	6/29/16 2:41	7/13/16 13:12	6063000273	Copper	0.6	1.3	ppm
058-273A Drinking Fountain outside of Room 231 #2	6/29/16 2:41	7/13/16 13:12	6063000273	Lead	2	15	ppb
058-274A Drinking Fountain outside of Room 231 #3	6/29/16 2:43	7/13/16 13:12	6063000274	Copper	1.2	1.3	ppm
058-274A Drinking Fountain outside of Room 231 #3	6/29/16 2:43	7/13/16 13:12	6063000274	Lead	2	15	ppb
058-275A Spigot outside of Lower Parking	6/29/16 3:23	7/13/16 13:12	6063000275	Copper	0.3	1.3	ppm
058-275A Spigot outside of Lower Parking	6/29/16 3:23	7/13/16 13:12	6063000275	Lead	28	15	ppb
058-276A Spigot outside Northeast Doors	6/29/16 3:40	7/13/16 13:12	6063000276	Copper	1.1	1.3	ppm
058-276A Spigot outside Northeast Doors	6/29/16 3:40	7/13/16 13:12	6063000276	Lead	17	15	ppb
058-277A Spigot outside Doors to Football Field	6/29/16 3:50	7/13/16 13:13	6063000277	Copper	0.3	1.3	ppm
058-277A Spigot outside Doors to Football Field	6/29/16 3:50	7/13/16 13:13	6063000277	Lead	6	15	ppb
058-278A Drinking Fountain outside Concession Stand by Football Field #1	6/29/16 3:55	7/13/16 13:13	6063000278	Copper	0.6	1.3	ppm
058-278A Drinking Fountain outside Concession Stand by Football Field #1	6/29/16 3:55	7/13/16 13:13	6063000278	Lead	1	15	ppb
058-279A Drinking Fountain outside Concession Stand by Football Field #2	6/29/16 3:57	7/13/16 13:13	6063000279	Copper	0.5	1.3	ppm
058-279A Drinking Fountain outside Concession Stand by Football Field #2	6/29/16 3:57	7/13/16 13:13	6063000279	Lead	1	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Lincoln High School

Sample Identification # and Location	Date & Time Collected	Date & Time Analyzed	Container ID	Analyte	Results	EPA Action Limit	Units
058-280A Drinking Fountain outside Concession Stand by Football Field #3	6/29/16 3:59	7/13/16 13:13	6063000280	Copper	0.5	1.3	ppm
058-280A Drinking Fountain outside Concession Stand by Football Field #3	6/29/16 3:59	7/13/16 13:13	6063000280	Lead	1	15	ppb
058-281A Spigot outside Concession	6/29/16 3:58	7/13/16 13:13	6063000281	Copper	0.7	1.3	ppm
058-281A Spigot outside Concession	6/29/16 3:58	7/13/16 13:13	6063000281	Lead	16	15	ppb
058-282A Sink Faucet inside Concession #1	6/29/16 9:01	7/13/16 13:13	6063000282	Copper	0.3	1.3	ppm
058-282A Sink Faucet inside Concession #1	6/29/16 9:01	7/13/16 13:13	6063000282	Lead	7	15	ppb
058-283A Sink Faucet inside Concession #2	6/29/16 4:03	7/13/16 13:13	6063000283	Copper	0.1	1.3	ppm
058-283A Sink Faucet inside Concession #2	6/29/16 4:03	7/13/16 13:13	6063000283	Lead	0	15	ppb
058-284A Sink Faucet inside Concession #3	6/29/16 4:05	7/13/16 13:13	6063000284	Copper	0.4	1.3	ppm
058-284A Sink Faucet inside Concession #3	6/29/16 4:05	7/13/16 13:13	6063000284	Lead	2	15	ppb
058-285A Sink Faucet inside Concession Storage Room	6/29/16 4:07	7/13/16 13:13	6063000285	Copper	0.5	1.3	ppm
058-285A Sink Faucet inside Concession Storage Room	6/29/16 4:07	7/13/16 13:13	6063000285	Lead	9	15	ppb
058-286A Sink Faucet inside Concession Mens Restroom #1	6/29/16 4:09	7/13/16 13:13	6063000286	Copper	0.5	1.3	ppm
058-286A Sink Faucet inside Concession Mens Restroom #1	6/29/16 4:09	7/13/16 13:13	6063000286	Lead	1	15	ppb
058-287A Sink Faucet inside Concession Mens Restroom #2	6/29/16 4:11	7/13/16 13:14	6063000287	Copper	0.4	1.3	ppm
058-287A Sink Faucet inside Concession Mens Restroom #2	6/29/16 4:11	7/13/16 13:14	6063000287	Lead	1	15	ppb
058-288A Sink Faucet inside Concession Mens Restroom #3	6/29/16 4:13	7/13/16 13:14	6063000288	Copper	0.5	1.3	ppm
058-288A Sink Faucet inside Concession Mens Restroom #3	6/29/16 4:13	7/13/16 13:14	6063000288	Lead	2	15	ppb
058-289A Sink Faucet inside Concession Mens Restroom #4	6/29/16 4:15	7/13/16 13:14	6063000289	Copper	0.5	1.3	ppm
058-289A Sink Faucet inside Concession Mens Restroom #4	6/29/16 4:15	7/13/16 13:14	6063000289	Lead	3	15	ppb
058-290A Sink Faucet inside Concession Mens Restroom #5	6/29/16 4:17	7/13/16 13:14	6063000290	Copper	0.6	1.3	ppm
058-290A Sink Faucet inside Concession Mens Restroom #5	6/29/16 4:17	7/13/16 13:14	6063000290	Lead	3	15	ppb
058-291A Sink Faucet inside Concession Mens Restroom #6	6/29/16 4:19	7/13/16 13:14	6063000291	Copper	0.5	1.3	ppm
058-291A Sink Faucet inside Concession Mens Restroom #6	6/29/16 4:19	7/13/16 13:14	6063000291	Lead	5	15	ppb
058-292A Sink Faucet inside Concession Womens Restroom #1	6/29/16 4:11	7/13/16 13:14	6063000292	Copper	0.6	1.3	ppm
058-292A Sink Faucet inside Concession Womens Restroom #1	6/29/16 4:11	7/13/16 13:14	6063000292	Lead	1	15	ppb
058-293A Sink Faucet inside Concession Womens Restroom #2	6/29/16 4:13	7/13/16 13:14	6063000293	Copper	0.5	1.3	ppm
058-293A Sink Faucet inside Concession Womens Restroom #2	6/29/16 4:13	7/13/16 13:14	6063000293	Lead	2	15	ppb
058-294A Sink Faucet inside Concession Womens Restroom #3	6/29/16 4:15	7/13/16 13:14	6063000294	Copper	0.6	1.3	ppm
058-294A Sink Faucet inside Concession Womens Restroom #3	6/29/16 4:15	7/13/16 13:14	6063000294	Lead	1	15	ppb
058-295A Sink Faucet inside Concession Womens Restroom #4	6/29/16 4:17	7/13/16 13:14	6063000295	Copper	0.5	1.3	ppm
058-295A Sink Faucet inside Concession Womens Restroom #4	6/29/16 4:17	7/13/16 13:14	6063000295	Lead	2	15	ppb
058-296A Spigot in Fenced off Garden in Front	6/29/16 3:35	7/13/16 13:14	6063000296	Copper	0.4	1.3	ppm
058-296A Spigot in Fenced off Garden in Front	6/29/16 3:35	7/13/16 13:14	6063000296	Lead	12	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

ND = Non detect

Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.