

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Llewelyn Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
059-01A Boiler Room Sink Faucet	6/26/2016 20:46	7/7/2016 02:39	10354058001	Copper	0.0	1.3	ppm
059-01A Boiler Room Sink Faucet	6/26/2016 20:46	7/7/2016 02:39	10354058001	Lead	18	15	ppb
059-02A Supply Closet 89A Sink Faucet	6/26/2016 20:49	7/7/2016 02:44	10354058003	Copper	0.1	1.3	ppm
059-02A Supply Closet 89A Sink Faucet	6/26/2016 20:49	7/7/2016 02:44	10354058003	Lead	7	15	ppb
059-03A Drinking Fountain (101)	6/26/2016 20:51	7/7/2016 02:46	10354058005	Copper	0.0	1.3	ppm
059-03A Drinking Fountain (101)	6/26/2016 20:51	7/7/2016 02:46	10354058005	Lead	14.6	15	ppb
059-04A Girls Bathroom 9 Sink Faucet	6/26/2016 20:54	7/7/2016 02:47	10354058007	Copper	0.0	1.3	ppm
059-04A Girls Bathroom 9 Sink Faucet	6/26/2016 20:54	7/7/2016 02:47	10354058007	Lead	12	15	ppb
059-05A Girls Bathroom 9 Water Spigot	6/26/2016 20:56	7/7/2016 02:49	10354058009	Copper	0.3	1.3	ppm
059-05A Girls Bathroom 9 Water Spigot	6/26/2016 20:56	7/7/2016 20:22	10354058009	Lead	488	15	ppb
059-06A Classroom 102 Sink Faucet	6/26/2016 20:56	7/7/2016 02:53	10354058011	Copper	0.4	1.3	ppm
059-06A Classroom 102 Sink Faucet	6/26/2016 20:56	7/7/2016 02:53	10354058011	Lead	16	15	ppb
059-07A Classroom 102 Drinking Fountain	6/26/2016 20:58	7/7/2016 02:54	10354058013	Copper	0.2	1.3	ppm
059-07A Classroom 102 Drinking Fountain	6/26/2016 20:58	7/7/2016 02:54	10354058013	Lead	15.2	15	ppb
059-08A Drinking Fountain Outside Office	6/26/2016 21:01	7/7/2016 02:55	10354058015	Copper	0.0	1.3	ppm
059-08A Drinking Fountain Outside Office	6/26/2016 21:01	7/7/2016 02:55	10354058015	Lead	2	15	ppb
059-09A Classroom 103 Sink Faucet	6/26/2016 21:04	7/7/2016 02:57	10354058017	Copper	0.5	1.3	ppm
059-09A Classroom 103 Sink Faucet	6/26/2016 21:04	7/7/2016 02:57	10354058017	Lead	12	15	ppb
059-10A Classroom 103 Drinking Fountain	6/26/2016 21:04	7/7/2016 12:14	10354058019	Copper	0.4	1.3	ppm
059-10A Classroom 103 Drinking Fountain	6/26/2016 21:04	7/7/2016 12:14	10354058019	Lead	13	15	ppb
059-11A Custodian Mop Sink Faucet	6/26/2016 21:06	7/7/2016 02:58	10354058021	Copper	0.1	1.3	ppm
059-11A Custodian Mop Sink Faucet	6/26/2016 21:06	7/7/2016 02:58	10354058021	Lead	14.7	15	ppb
059-12A Boys Bathroom 8 Sink Faucet #1	6/26/2016 21:09	7/7/2016 02:59	10354058023	Copper	0.2	1.3	ppm
059-12A Boys Bathroom 8 Sink Faucet #1	6/26/2016 21:09	7/7/2016 02:59	10354058023	Lead	11	15	ppb
059-13A Boys Bathroom 8 Sink Faucet #2	6/26/2016 21:09	7/7/2016 03:02	10354058025	Copper	0.2	1.3	ppm
059-13A Boys Bathroom 8 Sink Faucet #2	6/26/2016 21:09	7/7/2016 03:02	10354058025	Lead	7	15	ppb
059-14A Boys Bathroom 8 Water Spigot	6/26/2016 21:11	7/7/2016 03:04	10354058027	Copper	0.3	1.3	ppm
059-14A Boys Bathroom 8 Water Spigot	6/26/2016 21:11	7/7/2016 03:04	10354058027	Lead	34	15	ppb
059-15A Health Room Sink Faucet	6/26/2016 21:13	7/7/2016 03:05	10354058029	Copper	0.1	1.3	ppm
059-15A Health Room Sink Faucet	6/26/2016 21:13	7/7/2016 03:05	10354058029	Lead	13	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Llewellyn Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
059-16A Faculty/Adult Bathroom Sink Faucet	6/26/2016 21:14	7/7/2016 03:09	10354058031	Copper	0.4	1.3	ppm
059-16A Faculty/Adult Bathroom Sink Faucet	6/26/2016 21:14	7/7/2016 03:09	10354058031	Lead	3	15	ppb
059-17A Drinking Fountain (Outside Cafe)	6/26/2016 21:15	7/7/2016 03:11	10354058033	Copper	0.0	1.3	ppm
059-17A Drinking Fountain (Outside Cafe)	6/26/2016 21:15	7/7/2016 03:11	10354058033	Lead	2	15	ppb
059-18A Kitchen Handwash Sink Faucet	6/26/2016 21:18	7/7/2016 03:12	10354058035	Copper	0.1	1.3	ppm
059-18A Kitchen Handwash Sink Faucet	6/26/2016 21:18	7/7/2016 03:12	10354058035	Lead	10	15	ppb
059-19A Kitchen Food Preparation Sink Faucet	6/26/2016 21:18	7/7/2016 03:13	10354058037	Copper	0.1	1.3	ppm
059-19A Kitchen Food Preparation Sink Faucet	6/26/2016 21:18	7/7/2016 03:13	10354058037	Lead	13	15	ppb
059-20A Kitchen Dishwash Sink Faucet	6/26/2016 21:20	7/7/2016 03:15	10354058039	Copper	0.1	1.3	ppm
059-20A Kitchen Dishwash Sink Faucet	6/26/2016 21:20	7/7/2016 03:15	10354058039	Lead	6	15	ppb
059-21A Girls Bathroom Sink Faucet #1	6/26/2016 21:23	7/7/2016 20:29	10354058041	Copper	0.1	1.3	ppm
059-21A Girls Bathroom Sink Faucet #1	6/26/2016 21:23	7/7/2016 20:29	10354058041	Lead	11	15	ppb
059-22A Girls Bathroom Sink Faucet #2	6/26/2016 21:23	7/7/2016 20:37	10354058043	Copper	0.1	1.3	ppm
059-22A Girls Bathroom Sink Faucet #2	6/26/2016 21:23	7/7/2016 20:37	10354058043	Lead	8	15	ppb
059-23A Girls Bathroom Water Spigot	6/26/2016 21:25	7/8/2016 08:16	10354058045	Copper	0.6	1.3	ppm
059-23A Girls Bathroom Water Spigot	6/26/2016 21:25	7/7/2016 20:38	10354058045	Lead	35	15	ppb
059-24A Custodial Closet Mop Sink Faucet	6/26/2016 21:27	7/7/2016 20:40	10354058047	Copper	0.1	1.3	ppm
059-24A Custodial Closet Mop Sink Faucet	6/26/2016 21:27	7/7/2016 20:40	10354058047	Lead	19	15	ppb
059-25A Faculty 105 Bathroom Sink Faucet	6/26/2016 21:29	7/7/2016 20:41	10354058049	Copper	0.1	1.3	ppm
059-25A Faculty 105 Bathroom Sink Faucet	6/26/2016 21:29	7/7/2016 20:41	10354058049	Lead	27	15	ppb
059-26A Drinking Fountain	6/26/2016 21:31	7/7/2016 20:42	10354058051	Copper	0.0	1.3	ppm
059-26A Drinking Fountain	6/26/2016 21:31	7/7/2016 20:42	10354058051	Lead	2	15	ppb
059-27A Classroom 107 Sink Faucet	6/26/2016 21:31	7/7/2016 20:44	10354058053	Copper	0.2	1.3	ppm
059-27A Classroom 107 Sink Faucet	6/26/2016 21:31	7/7/2016 20:44	10354058053	Lead	46	15	ppb
059-28A Classroom 108 Sink Faucet	6/26/2016 21:34	7/7/2016 20:45	10354058055	Copper	0.1	1.3	ppm
059-28A Classroom 108 Sink Faucet	6/26/2016 21:34	7/7/2016 20:45	10354058055	Lead	59	15	ppb
059-29A Classroom 109 Sink Faucet	6/26/2016 21:34	7/8/2016 08:18	10354058057	Copper	0.7	1.3	ppm
059-29A Classroom 109 Sink Faucet	6/26/2016 21:34	7/7/2016 20:47	10354058057	Lead	14.5	15	ppb
059-30A Classroom 109 Drinking Fountain	6/26/2016 21:34	7/7/2016 20:48	10354058059	Copper	0.2	1.3	ppm
059-30A Classroom 109 Drinking Fountain	6/26/2016 21:34	7/7/2016 20:48	10354058059	Lead	2	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Llewellyn Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
059-31A Boys Bathroom Sink Faucet #1	6/26/2016 21:37	7/7/2016 20:52	10354058061	Copper	0.1	1.3	ppm
059-31A Boys Bathroom Sink Faucet #1	6/26/2016 21:37	7/7/2016 20:52	10354058061	Lead	26	15	ppb
059-32A Boys Bathroom Sink Faucet #2	6/26/2016 21:38	7/7/2016 20:53	10354058063	Copper	0.1	1.3	ppm
059-32A Boys Bathroom Sink Faucet #2	6/26/2016 21:38	7/7/2016 20:53	10354058063	Lead	31	15	ppb
059-33A Boys Bathroom Water Spigot	6/26/2016 21:40	7/7/2016 20:55	10354058065	Copper	0.0	1.3	ppm
059-33A Boys Bathroom Water Spigot	6/26/2016 21:40	7/7/2016 20:55	10354058065	Lead	7	15	ppb
059-34A Drinking Fountain Bottle Fill (109)	6/26/2016 21:43	7/8/2016 08:20	10354058067	Copper	0.8	1.3	ppm
059-34A Drinking Fountain Bottle Fill (109)	6/26/2016 21:43	7/7/2016 20:57	10354058067	Lead	4	15	ppb
059-35A Drinking Fountain (109) #1	6/26/2016 21:45	7/7/2016 20:59	10354058069	Copper	0.3	1.3	ppm
059-35A Drinking Fountain (109) #1	6/26/2016 21:45	7/7/2016 20:59	10354058069	Lead	3	15	ppb
059-36A Drinking Fountain (109) #2	6/26/2016 21:45	7/8/2016 08:22	10354058071	Copper	1.8	1.3	ppm
059-36A Drinking Fountain (109) #2	6/26/2016 21:45	7/7/2016 21:00	10354058071	Lead	3	15	ppb
059-37A Library Sink Faucet	6/26/2016 21:48	7/7/2016 21:01	10354058073	Copper	0.2	1.3	ppm
059-37A Library Sink Faucet	6/26/2016 21:48	7/7/2016 21:01	10354058073	Lead	235	15	ppb
059-38A Classroom 110 Sink Faucet	6/26/2016 21:48	7/7/2016 21:03	10354058075	Copper	0.1	1.3	ppm
059-38A Classroom 110 Sink Faucet	6/26/2016 21:48	7/7/2016 21:03	10354058075	Lead	38	15	ppb
059-39A Classroom 110 Drinking Fountain	6/26/2016 21:50	7/7/2016 21:04	10354058077	Copper	0.0	1.3	ppm
059-39A Classroom 110 Drinking Fountain	6/26/2016 21:50	7/7/2016 21:04	10354058077	Lead	11	15	ppb
059-40A Classroom 210 Sink Faucet	6/26/2016 21:53	7/8/2016 08:27	10354058079	Copper	0.8	1.3	ppm
059-40A Classroom 210 Sink Faucet	6/26/2016 21:53	7/7/2016 21:08	10354058079	Lead	22	15	ppb
059-41A Classroom 210 Drinking Fountain	6/26/2016 21:55	7/7/2016 22:36	10354058081	Copper	0.7	1.3	ppm
059-41A Classroom 210 Drinking Fountain	6/26/2016 21:55	7/7/2016 20:33	10354058081	Lead	21	15	ppb
059-42A Boys Bathroom Sink Faucet #1	6/26/2016 21:58	7/7/2016 20:39	10354058083	Copper	0.0	1.3	ppm
059-42A Boys Bathroom Sink Faucet #1	6/26/2016 21:58	7/7/2016 20:39	10354058083	Lead	19	15	ppb
059-43A Boys Bathroom Sink Faucet #2	6/26/2016 21:58	7/7/2016 20:43	10354058085	Copper	0.1	1.3	ppm
059-43A Boys Bathroom Sink Faucet #2	6/26/2016 21:58	7/7/2016 20:43	10354058085	Lead	16	15	ppb
059-44A Boys Bathroom Water Spigot	6/26/2016 22:00	7/7/2016 20:44	10354058087	Copper	0.0	1.3	ppm
059-44A Boys Bathroom Water Spigot	6/26/2016 22:00	7/7/2016 20:44	10354058087	Lead	4	15	ppb
059-45A Classroom 207 Sink Faucet	6/26/2016 22:03	7/7/2016 20:45	10354058089	Copper	0.1	1.3	ppm
059-45A Classroom 207 Sink Faucet	6/26/2016 22:03	7/7/2016 20:45	10354058089	Lead	11	15	ppb

Analysis by: Grant's Pass

Reviewed by: TRC Environmental Corp

3 of 5

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Llewellyn Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
059-46A Custodian Closet Mop Sink Faucet	6/26/2016 22:06	7/7/2016 20:46	10354058091	Copper	0.0	1.3	ppm
059-46A Custodian Closet Mop Sink Faucet	6/26/2016 22:06	7/7/2016 20:46	10354058091	Lead	3	15	ppb
059-47A Girls Bathroom Sink Faucet #1	6/26/2016 22:09	7/7/2016 20:48	10354058093	Copper	0.1	1.3	ppm
059-47A Girls Bathroom Sink Faucet #1	6/26/2016 22:09	7/7/2016 20:48	10354058093	Lead	29	15	ppb
059-48A Girls Bathroom Sink Faucet #2	6/26/2016 22:11	7/7/2016 20:49	10354058095	Copper	0.1	1.3	ppm
059-48A Girls Bathroom Sink Faucet #2	6/26/2016 22:11	7/7/2016 20:49	10354058095	Lead	34	15	ppb
059-49A Girls Bathroom Water Spigot	6/26/2016 22:11	7/7/2016 20:50	10354058097	Copper	0.1	1.3	ppm
059-49A Girls Bathroom Water Spigot	6/26/2016 22:11	7/7/2016 20:50	10354058097	Lead	28	15	ppb
059-50A Drinking Fountain Bottle Fill	6/26/2016 22:14	7/7/2016 22:39	10354058099	Copper	2.4	1.3	ppm
059-50A Drinking Fountain Bottle Fill	6/26/2016 22:14	7/7/2016 20:51	10354058099	Lead	4	15	ppb
059-51A Drinking Fountain (206) #1	6/26/2016 22:17	7/7/2016 22:40	10354058101	Copper	1.4	1.3	ppm
059-51A Drinking Fountain (206) #1	6/26/2016 22:17	7/7/2016 20:52	10354058101	Lead	4	15	ppb
059-52A Drinking Fountain (206) #2	6/26/2016 22:17	7/7/2016 22:41	10354058103	Copper	0.9	1.3	ppm
059-52A Drinking Fountain (206) #2	6/26/2016 22:17	7/7/2016 20:58	10354058103	Lead	3	15	ppb
059-53A Drinking Fountain by 205B #1	6/26/2016 22:20	7/7/2016 20:59	10354058105	Copper	0.0	1.3	ppm
059-53A Drinking Fountain by 205B #1	6/26/2016 22:20	7/7/2016 20:59	10354058105	Lead	8	15	ppb
059-54A Drinking Fountain by 205B #2	6/26/2016 22:22	7/7/2016 21:00	10354058107	Copper	0.2	1.3	ppm
059-54A Drinking Fountain by 205B #2	6/26/2016 22:22	7/7/2016 21:00	10354058107	Lead	7	15	ppb
059-55A Custodian Closet Mop Sink Faucet	6/26/2016 22:25	7/7/2016 21:01	10354058109	Copper	0.1	1.3	ppm
059-55A Custodian Closet Mop Sink Faucet	6/26/2016 22:25	7/7/2016 21:01	10354058109	Lead	11	15	ppb
059-56A Boys Bathroom Sink Faucet	6/26/2016 22:28	7/7/2016 21:03	10354058111	Copper	0.0	1.3	ppm
059-56A Boys Bathroom Sink Faucet	6/26/2016 22:28	7/7/2016 21:03	10354058111	Lead	17	15	ppb
059-57A Boys Bathroom Water Spigot	6/26/2016 22:30	7/7/2016 21:04	10354058113	Copper	0.1	1.3	ppm
059-57A Boys Bathroom Water Spigot	6/26/2016 22:30	7/7/2016 21:04	10354058113	Lead	52	15	ppb
059-58A Classroom 204 Sink Faucet	6/26/2016 22:32	7/7/2016 21:05	10354058115	Copper	0.1	1.3	ppm
059-58A Classroom 204 Sink Faucet	6/26/2016 22:32	7/7/2016 21:05	10354058115	Lead	19	15	ppb
059-59A Classroom 203 Sink Faucet	6/26/2016 22:35	7/7/2016 21:06	10354058117	Copper	0.1	1.3	ppm
059-59A Classroom 203 Sink Faucet	6/26/2016 22:35	7/7/2016 21:06	10354058117	Lead	9	15	ppb
059-60A Drinking Fountain (202)	6/26/2016 22:38	7/7/2016 21:07	10354058119	Copper	0.0	1.3	ppm
059-60A Drinking Fountain (202)	6/26/2016 22:38	7/7/2016 21:07	10354058119	Lead	4	15	ppb

Analysis by: Grant's Pass

Reviewed by: TRC Environmental Corp

4 of 5

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Llewelyn Elementary School

Sample Identification # and Location	Date/Time Collected	Date/Time Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
059-61A Classroom 202 Sink Faucet	6/26/2016 22:41	7/7/2016 22:25	10354058121	Copper	0.3	1.3	ppm
059-61A Classroom 202 Sink Faucet	6/26/2016 22:41	7/7/2016 22:25	10354058121	Lead	8	15	ppb
059-62A Classroom 203 Drinking Fountain	6/26/2016 22:43	7/7/2016 22:33	10354058123	Copper	0.3	1.3	ppm
059-62A Classroom 203 Drinking Fountain	6/26/2016 22:43	7/7/2016 22:33	10354058123	Lead	6	15	ppb
059-63A Girls Bathroom Sink Faucet #1	6/26/2016 22:46	7/7/2016 22:34	10354058125	Copper	0.0	1.3	ppm
059-63A Girls Bathroom Sink Faucet #1	6/26/2016 22:46	7/7/2016 22:34	10354058125	Lead	52	15	ppb
059-64A Girls Bathroom Sink Faucet #2	6/26/2016 22:48	7/7/2016 22:36	10354058127	Copper	0.0	1.3	ppm
059-64A Girls Bathroom Sink Faucet #2	6/26/2016 22:48	7/7/2016 22:36	10354058127	Lead	14	15	ppb
059-65A Girls Bathroom Water Spigot	6/26/2016 22:50	7/7/2016 22:37	10354058129	Copper	0.0	1.3	ppm
059-65A Girls Bathroom Water Spigot	6/26/2016 22:50	7/7/2016 22:37	10354058129	Lead	13	15	ppb
059-66A Staff Bathroom Sink Faucet	6/26/2016 22:53	7/7/2016 22:38	10354058131	Copper	0.3	1.3	ppm
059-66A Staff Bathroom Sink Faucet	6/26/2016 22:53	7/7/2016 22:38	10354058131	Lead	60	15	ppb
059-67A Portable Building Sink Faucet	6/26/2016 23:00	7/7/2016 22:40	10354058133	Copper	0.1	1.3	ppm
059-67A Portable Building Sink Faucet	6/26/2016 23:00	7/7/2016 22:40	10354058133	Lead	24	15	ppb
059-68A Portable Building Drinking Fountain	6/26/2016 23:03	7/7/2016 22:41	10354058135	Copper	0.0	1.3	ppm
059-68A Portable Building Drinking Fountain	6/26/2016 23:03	7/7/2016 22:41	10354058135	Lead	14	15	ppb
059-69A Outside Water Spigot	6/26/2016 23:08	7/7/2016 22:43	10354058137	Copper	0.2	1.3	ppm
059-69A Outside Water Spigot	6/26/2016 23:08	7/7/2016 22:43	10354058137	Lead	8	15	ppb

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples exceed the Environmental Protection Agency (EPA) guidance.