

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Madison High School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
060-01A Custodial Room A-13 Sink Faucet	7/1/2016 18:18	7/17/2016 17:39	10354438001	Copper	0.3	1.3	ppm
060-01A Custodial Room A-13 Sink Faucet	7/1/2016 18:18	7/15/2016 19:56	10354438001	Lead	4	15	ppb
060-02A Custodial Locker Room Sink Faucet #1	7/1/2016 18:21	7/17/2016 17:42	10354438003	Copper	0.4	1.3	ppm
060-02A Custodial Locker Room Sink Faucet #1	7/1/2016 18:21	7/15/2016 20:02	10354438003	Lead	5	15	ppb
060-03A Custodial Locker Room Sink Faucet #2	7/1/2016 18:23	7/17/2016 17:43	10354438005	Copper	0.3	1.3	ppm
060-03A Custodial Locker Room Sink Faucet #2	7/1/2016 18:23	7/15/2016 20:03	10354438005	Lead	29	15	ppb
060-04A Custodial Locker Room Shower	7/1/2016 18:24	7/17/2016 17:45	10354438007	Copper	0.2	1.3	ppm
060-04A Custodial Locker Room Shower	7/1/2016 18:24	7/15/2016 20:04	10354438007	Lead	32	15	ppb
060-05A Custodial A-10 Sink Faucet	7/1/2016 18:39	7/15/2016 20:06	10354438009	Copper	0.1	1.3	ppm
060-05A Custodial A-10 Sink Faucet	7/1/2016 18:39	7/15/2016 20:06	10354438009	Lead	0	15	ppb
060-06A Classroom A-16 Sink Faucet	7/1/2016 18:44	7/17/2016 17:46	10354438011	Copper	0.6	1.3	ppm
060-06A Classroom A-16 Sink Faucet	7/1/2016 18:44	7/15/2016 20:10	10354438011	Lead	3	15	ppb
060-07A Classroom A-16 Drinking Fountain	7/1/2016 18:45	7/17/2016 17:47	10354438013	Copper	0.8	1.3	ppm
060-07A Classroom A-16 Drinking Fountain	7/1/2016 18:45	7/15/2016 20:11	10354438013	Lead	1	15	ppb
060-08A Room A-17 Sink Faucet	7/1/2016 18:51	7/17/2016 17:49	10354438015	Copper	2.3	1.3	ppm
060-08A Room A-17 Sink Faucet	7/1/2016 18:51	7/17/2016 17:49	10354438015	Lead	217	15	ppb
060-09A Classroom A-18 Handwash	7/1/2016 18:55	7/17/2016 17:53	10354438017	Copper	0.2	1.3	ppm
060-09A Classroom A-18 Handwash	7/1/2016 18:55	7/15/2016 20:14	10354438017	Lead	2	15	ppb
060-10A Classroom A-19 Sink Faucet	7/1/2016 18:58	7/15/2016 20:16	10354438019	Copper	0.2	1.3	ppm
060-10A Classroom A-19 Sink Faucet	7/1/2016 18:58	7/15/2016 20:16	10354438019	Lead	5	15	ppb
060-11A Classroom A-20 Sink Faucet	7/1/2016 18:59	7/17/2016 17:54	10354438021	Copper	0.4	1.3	ppm
060-11A Classroom A-20 Sink Faucet	7/1/2016 18:59	7/15/2016 20:17	10354438021	Lead	3	15	ppb
060-12A Classroom A-19 Drinking Fountain	7/1/2016 19:06	7/8/2016 11:11	10354438023	Copper	1.0	1.3	ppm
060-12A Classroom A-19 Drinking Fountain	7/1/2016 19:06	7/8/2016 10:43	10354438023	Lead	19	15	ppb
060-13A Classroom A-19 Eyewash	7/1/2016 19:07	7/17/2016 17:55	10354438025	Copper	0.8	1.3	ppm
060-13A Classroom A-19 Eyewash	7/1/2016 19:07	7/15/2016 20:20	10354438025	Lead	31	15	ppb
060-14A Custodial Closet Sink Faucet	7/1/2016 19:22	7/17/2016 17:57	10354438027	Copper	0.2	1.3	ppm
060-14A Custodial Closet Sink Faucet	7/1/2016 19:22	7/15/2016 20:21	10354438027	Lead	4	15	ppb
060-15A Boys Bathroom Sink Faucet #1	7/1/2016 19:09	7/17/2016 17:58	10354438029	Copper	0.2	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Madison High School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
060-15A Boys Bathroom Sink Faucet #1	7/1/2016 19:09	7/15/2016 20:22	10354438029	Lead	11	15	ppb
060-16A Boys Bathroom Sink Faucet #2	7/1/2016 19:11	7/17/2016 18:00	10354438031	Copper	0.2	1.3	ppm
060-16A Boys Bathroom Sink Faucet #2	7/1/2016 19:11	7/15/2016 20:26	10354438031	Lead	18	15	ppb
060-17A Boys Bathroom Water Spigot	7/1/2016 19:16	7/8/2016 11:18	10354438033	Copper	0.7	1.3	ppm
060-17A Boys Bathroom Water Spigot	7/1/2016 19:16	7/8/2016 10:45	10354438033	Lead	45	15	ppb
060-18A Girls Bathroom Sink Faucet	7/1/2016 19:18	7/15/2016 20:28	10354438035	Copper	0.2	1.3	ppm
060-18A Girls Bathroom Sink Faucet	7/1/2016 19:18	7/15/2016 20:28	10354438035	Lead	14	15	ppb
060-19A Girls Bathroom Water Spigot	7/1/2016 19:19	7/8/2016 11:19	10354438037	Copper	1.30	1.3	ppm
060-19A Girls Bathroom Water Spigot	7/1/2016 19:19	7/8/2016 10:47	10354438037	Lead	74	15	ppb
060-20A Outside Gymnasium Drinking Fountain #1	7/1/2016 19:28	7/17/2016 18:01	10354438039	Copper	2.0	1.3	ppm
060-20A Outside Gymnasium Drinking Fountain #1	7/1/2016 19:28	7/15/2016 20:29	10354438039	Lead	1	15	ppb
060-21A Outside Gymnasium Drinking Fountain #2	7/1/2016 19:29	7/17/2016 18:02	10354438041	Copper	2.3	1.3	ppm
060-21A Outside Gymnasium Drinking Fountain #2	7/1/2016 19:29	7/15/2016 20:33	10354438041	Lead	1	15	ppb
060-22A Gymnasium Drinking Fountain	7/1/2016 19:32	7/17/2016 18:05	10354438043	Copper	0.6	1.3	ppm
060-22A Gymnasium Drinking Fountain	7/1/2016 19:32	7/15/2016 20:39	10354438043	Lead	2	15	ppb
060-23A Athletic Trainers Room Water Spigot	7/1/2016 19:43	7/17/2016 18:09	10354438045	Copper	0.1	1.3	ppm
060-23A Athletic Trainers Room Water Spigot	7/1/2016 19:43	7/17/2016 18:09	10354438045	Lead	16	15	ppb
060-24A Coach/PE Office Sink Faucet	7/1/2016 19:51	7/17/2016 18:10	10354438047	Copper	0.2	1.3	ppm
060-24A Coach/PE Office Sink Faucet	7/1/2016 19:51	7/17/2016 18:10	10354438047	Lead	4	15	ppb
060-25A Locker Room B Bathroom Sink Faucet #1	7/1/2016 19:53	7/17/2016 18:12	10354438049	Copper	0.4	1.3	ppm
060-25A Locker Room B Bathroom Sink Faucet #1	7/1/2016 19:53	7/17/2016 18:12	10354438049	Lead	4	15	ppb
060-26A Locker Room B Bathroom Sink Faucet #2	7/1/2016 19:54	7/17/2016 18:13	10354438051	Copper	0.5	1.3	ppm
060-26A Locker Room B Bathroom Sink Faucet #2	7/1/2016 19:54	7/17/2016 18:13	10354438051	Lead	28	15	ppb
060-27A Locker Room B Bathroom Water Spigot	7/1/2016 19:55	7/8/2016 11:20	10354438053	Copper	1.1	1.3	ppm
060-27A Locker Room B Bathroom Water Spigot	7/1/2016 19:55	7/8/2016 10:49	10354438053	Lead	36	15	ppb
060-28A Locker Room B Drinking Fountain	7/1/2016 19:54	7/17/2016 18:14	10354438055	Copper	0.4	1.3	ppm
060-28A Locker Room B Drinking Fountain	7/1/2016 19:54	7/17/2016 18:14	10354438055	Lead	1	15	ppb
060-29A Locker Room A Bathroom Sink Faucet #1	7/1/2016 20:01	7/17/2016 18:16	10354438057	Copper	0.2	1.3	ppm
060-29A Locker Room A Bathroom Sink Faucet #1	7/1/2016 20:01	7/17/2016 18:16	10354438057	Lead	3	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Madison High School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
060-30A Locker Room A Bathroom Sink Faucet #2	7/1/2016 20:02	7/17/2016 18:17	10354438059	Copper	0.3	1.3	ppm
060-30A Locker Room A Bathroom Sink Faucet #2	7/1/2016 20:02	7/17/2016 18:17	10354438059	Lead	3	15	ppb
060-31A Locker Room A Bathroom Water Spigot	7/1/2016 20:03	7/8/2016 11:22	10354438061	Copper	0.6	1.3	ppm
060-31A Locker Room A Bathroom Water Spigot	7/1/2016 20:03	7/8/2016 10:50	10354438061	Lead	29	15	ppb
060-32A Locker Room A Drinking Fountain	7/1/2016 20:07	7/17/2016 18:18	10354438063	Copper	0.2	1.3	ppm
060-32A Locker Room A Drinking Fountain	7/1/2016 20:07	7/17/2016 18:18	10354438063	Lead	1	15	ppb
060-33A Locker Room A Custodial Sink Faucet	7/1/2016 20:08	7/17/2016 18:20	10354438065	Copper	0.2	1.3	ppm
060-33A Locker Room A Custodial Sink Faucet	7/1/2016 20:08	7/17/2016 18:20	10354438065	Lead	4	15	ppb
060-34A Locker Room A Office Sink Faucet #1	7/1/2016 20:10	7/17/2016 18:25	10354438067	Copper	0.4	1.3	ppm
060-34A Locker Room A Office Sink Faucet #1	7/1/2016 20:10	7/17/2016 18:25	10354438067	Lead	10	15	ppb
060-35A Locker Room A Office Sink Faucet #2	7/1/2016 20:11	7/17/2016 18:27	10354438069	Copper	0.3	1.3	ppm
060-35A Locker Room A Office Sink Faucet #2	7/1/2016 20:11	7/17/2016 18:27	10354438069	Lead	3	15	ppb
060-36A Weight Room Drinking Fountain	7/1/2016 20:13	7/17/2016 18:28	10354438071	Copper	0.7	1.3	ppm
060-36A Weight Room Drinking Fountain	7/1/2016 20:13	7/17/2016 18:28	10354438071	Lead	1	15	ppb
060-37A Weight Room Water Spigot	7/1/2016 20:16	7/17/2016 18:29	10354438073	Copper	0.6	1.3	ppm
060-37A Weight Room Water Spigot	7/1/2016 20:16	7/17/2016 18:29	10354438073	Lead	17	15	ppb
060-38A Custodial Sink Faucet	7/1/2016 20:27	7/17/2016 18:31	10354438075	Copper	1.1	1.3	ppm
060-38A Custodial Sink Faucet	7/1/2016 20:27	7/17/2016 18:31	10354438075	Lead	6	15	ppb
060-39A Wrestle Drinking Fountain	7/1/2016 20:29	7/17/2016 18:32	10354438077	Copper	1.5	1.3	ppm
060-39A Wrestle Drinking Fountain	7/1/2016 20:29	7/17/2016 18:32	10354438077	Lead	4	15	ppb
060-40A Classroom 65 Sink Faucet #1	7/1/2016 20:39	7/17/2016 18:33	10354438079	Copper	0.6	1.3	ppm
060-40A Classroom 65 Sink Faucet #1	7/1/2016 20:39	7/17/2016 18:33	10354438079	Lead	5	15	ppb
060-41A Classroom 65 Sink Faucet #2	7/1/2016 20:39	7/17/2016 20:15	10354438081	Copper	0.7	1.3	ppm
060-41A Classroom 65 Sink Faucet #2	7/1/2016 20:39	7/15/2016 23:17	10354438081	Lead	11	15	ppb
060-42A Classroom 65 Sink Faucet #3	7/1/2016 20:39	7/17/2016 20:20	10354438083	Copper	0.3	1.3	ppm
060-42A Classroom 65 Sink Faucet #3	7/1/2016 20:39	7/15/2016 23:23	10354438083	Lead	9	15	ppb
060-43A Classroom B-64 Sink Faucet #1	7/1/2016 20:50	7/17/2016 20:21	10354438085	Copper	0.2	1.3	ppm
060-43A Classroom B-64 Sink Faucet #1	7/1/2016 20:50	7/15/2016 23:24	10354438085	Lead	13	15	ppb
060-44A Classroom B-64 Sink Faucet #2	7/1/2016 20:50	7/15/2016 23:26	10354438087	Copper	0.2	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Madison High School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
060-44A Classroom B-64 Sink Faucet #2	7/1/2016 20:50	7/15/2016 23:26	10354438087	Lead	13	15	ppb
060-45A Classroom B-64 Sink Faucet #3	7/1/2016 20:52	7/15/2016 23:30	10354438089	Copper	0.1	1.3	ppm
060-45A Classroom B-64 Sink Faucet #3	7/1/2016 20:52	7/15/2016 23:30	10354438089	Lead	10	15	ppb
060-46A Classroom B-64 Sink Faucet #4	7/1/2016 20:52	7/17/2016 20:23	10354438091	Copper	0.2	1.3	ppm
060-46A Classroom B-64 Sink Faucet #4	7/1/2016 20:52	7/15/2016 23:31	10354438091	Lead	14	15	ppb
060-47A Classroom B-64 Sink Faucet #5	7/1/2016 20:52	7/15/2016 23:33	10354438093	Copper	0.2	1.3	ppm
060-47A Classroom B-64 Sink Faucet #5	7/1/2016 20:52	7/15/2016 23:33	10354438093	Lead	12	15	ppb
060-48A Classroom B-64 Sink Faucet #6	7/1/2016 20:53	7/15/2016 23:34	10354438095	Copper	0.2	1.3	ppm
060-48A Classroom B-64 Sink Faucet #6	7/1/2016 20:53	7/15/2016 23:34	10354438095	Lead	6	15	ppb
060-49A Classroom B-64 Sink Faucet #7	7/1/2016 20:53	7/15/2016 23:36	10354438097	Copper	0.1	1.3	ppm
060-49A Classroom B-64 Sink Faucet #7	7/1/2016 20:53	7/15/2016 23:36	10354438097	Lead	9	15	ppb
060-50A Classroom B-64 Sink Faucet #8	7/1/2016 20:54	7/15/2016 23:37	10354438099	Copper	0.1	1.3	ppm
060-50A Classroom B-64 Sink Faucet #8	7/1/2016 20:54	7/15/2016 23:37	10354438099	Lead	10	15	ppb
060-51A Classroom B-64 Sink Faucet #9	7/1/2016 20:54	7/15/2016 23:38	10354438101	Copper	0.1	1.3	ppm
060-51A Classroom B-64 Sink Faucet #9	7/1/2016 20:54	7/15/2016 23:38	10354438101	Lead	5	15	ppb
060-52A Classroom B-67 Sink Faucet #1	7/1/2016 20:57	7/15/2016 23:41	10354438103	Copper	0.2	1.3	ppm
060-52A Classroom B-67 Sink Faucet #1	7/1/2016 20:57	7/15/2016 23:41	10354438103	Lead	13	15	ppb
060-53A Classroom B-67 Sink Faucet #2	7/1/2016 20:57	7/15/2016 23:43	10354438105	Copper	0.2	1.3	ppm
060-53A Classroom B-67 Sink Faucet #2	7/1/2016 20:57	7/15/2016 23:43	10354438105	Lead	9	15	ppb
060-54A Classroom B-67 Sink Faucet #3	7/1/2016 20:58	7/17/2016 20:24	10354438107	Copper	1.0	1.3	ppm
060-54A Classroom B-67 Sink Faucet #3	7/1/2016 20:58	7/15/2016 23:47	10354438107	Lead	7	15	ppb
060-56A Hallway Drinking Fountain (B-68)	7/1/2016 21:03	7/17/2016 20:25	10354438111	Copper	0.9	1.3	ppm
060-56A Hallway Drinking Fountain (B-68)	7/1/2016 21:03	7/15/2016 23:48	10354438111	Lead	1	15	ppb
060-57A Girls Bathroom B-69 Sink Faucet #1	7/1/2016 21:06	7/17/2016 20:27	10354438113	Copper	0.5	1.3	ppm
060-57A Girls Bathroom B-69 Sink Faucet #1	7/1/2016 21:06	7/15/2016 23:50	10354438113	Lead	1	15	ppb
060-58A Girls Bathroom B-69 Sink Faucet #2	7/1/2016 21:07	7/18/2016 11:48	10354438115	Copper	0.2	1.3	ppm
060-58A Girls Bathroom B-69 Sink Faucet #2	7/1/2016 21:07	7/15/2016 23:51	10354438115	Lead	5	15	ppb
060-59A Girls Bathroom B-69 Water Spigot	7/1/2016 21:12	7/8/2016 11:23	10354438117	Copper	1.6	1.3	ppm
060-59A Girls Bathroom B-69 Water Spigot	7/1/2016 21:12	7/8/2016 10:52	10354438117	Lead	300	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Madison High School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
060-60A Boys Bathroom B-70 Sink Faucet #1	7/1/2016 21:15	7/17/2016 20:28	10354438119	Copper	0.4	1.3	ppm
060-60A Boys Bathroom B-70 Sink Faucet #1	7/1/2016 21:15	7/15/2016 23:52	10354438119	Lead	6	15	ppb
060-61A Boys Bathroom B-70 Sink Faucet #2	7/1/2016 21:16	7/17/2016 18:37	10354438121	Copper	0.2	1.3	ppm
060-61A Boys Bathroom B-70 Sink Faucet #2	7/1/2016 21:16	7/17/2016 18:37	10354438121	Lead	4	15	ppb
060-62A Boys Bathroom B-70 Sink Faucet #3	7/1/2016 21:18	7/17/2016 18:43	10354438123	Copper	0.4	1.3	ppm
060-62A Boys Bathroom B-70 Sink Faucet #3	7/1/2016 21:18	7/15/2016 21:21	10354438123	Lead	2	15	ppb
060-63A Boys Bathroom B-70 Water Spigot	7/1/2016 21:16	7/8/2016 11:24	10354438125	Copper	1.0	1.3	ppm
060-63A Boys Bathroom B-70 Water Spigot	7/1/2016 21:16	7/8/2016 10:53	10354438125	Lead	18	15	ppb
060-64A Classroom B-71 Sink Faucet #1	7/1/2016 21:20	7/17/2016 18:44	10354438127	Copper	0.3	1.3	ppm
060-64A Classroom B-71 Sink Faucet #1	7/1/2016 21:20	7/15/2016 21:22	10354438127	Lead	62	15	ppb
060-65A Classroom B-71 Sink Faucet #2	7/1/2016 21:20	7/17/2016 18:45	10354438129	Copper	0.6	1.3	ppm
060-65A Classroom B-71 Sink Faucet #2	7/1/2016 21:20	7/15/2016 21:23	10354438129	Lead	16	15	ppb
060-66A Classroom B-71 Sink Faucet #3	7/1/2016 21:21	7/17/2016 18:47	10354438131	Copper	0.5	1.3	ppm
060-66A Classroom B-71 Sink Faucet #3	7/1/2016 21:21	7/15/2016 21:25	10354438131	Lead	12	15	ppb
060-67A Classroom B-71 Sink Faucet #4	7/1/2016 21:22	7/17/2016 18:48	10354438133	Copper	0.2	1.3	ppm
060-67A Classroom B-71 Sink Faucet #4	7/1/2016 21:22	7/15/2016 21:26	10354438133	Lead	8	15	ppb
060-68A Kitchen Handwash Sink Faucet	7/1/2016 21:27	7/17/2016 18:50	10354438135	Copper	0.7	1.3	ppm
060-68A Kitchen Handwash Sink Faucet	7/1/2016 21:27	7/15/2016 21:28	10354438135	Lead	80	15	ppb
060-69A Kitchen Food Prep Sink Faucet	7/1/2016 21:38	7/17/2016 18:51	10354438137	Copper	0.3	1.3	ppm
060-69A Kitchen Food Prep Sink Faucet	7/1/2016 21:38	7/15/2016 21:29	10354438137	Lead	8	15	ppb
060-70A Kitchen Sink Faucet #1	7/1/2016 21:40	7/15/2016 21:33	10354438139	Copper	0.2	1.3	ppm
060-70A Kitchen Sink Faucet #1	7/1/2016 21:40	7/15/2016 21:33	10354438139	Lead	3	15	ppb
060-71A Kitchen Sink Faucet #2	7/1/2016 21:40	7/17/2016 18:52	10354438141	Copper	0.3	1.3	ppm
060-71A Kitchen Sink Faucet #2	7/1/2016 21:40	7/15/2016 21:35	10354438141	Lead	7	15	ppb
060-72A Kitchen Sink Faucet #3	7/1/2016 21:41	7/15/2016 21:36	10354438143	Copper	0.1	1.3	ppm
060-72A Kitchen Sink Faucet #3	7/1/2016 21:41	7/15/2016 21:36	10354438143	Lead	2	15	ppb
060-73A Kitchen Sink Faucet #4	7/1/2016 21:42	7/17/2016 18:54	10354438145	Copper	0.2	1.3	ppm
060-73A Kitchen Sink Faucet #4	7/1/2016 21:42	7/15/2016 21:39	10354438145	Lead	4	15	ppb
060-74A Kitchen Handwash Sink Faucet	7/1/2016 21:43	7/17/2016 18:58	10354438147	Copper	0.4	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Madison High School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
060-74A Kitchen Handwash Sink Faucet	7/1/2016 21:43	7/15/2016 21:40	10354438147	Lead	2	15	ppb
060-75A Kitchen Bathroom Sink Faucet	7/1/2016 21:45	7/17/2016 18:59	10354438149	Copper	0.3	1.3	ppm
060-75A Kitchen Bathroom Sink Faucet	7/1/2016 21:45	7/15/2016 21:42	10354438149	Lead	5	15	ppb
060-76A Kitchen Locker Room Sink Faucet	7/1/2016 21:46	7/17/2016 19:00	10354438151	Copper	0.6	1.3	ppm
060-76A Kitchen Locker Room Sink Faucet	7/1/2016 21:46	7/15/2016 21:43	10354438151	Lead	5	15	ppb
060-77A Kitchen Dishwash Sink Faucet	7/1/2016 21:48	7/17/2016 19:02	10354438153	Copper	0.5	1.3	ppm
060-77A Kitchen Dishwash Sink Faucet	7/1/2016 21:48	7/15/2016 21:45	10354438153	Lead	3	15	ppb
060-78A Cafeteria Drinking Fountain	7/1/2016 21:53	7/17/2016 19:03	10354438155	Copper	0.7	1.3	ppm
060-78A Cafeteria Drinking Fountain	7/1/2016 21:53	7/15/2016 21:46	10354438155	Lead	0	15	ppb
060-79A Cafeteria Office Sink Faucet	7/1/2016 22:00	7/8/2016 11:26	10354438157	Copper	5.3	1.3	ppm
060-79A Cafeteria Office Sink Faucet	7/1/2016 22:00	7/8/2016 11:26	10354438157	Lead	1180	15	ppb
060-80A Workshop B-56 Sink Faucet	7/1/2016 22:09	7/17/2016 19:04	10354438159	Copper	0.3	1.3	ppm
060-80A Workshop B-56 Sink Faucet	7/1/2016 22:09	7/15/2016 21:50	10354438159	Lead	11	15	ppb
060-81A Health Clinic Sink Faucet #1	7/1/2016 22:11	7/17/2016 19:06	10354438161	Copper	0.6	1.3	ppm
060-81A Health Clinic Sink Faucet #1	7/1/2016 22:11	7/15/2016 21:54	10354438161	Lead	5	15	ppb
060-82A Health Clinic Sink Faucet #2	7/1/2016 22:13	7/17/2016 19:08	10354438163	Copper	0.2	1.3	ppm
060-82A Health Clinic Sink Faucet #2	7/1/2016 22:13	7/15/2016 22:00	10354438163	Lead	9	15	ppb
060-83A Health Clinic Sink Faucet #3	7/1/2016 22:13	7/17/2016 19:10	10354438165	Copper	0.5	1.3	ppm
060-83A Health Clinic Sink Faucet #3	7/1/2016 22:13	7/15/2016 22:01	10354438165	Lead	9	15	ppb
060-84A Health Clinic Sink Faucet #4	7/1/2016 22:15	7/17/2016 19:14	10354438167	Copper	0.3	1.3	ppm
060-84A Health Clinic Sink Faucet #4	7/1/2016 22:15	7/15/2016 22:03	10354438167	Lead	4	15	ppb
060-85A Health Clinic Bathroom Sink Faucet	7/1/2016 22:16	7/17/2016 19:15	10354438169	Copper	0.3	1.3	ppm
060-85A Health Clinic Bathroom Sink Faucet	7/1/2016 22:16	7/15/2016 22:07	10354438169	Lead	10	15	ppb
060-86A Exam Room 2 Sink Faucet	7/1/2016 22:17	7/17/2016 19:16	10354438171	Copper	0.3	1.3	ppm
060-86A Exam Room 2 Sink Faucet	7/1/2016 22:17	7/15/2016 22:08	10354438171	Lead	4	15	ppb
060-87A Exam Room 1 Sink Faucet	7/1/2016 22:17	7/17/2016 19:18	10354438173	Copper	0.4	1.3	ppm
060-87A Exam Room 1 Sink Faucet	7/1/2016 22:17	7/15/2016 22:09	10354438173	Lead	10	15	ppb
060-88A Hallway Drinking Fountain (B-42) #1	7/1/2016 22:20	7/17/2016 19:19	10354438175	Copper	0.7	1.3	ppm
060-88A Hallway Drinking Fountain (B-42) #1	7/1/2016 22:20	7/15/2016 22:11	10354438175	Lead	2	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Madison High School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
060-89A Hallway Drinking Fountain (B-42) #2	7/1/2016 22:20	7/17/2016 19:20	10354438177	Copper	0.3	1.3	ppm
060-89A Hallway Drinking Fountain (B-42) #2	7/1/2016 22:20	7/15/2016 22:12	10354438177	Lead	3	15	ppb
060-90A Hallway Drinking Fountain (B-42) #3	7/1/2016 22:21	7/17/2016 19:22	10354438179	Copper	0.7	1.3	ppm
060-90A Hallway Drinking Fountain (B-42) #3	7/1/2016 22:21	7/15/2016 22:14	10354438179	Lead	4	15	ppb
060-91A Custodial B-42 Sink Faucet	7/1/2016 22:24	7/18/2016 11:17	10354438181	Copper	0.5	1.3	ppm
060-91A Custodial B-42 Sink Faucet	7/1/2016 22:24	7/17/2016 19:23	10354438181	Lead	1	15	ppb
060-92A Bathroom Outside B-43 Sink Faucet	7/1/2016 22:26	7/17/2016 19:26	10354438183	Copper	0.5	1.3	ppm
060-92A Bathroom Outside B-43 Sink Faucet	7/1/2016 22:26	7/15/2016 22:18	10354438183	Lead	5	15	ppb
060-93A Girls Dressing Room Bathroom Sink Faucet	7/1/2016 22:29	7/18/2016 11:19	10354438185	Copper	0.9	1.3	ppm
060-93A Girls Dressing Room Bathroom Sink Faucet	7/1/2016 22:29	7/15/2016 22:19	10354438185	Lead	4	15	ppb
060-94A Boys Dressing Room Bathroom Sink Faucet	7/1/2016 22:32	7/18/2016 11:20	10354438187	Copper	0.9	1.3	ppm
060-94A Boys Dressing Room Bathroom Sink Faucet	7/1/2016 22:32	7/15/2016 22:23	10354438187	Lead	8	15	ppb
060-95A Projection Room B-41 Sink Faucet	7/1/2016 22:36	7/18/2016 11:21	10354438189	Copper	1.7	1.3	ppm
060-95A Projection Room B-41 Sink Faucet	7/1/2016 22:36	7/15/2016 22:25	10354438189	Lead	70	15	ppb
060-96A Hallway Drinking Fountain (B-40) #1	7/1/2016 22:39	7/18/2016 11:23	10354438191	Copper	0.9	1.3	ppm
060-96A Hallway Drinking Fountain (B-40) #1	7/1/2016 22:39	7/15/2016 22:26	10354438191	Lead	2	15	ppb
060-97A Hallway Drinking Fountain (B-40) #2	7/1/2016 22:39	7/18/2016 11:24	10354438193	Copper	0.5	1.3	ppm
060-97A Hallway Drinking Fountain (B-40) #2	7/1/2016 22:39	7/15/2016 22:27	10354438193	Lead	3	15	ppb
060-98A Custodial Closet B-40 Sink Faucet	7/1/2016 22:42	7/18/2016 11:25	10354438195	Copper	0.4	1.3	ppm
060-98A Custodial Closet B-40 Sink Faucet	7/1/2016 22:42	7/15/2016 22:29	10354438195	Lead	2	15	ppb
060-99A Staff Restroom B-29 Sink Faucet	7/1/2016 22:45	7/18/2016 13:45	10354438197	Copper	0.5	1.3	ppm
060-99A Staff Restroom B-29 Sink Faucet	7/1/2016 22:45	7/18/2016 13:22	10354438197	Lead	4	15	ppb
060-100A Girls Bathroom Sink Faucet #1	7/1/2016 23:11	7/18/2016 13:47	10354438199	Copper	0.5	1.3	ppm
060-100A Girls Bathroom Sink Faucet #1	7/1/2016 23:11	7/18/2016 13:23	10354438199	Lead	4	15	ppb
060-101A Girls Bathroom Sink Faucet #2	7/1/2016 23:11	7/10/2016 17:32	10354438201	Copper	0.3	1.3	ppm
060-101A Girls Bathroom Sink Faucet #2	7/1/2016 23:11	7/10/2016 17:32	10354438201	Lead	10	15	ppb
060-102A Girls Bathroom Sink Faucet #3	7/1/2016 23:12	7/10/2016 17:37	10354438203	Copper	0.2	1.3	ppm
060-102A Girls Bathroom Sink Faucet #3	7/1/2016 23:12	7/10/2016 17:37	10354438203	Lead	4	15	ppb
060-103A Girls Bathroom Sink Faucet #4	7/1/2016 23:12	7/19/2016 09:52	10354438205	Copper	0.3	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Madison High School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
060-103A Girls Bathroom Sink Faucet #4	7/1/2016 23:12	7/19/2016 09:52	10354438205	Lead	28	15	ppb
060-104A Girls Bathroom Sink Faucet #5	7/1/2016 23:13	7/19/2016 09:53	10354438207	Copper	0.3	1.3	ppm
060-104A Girls Bathroom Sink Faucet #5	7/1/2016 23:13	7/19/2016 09:53	10354438207	Lead	7	15	ppb
060-105A Girls Bathroom Water Spigot	7/1/2016 23:13	7/8/2016 11:00	10354438209	Copper	0.3	1.3	ppm
060-105A Girls Bathroom Water Spigot	7/1/2016 23:13	7/8/2016 11:00	10354438209	Lead	30	15	ppb
060-106A Boys Bathroom Sink Faucet #1	7/1/2016 23:15	7/10/2016 17:43	10354438211	Copper	0.4	1.3	ppm
060-106A Boys Bathroom Sink Faucet #1	7/1/2016 23:15	7/10/2016 17:43	10354438211	Lead	12	15	ppb
060-107A Boys Bathroom Sink Faucet #2	7/1/2016 23:15	7/12/2016 03:14	10354438213	Copper	0.3	1.3	ppm
060-107A Boys Bathroom Sink Faucet #2	7/1/2016 23:15	7/12/2016 03:14	10354438213	Lead	12	15	ppb
060-108A Boys Bathroom Sink Faucet #3	7/1/2016 23:16	7/12/2016 09:33	10354438215	Copper	0.6	1.3	ppm
060-108A Boys Bathroom Sink Faucet #3	7/1/2016 23:16	7/12/2016 03:19	10354438215	Lead	13	15	ppb
060-110A Hallway Drinking Fountain (B-38) #1	7/1/2016 23:19	7/10/2016 17:44	10354438219	Copper	0.1	1.3	ppm
060-110A Hallway Drinking Fountain (B-38) #1	7/1/2016 23:19	7/10/2016 17:44	10354438219	Lead	2	15	ppb
060-111A Hallway Drinking Fountain (B-38) #2	7/1/2016 23:20	7/10/2016 17:45	10354438221	Copper	0.1	1.3	ppm
060-111A Hallway Drinking Fountain (B-38) #2	7/1/2016 23:20	7/10/2016 17:45	10354438221	Lead	3	15	ppb
060-112A Nursery B-38 Bathroom Sink Faucet	7/1/2016 23:22	7/10/2016 17:47	10354438223	Copper	0.2	1.3	ppm
060-112A Nursery B-38 Bathroom Sink Faucet	7/1/2016 23:22	7/10/2016 17:47	10354438223	Lead	1	15	ppb
060-113A Nursery Play Area Sink Faucet #1	7/1/2016 23:24	7/10/2016 17:48	10354438225	Copper	0.2	1.3	ppm
060-113A Nursery Play Area Sink Faucet #1	7/1/2016 23:24	7/10/2016 17:48	10354438225	Lead	2	15	ppb
060-114A Nursery Play Area Sink Faucet #2	7/1/2016 23:26	7/10/2016 17:49	10354438227	Copper	0.2	1.3	ppm
060-114A Nursery Play Area Sink Faucet #2	7/1/2016 23:26	7/10/2016 17:49	10354438227	Lead	2	15	ppb
060-115A Nursery B-38 Kids Bathroom Sink Faucet #1	7/1/2016 23:28	7/10/2016 17:50	10354438229	Copper	0.2	1.3	ppm
060-115A Nursery B-38 Kids Bathroom Sink Faucet #1	7/1/2016 23:28	7/10/2016 17:50	10354438229	Lead	2	15	ppb
060-116A Nursery B-38 Kids Bathroom Sink Faucet #2	7/1/2016 23:34	7/10/2016 17:54	10354438231	Copper	0.2	1.3	ppm
060-116A Nursery B-38 Kids Bathroom Sink Faucet #2	7/1/2016 23:34	7/10/2016 17:54	10354438231	Lead	3	15	ppb
060-117A Nursery B-38 Dishwash Sink Faucet	7/1/2016 23:32	7/10/2016 17:58	10354438233	Copper	0.3	1.3	ppm
060-117A Nursery B-38 Dishwash Sink Faucet	7/1/2016 23:32	7/10/2016 17:58	10354438233	Lead	2	15	ppb
060-118A Nursery B-38 Handwash Sink Faucet	7/1/2016 23:35	7/10/2016 17:59	10354438235	Copper	0.3	1.3	ppm
060-118A Nursery B-38 Handwash Sink Faucet	7/1/2016 23:35	7/10/2016 17:59	10354438235	Lead	1	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Madison High School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
060-119A Custodial Closet B60 Sink Faucet	7/1/2016 23:44	7/19/2016 09:55	10354438237	Copper	0.3	1.3	ppm
060-119A Custodial Closet B60 Sink Faucet	7/1/2016 23:44	7/19/2016 09:55	10354438237	Lead	4	15	ppb
060-120A Hallway Drinking Fountain (B-58) #1	7/1/2016 23:46	7/10/2016 21:08	10354438239	Copper	0.8	1.3	ppm
060-120A Hallway Drinking Fountain (B-58) #1	7/1/2016 23:46	7/10/2016 21:08	10354438239	Lead	2	15	ppb
060-121A Hallway Drinking Fountain (B-58) #2	7/1/2016 23:47	7/10/2016 21:10	10354438241	Copper	0.5	1.3	ppm
060-121A Hallway Drinking Fountain (B-58) #2	7/1/2016 23:47	7/10/2016 18:05	10354438241	Lead	3	15	ppb
060-122A Room B-58 Sink Faucet	7/1/2016 23:47	7/10/2016 18:13	10354438243	Copper	0.3	1.3	ppm
060-122A Room B-58 Sink Faucet	7/1/2016 23:47	7/10/2016 18:13	10354438243	Lead	6	15	ppb
060-123A Classroom B-18 Sink Faucet	7/1/2016 23:50	7/10/2016 18:14	10354438245	Copper	0.3	1.3	ppm
060-123A Classroom B-18 Sink Faucet	7/1/2016 23:50	7/10/2016 18:14	10354438245	Lead	4	15	ppb
060-124A Classroom B-16 Drinking Fountain	7/1/2016 23:52	7/10/2016 21:15	10354438247	Copper	0.6	1.3	ppm
060-124A Classroom B-16 Drinking Fountain	7/1/2016 23:52	7/10/2016 21:15	10354438247	Lead	6	15	ppb
060-125A Classroom B-148 Sink Faucet	7/1/2016 23:54	7/19/2016 09:59	10354438249	Copper	0.5	1.3	ppm
060-125A Classroom B-148 Sink Faucet	7/1/2016 23:54	7/19/2016 09:59	10354438249	Lead	4	15	ppb
060-126A Classroom B-13 Drinking Fountain	7/1/2016 23:55	7/8/2016 11:27	10354438251	Copper	1.2	1.3	ppm
060-126A Classroom B-13 Drinking Fountain	7/1/2016 23:55	7/8/2016 11:02	10354438251	Lead	9	15	ppb
060-127A Womens Faculty Bathroom B-7 Sink Faucet	7/1/2016 23:56	7/19/2016 10:00	10354438253	Copper	0.3	1.3	ppm
060-127A Womens Faculty Bathroom B-7 Sink Faucet	7/1/2016 23:56	7/19/2016 10:00	10354438253	Lead	1	15	ppb
060-128A Mens Faculty Bathroom B-6 Sink Faucet	7/1/2016 23:58	7/19/2016 10:02	10354438255	Copper	0.3	1.3	ppm
060-128A Mens Faculty Bathroom B-6 Sink Faucet	7/1/2016 23:58	7/19/2016 10:02	10354438255	Lead	2	15	ppb
060-129A Room B-5 Sink Faucet	7/1/2016 00:00	7/19/2016 10:03	10354438257	Copper	0.4	1.3	ppm
060-129A Room B-5 Sink Faucet	7/1/2016 00:00	7/19/2016 10:03	10354438257	Lead	14	15	ppb
060-130A Room B-4 Sink Faucet	7/1/2016 00:02	7/10/2016 21:17	10354438259	Copper	0.5	1.3	ppm
060-130A Room B-4 Sink Faucet	7/1/2016 00:02	7/10/2016 21:17	10354438259	Lead	11	15	ppb
060-131A Hallway Drinking Fountain Outside B1	7/1/2016 00:05	7/19/2016 10:05	10354438261	Copper	0.2	1.3	ppm
060-131A Hallway Drinking Fountain Outside B1	7/1/2016 00:05	7/19/2016 10:05	10354438261	Lead	3	15	ppb
060-132A Office Workroom Sink Faucet	7/1/2016 00:07	7/10/2016 21:18	10354438263	Copper	0.6	1.3	ppm
060-132A Office Workroom Sink Faucet	7/1/2016 00:07	7/10/2016 21:18	10354438263	Lead	4	15	ppb
060-133A Custodial Closet Sink Faucet	7/1/2016 00:10	7/19/2016 10:11	10354438265	Copper	0.3	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Madison High School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
060-133A Custodial Closet Sink Faucet	7/1/2016 00:10	7/19/2016 10:11	10354438265	Lead	4	15	ppb
060-134A Nurses Office B1-L Sink Faucet	7/1/2016 00:12	7/19/2016 10:32	10354438267	Copper	0.5	1.3	ppm
060-134A Nurses Office B1-L Sink Faucet	7/1/2016 00:12	7/19/2016 10:12	10354438267	Lead	6	15	ppb
060-136A Classroom C-60 Sink Faucet #1	7/1/2016 01:57	7/10/2016 21:19	10354438269	Copper	1.5	1.3	ppm
060-136A Classroom C-60 Sink Faucet #1	7/1/2016 01:57	7/10/2016 18:33	10354438269	Lead	24	15	ppb
060-137A Classroom C-60 Sink Faucet #2	7/1/2016 01:57	7/10/2016 21:20	10354438271	Copper	1.2	1.3	ppm
060-137A Classroom C-60 Sink Faucet #2	7/1/2016 01:57	7/10/2016 21:20	10354438271	Lead	4	15	ppb
060-138A Boys Bathroom Sink Faucet #1	7/1/2016 02:01	7/10/2016 21:21	10354438273	Copper	0.5	1.3	ppm
060-138A Boys Bathroom Sink Faucet #1	7/1/2016 02:01	7/10/2016 21:21	10354438273	Lead	5	15	ppb
060-139A Boys Bathroom Sink Faucet #2	7/1/2016 02:01	7/19/2016 10:14	10354438275	Copper	0.4	1.3	ppm
060-139A Boys Bathroom Sink Faucet #2	7/1/2016 02:01	7/19/2016 10:14	10354438275	Lead	61	15	ppb
060-140A Boys Bathroom Water Spigot	7/1/2016 02:02	7/12/2016 09:05	10354438277	Copper	0.5	1.3	ppm
060-140A Boys Bathroom Water Spigot	7/1/2016 02:02	7/12/2016 02:00	10354438277	Lead	10	15	ppb
060-141A Girls Bathroom Sink Faucet	7/1/2016 02:04	7/19/2016 10:15	10354438279	Copper	0.3	1.3	ppm
060-141A Girls Bathroom Sink Faucet	7/1/2016 02:04	7/19/2016 10:15	10354438279	Lead	8	15	ppb
060-142A Girls Bathroom Water Spigot	7/1/2016 02:07	7/18/2016 11:27	10354438281	Copper	0.2	1.3	ppm
060-142A Girls Bathroom Water Spigot	7/1/2016 02:07	7/15/2016 22:33	10354438281	Lead	17	15	ppb
060-143A Classroom C-57 Sink Faucet #1	7/1/2016 02:09	7/18/2016 11:32	10354438283	Copper	0.8	1.3	ppm
060-143A Classroom C-57 Sink Faucet #1	7/1/2016 02:09	7/15/2016 22:41	10354438283	Lead	8	15	ppb
060-144A Classroom C-57 Sink Faucet #2	7/1/2016 02:10	7/18/2016 11:33	10354438285	Copper	0.5	1.3	ppm
060-144A Classroom C-57 Sink Faucet #2	7/1/2016 02:10	7/15/2016 22:43	10354438285	Lead	9	15	ppb
060-145A Hallway Drinking Fountain (C-57) #1	7/1/2016 02:13	7/18/2016 11:35	10354438287	Copper	0.9	1.3	ppm
060-145A Hallway Drinking Fountain (C-57) #1	7/1/2016 02:13	7/15/2016 22:44	10354438287	Lead	2	15	ppb
060-146A Hallway Drinking Fountain (C-57) #2	7/1/2016 02:15	7/18/2016 11:36	10354438289	Copper	0.9	1.3	ppm
060-146A Hallway Drinking Fountain (C-57) #2	7/1/2016 02:15	7/15/2016 22:45	10354438289	Lead	2	15	ppb
060-147A Classroom C-56 Sink Faucet #1	7/1/2016 02:17	7/18/2016 11:37	10354438291	Copper	1.0	1.3	ppm
060-147A Classroom C-56 Sink Faucet #1	7/1/2016 02:17	7/15/2016 22:47	10354438291	Lead	11	15	ppb
060-148A Classroom C-56 Sink Faucet #2	7/1/2016 02:17	7/18/2016 11:39	10354438293	Copper	0.9	1.3	ppm
060-148A Classroom C-56 Sink Faucet #2	7/1/2016 02:17	7/15/2016 22:48	10354438293	Lead	7	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Madison High School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
060-149A Classroom C-56 Sink Faucet #3	7/1/2016 02:18	7/18/2016 11:40	10354438295	Copper	0.9	1.3	ppm
060-149A Classroom C-56 Sink Faucet #3	7/1/2016 02:18	7/15/2016 22:50	10354438295	Lead	9	15	ppb
060-150A Classroom C-55 Sink Faucet #1	7/1/2016 02:21	7/18/2016 11:41	10354438297	Copper	1.1	1.3	ppm
060-150A Classroom C-55 Sink Faucet #1	7/1/2016 02:21	7/15/2016 22:51	10354438297	Lead	6	15	ppb
060-151A Classroom C-55 Sink Faucet #2	7/1/2016 02:23	7/18/2016 11:43	10354438299	Copper	1.0	1.3	ppm
060-151A Classroom C-55 Sink Faucet #2	7/1/2016 02:23	7/15/2016 22:52	10354438299	Lead	8	15	ppb
060-152A Classroom C-55 Sink Faucet #3	7/1/2016 02:25	7/18/2016 11:44	10354438301	Copper	1.1	1.3	ppm
060-152A Classroom C-55 Sink Faucet #3	7/1/2016 02:25	7/15/2016 22:56	10354438301	Lead	5	15	ppb
060-153A Classroom C-55 Sink Faucet #4	7/1/2016 02:26	7/17/2016 20:03	10354438303	Copper	0.8	1.3	ppm
060-153A Classroom C-55 Sink Faucet #4	7/1/2016 02:26	7/15/2016 22:59	10354438303	Lead	6	15	ppb
060-154A Classroom C-55 Sink Faucet #5	7/1/2016 02:28	7/17/2016 20:04	10354438305	Copper	0.7	1.3	ppm
060-154A Classroom C-55 Sink Faucet #5	7/1/2016 02:28	7/15/2016 23:01	10354438305	Lead	10	15	ppb
060-155A Classroom C-53 Sink Faucet #1	7/1/2016 02:30	7/17/2016 20:05	10354438307	Copper	0.3	1.3	ppm
060-155A Classroom C-53 Sink Faucet #1	7/1/2016 02:30	7/15/2016 23:02	10354438307	Lead	126	15	ppb
060-156A Classroom C-53 Sink Faucet #2	7/1/2016 02:32	7/17/2016 20:07	10354438309	Copper	0.7	1.3	ppm
060-156A Classroom C-53 Sink Faucet #2	7/1/2016 02:32	7/15/2016 23:03	10354438309	Lead	14.6	15	ppb
060-157A Classroom C-53 Sink Faucet #3	7/1/2016 02:33	7/17/2016 20:08	10354438311	Copper	0.5	1.3	ppm
060-157A Classroom C-53 Sink Faucet #3	7/1/2016 02:33	7/15/2016 23:05	10354438311	Lead	2	15	ppb
060-158A Classroom C-53 Sink Faucet #4	7/1/2016 02:34	7/17/2016 20:09	10354438313	Copper	0.6	1.3	ppm
060-158A Classroom C-53 Sink Faucet #4	7/1/2016 02:34	7/15/2016 23:06	10354438313	Lead	11	15	ppb
060-159A Classroom C-53 Sink Faucet #5	7/1/2016 02:35	7/17/2016 20:11	10354438315	Copper	0.7	1.3	ppm
060-159A Classroom C-53 Sink Faucet #5	7/1/2016 02:35	7/15/2016 23:08	10354438315	Lead	13	15	ppb
060-160A Classroom C-53 Sink Faucet #6	7/1/2016 02:36	7/17/2016 20:12	10354438317	Copper	0.4	1.3	ppm
060-160A Classroom C-53 Sink Faucet #6	7/1/2016 02:36	7/15/2016 23:09	10354438317	Lead	3	15	ppb
060-161A Classroom C-53 Sink Faucet #7	7/1/2016 02:37	7/17/2016 20:13	10354438319	Copper	1.1	1.3	ppm
060-161A Classroom C-53 Sink Faucet #7	7/1/2016 02:37	7/15/2016 23:13	10354438319	Lead	17	15	ppb
060-162A Classroom C-53 Sink Faucet #8	7/1/2016 02:38	7/10/2016 20:48	10354438321	Copper	0.7	1.3	ppm
060-162A Classroom C-53 Sink Faucet #8	7/1/2016 02:38	7/10/2016 16:51	10354438321	Lead	16	15	ppb
060-163A Classroom C-53 Sink Faucet #9	7/1/2016 02:39	7/19/2016 10:17	10354438323	Copper	0.7	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Madison High School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
060-163A Classroom C-53 Sink Faucet #9	7/1/2016 02:39	7/10/2016 16:59	10354438323	Lead	12	15	ppb
060-164A Classroom C-53 Sink Faucet #10	7/1/2016 02:41	7/19/2016 10:18	10354438325	Copper	0.6	1.3	ppm
060-164A Classroom C-53 Sink Faucet #10	7/1/2016 02:41	7/10/2016 17:00	10354438325	Lead	31	15	ppb
060-165A Classroom C-53 Sink Faucet #11	7/1/2016 02:42	7/19/2016 10:19	10354438327	Copper	0.8	1.3	ppm
060-165A Classroom C-53 Sink Faucet #11	7/1/2016 02:42	7/10/2016 17:01	10354438327	Lead	36	15	ppb
060-166A Classroom C-53 Sink Faucet #12	7/1/2016 02:44	7/19/2016 10:21	10354438329	Copper	0.6	1.3	ppm
060-166A Classroom C-53 Sink Faucet #12	7/1/2016 02:44	7/10/2016 17:02	10354438329	Lead	32	15	ppb
060-167A Classroom C-53 Sink Faucet #13	7/1/2016 02:45	7/19/2016 10:25	10354438331	Copper	0.7	1.3	ppm
060-167A Classroom C-53 Sink Faucet #13	7/1/2016 02:45	7/10/2016 17:03	10354438331	Lead	10	15	ppb
060-168A Classroom C-53 Sink Faucet #14	7/1/2016 02:46	7/19/2016 10:27	10354438333	Copper	0.6	1.3	ppm
060-168A Classroom C-53 Sink Faucet #14	7/1/2016 02:46	7/10/2016 17:05	10354438333	Lead	11	15	ppb
060-169A Classroom C-53 Sink Faucet #15	7/1/2016 02:48	7/10/2016 17:06	10354438335	Copper	0.4	1.3	ppm
060-169A Classroom C-53 Sink Faucet #15	7/1/2016 02:48	7/10/2016 17:06	10354438335	Lead	11	15	ppb
060-170A Classroom C-53 Sink Faucet #16	7/1/2016 02:49	7/19/2016 10:28	10354438337	Copper	0.7	1.3	ppm
060-170A Classroom C-53 Sink Faucet #16	7/1/2016 02:49	7/10/2016 17:07	10354438337	Lead	27	15	ppb
060-171A Classroom C-53 Sink Faucet #17	7/1/2016 02:50	7/10/2016 17:11	10354438339	Copper	0.3	1.3	ppm
060-171A Classroom C-53 Sink Faucet #17	7/1/2016 02:50	7/10/2016 17:11	10354438339	Lead	11	15	ppb
060-172A Classroom C-53 Sink Faucet #18	7/1/2016 02:51	7/10/2016 17:12	10354438341	Copper	0.3	1.3	ppm
060-172A Classroom C-53 Sink Faucet #18	7/1/2016 02:51	7/10/2016 17:12	10354438341	Lead	66	15	ppb
060-173A Classroom C-54 Sink Faucet #1	7/1/2016 02:52	7/10/2016 17:14	10354438343	Copper	0.4	1.3	ppm
060-173A Classroom C-54 Sink Faucet #1	7/1/2016 02:52	7/10/2016 17:14	10354438343	Lead	141	15	ppb
060-174A Classroom C-54 Sink Faucet #2	7/1/2016 02:53	7/10/2016 21:01	10354438345	Copper	1.0	1.3	ppm
060-174A Classroom C-54 Sink Faucet #2	7/1/2016 02:53	7/10/2016 17:16	10354438345	Lead	11	15	ppb
060-175A Classroom C-54 Sink Faucet #3	7/1/2016 02:54	7/10/2016 21:02	10354438347	Copper	0.9	1.3	ppm
060-175A Classroom C-54 Sink Faucet #3	7/1/2016 02:54	7/10/2016 17:17	10354438347	Lead	112	15	ppb
060-176A Classroom C-54 Sink Faucet #4	7/1/2016 02:57	7/10/2016 21:04	10354438349	Copper	0.9	1.3	ppm
060-176A Classroom C-54 Sink Faucet #4	7/1/2016 02:57	7/10/2016 17:18	10354438349	Lead	11	15	ppb
060-177A Classroom C-54 Sink Faucet #5	7/1/2016 03:00	7/19/2016 10:31	10354438351	Copper	1.1	1.3	ppm
060-177A Classroom C-54 Sink Faucet #5	7/1/2016 03:00	7/10/2016 17:19	10354438351	Lead	5	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Madison High School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
060-178A Classroom C-51 Sink Faucet #1	7/1/2016 03:02	7/10/2016 17:20	10354438353	Copper	0.3	1.3	ppm
060-178A Classroom C-51 Sink Faucet #1	7/1/2016 03:02	7/10/2016 17:20	10354438353	Lead	17	15	ppb
060-179A Classroom C-51 Sink Faucet #2	7/1/2016 03:04	7/10/2016 17:21	10354438355	Copper	0.4	1.3	ppm
060-179A Classroom C-51 Sink Faucet #2	7/1/2016 03:04	7/10/2016 17:21	10354438355	Lead	2	15	ppb
060-180A Classroom C-51 Sink Faucet #3	7/1/2016 03:07	7/10/2016 21:06	10354438357	Copper	0.6	1.3	ppm
060-180A Classroom C-51 Sink Faucet #3	7/1/2016 03:07	7/10/2016 17:26	10354438357	Lead	20	15	ppb
060-181A Classroom C-51 Sink Faucet #4	7/1/2016 03:10	7/10/2016 21:07	10354438359	Copper	0.8	1.3	ppm
060-181A Classroom C-51 Sink Faucet #4	7/1/2016 03:10	7/10/2016 17:28	10354438359	Lead	9	15	ppb
060-182A Classroom C-51 Sink Faucet #5	7/1/2016 03:11	7/17/2016 20:29	10354438361	Copper	0.7	1.3	ppm
060-182A Classroom C-51 Sink Faucet #5	7/1/2016 03:11	7/15/2016 23:57	10354438361	Lead	10	15	ppb
060-183A Classroom C-51 Sink Faucet #6	7/1/2016 03:13	7/17/2016 20:39	10354438363	Copper	0.8	1.3	ppm
060-183A Classroom C-51 Sink Faucet #6	7/1/2016 03:13	7/17/2016 20:38	10354438363	Lead	13	15	ppb
060-184A Classroom C-51 Sink Faucet #7	7/1/2016 03:15	7/17/2016 20:42	10354438365	Copper	0.7	1.3	ppm
060-184A Classroom C-51 Sink Faucet #7	7/1/2016 03:15	7/17/2016 20:40	10354438365	Lead	17	15	ppb
060-185A Classroom C-51 Sink Faucet #8	7/1/2016 03:17	7/17/2016 20:44	10354438367	Copper	0.8	1.3	ppm
060-185A Classroom C-51 Sink Faucet #8	7/1/2016 03:17	7/17/2016 20:43	10354438367	Lead	8	15	ppb
060-186A Classroom C-51 Sink Faucet #9	7/1/2016 03:18	7/17/2016 20:47	10354438369	Copper	0.5	1.3	ppm
060-186A Classroom C-51 Sink Faucet #9	7/1/2016 03:18	7/17/2016 20:46	10354438369	Lead	6	15	ppb
060-187A Classroom C-51 Sink Faucet #10	7/1/2016 03:20	7/17/2016 20:53	10354438371	Copper	0.7	1.3	ppm
060-187A Classroom C-51 Sink Faucet #10	7/1/2016 03:20	7/17/2016 20:51	10354438371	Lead	17	15	ppb
060-188A Classroom C-51 Sink Faucet #11	7/1/2016 03:20	7/17/2016 20:55	10354438373	Copper	0.7	1.3	ppm
060-188A Classroom C-51 Sink Faucet #11	7/1/2016 03:20	7/17/2016 20:54	10354438373	Lead	14.9	15	ppb
060-189A Classroom C-51 Sink Faucet #12	7/1/2016 03:22	7/17/2016 20:58	10354438375	Copper	0.3	1.3	ppm
060-189A Classroom C-51 Sink Faucet #12	7/1/2016 03:22	7/17/2016 20:57	10354438375	Lead	47	15	ppb
060-190A Classroom C-51 Eyewash	7/1/2016 03:24	7/17/2016 21:01	10354438377	Copper	0.2	1.3	ppm
060-190A Classroom C-51 Eyewash	7/1/2016 03:24	7/17/2016 20:59	10354438377	Lead	12	15	ppb
060-191A Room C-51A Sink Faucet #1	7/1/2016 03:24	7/17/2016 21:03	10354438379	Copper	0.4	1.3	ppm
060-191A Room C-51A Sink Faucet #1	7/1/2016 03:24	7/17/2016 21:02	10354438379	Lead	10	15	ppb
060-192A Room C-51A Sink Faucet #2	7/1/2016 03:28	7/17/2016 21:09	10354438381	Copper	0.4	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Madison High School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
060-192A Room C-51A Sink Faucet #2	7/1/2016 03:28	7/17/2016 21:07	10354438381	Lead	5	15	ppb
060-193A Classroom C-49 Sink Faucet	7/1/2016 03:31	7/17/2016 21:13	10354438383	Copper	0.5	1.3	ppm
060-193A Classroom C-49 Sink Faucet	7/1/2016 03:31	7/17/2016 21:12	10354438383	Lead	5	15	ppb
060-194A Custodial Closet C-50 Sink Faucet	7/1/2016 03:33	7/12/2016 09:06	10354438385	Copper	0.2	1.3	ppm
060-194A Custodial Closet C-50 Sink Faucet	7/1/2016 03:33	7/12/2016 09:06	10354438385	Lead	2	15	ppb
060-195A Classroom C-47 Sink Faucet	7/1/2016 03:38	7/17/2016 21:16	10354438387	Copper	0.6	1.3	ppm
060-195A Classroom C-47 Sink Faucet	7/1/2016 03:38	7/17/2016 21:14	10354438387	Lead	103	15	ppb
060-196A Hallway Drinking Fountain (C-46)	7/1/2016 03:38	7/17/2016 21:18	10354438389	Copper	1.1	1.3	ppm
060-196A Hallway Drinking Fountain (C-46)	7/1/2016 03:38	7/17/2016 21:17	10354438389	Lead	1	15	ppb
060-197A Room C-12 Closet Sink Faucet	7/1/2016 03:42	7/17/2016 21:24	10354438391	Copper	0.8	1.3	ppm
060-197A Room C-12 Closet Sink Faucet	7/1/2016 03:42	7/17/2016 21:20	10354438391	Lead	12	15	ppb
060-198A Room C-22 Bathroom Sink Faucet #1	7/1/2016 03:44	7/17/2016 21:27	10354438393	Copper	0.4	1.3	ppm
060-198A Room C-22 Bathroom Sink Faucet #1	7/1/2016 03:44	7/17/2016 21:25	10354438393	Lead	16	15	ppb
060-199A Room C-22 Bathroom Sink Faucet #2	7/1/2016 03:44	7/17/2016 21:29	10354438395	Copper	0.5	1.3	ppm
060-199A Room C-22 Bathroom Sink Faucet #2	7/1/2016 03:44	7/17/2016 21:28	10354438395	Lead	6	15	ppb
060-200A Hallway Drinking Fountain Southeast #1	7/1/2016 03:46	7/17/2016 21:32	10354438397	Copper	0.6	1.3	ppm
060-200A Hallway Drinking Fountain Southeast #1	7/1/2016 03:46	7/17/2016 21:31	10354438397	Lead	2	15	ppb
060-201A Hallway Drinking Fountain Southeast #2	7/1/2016 03:47	7/17/2016 21:35	10354438399	Copper	0.5	1.3	ppm
060-201A Hallway Drinking Fountain Southeast #2	7/1/2016 03:47	7/17/2016 21:33	10354438399	Lead	2	15	ppb
060-202A Faculty Bathroom C-25 Sink Faucet	7/1/2016 03:49	7/18/2016 11:50	10354438401	Copper	0.6	1.3	ppm
060-202A Faculty Bathroom C-25 Sink Faucet	7/1/2016 03:49	7/17/2016 15:37	10354438401	Lead	5	15	ppb
060-203A Girl Bathroom C-23 Sink Faucet #1	7/1/2016 03:54	7/18/2016 11:52	10354438403	Copper	0.5	1.3	ppm
060-203A Girl Bathroom C-23 Sink Faucet #1	7/1/2016 03:54	7/17/2016 15:43	10354438403	Lead	8	15	ppb
060-204A Girl Bathroom C-23 Sink Faucet #2	7/1/2016 03:52	7/18/2016 11:54	10354438405	Copper	0.3	1.3	ppm
060-204A Girl Bathroom C-23 Sink Faucet #2	7/1/2016 03:52	7/17/2016 15:44	10354438405	Lead	6	15	ppb
060-205A Girl Bathroom C-23 Sink Faucet #3	7/1/2016 03:55	7/18/2016 11:55	10354438407	Copper	0.6	1.3	ppm
060-205A Girl Bathroom C-23 Sink Faucet #3	7/1/2016 03:55	7/17/2016 15:46	10354438407	Lead	7	15	ppb
060-206A Boys Bathroom C-24 Sink Faucet #1	7/1/2016 03:57	7/18/2016 11:56	10354438409	Copper	0.4	1.3	ppm
060-206A Boys Bathroom C-24 Sink Faucet #1	7/1/2016 03:57	7/17/2016 15:47	10354438409	Lead	4	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Madison High School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
060-207A Boys Bathroom C-24 Sink Faucet #2	7/1/2016 03:58	7/18/2016 11:58	10354438411	Copper	0.2	1.3	ppm
060-207A Boys Bathroom C-24 Sink Faucet #2	7/1/2016 03:58	7/17/2016 15:52	10354438411	Lead	10	15	ppb
060-208A Boys Bathroom C-24 Water Spigot	7/1/2016 03:59	7/17/2016 15:53	10354438413	Copper	0.2	1.3	ppm
060-208A Boys Bathroom C-24 Water Spigot	7/1/2016 03:59	7/17/2016 15:53	10354438413	Lead	2	15	ppb
060-209A Hallway Drinking Fountain (C-34) #1	7/1/2016 04:01	7/18/2016 11:59	10354438415	Copper	1.30	1.3	ppm
060-209A Hallway Drinking Fountain (C-34) #1	7/1/2016 04:01	7/17/2016 15:54	10354438415	Lead	3	15	ppb
060-210A Hallway Drinking Fountain (C-34) #2	7/1/2016 04:03	7/18/2016 12:00	10354438417	Copper	1.1	1.3	ppm
060-210A Hallway Drinking Fountain (C-34) #2	7/1/2016 04:03	7/17/2016 15:56	10354438417	Lead	2	15	ppb
060-211A Custodial Closet C-36 Sink Faucet	7/1/2016 04:07	7/18/2016 12:04	10354438419	Copper	0.5	1.3	ppm
060-211A Custodial Closet C-36 Sink Faucet	7/1/2016 04:07	7/17/2016 15:57	10354438419	Lead	1	15	ppb
060-212A Hallway Drinking Fountain (C-42) #1	7/1/2016 04:08	7/18/2016 12:06	10354438421	Copper	0.5	1.3	ppm
060-212A Hallway Drinking Fountain (C-42) #1	7/1/2016 04:08	7/17/2016 15:58	10354438421	Lead	3	15	ppb
060-213A Hallway Drinking Fountain (C-42) #2	7/1/2016 04:10	7/18/2016 12:07	10354438423	Copper	0.6	1.3	ppm
060-213A Hallway Drinking Fountain (C-42) #2	7/1/2016 04:10	7/17/2016 16:01	10354438423	Lead	5	15	ppb
060-214A Room C-42 Sink Faucet	7/1/2016 04:11	7/18/2016 12:08	10354438425	Copper	0.6	1.3	ppm
060-214A Room C-42 Sink Faucet	7/1/2016 04:11	7/17/2016 16:03	10354438425	Lead	14	15	ppb
060-215A Faculty Lounge C-19 Sink Faucet	7/1/2016 04:14	7/18/2016 12:10	10354438427	Copper	0.4	1.3	ppm
060-215A Faculty Lounge C-19 Sink Faucet	7/1/2016 04:14	7/17/2016 16:04	10354438427	Lead	7	15	ppb
060-216A Womens Faculty Bathroom C-13 Sink Faucet	7/1/2016 04:19	7/18/2016 12:11	10354438429	Copper	0.3	1.3	ppm
060-216A Womens Faculty Bathroom C-13 Sink Faucet	7/1/2016 04:19	7/18/2016 12:11	10354438429	Lead	4	15	ppb
060-217A Mens Faculty Bathroom C-12 Sink Faucet	7/1/2016 04:22	7/18/2016 12:12	10354438431	Copper	0.4	1.3	ppm
060-217A Mens Faculty Bathroom C-12 Sink Faucet	7/1/2016 04:22	7/18/2016 12:12	10354438431	Lead	5	15	ppb
060-218A Custodial Closet C-9 Sink Faucet	7/1/2016 04:23	7/12/2016 09:08	10354438433	Copper	0.1	1.3	ppm
060-218A Custodial Closet C-9 Sink Faucet	7/1/2016 04:23	7/12/2016 09:08	10354438433	Lead	2	15	ppb
060-219A Girls Bathroom C-8 Sink Faucet #1	7/1/2016 04:24	7/18/2016 12:15	10354438435	Copper	0.6	1.3	ppm
060-219A Girls Bathroom C-8 Sink Faucet #1	7/1/2016 04:24	7/18/2016 12:14	10354438435	Lead	5	15	ppb
060-220A Girls Bathroom C-8 Sink Faucet #2	7/1/2016 04:25	7/18/2016 12:17	10354438437	Copper	1.30	1.3	ppm
060-220A Girls Bathroom C-8 Sink Faucet #2	7/1/2016 04:25	7/18/2016 12:17	10354438437	Lead	45	15	ppb
060-221A Girls Bathroom C-8 Sink Faucet #3	7/1/2016 04:25	7/18/2016 12:48	10354438439	Copper	0.5	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Madison High School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
060-221A Girls Bathroom C-8 Sink Faucet #3	7/1/2016 04:25	7/18/2016 12:46	10354438439	Lead	5	15	ppb
060-222A Girls Bathroom C-8 Sink Faucet #4	7/1/2016 04:26	7/18/2016 12:50	10354438441	Copper	0.6	1.3	ppm
060-222A Girls Bathroom C-8 Sink Faucet #4	7/1/2016 04:26	7/18/2016 12:50	10354438441	Lead	10	15	ppb
060-223A Girls Bathroom C-8 Sink Faucet #5	7/1/2016 04:26	7/18/2016 12:53	10354438443	Copper	0.5	1.3	ppm
060-223A Girls Bathroom C-8 Sink Faucet #5	7/1/2016 04:26	7/18/2016 12:53	10354438443	Lead	4	15	ppb
060-224A Girls Bathroom C-8 Water Spigot	7/1/2016 04:28	7/12/2016 09:12	10354438445	Copper	1.30	1.3	ppm
060-224A Girls Bathroom C-8 Water Spigot	7/1/2016 04:28	7/12/2016 02:04	10354438445	Lead	92	15	ppb
060-225A Classroom C-6 Sink Faucet	7/1/2016 04:31	7/18/2016 12:54	10354438447	Copper	0.5	1.3	ppm
060-225A Classroom C-6 Sink Faucet	7/1/2016 04:31	7/18/2016 12:54	10354438447	Lead	9	15	ppb
060-226A Classroom C-4 Sink Faucet	7/1/2016 04:32	7/18/2016 12:56	10354438449	Copper	0.6	1.3	ppm
060-226A Classroom C-4 Sink Faucet	7/1/2016 04:32	7/18/2016 12:56	10354438449	Lead	5	15	ppb
060-227A Classroom C-3 Sink Faucet	7/1/2016 04:34	7/18/2016 12:57	10354438451	Copper	0.5	1.3	ppm
060-227A Classroom C-3 Sink Faucet	7/1/2016 04:34	7/18/2016 12:57	10354438451	Lead	17	15	ppb
060-228A Classroom C-2 Sink Faucet	7/1/2016 04:36	7/18/2016 12:59	10354438453	Copper	0.8	1.3	ppm
060-228A Classroom C-2 Sink Faucet	7/1/2016 04:36	7/18/2016 12:59	10354438453	Lead	11	15	ppb
060-229A Classroom C-1 Sink Faucet	7/1/2016 04:37	7/18/2016 13:03	10354438455	Copper	0.7	1.3	ppm
060-229A Classroom C-1 Sink Faucet	7/1/2016 04:37	7/18/2016 13:03	10354438455	Lead	13	15	ppb
060-230A Outside Spigot #1	7/1/2016 05:16	7/18/2016 13:04	10354438457	Copper	0.7	1.3	ppm
060-230A Outside Spigot #1	7/1/2016 05:16	7/18/2016 13:04	10354438457	Lead	2	15	ppb
060-231A Outside Spigot #2	7/1/2016 05:19	7/18/2016 13:05	10354438459	Copper	0.6	1.3	ppm
060-231A Outside Spigot #2	7/1/2016 05:19	7/18/2016 13:05	10354438459	Lead	15.3	15	ppb
060-232A Outside Spigot #3	7/1/2016 05:22	7/18/2016 13:07	10354438461	Copper	0.6	1.3	ppm
060-232A Outside Spigot #3	7/1/2016 05:22	7/18/2016 13:07	10354438461	Lead	11	15	ppb
060-233A Outside Spigot #4	7/1/2016 05:12	7/18/2016 13:08	10354438463	Copper	0.9	1.3	ppm
060-233A Outside Spigot #4	7/1/2016 05:12	7/17/2016 16:43	10354438463	Lead	8	15	ppb
060-234A Outside Spigot #5	7/1/2016 05:14	7/18/2016 13:09	10354438465	Copper	0.7	1.3	ppm
060-234A Outside Spigot #5	7/1/2016 05:14	7/17/2016 16:46	10354438465	Lead	8	15	ppb
060-235A Outside Spigot #6	7/1/2016 06:12	7/18/2016 13:11	10354438467	Copper	0.7	1.3	ppm
060-235A Outside Spigot #6	7/1/2016 06:12	7/17/2016 16:48	10354438467	Lead	4	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Madison High School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
060-236A Outside Spigot #7	7/1/2016 06:16	7/18/2016 13:12	10354438469	Copper	0.2	1.3	ppm
060-236A Outside Spigot #7	7/1/2016 06:16	7/17/2016 16:49	10354438469	Lead	4	15	ppb
060-237A Outside Spigot #8	7/1/2016 06:18	7/18/2016 13:13	10354438471	Copper	0.4	1.3	ppm
060-237A Outside Spigot #8	7/1/2016 06:18	7/17/2016 16:50	10354438471	Lead	14	15	ppb
060-238A Outside Spigot #9	7/1/2016 06:21	7/18/2016 13:15	10354438473	Copper	0.6	1.3	ppm
060-238A Outside Spigot #9	7/1/2016 06:21	7/17/2016 16:52	10354438473	Lead	16	15	ppb
060-239A Outside Spigot #10	7/1/2016 06:25	7/18/2016 13:19	10354438475	Copper	1.2	1.3	ppm
060-239A Outside Spigot #10	7/1/2016 06:25	7/17/2016 16:53	10354438475	Lead	76	15	ppb
060-240A Outside Spigot #11	7/1/2016 06:28	7/18/2016 13:21	10354438477	Copper	0.7	1.3	ppm
060-240A Outside Spigot #11	7/1/2016 06:28	7/17/2016 16:54	10354438477	Lead	19	15	ppb
060-241A Outside Spigot #12	7/1/2016 06:32	7/12/2016 09:13	10354438479	Copper	1.1	1.3	ppm
060-241A Outside Spigot #12	7/1/2016 06:32	7/12/2016 02:08	10354438479	Lead	68	15	ppb
060-242A Outside Spigot #13	7/1/2016 06:38	7/12/2016 09:41	10354438481	Copper	3.4	1.3	ppm
060-242A Outside Spigot #13	7/1/2016 06:38	7/12/2016 02:09	10354438481	Lead	204	15	ppb
060-243A Outside Spigot #14	7/1/2016 06:41	7/12/2016 09:16	10354438483	Copper	1.8	1.3	ppm
060-243A Outside Spigot #14	7/1/2016 06:41	7/12/2016 02:11	10354438483	Lead	62	15	ppb
060-244A Outside Spigot #15	7/1/2016 06:43	7/18/2016 13:25	10354438485	Copper	0.6	1.3	ppm
060-244A Outside Spigot #15	7/1/2016 06:43	7/17/2016 17:04	10354438485	Lead	26	15	ppb
060-245A Outside Spigot #16	7/1/2016 06:46	7/18/2016 13:27	10354438487	Copper	0.4	1.3	ppm
060-245A Outside Spigot #16	7/1/2016 06:46	7/17/2016 17:10	10354438487	Lead	8	15	ppb
060-246A Outside Spigot #17	7/1/2016 06:49	7/18/2016 13:29	10354438489	Copper	1.1	1.3	ppm
060-246A Outside Spigot #17	7/1/2016 06:49	7/17/2016 17:11	10354438489	Lead	29	15	ppb
060-247A Outside Spigot #18	7/1/2016 06:54	7/18/2016 13:30	10354438491	Copper	0.7	1.3	ppm
060-247A Outside Spigot #18	7/1/2016 06:54	7/17/2016 17:13	10354438491	Lead	27	15	ppb
060-248A Outside Spigot #19	7/1/2016 06:57	7/18/2016 13:32	10354438493	Copper	0.7	1.3	ppm
060-248A Outside Spigot #19	7/1/2016 06:57	7/17/2016 17:14	10354438493	Lead	6	15	ppb
060-249A Outside Spigot #20	7/1/2016 06:05	7/18/2016 13:36	10354438495	Copper	1.8	1.3	ppm
060-249A Outside Spigot #20	7/1/2016 06:05	7/17/2016 17:16	10354438495	Lead	70	15	ppb
060-250A Outside Spigot #21	7/1/2016 06:02	7/12/2016 07:58	10354438497	Copper	1.30	1.3	ppm

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Madison High School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
060-250A Outside Spigot #21	7/1/2016 06:02	7/11/2016 22:27	10354438497	Lead	133	15	ppb
060-251A Outside Spigot #22	7/1/2016 06:00	7/18/2016 13:37	10354438499	Copper	1.1	1.3	ppm
060-251A Outside Spigot #22	7/1/2016 06:00	7/17/2016 17:20	10354438499	Lead	26	15	ppb
060-252A Outside Spigot #23	7/1/2016 05:57	7/18/2016 13:38	10354438501	Copper	1.1	1.3	ppm
060-252A Outside Spigot #23	7/1/2016 05:57	7/17/2016 17:21	10354438501	Lead	21	15	ppb
060-253A Outside Spigot #24	7/1/2016 05:55	7/18/2016 13:40	10354438503	Copper	0.9	1.3	ppm
060-253A Outside Spigot #24	7/1/2016 05:55	7/17/2016 17:22	10354438503	Lead	5	15	ppb
060-254A Outside Spigot #25	7/1/2016 05:53	7/17/2016 17:24	10354438505	Copper	0.0	1.3	ppm
060-254A Outside Spigot #25	7/1/2016 05:53	7/17/2016 17:24	10354438505	Lead	2	15	ppb
060-255A Outside Spigot #26	7/1/2016 05:50	7/17/2016 17:25	10354438507	Copper	0.0	1.3	ppm
060-255A Outside Spigot #26	7/1/2016 05:50	7/17/2016 17:25	10354438507	Lead	5	15	ppb
060-256A Outside Spigot #27	7/1/2016 05:47	7/17/2016 17:28	10354438509	Copper	0.1	1.3	ppm
060-256A Outside Spigot #27	7/1/2016 05:47	7/17/2016 17:28	10354438509	Lead	14.7	15	ppb
060-257A Outside Spigot #28	7/1/2016 05:43	7/17/2016 17:29	10354438511	Copper	0.0	1.3	ppm
060-257A Outside Spigot #28	7/1/2016 05:43	7/17/2016 17:29	10354438511	Lead	2	15	ppb
060-258A Outside Spigot #29	7/1/2016 05:41	7/18/2016 13:41	10354438513	Copper	1.4	1.3	ppm
060-258A Outside Spigot #29	7/1/2016 05:41	7/17/2016 17:31	10354438513	Lead	35	15	ppb
060-259A Outside Spigot #30	7/1/2016 05:39	7/17/2016 17:32	10354438515	Copper	0.0	1.3	ppm
060-259A Outside Spigot #30	7/1/2016 05:39	7/17/2016 17:32	10354438515	Lead	2	15	ppb
060-260A Outside Spigot #31	7/1/2016 05:37	7/17/2016 17:36	10354438517	Copper	0.0	1.3	ppm
060-260A Outside Spigot #31	7/1/2016 05:37	7/17/2016 17:36	10354438517	Lead	3	15	ppb
060-261A Outside Spigot #32	7/1/2016 05:35	7/17/2016 17:38	10354438519	Copper	0.0	1.3	ppm
060-261A Outside Spigot #32	7/1/2016 05:35	7/17/2016 17:38	10354438519	Lead	2	15	ppb
060-262A Outside Spigot #33	7/1/2016 05:32	7/12/2016 03:20	10354438521	Copper	0.0	1.3	ppm
060-262A Outside Spigot #33	7/1/2016 05:32	7/12/2016 03:20	10354438521	Lead	2	15	ppb
060-263A Outside Spigot #34	7/1/2016 05:30	7/12/2016 03:22	10354438523	Copper	0.0	1.3	ppm
060-263A Outside Spigot #34	7/1/2016 05:30	7/12/2016 03:22	10354438523	Lead	2	15	ppb
060-264A Outside Spigot #35	7/1/2016 05:21	7/12/2016 09:34	10354438525	Copper	0.9	1.3	ppm
060-264A Outside Spigot #35	7/1/2016 05:21	7/12/2016 03:23	10354438525	Lead	1	15	ppb

Portland Public Schools
Lead and Copper Water Sampling Results
A (First Draw) Sample Data
Madison High School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Analyte	Results	EPA Action Level	Units
--------------------------------------	---------------------	---------------	--------------	---------	---------	------------------	-------

EPA Action Level for Lead of 15 ppb

EPA Action Level for Copper of 1.3 ppm

Highlighted samples are at or exceed the Environmental Protection Agency (EPA) guidance.